

# Formation of $N_2O$ and $NO_2$ Across Conventional DeNOx SCR Catalysts

1019614

---



# Formation of N<sub>2</sub>O and NO<sub>2</sub> Across Conventional DeNO<sub>x</sub> SCR Catalysts

1019614

Technical Update, December 2009

EPRI Project Manager  
A. Jimenez

## **DISCLAIMER OF WARRANTIES AND LIMITATION OF LIABILITIES**

THIS DOCUMENT WAS PREPARED BY THE ORGANIZATION(S) NAMED BELOW AS AN ACCOUNT OF WORK SPONSORED OR COSPONSORED BY THE ELECTRIC POWER RESEARCH INSTITUTE, INC. (EPRI). NEITHER EPRI, ANY MEMBER OF EPRI, ANY COSPONSOR, THE ORGANIZATION(S) BELOW, NOR ANY PERSON ACTING ON BEHALF OF ANY OF THEM:

(A) MAKES ANY WARRANTY OR REPRESENTATION WHATSOEVER, EXPRESSED OR IMPLIED, (I) WITH RESPECT TO THE USE OF ANY INFORMATION, APPARATUS, METHOD, PROCESS, OR SIMILAR ITEM DISCLOSED IN THIS DOCUMENT, INCLUDING MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE, OR (II) THAT SUCH USE DOES NOT INFRINGE ON OR INTERFERE WITH PRIVATELY OWNED RIGHTS, INCLUDING ANY PARTY'S INTELLECTUAL PROPERTY, OR (III) THAT THIS DOCUMENT IS SUITABLE TO ANY PARTICULAR USER'S CIRCUMSTANCE; OR

(B) ASSUMES RESPONSIBILITY FOR ANY DAMAGES OR OTHER LIABILITY WHATSOEVER (INCLUDING ANY CONSEQUENTIAL DAMAGES, EVEN IF EPRI OR ANY EPRI REPRESENTATIVE HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES) RESULTING FROM YOUR SELECTION OR USE OF THIS DOCUMENT OR ANY INFORMATION, APPARATUS, METHOD, PROCESS, OR SIMILAR ITEM DISCLOSED IN THIS DOCUMENT.

ORGANIZATION(S) THAT PREPARED THIS DOCUMENT

**W. S. Hinton and Associates**

## **NOTE**

For further information about EPRI, call the EPRI Customer Assistance Center at 800.313.3774 or e-mail [askepri@epri.com](mailto:askepri@epri.com).

Electric Power Research Institute and EPRI are registered service marks of the Electric Power Research Institute, Inc.

Copyright © 2009 Electric Power Research Institute, Inc. All rights reserved.

# CITATIONS

---

This report was prepared by

Electric Power Research Institute (EPRI)  
3420 Hillview Avenue  
Palo Alto, California, 94304

Principal Investigator  
A. Jimenez

W. S. Hinton and Associates  
1612 Smugglers Cove Circle  
Gulf Breeze, FL 32563

Principal Investigator  
W. Scott Hinton, Ph.D., P.E.

This report describes research sponsored by EPRI.

The report is a corporate document that should be cited in the literature in the following manner:  
*Formation of  $N_2O$  and  $NO_2$  Across Conventional SCR Catalysts*, EPRI, Palo Alto, CA: 2009.  
1019614



## ACKNOWLEDGEMENT

---

The authors would like to thank the participating catalyst suppliers for their contribution of catalyst material, as well as their technical support for this project. We would also like to specially thank Mr. Thorsten Dux of EON Engineering test facility for his dedication to the difficult task of accurately measuring  $N_2O$  and  $NO_2$ . Special thanks also go to Ms. April Sibley of Southern Company Services Inc. for her technical and administrative support during the course of the project.





# PRODUCT DESCRIPTION

---

This project investigated the formation of  $N_2O$  and  $NO_2$  across conventional DeNO<sub>x</sub> selective catalytic reduction (SCR) catalysts.  $N_2O$  is a particularly strong greenhouse gas, and both  $N_2O$  and  $NO_2$  may adversely impact downstream processes. Additional data related to their formation or reduction across SCR catalysts is desirable.

## Results & Findings

Test results showed that the range of NO<sub>x</sub> activities was consistent with the industry fleet of conventional coal-fired boiler catalysts. SO<sub>2</sub> conversion values also were consistent with industry experience, even though they covered a broad range. As a result, none of the catalysts produced  $N_2O$  at levels greater than the system detection limit. The single sample tested for  $NO_2$  production resulted in a net decrease in  $NO_2$  across the catalyst.

## Challenges & Objective(s)

This project was designed to determine if  $N_2O$  and  $NO_2$  formation should be a concern for the current fleet of conventional SCR catalysts.

## Applications, Values & Use

Test results will help evaluate behavior of current commercial SCR catalyst formulations. Because catalyst design has advanced over the years, historical data may not accurately reflect current catalyst behavior.

## EPRI Perspective

Project findings determined that  $N_2O$  formation should not be a concern for the current fleet of conventional SCR catalysts. The findings also indicated that  $NO_2$  will not be produced across conventional catalysts, but will be reduced. As catalyst formulations change over time or otherwise deviate from the current design,  $N_2O$  and  $NO_2$  formation could be a consideration.

## Approach

The project team evaluated four samples of conventional SCR catalysts under bench-scale conditions for their behavior with respect to  $N_2O$  and  $NO_2$  production. The test program covered a broad range of conventional SCR catalyst from different suppliers. The catalysts were exposed, prior to testing, for varying lengths of time to flue gas from a commercial boiler firing fuels consistent with low-sulfur, eastern bituminous coal. The samples were then tested for  $N_2O$  production in a bench-scale reactor. The team tested a single catalyst sample for  $NO_2$  production. Catalyst activity and SO<sub>2</sub> conversion testing was done in accordance with the VGB testing protocol. Flue gas conditions and flow rates were typical of low-sulfur coal-fired flue gas.

The project team also examined  $NO_2$  data from a previous EPRI project that evaluated mercury oxidation across new, aged, and regenerated catalysts for both honeycomb and plate catalysts.

**Keywords**

Selective catalytic reduction (SCR)

SCR catalyst

Nitrogen oxides (NO<sub>x</sub>)

Nitrogen dioxide (NO<sub>2</sub>)

Nitrous oxide (N<sub>2</sub>O)

## ABSTRACT

---

This project was designed to determine if  $N_2O$  and  $NO_2$  formation should be a concern for the current fleet of conventional SCR catalysts. The project team investigated the formation of  $N_2O$  and  $NO_2$  across conventional DeNOx Selective Catalytic Reduction (SCR) catalysts.  $N_2O$  is a particularly strong greenhouse gas, and both  $N_2O$  and  $NO_2$  may adversely impact downstream processes. The project team evaluated four samples of conventional SCR catalysts under bench-scale conditions for their behavior with respect to  $N_2O$  and  $NO_2$  production. The team also examined  $NO_2$  data from a previous EPRI project that evaluated mercury oxidation across new, aged, and regenerated catalysts for both honeycomb and plate catalysts. Test results showed that none of the catalysts produced  $N_2O$  at levels greater than the system detection limit (5 ppmvd). The single sample tested for  $NO_2$  production resulted in a net decrease in  $NO_2$  across the catalyst. These findings indicate that  $N_2O$  and  $NO_2$  formation should not be a concern for the current fleet of conventional SCR catalysts.



# CONTENTS

---

<b>1 INTRODUCTION .....</b>	<b>1-1</b>
Background .....	1-1
Objectives .....	1-1
Catalyst Design .....	1-1
Catalyst Exposure .....	1-2
<b>2 TESTING APPROACH.....</b>	<b>2-1</b>
Test Facility Design and Experimental Conditions .....	2-1
Gas Measurement .....	2-2
DeNO <sub>x</sub> and SO <sub>2</sub> Conversion Reporting Basis.....	2-3
NO <sub>x</sub> Activity .....	2-3
SO <sub>2</sub> to SO <sub>3</sub> Conversion .....	2-4
Simulated Flue Gas.....	2-5
<b>3 TEST RESULTS .....</b>	<b>3-1</b>
<b>4 SUPPLEMENTAL NO<sub>2</sub> DATA .....</b>	<b>4-1</b>
Background .....	4-1
Catalyst Characteristics.....	4-1
Pilot Plant Operating Conditions .....	4-2
Reference Flue Gas Constituents .....	4-4
Test Results .....	4-4
<b>5 CONCLUSIONS .....</b>	<b>5-1</b>



# LIST OF FIGURES

---

Figure 2-1 Flow Diagram for Bench-Scale Test Facility.....	2-1
Figure 2-2 Photographs of Laboratory Test Reactor with Catalyst Sample.....	2-2
Figure 4-1 Three Train Pilot Scale Reactor .....	4-3
Figure 4-2 Photograph of Pilot Catalyst Module (side and top views) .....	4-4





# LIST OF TABLES

---

Table 1-1 SCR and Catalyst Design Parameters .....	1-2
Table 1-2 Catalyst Exposure Hours .....	1-2
Table 1-3 Representative Coal Analyses – Ultimate Analysis .....	1-3
Table 2-1 Gas Measurement Devices .....	2-3
Table 2-2 Simulated Flue Gas Composition and Flow Rate .....	2-5
Table 3-1 Test Results.....	3-2
Table 4-1 Exposure Conditions of Characteristics of Aged Catalyst Samples.....	4-2
Table 4-2 Nominal Pilot Plant Operating Conditions.....	4-2
Table 4-3 Pilot Plant NO <sub>2</sub> Test Results .....	4-5



# 1

## INTRODUCTION

---

### Background

Coal-fired flue gases generally contain a mixture of nitrogen oxides (NO<sub>x</sub>), in the form of nitric oxide (NO), nitrogen dioxide (NO<sub>2</sub>) and nitrous oxide (N<sub>2</sub>O). The vast majority of the total NO<sub>x</sub> is typically present as NO (>95%), with NO<sub>2</sub> and N<sub>2</sub>O levels usually in the low ppm range. The relative amounts of NO, NO<sub>2</sub> and N<sub>2</sub>O for any particular operating unit are strongly affected by boiler operating conditions, especially as a function of fuel type, temperature profile, and oxygen concentrations.

Historically, selective catalytic reduction (SCR) technology has focused on the removal of NO, since this is the principal NO<sub>x</sub> component. Early industry data showed that NO<sub>2</sub> was reduced across the vanadium-titania based catalyst, similar to the NO, and also showed that N<sub>2</sub>O levels were consistently low throughout the system. Studies from Muzio<sup>1</sup> and Blanco<sup>2</sup> have demonstrated that N<sub>2</sub>O does not form across vanadium-titania catalyst. They also demonstrated that components such as platinum and copper-nickel can generate N<sub>2</sub>O. Conventional SCR catalyst formulations will vary depending on make, but the main components are titania (TiO<sub>2</sub>), silica, tungsten, molybdenum, and vanadium.

Given that N<sub>2</sub>O is a particularly strong greenhouse gas, and given that both N<sub>2</sub>O and NO<sub>2</sub> may adversely impact downstream processes, additional data related to the formation or reduction across SCR catalysts is desirable. It is of special interest to evaluate the behavior of current commercial SCR catalyst formulations, since catalyst design has advanced over time, and therefore historical data may not accurately reflect the current catalyst behavior.

### Objectives

The primary objective of the program was to determine the behavior of conventional SCR catalysts in terms of N<sub>2</sub>O and NO<sub>2</sub> production/reduction under normal operating conditions.

### Catalyst Design

Four catalyst samples of conventional design were selected for testing in this program, all from different suppliers. These catalysts were utilized in alternate EPRI projects, and sampled for laboratory testing. All catalysts were designed for application to coal-fired boilers, and thus had a relatively large pitch. Latitude was given to the catalyst suppliers in terms of the activity and SO<sub>2</sub> conversion of the formulations provided, thus a relatively wide range of catalyst characteristics was obtained. The catalyst samples consisted of two (2) plate type catalysts, one (1) honeycomb

---

<sup>1</sup> Muzio, L. Evaluation of Hybrid SNCR/SCR System Performance. Laguna Hills, California. 1992

<sup>2</sup> Blanco, J. Alumina- and titania-based monolithic catalysts for low temperature selective catalytic reduction of nitrogen oxides. Instituto de Catálisis y Petroleoquímica. Madrid, Spain. 2000.

---

*Introduction*

catalyst, and one (1) corrugated type catalyst. The catalysts were designed based on the SCR reactor parameters shown in Table 1-1.

**Table 1-1  
SCR and Catalyst Design Parameters**

<b>Parameter</b>	<b>Value</b>
Reactor Catalyst Layers	3
Reagent Type	Anhydrous Ammonia
Cleaning System	Sonic horns (one per layer)
Temperature (nominal baseline)	700°F (371°C)
Reactor NO <sub>x</sub> Removal Level	90%
Ammonia Slip	< 2 ppmv
SO <sub>2</sub> Conversion	Not specified
Fuel Type	Bituminous

**Catalyst Exposure**

Prior to N<sub>2</sub>O and NO<sub>2</sub> testing, catalysts were used as part of a different research program where catalyst samples were exposed to flue gas in a slip-stream reactor attached to a 75 MW, T-fired unit firing pulverized coal. Flue gas was extracted from the host boiler prior to any ash collection. Catalysts were exposed for various lengths of time, as shown in Table 1-2. Both Catalysts C and D were relatively new; while Catalyst A was aged (catalyst life is approximately 20,000 hours, depending on fuel).

**Table 1-2  
Catalyst Exposure Hours**

<b>Catalyst</b>	<b>A</b>	<b>B</b>	<b>C</b>	<b>D</b>
<b>Approximate Exposure Hours</b>	16,000	8,000	2,000	2,000

The host unit fuel was sourced from various locations, and included various fuel blends, but in all cases the fuels were similar to eastern bituminous coal, with low to mid-sulfur and low to mid-chlorine. Representative coal analyses which approximate the range of coals fired over the catalyst's exposure history are shown in Table 1-3.

**Table 1-3**  
**Representative Coal Analyses – Ultimate Analysis**

Coal ID	A	B	C	D	E	F	G
State	Colombia, SA	Colombia, SA	UT	WV	WV	IL	IL
<b>ULTIMATE ANALYSIS</b> (% , dry basis)							
Total Moisture	12.39	9.77	6.54	5.63	5.75	11.89	11.39
Ash	7.03	6.92	10.05	16.03	14.46	8.2	7.26
HOC (Btu/lb)	13003	13366	13325	12612	12785	13570	13656
Total Sulfur	0.65	0.59	1.3	0.66	0.94	1.75	1.18
Carbon	73.63	77.94	76.95	72.01	74.12	76.87	78.49
Hydrogen	4.94	4.94	4.78	4.49	4.62	4.98	4.85
Nitrogen	1.49	1.56	1.56	1.3	1.31	1.75	1.84
Oxygen	12.26	8.05	5.36	5.51	4.55	6.45	6.38
Volatiles	37.47	37.12	35.22	31.22	30.12	34.32	32.32
Fixed Carbon	55.5	55.96	54.73	52.75	55.42	57.48	60.42
Ash Fusion IT (°F)	2196	2368	2060	2541	2800	2046	2154
Ash Fusion ST(°F)	2378	2574	2134	2510	2800	2134	2260
Ash Fusion HT(°F)	2438	2652	2158	2645	2800	2238	2238
Ash Fusion FT(°F)	2532	2728	2260	2662	2800	2340	2534
Grindability Index	40	44	45	46	44	53	52
<b>ASH CONSTITUENTS</b> (% , as ashed in laboratory)							
Al <sub>2</sub> O <sub>3</sub>	20.94	20.31	18.28	29.4	29.46	19.88	22.42
Fe <sub>2</sub> O <sub>3</sub>	7.13	7.48	4.37	3.75	4.4	17.13	11.85
CaO	2.49	1.23	10.51	1	0.67	2.07	1.91
MgO	1.32	1.01	3.26	1.1	0.82	0.93	1.07
MnO <sub>2</sub>	0.03152	0.0461	0.03018		0.0164	0.03108	0.03288
P <sub>2</sub> O <sub>5</sub>	0.32	0.28	0.16		0.17	0.55	0.36
K <sub>2</sub> O	1.81	1.52	1.25	2.98	2.77	2.48	2.66
SiO <sub>2</sub>	59.62	64.72	43.63	63	59.14	52.67	55.26
Na <sub>2</sub> O	1.49	0.56	4.57	0.346	0.2	1.06	1.28
SO <sub>3</sub>	3.21	1.55	11.69	0.636	0.59	1.81	1.82
TiO <sub>2</sub>	1	1	1.08	1.75	1.66	1.25	1.31




# 2

## TESTING APPROACH

### Test Facility Design and Experimental Conditions

The catalysts were tested in a bench-scale facility at an independent laboratory. The testing apparatus and experimental design was consistent with typical testing for deNO<sub>x</sub> and SO<sub>2</sub> conversion activity.<sup>3</sup> Figure 2-1 shows the flow diagram for the test facility. A propane fired boiler (1) was used to generate the flue gas. The gas passes through an electric reheater (2) to assure a stable and precise temperature. The flue gas conditioning unit (3) adjusts the required SO<sub>2</sub> and NH<sub>3</sub> levels upstream (4) and downstream (6) of the catalyst chamber (5) for O<sub>2</sub>, SO<sub>2</sub>, and nitric oxide (NO<sub>x</sub>) and nitrous oxide (N<sub>2</sub>O) measurement in the flue gas. Figure 2-2 shows two photographs of the laboratory test reactor, with catalyst sample being installed.



**Figure 2-1**  
**Flow Diagram for Bench-Scale Test Facility**

<sup>3</sup> See “Protocol for Laboratory Testing of SR Catalyst: 2<sup>nd</sup> Edition,” EPRI Report No. 1014256, 12/21/2007; and “VGB Guideline for the Testing of DeNO<sub>x</sub> Catalytic Converters, VGB-R 302He, 2<sup>nd</sup> Revised Version, Published by VGB Kraftwerkstechnik, Klinkestrasse 27-31, 45136 Essen, Germany.



**Figure 2-2**  
**Photographs of Laboratory Test Reactor with Catalyst Sample**

### ***Gas Measurement***

The continuous gas analysis system uses a heated filter element and sample line. A chiller removes excess moisture to a dewpoint of 4°C (39°F). After the pump and filter unit, the gas path splits to the SO<sub>2</sub> detector and the SO<sub>2</sub> scrubber. A 3% hydrogen peroxide solution removes more than 90% of the SO<sub>2</sub> before entering the NO<sub>x</sub>, N<sub>2</sub>O, and O<sub>2</sub> analyzer. Figure 2-1 shows the gas detectors that are utilized with the bench-scale apparatus.



**Table 2-1**  
**Gas Measurement Devices**

Gas	Device	Measurement Method
O <sub>2</sub>	ABB AO2000	Paramagnetic
SO <sub>2</sub>	ABB AO2000	UV
NO <sub>x</sub>	Ecophysics 800	CLD
N <sub>2</sub> O	Siemens 5E	NDIR

## DeNO<sub>x</sub> and SO<sub>2</sub> Conversion Reporting Basis

### NO<sub>x</sub> Activity

The values for NO<sub>x</sub> activity (K-value) are calculated using Equation 1 below:

$$K = -Av * \ln(1-\eta_{NOx}) \quad \text{Equation 1}$$

Where Av is the area velocity and  $\eta_{NOx}$  is the catalyst deNO<sub>x</sub> efficiency at an ammonia to NO<sub>x</sub> ration equal to 1.

Av is ratio of the flue gas volumetric flow rate (m<sup>3</sup>/h) over the actual catalyst surface area (m<sup>2</sup>) and is defined by:

$$Av = \frac{V}{A_{act}} \quad \text{Equation 2}$$

The NO<sub>x</sub> efficiency is denoted by:

$$\eta_{NOx} = \frac{NO_{x-inlet} - NO_{x-outlet}}{NO_{x-Inlet}} \quad \text{Equation 3}$$

where NO<sub>x</sub>-inlet is the NO<sub>x</sub> inlet concentration (ppm) and NO<sub>x</sub>-outlet is the NO<sub>x</sub> outlet concentration (ppm).

### **SO<sub>2</sub> to SO<sub>3</sub> Conversion**

In the bench-scale reactor, the SO<sub>2</sub> to SO<sub>3</sub> conversion rate is measured without ammonia injection. This testing protocol was postulated by VGB-R302He2<sup>4</sup> in order to represent worst case operating conditions, given that the DeNOx reaction competes with SO<sub>2</sub> to SO<sub>3</sub> conversion in the catalyst. As a result, SO<sub>2</sub> to SO<sub>3</sub> conversion usually decreases significantly within the SCR reactor when ammonia is added to the flue gas. Thus measuring SO<sub>2</sub> to SO<sub>3</sub> conversion without ammonia ensures reproducible results and yields the highest “worse case” conversion rate possible. SO<sub>2</sub> to SO<sub>3</sub> conversion is given by Equation 4 below.

$$K_{SO_2} = \frac{SO_3 \text{ out} - SO_3 \text{ in}}{SO_2} * 100 [\%] \quad \text{Equation 4}$$

The SO<sub>2</sub> conversion rate (K<sub>SO<sub>2</sub></sub>) is defined as follows:

SO<sub>3</sub> out: SO<sub>3</sub> outlet concentration (ppmvd)

SO<sub>3</sub> in: SO<sub>3</sub> inlet concentration (ppmvd)

SO<sub>2</sub>: SO<sub>2</sub> flue gas concentration (ppmvd)

A sufficient catalyst conditioning time with flue gas without NH<sub>3</sub> is important in order to generate reproducible value for the SO<sub>2</sub>/SO<sub>3</sub> conversion rate.

---

<sup>4</sup> Guideline For The Testing Of DeNOx Catalytic Converters, VGB R-302He, 2nd revised version, published by VGB Kraftwerkstechnik, Klinkestrasse 27-31, 45136 Essen, Germany, 1998.

## Simulated Flue Gas

Table 2-2 shows the simulated flue gas concentrations and flow rate that were utilized for the testing. These conditions were consistent with conventional catalyst applications on coal-fired boilers, firing low sulfur coal, and having a moderate level of NO<sub>x</sub>.

**Table 2-2**  
**Simulated Flue Gas Composition and Flow Rate**

Parameter	Units	Value
Flue Gas Flow Rate (for 150 mm X 150 mm test element)	m <sup>3</sup> /h (STP, wet, actual O <sub>2</sub> )	120
Temperature	°F	700
NO <sub>x</sub> Inlet	ppmv (STP, dry, actual O <sub>2</sub> )	200
SO <sub>2</sub> Inlet	ppmv (STP)	500
SO <sub>3</sub> Inlet	ppmv (STP)	TBD
NH <sub>3</sub> /NO <sub>x</sub> Ratio (α) for activity	ppm/ppm	1.000
NH <sub>3</sub> /NO <sub>x</sub> Ratio (α) for SO <sub>2</sub> Conversion	ppm/ppm	0.000
O <sub>2</sub>	% by volume (dry)	4.0
H <sub>2</sub> O	% by volume	10.0



# 3

## TEST RESULTS

---

Table 3-1 shows the results of the bench-scale testing. The actual linear and area velocities are given, along with NO<sub>x</sub> removal efficiency, activity, SO<sub>2</sub> conversion, N<sub>2</sub>O production, and the pressure drop of the sample as tested. Since the tests were conducted at constant volumetric flow rate, the linear and area velocities differed according to the geometry of the particular catalyst sample being tested.

The data show that the catalysts ranged in activity from roughly 30 to 45 m/h. These activity values are consistent with conventional commercial SCR catalysts applied to coal-fired boilers. The SO<sub>2</sub> conversion rates ranged from a low of 0.12 to a high of 0.86. Although this is a relatively broad range, it is well within the industry experience where different requirements and operating philosophies allow for a relatively broad range of SO<sub>2</sub> conversions to be utilized.

In terms of N<sub>2</sub>O production, none of the catalysts produced a significant amount of N<sub>2</sub>O, since all test data showed outlet N<sub>2</sub>O levels of < 5 ppmvd. Note that N<sub>2</sub>O testing included three NH<sub>3</sub>/NO<sub>x</sub> ratio ( $\alpha$ ) conditions. The single catalyst tested for NO<sub>2</sub> production showed a reduction in NO<sub>2</sub> from 2.7 ppmvd at the inlet to <1 ppmvd (the detection limit) at the outlet. Thus, no net NO<sub>2</sub> was produced by the catalyst. The exact rate of NO<sub>2</sub> reduction could not be determined, given the low inlet level and the comparatively high detection limit. The data do show, however, that the NO<sub>2</sub> reduction rate was at least 63%. Note that the overall NO<sub>x</sub> reduction for the NO<sub>2</sub> test was roughly 83%.

Test Results

**Table 3-1  
Test Results**

Parameter	Catalyst A	Catalyst B	Catalyst C	Catalyst D
Linear Velocity (actual m/s)	3.52	3.36	3.45	3.53
Area Velocity (actual m/s)	25.0	21.1	23.9	31.1
NO <sub>x</sub> Removal Eff. (%)	69.1	84.1	84.6	72.5
Activity (m/h)	29.4	38.7	44.7	40.1
SO <sub>2</sub> Conversion Rate, as tested at $\alpha=0$ (%)*	0.86	0.12	0.33	0.33
N <sub>2</sub> O production (ppmvd)				
$\alpha = 0.00$	<LDL**	<LDL	<LDL	<LDL
$\alpha = 0.66$	<LDL	<LDL	<LDL	<LDL
$\alpha = 1.00$	<LDL	<LDL	<LDL	<LDL
NO/NO <sub>2</sub> Data (ppmvd)				
NO <sub>in</sub>		197.9		
NO <sub>2in</sub>		2.7		
NO <sub>out</sub>		33.7		
NO <sub>2out</sub>		<1		
Pressure drop, as tested (mbar)	0.35	0.59	0.69	0.31

\*  $\alpha$  is the ammonia to NO<sub>x</sub> ration

\*\* LDL: Lower than detection limit – 5 ppmvd N<sub>2</sub>O

# 4

## SUPPLEMENTAL NO<sub>2</sub> DATA

---

### Background

A previous EPRI project examined the mercury oxidation behavior of new, aged, and regenerated SCR catalyst in a three-train pilot facility for their behavior with respect to mercury oxidation.<sup>5</sup> Although NO<sub>2</sub> behavior was not a focus of the project, NO<sub>2</sub> data were acquired as a matter of course during the project testing.<sup>6</sup> These data has been reviewed and summarized in support of this project.

### Catalyst Characteristics

Two groups of catalyst types were evaluated in the above referenced project, one including honeycombs, and one other including plates. New, aged, and regenerated versions of each of these catalysts were evaluated in the pilot facility, for a total of six (6) distinct catalyst versions. Both catalyst types were consistent with current commercial SCR catalysts for application to high-dust coal fired boiler flue gas. The exposure conditions of the aged catalyst samples are summarized below in Table 4-1. New versions of the catalysts were sourced from the manufacturer and were of identical formulation to that of the aged catalyst. Regenerated versions of the catalysts were obtained by regenerating samples of the aged catalysts following full-scale regeneration practices. Additional information on the catalysts can be found in the above referenced reports.

---

<sup>5</sup> See “Mercury Oxidation Behavior of New, Aged, and regenerated SCR Catalysts,” EPRI Report No. 1014252, 12/20/2007; and “Regenerated Plate Type SCR Catalyst Performance,” EPRI Report No. 1018487. 1/26/2009.

<sup>6</sup> NO<sub>x</sub> and other gaseous constituents were measured via continuous FTIR spectroscopy, which gave a wide range of potential analytes.

**Table 4-1  
Exposure Conditions of Characteristics of Aged Catalyst Samples**

Parameter	Honeycomb Catalyst	Plate Catalyst
Exposure Hours	20,000	22,000
Boiler Configuration	T-Fired	T-Fired
Coal	Central Appalachian	Central Appalachian
Coal Sulfur Content	1.2 %	1.4 %
Inlet NO <sub>x</sub>	0.45 %	0.48 %
Design DeNO <sub>x</sub>	90 %	90 %
Activity (m/hr)		
New	48.1	48.3
Aged	35.1	28.0
Regen	42.0 <sup>7</sup>	36.9
SO <sub>2</sub> Conversion (%)		
New	0.31	0.17
Aged	0.36	0.16
Regen	0.43 <sup>5</sup>	0.40

### Pilot Plant Operating Conditions

The pilot plant operated as a slip stream facility attached to a 150 MW T-fired boiler, firing low-chlorine central Appalachian coal. Figures 4-1 and 4-2 depict the pilot-scale reactor and a catalyst test module respectively. Table 4-2 gives the nominal operating conditions for the tests. Two layers of catalyst were utilized in the pilot reactors, making the overall configuration similar to a full-scale SCR application. Additional data related to the pilot plant design, operation, and host boiler can be found in the previously referenced EPRI reports.

**Table 4-2  
Nominal Pilot Plant Operating Conditions**

Parameter	Value
Space Velocity	4,000 hr <sup>-1</sup> @ 68°F (20°C)
Temperature	650°F (343°C)
Reactor DeNO <sub>x</sub>	90 %
Inlet NO <sub>x</sub>	225 ppm
SO <sub>2</sub>	850 ppm
O <sub>2</sub>	6 %
CO <sub>2</sub>	12 %
CO	7 ppm
Chlorine	5 ppm

<sup>7</sup> The regeneration process resulted in two distinct groups of regenerated catalyst being produced, due to some exposure differences between the various catalysts elements that were being treated. The values for activity and SO<sub>2</sub> conversion represent the average of these two batches of regenerated catalyst, and are representative of the activity and SO<sub>2</sub> conversion for the reactor as a whole, as installed in the pilot plant.






Figure 4-1  
Three Train Pilot Scale Reactor



**Figure 4-2**  
**Photograph of Pilot Catalyst Module (side and top views)**

### Reference Flue Gas Constituents

Reference flue gas constituents, including H<sub>2</sub>O, NO<sub>2</sub>, NO, SO<sub>2</sub>, HCl, NH<sub>3</sub>, CO<sub>2</sub>, and CO were measured using a Fourier Transform Infrared (FTIR) Spectrometer. FTIR technology allows for the simultaneous measurement of target flue gas constituents based upon infrared spectra. The low detection limits of the instrument along with near real-time response, made this measurement technique highly suitable for the application. A MKS Multigas™ 2030 FTIR instrument<sup>8</sup> was utilized. The sample taken from the QGIS probe was transported to the FTIR through a heated stainless steel sample line. The line was heated to approximately 450°F (232°C) to ensure no loss of ammonia during transport. The sample flow through the FTIR was induced by a vacuum pump at a flow rate of about 2 liters per minute. The oxygen content of the flue gas exiting the FTIR was measured periodically with a hand-held oxygen analyzer. A background zero check was conducted each day using nitrogen from gas bottles. Calibration spectra for each gas were held internally in the FTIR. This provided for accurate real-time display and data logging of actual measured gas concentrations (wet basis) in the sampled flue gas.

### Test Results

The NO<sub>2</sub> data from the pilot plant testing is shown below in Table 4-3. In all cases, the measured NO<sub>2</sub> level was below the detection limit of approximately 1 ppm. This indicates that there was very little formation of NO<sub>2</sub> in the boiler itself, and that the catalyst did not produce any additional NO<sub>2</sub> (at least within the sensitivity of the measurement method). Since these data were acquired for new, aged, and regenerated catalysts of both honeycomb and plate type, there is some confidence that catalyst aging or regeneration does not adversely affect the NO<sub>2</sub> behavior of the catalysts.

<sup>8</sup> Manufactured by MKS Instruments, 90 Industrial Way, Wilmington, Massachusetts 01887

**Table 4-3**  
**Pilot Plant NO<sub>2</sub> Test Results**

Catalyst	Honeycomb			Plate		
	New	Aged	Regen.	New	Aged	Regen.
NO <sub>2</sub> In	< 1 ppm	< 1 ppm	< 1 ppm	< 1 ppm	< 1 ppm	< 1 ppm
NO <sub>2</sub> Out	< 1 ppm	< 1 ppm	< 1 ppm	< 1 ppm	< 1 ppm	< 1 ppm



# 5

## CONCLUSIONS

---

The test program covered a relatively broad range of conventional SCR catalysts, with designs consistent with coal-fired applications. The activity and SO<sub>2</sub> conversions values of the catalysts were consistent with industry experience. Within the sensitivity of the experimental design, none of the catalysts produced detectable amounts of N<sub>2</sub>O. Assuming that these results apply to the commercial conventional SCR catalyst fleet as a whole, it does not appear that N<sub>2</sub>O formation will be of concern for conventional catalysts. However, as catalyst formulations change over time or otherwise deviate from the current normal conventional catalyst design, N<sub>2</sub>O formation may be a consideration. Similar to the findings for N<sub>2</sub>O, the data indicate that the conventional catalysts tested do not have the propensity to produce NO<sub>2</sub>. Limited data indicate that NO<sub>2</sub> is reduced across the catalyst similar to NO, but the exact rate of NO<sub>2</sub> reduction could not be determined with the available data. As with N<sub>2</sub>O formation, changes in catalyst design may result in NO<sub>2</sub> formation/reduction characteristics which differ from the current findings.





## **Export Control Restrictions**

Access to and use of EPRI Intellectual Property is granted with the specific understanding and requirement that responsibility for ensuring full compliance with all applicable U.S. and foreign export laws and regulations is being undertaken by you and your company. This includes an obligation to ensure that any individual receiving access hereunder who is not a U.S. citizen or permanent U.S. resident is permitted access under applicable U.S. and foreign export laws and regulations. In the event you are uncertain whether you or your company may lawfully obtain access to this EPRI Intellectual Property, you acknowledge that it is your obligation to consult with your company's legal counsel to determine whether this access is lawful. Although EPRI may make available on a case-by-case basis an informal assessment of the applicable U.S. export classification for specific EPRI Intellectual Property, you and your company acknowledge that this assessment is solely for informational purposes and not for reliance purposes. You and your company acknowledge that it is still the obligation of you and your company to make your own assessment of the applicable U.S. export classification and ensure compliance accordingly. You and your company understand and acknowledge your obligations to make a prompt report to EPRI and the appropriate authorities regarding any access to or use of EPRI Intellectual Property hereunder that may be in violation of applicable U.S. or foreign export laws or regulations.

## **The Electric Power Research Institute (EPRI)**

The Electric Power Research Institute (EPRI), with major locations in Palo Alto, California; Charlotte, North Carolina; and Knoxville, Tennessee, was established in 1973 as an independent, nonprofit center for public interest energy and environmental research. EPRI brings together members, participants, the Institute's scientists and engineers, and other leading experts to work collaboratively on solutions to the challenges of electric power. These solutions span nearly every area of electricity generation, delivery, and use, including health, safety, and environment. EPRI's members represent over 90% of the electricity generated in the United States. International participation represents nearly 15% of EPRI's total research, development, and demonstration program.

Together...Shaping the Future of Electricity

© 2009 Electric Power Research Institute (EPRI), Inc. All rights reserved.  
Electric Power Research Institute, EPRI, and TOGETHER...SHAPING  
THE FUTURE OF ELECTRICITY are registered service marks of the  
Electric Power Research Institute, Inc.

1019614