



Energy Storage Cost Summary for Utility Planning: Executive Summary

3002008877, November 2016

EPRI Project Managers G. Damato E. Minear

DISCLAIMER OF WARRANTIES AND LIMITATION OF LIABILITIES

THIS DOCUMENT WAS PREPARED BY THE ORGANIZATION(S) NAMED BELOW ASAN ACCOUNT OF WORK SPONSORED OR COSPONSORED BY THE ELECTRIC POWER RESEARCH INSTITUTE, INC. (EPRI). NEITHER EPRI, ANY MEMBER OF EPRI, ANY COSPONSOR, THE ORGANIZATION(S) BELOW, NOR ANY PERSON ACTING ON BEHALF OF ANY OF THEM:

(A) MAKES ANY WARRANTY OR REPRESENTATION WHATSOEVER, EXPRESS OR IMPLIED, (I) WITH RESPECT TO THE USE OF ANY INFORMATION, APPARATUS, METHOD, PROCESS, OR SIMILAR ITEM DISCLOSED IN THIS DOCUMENT, INCLUDING MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE, OR (II) THAT SUCH USE DOES NOT INFRINGE ON OR INTERFERE WITH PRIVATELY OWNED RIGHTS, INCLUDING ANY PARTY'S INTELLECTUAL PROPERTY, OR (III) THAT THIS DOCUMENT IS SUITABLE TO ANY PARTICULAR USER'S CIRCUMSTANCE; OR

(B) ASSUMES RESPONSIBILITY FOR ANY DAMAGES OR OTHER LIABILITY WHATSOEVER (INCLUDING ANY CONSEQUENTIAL DAMAGES, EVEN IF EPRI OR ANY EPRI REPRESENTATIVE HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES) RESULTING FROM YOUR SELECTION OR USE OF THIS DOCUMENT OR ANY INFORMATION, APPARATUS, METHOD, PROCESS, OR SIMILAR ITEM DISCLOSED IN THIS DOCUMENT.

REFERENCE HEREIN TO ANY SPECIFIC COMMERCIAL PRODUCT, PROCESS, ORSERVICE BY ITS TRADE NAME, TRADEMARK, MANUFACTURER, OR OTHERWISE, DOES NOT NECESSARILY CONSTITUTE OR IMPLY ITS ENDORSEMENT, RECOMMENDATION, OR FAVORING BY EPRI.

THE ELECTRIC POWER RESEARCH INSTITUTE (EPRI) PREPARED THIS REPORT.

NOTE

For further information about EPRI, call the EPRI Customer Assistance Center at 800.313.3774 or e-mail askepri@epri.com.

Electric Power Research Institute, EPRI, and TOGETHER ... SHAPING THE FUTURE OF ELECTRICITY are registered service marks of the Electric Power Research Institute, Inc.

Copyright © 2016 Electric Power Research Institute, Inc. All rights reserved



Acknowledgments

This report was prepared by

Electric Power Research Institute 3420 Hillview Avenue Palo Alto, California 94304

Principal Investigators E. Minear B. Kaun

G. Damato

Hoffman Power Consulting P.O. Box 580 Morgan Hill, CA 95038

Principal Investigators V. MacLaren-Wray S. Hoffman

This report describes research sponsored by the Electric Power Research Institute (EPRI).



Abstract

This an executive summary of a report that was prepared as a utility resource for planners and others involved in evaluating energy storage. As grid-connected energy storage installations transition from the demonstration phase to commercial deployment, it becomes increasingly important to understand the cost and valuation of storage. This is especially true when comparing to conventional generation or "wiresbased" alternatives. This report provides projected installed costs for energy storage systems assuming installation and start of commercial operation in 2017 and discusses various cost metrics used for storage and their applicability. Additionally, this report illustrates importance of predetermining energy storage value as well as cost. Due to a multitude of energy storage sizes, locations, and uses, comparisons based on simplified duty cycle assumptions have potential to mislead planners and investors.



Table of Contents

Introduction	1
Cost Study Methodology	2
Summary of Cost Results	3
Cost Metrics	4
Cost-Benefit Analysis	5



Results

Cost Methodolog

Cost Metrics Cost-Benetit Analysis

Description of Contents

This cost summary was developed to support utility resource planners in their understanding of energy storage costs, cost metrics and provide a brief introduction to valuation. This executive summary includes the following section and contents:

• **Cost Methodology** – The scope of the cost study is to provide installed cost for technologies with commercial deployment track records. This section describes the technology section and data collection process. Additionally, since energy storage is an energy limited resource unlike conventional generation, there is some discussion to highlight that costs can not simply be communicated on a \$/kW or \$/kWh basis for a given technology, the power and energy rating must be factored in.

 Cost Results – This section includes total installed costs contemplating project configurations for the various technologies and an example of a detailed breakdown of lithium ion system costs that were also collected in this study. The costs are based on a 2017 reference year for installation. Future cost projections (beyond 2017) were not included in this study, but EPRI research in both the energy storage and transportation programs, indicate that battery and system costs will continue to decrease in the next few years.

• **Cost Metrics** – There are several different cost metrics used in evaluating energy storage. This section contains an overview of those metrics and their applicability.

 Cost-Benefit Analysis – This section presents an example of cost-benefit analysis for a resource adequacy or capacity use case with the key message that cost is only one part of the equation and benefits must be included for a complete evaluation.



Cost Study Methodology

Description and discussion of approach to generate current energy storage cost estimates



Technology Selection for Cost Study

- To support depth of analysis, technology scope was limited.
- Technologies were prioritized based on the following criteria
 - Maturity of technology and derivative products
 - Substantial recent changes in cost/price due to recent technical or business developments
- Selected Technologies:
 - Compressed Air Energy Storage (CAES)
 - Pumped Hydro
 - Lead Acid Batteries
 - Lithium Ion Batteries
 - Sodium Sulfur (NaS) Batteries
 - Flywheel





Introduction

Methodology

Cost

Cost

Cost

Cost-Benefit

Scope of Energy Storage Costs Considered

- Scope consistent with other technologies included in EPRI Technology Assessment Guides, except contingencies are not included [1]
- Energy Storage Integration Council (ESIC) Cost Tool and Template was used to identify scope of installation costs. [2]
 - Tool was developed to provide exhaustive list of project cost components and help facilitate clear communication in a request for proposal/quote
 - Screen shot shown to right shows this project scope (i.e. inclusions/exclusions).
 - Not all cost items in the template are shown.
 Operations and
 Maintenance, replacement, and other recurring costs
 were not included in this study.

Cost Line Item	Cost Input Options
Total Project Development	Excluded
Project Development Oversight	
Site Selection	
Permitting - Land Use	
Power system feasibility / interconnection study (e.g. WDAT, Rule 21)	<u> </u>
Specification Development	ett
Solicitation Development	l di la constante di la consta
Proposal Evaluation, Negotiation, & Contracting	
Other Project Development Costs	
Total Energy Storage Product	Included-Not Itemized
Battery / Energy Storage Medium	
Power Conversion System (PCS)	
Control Software	
Control Equipment	
UPS & Other Electronics	_
ESS Thermal Management System	es e
Pre-Engineered ESS Structural Components (e.g. containers & racks)	
Security Equipment	O
Safety Equipment (e.g. fire suppression)	
Other ESS Purchases	
Total ESS Shipping	Included-Not Itemized
Total Project Management	Included-Not Itemized
Total Engineering Study	Included-Not Itemized
Total Grid Integration Equipment	Included-Not Itemized
Transformer(s)	
Protection Equipment	
Switchgear	
Other Integration Equipment	
Total Metering & Telemetry	Included-Not Itemized
Total Grid Integration Site Manager Software Purchase & Certification	Included-Not Itemized
Total ESS Data Storage Computer & SCADA Software or Data Historian	Included-Not Itemized
Total Site Installation	Included-Not Itemized
Total ESS Installation	Included-Not Itemized
Total Commissioning and Acceptance Testing	Included-Not Itemized
Total Training	Included-Not Itemized
Total Upfront Financing Fees	Excluded
Total SG&A	Included-Not Itemized
Total Unfront FSS Program Costs	Excluded
i cha opinicit cost regioni costo	CARIOUCU



Introdu

Data Collection Approach and Process

- Initial cost ranges developed by EPRI project experience and previous studies. Ranges refined by industry input from ESS vendors, integrators, developers, and general contractor/engineering, procurement and construction firms.
- Detailed lithium ion estimates were obtained for three example use cases. These were used to validate associated summary ranges and provided further insight to the break down of project costs by major component/category.
- Pumped Hydro estimates are based on a 2010 EPRI Study [3] and escalated by 2% per year
- CAES estimates were validated internally within EPRI by subject matter experts with experience deploying CAES systems



Introduction

Cost Methodology

Cost Results

Cost Metrics

ost-Be

Scaling Factors for Energy Storage Costs

- Installed costs for energy storage scale two dimensions:
 - Power-related costs (\$/kW or \$/MW) scale by the rated capacity of the storage plant, similar to conventional generation
 - Energy-related costs (\$/kWh or \$/MWh) scale by the size of the energy storage reservoir.
- Total cost ranges therefore depend on the scale of the energy storage in each dimension as well as variations in site-specific costs.
- Expression of costs on a \$/kW basis is preferred for improved comparison with other generation options for integrated resource planners. However, to highlight the impact of scale, in both power rating and energy rating, different project reference sizes are presented to incorporate impacts of power- and energy-related scaling factors.
- System sizes selected for study are based on similar-sized projects that have been built recently or are under current development, in order to access more up-to-date data than are available at present for other technologies. Also, sizes help to provide some comparative insight on how duration impacts costs.



Summary of Cost Results

Cost ranges and illustrative examples for energy storage technologies





- Costs are for 2017 installation reference year only and assumes overnight installed costs.
- Suppliers and publicly available studies indicate continuing trend of cost decline for batterybased storage technologies, particularly lithium-ion.
- Installed costs <u>exclude</u> land costs, owners costs, and contingency. Detailed list of inclusions and exclusions is provided in previous section.
- Average is not necessarily mid-point of the range



Cost-Benefit

Analysis

Energy Storage Installed Cost Summary: 2017

Application	Technology	Rating (MW)	Duration (hours)	2017 Cost (\$/KW)	
Bulk Storage	Pumped Hydro	300-1000	10	1700 - 5100	
	CAES	100-300	10	1300 - 2800	
	CAES	30-50	6	2000 - 3300	
	Lithium Ion	30-50	6	2500 - 3900	
	Lead Acid	30-50	6	2800 - 4200	
	NaS	30-50	6	2700 - 4200	
	Lithium Ion	50-100	4	1600 - 2700	
T&D Grid Support	CAES (Above Ground)	10-20	4	2300 - 3500	
	Lithium Ion	10-20	4	1800 - 2800	
	Lead Acid	10-20	4	2200 - 3700	
	NaS	10-20	6	2800 - 4400	
	Lithium Ion	1-5	2	1200 - 2000	
Frequency Regulation	Lithium Ion	20	0.5	550 - 1200	
	Flywheel	20	0.25	800 - 2000	



Breakout costs for Lithium Ion

- Lithium ion costs were further broken down into the costs of major system components
 - ESS Product includes the battery, PCS, control software, ESS thermal management systems, ESS safety systems, pre-engineered racks and containers
 - Site and Grid Integration encompasses remaining costs such as grid integration equipment, installation, engineering and project management
 - Fees, General and Administrative (G&A) costs were assumed to be 10% of total project cost. This is based on typical Fees and G&A included for other technologies in the Technology Assessment Guide [1]
- Example cost in the table are based on a 20MW, 4 hour system
- Additional breakouts of balance of plant costs and full breakout costs for 2MW, 2 hour and 20MW, 0.5 hour lithium ion systems are included in the full report [4]

Technology Description		Li-ion		
Rating	MW	20		
Duration	Hours	4		
Commercial Start Year of Service	Year	2017		
ESS Product	\$/kW	1420		
ESS Shipping	\$/kW			
Grid Integration Equipment (up to high	¢ /LAN			
side of step up transformer)	Ş/KVV			
Metering and Telemetry	\$/kW	1		
Grid Integration Site Manager Software	¢ /LAN	645		
Purchase and Certification	Ş/KVV			
ESS Data Storage Computer and SCADA	¢ /LAA			
Software or Data Historian	Ş/KVV			
Site Installation	\$/kW	· · ·		
ESS Installation	\$/kW			
Commissioning and Acceptance Testing	\$/kW			
Project Management	\$/kW			
Engineering Study	\$/kW			
Training	\$/kW			
Project Development	\$/kW	not included		
Extended Warranty Option	\$/kW	not included		
Upfront ESS Program Costs	\$/kW	not included		
Subtotal Installed Plant Cost	\$/kW	2085		
Tax for ESS Product and Grid Integration	¢ /LAN	4.45		
Equipment (7%)	Ş/KVV	145		
Fee and G&A (10%)	\$/kW	210		
Process Contingency	\$/kW	not included		
Project Contingency	\$/kW	not included		
Total Installed Plant Cost	\$/kW	2440		



Introduction

Methodology

Results

Cost Metrics

Cost-Benefit

Analysis

Cost Metrics

Discussion of metrics and applicability for expression and comparison of energy storage costs



Metrics Used for Storage Cost Comparison

There are currently several metrics for measuring the cost of energy storage systems. Due to the distinguishing characteristics of energy storage relative to traditional generation, it is important to understand the various cost metrics and the scenarios under which it would make sense to apply them. The table below provides a summary of the commonly-used cost metrics and their broad applications.

Metric	Expressed as:	Applications and <i>caveats:</i>
Installed Cost	\$/kW	Comparisons with reliability-based capacity resources, such as CT Used as an input to more-detailed cost-benefit analyses
Levelized Cost of Capacity	\$/kW-Year	Primarily used for comparing to reliability-based capacity resources, such as CT Cost of New Entry (CONE) assessment
Present Value of Life-cycle Costs	PV \$/kW or PV \$/kWh	Used for storage technologies, typically not for conventional generation Compared with PV of revenue for cost-benefit evaluation Specific to a given technology and use case and not for direct comparisons with alternatives.
Levelized Cost of Electricity (LCOE)\$/MWhUsed to normalize generation cost between a costs and capacity factors.%/MWhPrimarily of interest for energy resources such generationMisleading for energy storage because stora producing device, and LCOE does not capture capacity and flexibility.		Used to normalize generation cost between different installed costs and capacity factors. Primarily of interest for energy resources such as baseload fossil generation <i>Misleading for energy storage because storage is not a net energy producing device, and LCOE does not capture the value of storage capacity and flexibility.</i>



ELECTRIC POWER

RESEARCH INSTITUTE

Introduction



Metrics (Continued)

Installed Cost (\$) includes all equipment, delivery, installation, interconnection and step-up transformers. This metric assumes a site is available; so does not include the cost of land or project planning costs. It does not account for ongoing costs, replacement costs, or any income or benefits obtained from storage.

Levelized Cost of Capacity is a lifecycle measure of fixed and variable costs. The objective is to identify a value for the revenue per kW of capacity that the generator needs to produce, on a time-discounted basis, to cover those lifecycle costs. For storage, the variable costs include off-peak charging costs which may change over time. Consistent with usage when applied to conventional generation, this metric does not incorporate any benefits or revenue obtained from storage operation.

Present Value of Life-Cycle Costs similarly accounts for fixed and variable costs over time. This metric includes installed costs, ongoing fixed O&M, variable O&M, and replacement equipment costs (including battery replacement) over the useful life of the plant. Costs are aggregated over time in present-value terms, using the selected discount rate. The resulting total present-valued cost is then divided either by rated output (kW) or by estimated total lifetime energy generation (kWh). Again, the variable costs include off-peak time-varying charging costs but do not incorporate any benefits or revenue obtained from storage operation. ESIC's Cost Tool provides this calculation in \$/kWh terms and refers to the metric as Total Cost of Energy Storage (TCOES). [2]

Levelized Cost of Electricity (LCOE) is the cost per unit of energy delivered, defined formally as the present value of all costs over the life of a project (including initial capital costs, all operational costs including fuel and O&M, and disposal costs) divided by the total energy delivered over the life of the project, and has units \$/kWh or \$/MWh delivered. "Present value" means that costs accrued and energy delivered in future years are "discounted" into present day equivalent values. LCOE is a simple and attractive metric when operationally equivalent generation technologies are being compared and when the only value under consideration is the delivered energy.



Cost-Benefit

Analysis

Cost-Benefit Analysis

Discussion of value and "net cost" considerations



Comparison of Net Cost of Capacity

For Illustration Only



- When analyzing the economics of an energy storage plant, it is important to understand not only the upfront installed costs, but the net market value. Energy storage differs from conventional generation in operating cost and market benefits. New tools are required for storage valuation.
- The economic analysis needs to capture costs and benefits during charging and discharging and also the multiple services an energy storage plant can provide to the grid: consuming and storing relatively low-cost (i.e., off-peak) electricity, displacing higher-cost (i.e. on-peak) generation, providing ancillary services, and supporting grid resiliency and security.

Cost of new capacity is full installed cost net lifetime operational benefits

Introduction

Methodolog

Cost Results

Cost Metrics

Cos

EPRI publicly available resources for further information on benefit and cost analysis for energy storage

- Storage Value Estimation Tool (StorageVET[™]) [forthcoming December 2016, more information at <u>www.storagevet.com</u>]
- "Cost-Effectiveness of Energy Storage in California." [EPRI 3002001162]
- ESIC Cost Template and Tool [EPRI 3002006072]



Introduction

Cost Metrics

Analysis

Full Report Forthcoming

Energy Storage Cost Summary for Utility Planning. EPRI, Palo Alto, CA, 2016. 3002008876.

For more information visit www.epri.com



References

[1] *Technical Assessment Guide (TAG®)-Power Generation and Storage Technology Options: 2012 Topics.* EPRI, Palo Alto, CA: 2013. 1024063.

[2] Energy Storage Cost Template and Tool: Guidelines Developed by the Energy Storage Integration Council for Distribution-Connected Systems (ESIC Cost Tool) v1.0, EPRI, Palo Alto, CA 2016. 3002006072.

[3] *Electric Energy Storage Technology Options: A White Paper Primer on Applications, Costs, and Benefits.* EPRI, Palo Alto, CA, 2010. 1020676.

[4] *Energy Storage Cost Summary for Utility Planning*. EPRI, Palo Alto, CA, 2016. 3002008876.



Together...Shaping the Future of Electricity

The Electric Power Research Institute, Safe **Inc.** (EPRI, www.epri.com) conducts research and development relating to the generation, delivery and use of electricity Reliable for the benefit of the public. An Electricity independent, nonprofit organization, EPRI brings together its scientists and engineers as well as experts from academia and industry to help address challenges in rironme Responsib electricity, including reliability, efficiency, affordability, health, safety and the environment. EPRI members represent 90% of the electric utility revenue in the United States with international participation in 35 countries. EPRI's principal offices and laboratories are located in Palo Alto, Calif.; Charlotte, N.C.; Knoxville, Tenn.; and Lenox, Mass.



Affordab/e