

# Digital Feedwater Control Algorithms—Real Time Simulation Using RELAP5

TP-112229

Effective October 22, 2009, this report has been made publicly available in accordance with Section 734.3(b)(3) and published in accordance with Section 734.7 of the U.S. Export Administration Regulations. As a result of this publication, this report is subject to only copyright protection and does not require any license agreement from EPRI. This notice supersedes the export control restrictions and any proprietary licensed material notices embedded in the document prior to publication.





# **Digital Feedwater Control Algorithms – Real-Time Simulation Using RELAP5**

TP-112229

Technical Progress, March 1999

EPRI Project Manager

R. Torok

## **DISCLAIMER OF WARRANTIES AND LIMITATION OF LIABILITIES**

THIS DOCUMENT WAS PREPARED BY THE ORGANIZATION(S) NAMED BELOW AS AN ACCOUNT OF WORK SPONSORED OR COSPONSORED BY THE ELECTRIC POWER RESEARCH INSTITUTE, INC. (EPRI). NEITHER EPRI, ANY MEMBER OF EPRI, ANY COSPONSOR, THE ORGANIZATION(S) BELOW, NOR ANY PERSON ACTING ON BEHALF OF ANY OF THEM:

- (A) MAKES ANY WARRANTY OR REPRESENTATION WHATSOEVER, EXPRESS OR IMPLIED, (I) WITH RESPECT TO THE USE OF ANY INFORMATION, APPARATUS, METHOD, PROCESS, OR SIMILAR ITEM DISCLOSED IN THIS DOCUMENT, INCLUDING MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE, OR (II) THAT SUCH USE DOES NOT INFRINGE ON OR INTERFERE WITH PRIVATELY OWNED RIGHTS, INCLUDING ANY PARTY'S INTELLECTUAL PROPERTY, OR (III) THAT THIS DOCUMENT IS SUITABLE TO ANY PARTICULAR USER'S CIRCUMSTANCE; OR
- (B) ASSUMES RESPONSIBILITY FOR ANY DAMAGES OR OTHER LIABILITY WHATSOEVER (INCLUDING ANY CONSEQUENTIAL DAMAGES, EVEN IF EPRI OR ANY EPRI REPRESENTATIVE HAS BEEN ADVISED OF THE POSSIBILITY OF SUCH DAMAGES) RESULTING FROM YOUR SELECTION OR USE OF THIS DOCUMENT OR ANY INFORMATION, APPARATUS, METHOD, PROCESS, OR SIMILAR ITEM DISCLOSED IN THIS DOCUMENT.

ORGANIZATION(S) THAT PREPARED THIS DOCUMENT

**Touch Base Computing**

## **ORDERING INFORMATION**

Requests for copies of this report should be directed to the EPRI Distribution Center, 207 Coggins Drive, P.O. Box 23205, Pleasant Hill, CA 94523, (925) 934-4212.

Electric Power Research Institute and EPRI are registered service marks of the Electric Power Research Institute, Inc. EPRI. POWERING PROGRESS is a service mark of the Electric Power Research Institute, Inc.

Copyright © 1999 Electric Power Research Institute, Inc. All rights reserved.

## CITATIONS

---

This document was prepared by

Touch Base Computing  
106 Woodcrest Drive  
Rome, GA 30161-4702

Authors

J. A. Mowrey  
P. R. Boylan

This document describes research sponsored by EPRI.

The publication is a corporate document that should be cited in the literature in the following manner:

*Digital Feedwater Control Algorithms – Real-Time Simulation Using RELAP5*, EPRI,  
Palo Alto, CA: 1999. TP-112229.



## **ABSTRACT**

---

A model developed to test and tune a digital feedwater control system for a boiling water reactor was expanded to include the feedwater heater system and a variable-speed drive recirculation pump option. The model consists of a RELAP5 thermal-hydraulic simulation coupled to a 'LabVIEW' control system simulation that can operate either interactively with a Foxboro IA control system or in a stand-alone plant simulation mode. This report describes in detail the changes that were made in the RELAP model and the 'LabVIEW' control interface.

Stand-alone plant transient test cases were run using the new feedwater system model, and results compared favorably to plant data. Parametric studies were performed to investigate the sensitivity of the feedwater heater control system to selected single failures and variations in response times of selected components. This project successfully demonstrated the utility of an inexpensive human-machine-interface for plant simulation, and the capability of modeling complex balance of plant control systems in RELAP5. It also demonstrated a tool for investigation of potential control scheme weaknesses. Finally, it developed a recirculation pump model with variable speed drive characteristics for use in future simulations.



## **ACKNOWLEDGEMENTS**

---

This work was funded jointly by EPRI and the Tennessee Valley Authority as a tailored collaboration project. The authors and EPRI would like to thank TVA for their support in supplying plant data and reviews in support of this project and to specifically acknowledge the following individuals at the Browns Ferry Nuclear Plant:

Gaylon Hicks

D. Tony Langley

S. Raymond Journey



# **CONTENTS**

---

1	Introduction	1-1
2	Stand Alone Model With Feedwater Heater Level Controls	2-1
3	Benchmarking Results at Various Power Levels	3-1
4	Model Benchmark Transients	4-1
5	Transients and Failure Analysis	5-1
6	Recirculation Pump Controls Changes	6-1
APPENDIX A	- RELAP5 MODEL INPUT DECK WITH NEW FEEDWATER HEATER SYSTEM*	
APPENDIX B	- RELAP5 MODEL INPUT DECK WITH NEW RECIRCULATION CONTROLS*	

*\*Note: Appendices are quite long (200 pages each) and can be downloaded from EPRIWeb.*



# 1

## INTRODUCTION

---

The main purpose of this project was to develop a stand-alone model that could be used to simulate both reactor feedwater control (pressure vessel level control) and feedwater heater control (heater level control). The approach was to expand a previously developed set of computer models used in the development of a feedwater control system to include the feedwater heater systems. This adds significant complexity to the model because of the intricacies of modeling condensing heat exchangers, but offers the added capability to investigate heater and integrated heater/feedwater control strategies. A submodel for a recirculation pump speed control variable speed drive was also developed (Section 6), but was not used in the model checkout tests reported here.

### 1.1 Background

Recently, digital feedwater control system testing and tuning has been performed by coupling a thermal-hydraulic plant simulation model with a control system simulator or the real control equipment, and an operator interface with data acquisition technology. This study is based on a project that applied such an approach to a new distributed digital Reactor Feedwater Control System (RFWCS) for the Browns Ferry Nuclear Plant (Units 2 and 3). The replacement RFWCS made use of the Foxboro Company's Intelligent Automation (I/A) System, consisting of fault tolerant UNIX based distributed digital hardware designed for process controls.

The model and interface modified in this project were originally developed to support real-time testing of the RFWCS. In order to fully test the functionality of the digital RFWCS, the interface was designed to allow initiation of multiple transients including signal failures, as well as display and recording of plant data. A PC was used to house National Instruments data acquisition cards and the operator interface, which was written in "LabVIEW," a National Instruments graphical data handling program for Windows. A RELAP5/MOD3.1 thermal-hydraulic model simulated the reactor system in real time code. The RELAP5 model could also operate in a stand-alone mode without the LabVIEW operator interface. Minor alterations were made to the RELAP5 source code to allow acceptance of external control signals and communication of

---

## *Introduction*

calculated parameters over the interface. The test model and interface have been described previously.<sup>1</sup>

Prior to the current project, the work was performed in phases. First, the trips and control systems were modeled, including the previously existing analog feedwater control system, feedwater pump speed governor and feedpump turbine. The original trips and control systems were used to benchmark the model against plant data from various transients.

Next, the control systems in the model were altered to allow real time coupling and testing of the Foxboro digital RFWCS. An interface allowed display of important test parameters, initiation of all test transients from the "control panel" of the virtual display, control of plant power level and other operator selected parameters, automatic capture of test data, and communication of parameters between the digital control system, the display and the RELAP5 model. The interface also introduced noise into the signal to simulate an actual signal and allowed for on and off scale signal failures to test the new control system.

The third phase duplicated the control algorithms from the RFWCS within the LabVIEW interface and RELAP5 model to produce a stand-alone simulation of the plant and RFWCS. The new stand-alone model and interface were benchmarked against transients run during testing of the digital RFWCS. The LabVIEW interface, RELAP5 source code and TCP/IP communications program, were altered to accommodate communications between the stand alone model and interface.<sup>2</sup>

## **1.2 Current Project**

In the current project, Foxboro feedwater heater level controls were duplicated in the model and interface. The entire model was updated to RELAP5/MOD 3.1.1. The hydrodynamic components were expanded to include the shell sides of the feedwater heaters and associated piping, steam supplies and condensers. The interface was expanded to handle additional communications and operator actions. The simulated feedwater heater level controls were tuned and benchmarked. Benchmarking was performed against steady state data at various power levels from both the previous test phase models and heat balance data from the plant (Section 3).

---

<sup>1</sup> J. A. Mowrey, S. I. Abdel-Khalik, and K. W. Ross, "Use of a Real-Time RELAP5 Model to Dynamically Test a Digital Feedwater Control System for a Boiling Water Reactor," *Nucl. Technol.*, **111**, 283 (1995).

<sup>2</sup> Mowrey, J. A., Abdel-Khalik, S. I. and Boylan, P. R., "Dynamic Testing and Simulation of Digital Control Systems for Boiling Water Reactors," Proceedings of Nuclear Plant Instrumentation, Control and Human-Machine Interface Technologies, Vol. 1, pg. 97-104, May 1996.

After the model was benchmarked at the various power levels, the heater level controls were tuned for 100% power operation and a set of partial power steady-state initialization transients was run using step changes down to 75%, 50% and 30% power (Section 4). Power changes were made from the operator interface by controlling recirculation pump speeds and rod reactivity. RELAP5 restart plot files were saved for each power level simulation. Results of the power level simulations were compared with plant data for steady state operation. This ensured that the restart plot files were accurate starting points for partial power transient runs.

The purpose was to test possible failure modes of the heater level controls and their effects on the plant. This was done to identify potential weaknesses in the feedwater heater level controls, including software and instrumentation (Section 5).

Another purpose of this project was to change the reactor recirculation pump controls from the fluid coupled drive in the existing model to a variable speed drive, to enable the model to investigate this option as a possible plant upgrade. To accomplish this, the recirculation pump controls internal to the RELAP5 model were replaced in the 100% model (Section 6).

### **1.3    RELAP5 Code**

The RELAP5 computer code is an advanced, best-estimate thermal-hydraulic code, developed at Idaho National Engineering Laboratory (INEL) under the sponsorship of the US Nuclear Regulatory Commission. The RELAP5/MOD2 version was based on the non-equilibrium, two-fluid modeling of two-phase flow, and included extensive flow-regime-dependent interphase and fluid-wall transfer models. The code has generic models which can be used in simulating various system configurations. The version of the code used here, RELAP5/MOD3.1.1, is capable of simulating all postulated accidents in reactor coolant systems except those requiring multi-dimensional core neutronics calculations.<sup>1</sup>

RELAP5 has been extensively applied in the past for various simulation, validation, experimental data analysis, and plant/system analysis purposes. Recently, attention has been paid to accurate modeling of control systems and circuitry, as well as mathematical modeling of the performance of physical components in balance-of-plant systems.

---

<sup>1</sup> K. E. Carlson et al., *RELAP5/MOD3 Code Manual Volume I: Code Structure, System Models, and Solution Methods*, NUREG/CR-5535, EGG-2596, EG&G Idaho, Idaho National Engineering Laboratory, June 1990.

Appendix A contains the RELAP5 input deck for the base model with the new feedwater heater components. Appendix B contains the input deck for the base model with the new heaters plus the variable recirculation speed parameters.

#### **1.4 Results Summary**

This project successfully demonstrated the capability of providing an inexpensive MMI for plant simulation, and the capability of modeling complex balance of plant control systems in RELAP5. It also demonstrated a tool for examination of control schemes for potential weak spots. Finally, it allowed creation of a model of future plant modifications, such as variable speed drives for the recirculation pumps.

# 2

## STAND ALONE MODEL WITH FEEDWATER HEATER LEVEL CONTROLS

---

Changes were made to the RELAP5 model previously developed, to a program called "term" which communicated between the operator interface and RELAP5 model, and to the LabVIEW operator interface to incorporate feedwater level control algorithms, including upgrading the RELAP5 model and executable to MOD3.1.1. It was necessary to upgrade to MOD3.1.1 in order to run the expanded RELAP5 model. The changes to the RELAP5 source code and "term" program were similar to the changes made for the RFWCS stand alone version, developed previously.

Nodalization diagrams of the RELAP5 model are shown in Figures 2-1, 2-2, and 2-3.

### Changes to RELAP5 Model

Changes made to the RELAP5 model included changes to the model nodalization as well as changes to the control variables. All additions were made to the RFWCS stand alone version. The following subsections describe the changes made to the model.

Appendix A contains the complete RELAP5 input deck for the model. Alterations for the addition of the feedwater heater shell sides and the level controls are highlighted in bold type.

*Stand Alone Model with Feedwater Heater Level Controls*




Figure 2-1 RELAP5 Reactor Coolant System Nodalization




Figure 2-2 RELAP5 Low Pressure FW Heater Nodalization




Figure 2-3 RELAP5 High Pressure FW Heater Nodalization

### **Changes to Hydrodynamic Volumes**

In order to add the shell sides of the feedwater heaters, it was necessary to renumber several hydrodynamic volumes in the feed train. This also necessitated renumbering the volumes in trips and control variables where the renumbered volumes were referenced. The heat structures associated with the volumes were also renumbered; 1580 became 1520. The following table shows which volumes were renumbered.

Table 2-1 Changed Volume and Junction Numbers	
Original Number	Revised Number
510	502
520	505
530	506
540	508
550	510
560	511
580	520
600	525
640	535
680	545
721	560
722	561
723	562
730	570
740	571
750	572

Table 2-1 Changed Volume and Junction Numbers	
Original Number	Revised Number
735	575
745	576
755	577
790	595
736	580
737	581
746	582
747	583
756	584
757	585
840	557
850	558
860	559

The B and C train feedwater heaters' tube sides and piping were split into two single trains in this version. The prior models used a set of single and double heaters with single and double piping volumes on the tube side. This was done to minimize the number of volumes and junctions in the previous models to allow them to run in real time. Also, there was no need for heater controls in previous models. The following table shows which double (B/C) volumes and junctions were replaced with both a B and C train volume or junction.

Table 2-2  
Double Volumes and Junctions Replaced with Single  
Volumes and Junctions

Original Volume	Replacement Volume	Description
590	521, 522	Drain Coolers
610	526, 527	Pipe DC to Htr 5
630	531, 532	Htr B, C5 Tube Sides
650	536, 537	Pipe B, C5 to B, C4
670	541, 542	Htr B, C4 Tube Sides
690	546, 547	Pipe B, C4 to B, C3
710	551, 552	Htr B, C3 Tube Sides
780	591, 592	Htr B, C2 Tube Sides
800	596, 597	Pipe B, C2 to B, C1
820	601, 602	Htr B, C1 Tube Sides

Flow areas in the volumes or junctions for the single items were one half that of the deleted double unit. Also note that the double heater tube side single volumes were replaced with single pipe components, with multiple junctions and volumes. Formerly, there was no need for multiple tube volumes since heat transfer into the tube side was controlled by control variables. In the current model, the tube side receives heat through the tube walls from the added shell sides. In order to simulate this more accurately, additional tube side volumes were needed. The affected components include numbers 531, 532, 541, 542, 551, 552, 591, 592, 601 and 602 listed above in Table 2-2.

In order to support the splitting of the double feed train components into single components representing trains B and C, it was also necessary to add junctions to the branch volumes serving as headers for the three feed trains. The resulting B and C train junctions had one half the flow area as the previous model's double junction. The component numbers for the affected branches are: 515, the branch volume from the condensate booster pumps to the drain coolers, formerly numbered as 570; 555, the branch volume connecting the number 3 heaters to the Reactor Feed Pump inlets, formerly numbered as 720; 588, the branch volume from the Reactor Feed Pump outlets

to the number 2 heaters, formerly numbered as 760; and 605, the inlet branch for feed water into the reactor, formerly branch component 830 and single junction 715.

Note that the single heater tube side single volumes were also replaced with single pipe components, with multiple junctions and volumes. As with the double heaters in the previous model, there was no need for multiple tube volumes since heat transfer into the tube side was controlled by control variables. In the current model, the tube side receives heat through the tube walls from the added shell sides. In order to simulate this more accurately, additional tube side volumes were needed. The affected components include: RFW heater A5 tubes (now component 530, was formerly 620), RFW heater A4 tubes (now component 540, was formerly 660), RFW heater A3 tubes (now component 550, was formerly 700), RFW heater A2 tubes (now component 590, was formerly 770), and RFW heater A1 tubes (now component 600, was formerly 810).

In addition, junctions were added to component 610, representing miscellaneous junctions in the B and C feed trains. Formerly, the multiple junction component was numbered as 870, and contained sixteen miscellaneous junctions for the A and B/C double train. The new component contains twenty-four for the A, B and C trains.

The shell sides of the feedwater heaters were added as an independent hydrodynamic system by card 121. The following table shows the added hydrodynamic components and their descriptions. Figures 2-4 through 2-8 show this nodalization scheme.

Table 2-3  
RFW Heater Shell Side Components

Component	Description
701	RFW HTR A1 Steam Supply
702	RFW HTR A2 Steam Supply
703	RFW HTR A3 Steam Supply
704	RFW HTR A4 Steam Supply #1
705	RFW HTR A4 Steam Supply #2
706	RFW HTR A5 Steam Supply #1
707	RFW HTR A5 Steam Supply #2
708	Moisture Separator

Table 2-3 RFW Heater Shell Side Components	
<b>Component</b>	<b>Description</b>
709	Moisture Separator Drain to HTR A2
710	RFW HTR A1 Steam Supply Valve
711	RFW HTR A2 Steam Supply Valve
712	RFW HTR A3 Steam Supply Valve
713	RFW HTR A4 Steam Supply Valve
714	RFW HTR A4 Steam Supply Valve
715	RFW HTR A5 Steam Supply Valve
716	RFW HTR A5 Steam Supply Valve
720	RFW Heater A1 Steam Dome
721	RFW HTR A1 Shellside Middle Volumes
722	RFW HTR A1 Tubesheet Shellside
723	RFW Heater A1 Drain Piping
725	RFW HTR A1 Drain Valve
730	RFW Heater A2 Steam Dome
731	RFW HTR A2 Drain Junction Volume
732	RFW HTR A2 Shellside Middle Volumes
733	RFW Heater A2 Tubesheet Shellside
734	RFW Heater A2 Drain Piping
735	RFW HTR A2 Drain Valve
737	RFW HTR A2 Bypass Valve

Table 2-3 RFW Heater Shell Side Components	
<b>Component</b>	<b>Description</b>
738	RFW Bank 2 Bypass Drain Piping to Condenser
740	RFW Heater A3 Steam Dome
741	RFW HTR A3 Drain Junction Volume
742	RFW HTR A3 Shellside Middle & Lower Volumes
743	RFW Heater A3 Subcooling Zone
744	RFW Heater A3 Drain Piping
745	RFW HTR A3 Drain Valve
747	RFW HTR A3 Multiple Junctions
750	RFW HTR A4 (top of shell nearest tubesheet)
751	RFW Heater A4 (top of shell furthest from tubesheet)
752	RFW Heater A4 (bottom of shell furthest from tubesheet)
753	RFW Heater A4 Subcooling Zone
754	RFW Heater A4 Drain Piping
755	RFW HTR A4 Drain Valve
757	RFW HTR A4 Bypass Valve
758	RFW Bank 4 Bypass Drain Piping to Condenser
760	RFW Heater A5 Flash Tank
761	RFW Heater A5 Drain Piping

Table 2-3 RFW Heater Shell Side Components	
<b>Component</b>	<b>Description</b>
762	RFW HTR A5 (top of shell nearest tubesheet)
763	RFW Heater A5 (top of shell furthest from tubesheet)
764	RFW Heater A5 (bottom of shell furthest from tubesheet)
765	RFW Heater A5 (bottom of shell nearest tubesheet)
766	RFW Heater A5 Collector
767	RFW HTR A5 Drain Valve
768	RFW HTR A5 Bypass Valve
801	RFW HTR B1 Steam Supply
802	RFW HTR B2 Steam Supply
803	RFW HTR B3 Steam Supply
804	RFW HTR B4 Steam Supply #1
805	RFW HTR B4 Steam Supply #2
806	RFW HTR B5 Steam Supply #1
807	RFW HTR B5 Steam Supply #2
808	Moisture Separator
809	Moisture Separator Drain to HTR B2
810	RFW HTR B1 Steam Supply Valve
811	RFW HTR B2 Steam Supply Valve
812	RFW HTR B3 Steam Supply Valve
813	RFW HTR B4 Steam Supply Valve

Table 2-3 RFW Heater Shell Side Components	
<b>Component</b>	<b>Description</b>
814	RFW HTR B4 Steam Supply Valve
815	RFW HTR B5 Steam Supply Valve
816	RFW HTR B5 Steam Supply Valve
820	RFW Heater A1 Steam Dome
821	RFW HTR B1 Shellside Middle Volumes
822	RFW Heater B1 Tubesheet Shellside
823	RFW Heater B1 Drain Piping
825	RFW HTR B1 Drain Valve
830	RFW Heater A2 Steam Dome
831	RFW HTR B2 Drain Junction Volume
832	RFW HTR B2 Shellside Middle Volumes
833	RFW Heater B2 Tubesheet Shellside
834	RFW Heater B2 Drain Piping
835	RFW HTR B2 Drain Valve
837	RFW HTR B2 Bypass Valve
840	RFW Heater B3 Steam Dome
841	RFW HTR B3 Drain Junction Volume
842	RFW Heater B3 Shellside Middle & Lower Volumes
843	RFW Heater B3 Subcooling Zone
844	RFW Heater B3 Drain Piping

Table 2-3 RFW Heater Shell Side Components	
<b>Component</b>	<b>Description</b>
845	RFW HTR B3 Drain Valve
847	RFW HTR B3 Multiple Junctions
850	RFW Heater B4 (top of shell nearest tubesheet)
851	RFW Heater B4 (top of shell furthest from tubesheet)
852	RFW Heater B4 (bottom of shell furthest from tubesheet)
853	RFW Heater B4 Subcooling Zone
854	RFW Heater B4 Drain Piping
855	RFW HTR B4 Drain Valve
857	RFW HTR B4 Bypass Valve
860	RFW Heater B5 Flash Tank
861	RFW Heater B5 Drain Piping
862	RFW Heater B5 (top of shell nearest tubesheet)
863	RFW Heater B5 (top of shell furthest from tubesheet)
864	RFW Heater B5 (bottom of shell furthest from tubesheet)
865	RFW Heater B5 (bottom of shell nearest tubesheet)
866	RFW Heater B5 Collector
867	RFW HTR B5 Drain Valve
868	RFW HTR B5 Bypass Valve

Table 2-3  
RFW Heater Shell Side Components

<b>Component</b>	<b>Description</b>
901	RFW HTR C1 Steam Supply
902	RFW HTR C2 Steam Supply
903	RFW HTR C3 Steam Supply
904	RFW HTR C4 Steam Supply #1
905	RFW HTR C4 Steam Supply #2
906	RFW HTR C5 Steam Supply #1
907	RFW HTR C5 Steam Supply #2
908	Moisture Separator
909	Moisture Separator Drain to HTR C2
910	RFW Heater C1 Steam Supply Valve
911	RFW Heater C2 Steam Supply Valve
912	RFW Heater C3 Steam Supply Valve
913	RFW Heater C4 Steam Supply Valve
914	RFW Heater C4 Steam Supply Valve
915	RFW Heater C5 Steam Supply Valve
916	RFW Heater C5 Steam Supply Valve
920	RFW Heater C1 Steam Dome
921	RFW Heater C1 Shellside Middle Volumes
922	RFW Heater C1 Tubesheet Shellside
923	RFW Heater C1 Drain Piping
925	RFW HTR C1 Drain Valve

Table 2-3 RFW Heater Shell Side Components	
<b>Component</b>	<b>Description</b>
930	RFW Heater C2 Steam Dome
931	RFW HTR C2 Drain Junction Volume
932	RFW Heater C2 Shellside Middle Volumes
933	RFW Heater C2 Tubesheet Shellside
934	RFW Heater C2 Drain Piping
935	RFW HTR C2 Drain Valve
937	RFW HTR C2 Bypass Valve
940	RFW Heater C3 Steam Dome
941	RFW HTR C3 Drain Junction Volume
942	RFW Heater C3 Shellside Middle & Lower Volumes
943	RFW Heater C3 Subcooling Zone
944	RFW Heater C3 Drain Piping
945	RFW HTR C3 Drain Valve
947	RFW HTR C3 Multiple Junctions
950	RFW Heater C4 (top of shell nearest tubesheet)
951	RFW Heater C4 (top of shell furthest from tubesheet)
952	RFW Heater C4 (bottom of shell furthest from tubesheet)
953	RFW Heater C4 Subcooling Zone
954	RFW Heater C4 Drain Piping

Table 2-3  
RFW Heater Shell Side Components

<b>Component</b>	<b>Description</b>
955	RFW HTR C4 Drain Valve
957	RFW HTR C4 Bypass Valve
960	RFW Heater C5 Flash Tank
961	RFW Heater C5 Drain Piping
962	RFW Heater C5 (top of shell nearest tubesheet)
963	RFW Heater C5 (top of shell furthest from tubesheet)
964	RFW Heater C5 (bottom of shell furthest from tubesheet)
965	RFW Heater C5 (bottom of shell nearest tubesheet)
966	RFW Heater C5 Collector
967	RFW HTR C5 Drain Valve
968	RFW HTR C5 Bypass Valve
969	RFW Heater Sump Header
970	HTR Sump / Condenser
971	HTR Sump / Condenser

*Stand Alone Model with Feedwater Heater Level Controls*




Figure 2-4 RELAP5 Nodalization for Feedwater Heater A1




Figure 2-5 RELAP5 Nodalization for Feedwater Heater A2

*Stand Alone Model with Feedwater Heater Level Controls*




Figure 2-6 RELAP5 Nodalization for Feedwater Heater A3




Figure 2-7 RELAP5 Nodalization for Feedwater Heater A4




Figure 2-8 RELAP5 Nodalization for Feedwater Heater A5

### ***Changes to Heat Structures***

Formerly, feedwater heater tubes were modeled as cylindrical tubes with the inside surface in contact with the feed water, and the outside surface modeled as an adiabatic boundary. Heat was generated in the tube structure depending on the reactor power. Drain cooler heat transfer was also modeled in this way for both the A and combined B/C drain cooler. The drain coolers are still modeled in this way in the new RELAP5 input deck. The changes to the drain cooler A heat structures have already been discussed. The structures were renumbered using the same scheme as the hydrodynamic volumes. The drain cooler B/C tube heat structures were split into separate B and C structures. Also, the control variable which sets the source for the B and C drain coolers was changed to the same control variable as previously used for the A drain cooler.

For the feed water heaters themselves, the new heat structures were also renumbered exactly as the hydrodynamic components were. In addition, the number of axial elements in each heat structure were increased in the new input deck, and the adiabatic tube outer boundary was changed to a convective boundary connected to the shell side hydrodynamic volumes for all feed water heater tubes. The control variables which formerly set the source term were no longer used. The B/C double heat structures were split into B and C single heat structures. Finally, additional mesh points were added radially within the tube structures.

### ***Changes to Trips***

Most changes to trips were due to renumbering hydrodynamic components. Three trips, 632, 633 and 634 were added. These were the logical inversion of the feed pump trips. These trips were used to close the steam supply valves to the associated feed water heater shell sides when a feed pump was tripped. This is done solely to ease the RELAP5 calculations when a heater train is taken off line.

### ***Changes to General Tables***

Changes to general tables consisted of deletion of tables formerly used to determine the tube source term for feed water heaters. With the addition of shell side components, these tables were no longer needed.

### ***Changes to Control Variables***

Changes to the control variables included calculation of collapsed level within the shell side, lagging of the calculated value of level to simulate an actual level instrument which was written out to the LabVIEW interface, and "constant" control variables for heater drain and bypass valve positions. The "constant" control variables were then lagged to simulate actual normalized valve positions. The controllers were simulated within the LabVIEW interface; the controller outputs were then written to the "constant" valve positions. The following table lists these added control variables.

**Table 2-4**  
**Feed Water Heater Level Control Variables**

<b>Control Variable Number</b>	<b>Description</b>
305	HTR A1 Collapsed Liquid Level
306	HTR A1 Level to LabVIEW
323	A1 Instant Drain Vlv Demand
324	A1 Drain Vlv Position
330	HTR A2 Collapsed Liquid Level
331	HTR A2 Level to LabVIEW
348	A2 Instant Drain Vlv Demand
349	A2 Drain Vlv Position
354	A2 Instant Bypass Vlv Demand
355	A2 Bypass Vlv Position
360	HTR A3 Collapsed Liquid Level
361	HTR A3 Level to LabVIEW
378	A3 Instant Drain Vlv Demand
379	A3 Drain Vlv Position
380	HTR A4 Collapsed Liquid Level
381	HTR A4 Level to LabVIEW
398	A4 Instant Drain Vlv Demand
399	A4 Drain Vlv Position
404	A4 Instant Bypass Vlv Demand
405	A4 Bypass Vlv Position
410	HTR A5 Collapsed Liquid Level
411	HTR A5 Level to LabVIEW

Table 2-4  
Feed Water Heater Level Control Variables

<b>Control Variable Number</b>	<b>Description</b>
428	A5 Instant Drain Vlv Demand
429	A5 Drain Vlv Position
434	A5 Instant Bypass Vlv Demand
435	A5 Bypass Vlv Position
440	HTR B1 Collapsed Liquid Level
441	HTR B1 Level to LabVIEW
449	B1 Instant Drain Vlv Demand
450	B1 Drain Vlv Position
451	HTR B2 Collapsed Liquid Level
452	HTR B2 Level to LabVIEW
457	B2 Instant Drain Vlv Demand
458	B2 Drain Vlv Position
459	B2 Instant Bypass Vlv Demand
460	B2 Bypass Vlv Position
465	HTR B3 Collapsed Liquid Level
466	HTR B3 Level to LabVIEW
471	B3 Instant Drain Vlv Demand
472	B3 Drain Vlv Position
475	HTR B4 Collapsed Liquid Level
476	HTR B4 Level to LabVIEW
481	B4 Instant Drain Vlv Demand

Table 2-4  
Feed Water Heater Level Control Variables

<b>Control Variable Number</b>	<b>Description</b>
482	B4 Drain Vlv Position
483	B4 Instant Bypass Vlv Demand
484	B4 Bypass Vlv Position
486	HTR B5 Collapsed Liquid Level
487	HTR B5 Level to LabVIEW
492	B5 Instant Drain Vlv Demand
493	B5 Drain Vlv Position
494	B5 Instant Bypass Vlv Demand
495	B5 Bypass Vlv Position
940	HTR C1 Collapsed Liquid Level
941	HTR C1 Level to LabVIEW
949	C1 Instant Drain Vlv Demand
950	C1 Drain Vlv Position
951	HTR C2 Collapsed Liquid Level
952	HTR C2 Level to LabVIEW
957	C2 Instant Drain Vlv Demand
958	C2 Drain Vlv Position
959	C2 Instant Bypass Vlv Demand
960	C2 Bypass Vlv Position
965	HTR C3 Collapsed Liquid Level
966	HTR C3 Level to LabVIEW
971	C3 Instant Drain Vlv Demand

Table 2-4  
Feed Water Heater Level Control Variables

<b>Control Variable Number</b>	<b>Description</b>
972	C3 Drain Vlv Position
975	HTR C4 Collapsed Liquid Level
976	HTR C4 Level to LabVIEW
981	C4 Instant Drain Vlv Demand
982	C4 Drain Vlv Position
983	C4 Instant Bypass Vlv Demand
984	C4 Bypass Vlv Position
986	HTR C5 Collapsed Liquid Level
987	HTR C5 Level to LabVIEW
992	C5 Instant Drain Vlv Demand
993	C5 Drain Vlv Position
994	C5 Instant Bypass Vlv Demand
995	C5 Bypass Vlv Position

Many control variables were only changed by the renumbering of the components that they reference. These control variables are not discussed further.

Prior to the current model, heat transfer across the feedwater heater tubes was calculated in the control variables. The shell sides were not modeled. This scheme is still used for the drain coolers. The control variable used to calculate heat transfer in the “double line” drain cooler was number 826 in the previous model; this control variable was deleted in the current model.

For the feedwater heater power across the tubes, the control variables used to set the source term in the tube heat structures in the previous model were deleted (811 - 815, 821 - 825). Control variables were used to calculate the tube power for comparison with plant data; these variables did not set a source term, but only monitored tube power.

---

### *Stand Alone Model with Feedwater Heater Level Controls*

These variables include 811 - 815, and they are sums of the RELAP5 calculated heat fluxes in the heat structures.

The control variables simulating the Woodward governors were also altered. The error terms were moved to control variables 586, 587 and 588, and the error term multipliers were changed to 0.02. This value converts the speed input range (600 - 5600 RPM) to percent error. The error term was then lagged by 0.1 second in control variables 595, 596 and 597. This was done to more accurately simulate the Woodward 505 transfer function. Control variables 690, 691 and 692 were changed from error terms to differential terms in the governor transport equations. The integral time constants and proportional term gains were also changed to agree with the Woodward transport equation in control variables 696, 697, 698, 699, 700 and 701. Lagging of the outputs of the Woodward governor outputs was deleted in the new model; these control variables were 702, 703 and 704.

In the new model, changes were also made to the multipliers for control variables simulating the feedwater level controllers. It was discovered that errors were made in the original stand alone model simulating the proportional and integral terms for PID blocks within the Foxboro I/A System. Basically, the PID block automatically adds a gain or multiplicative factor representing the ratio between block output and input ranges to the proportional and integral terms. In this model, these errors were corrected in the multiplicative factors in control variables 654, 655, 661, 664, 668 and 671.

The control variables were also altered in the feedwater level control area to use returned level steam flow and feedwater flow from LabVIEW. This allowed the model to update feedwater level control variables each 0.2 second, and feedwater heater level control variables each 0.5 second. The variables returned from LabVIEW were only changes each 0.5 or 0.2 second.

Other changes to control variables included changing the feedwater controller output limits following a reactor scram from 58% to 63%.

### **Changes to “term” Program**

Term is a program written to allow communications between the LabVIEW program on the PC and the workstation via a TCP/IP protocol. The only changes to this program and the source code of RELAP5 were based on the changes to the RELAP5 control variables which were passed between the operator interface and model. The changes to the control variables have been previously described.

### **Changes to the LabVIEW Interface**

The front panel remained exactly the same for the feedwater heater level stand alone version as the previous stand alone version. The major changes to the LabVIEW

interface involved changes to control the timing of signals to the RELAP5 model and the addition of PI controller simulations within LabVIEW for the feedwater heater level control valves and bypass valves.

Timing of control signals became critical when the feedwater heater level algorithms were added. The previous LabVIEW interface had passed level, steam flow, pressure and feedwater flow signals to the RELAP5 model every 200 msec to discretize control signals for the feedwater flow controllers. Since the model ran in real-time, the LabVIEW interface was constructed to update values every 200 msec. Once the feedwater heater level controls were added, the model no longer could run in real-time. Also, the feedwater heater level controls updated every 500 msec.

Two timing sub-virtual instruments were created. One passed new values for feedwater flow control variables for each 200 msec of problem time. The other passed a string containing feedwater heater levels directly to another sub-virtual instrument which contained the PI controllers every 500 msec of problem time. From there, the same timing sub-virtual instrument returned the new controller output string to the main virtual instrument for passing to the RELAP5 model's drain and bypass valves. Figure 2-9 shows the control diagram for the feedwater heater level timing sub-virtual instrument when updating the controller output. In between updates, the sub-virtual instrument did not pass the level string and returned the string from the last update to the main virtual instrument.

PI controllers were created for the drain and bypass valves within the LabVIEW interface. Figure 2-10 shows one of the PI controllers for the drain and bypass valve. The Foxboro I/A system used a single PI controller to control both valves. The drain valve was directly positioned by controller output, the bypass valve began to open when the controller output exceeded 75%, and was fully open at 100% controller output. Building the PI controllers within LabVIEW had several advantages. First, it made tuning of control loops and updating of control schemes easier for the stand alone version. Also, initialization of the controller on start up was made much easier by inserting the initial value and setting the "Initi" boolean. The controller output was set to the initial value, and when the "Initi" boolean was reset, the controller would bumplessly transition to automatic control. This same feature also allowed placing the controller in manual and setting its output.

---

*Stand Alone Model with Feedwater Heater Level Controls*

Block Diagram




Figure 2-9 LabVIEW Feedwater Heater Level Timing Sub-Virtual Instrument

Block Diagram




Figure 2-10 LabVIEW Controller Logic for the FW Heater Drain and Bypass Valves



# 3

## BENCHMARKING RESULTS AT VARIOUS POWER LEVELS

---

This section displays the results of model initialization at various power levels compared with plant data and benchmarking runs. The model was initialized at four different power levels, and restart plot files were created at each steady-state power level.

### 100% Power Level

The results of the 100% steady state power model compared with plant data are compared in the table below.

Table 3-1 Steady State Comparisons at 100% Reactor Power			
Parameter	RELAP5	PLANT DATA	% ERR.
REACTOR POWER	101.45	100.00	1.45
CORE MASS FLOW (Mlbm/hr)	99.532	98.500 <sup>1</sup>	1.05
FEEDWATER MASS FLOW (Mlbm/hr)	13.538	13.37 <sup>2</sup>	1.26

---

<sup>1</sup> Screen prints from Integrated Computer System taken on site at Browns Ferry, Unit 2 on December 21, 1993.

<sup>2</sup> Tennessee Valley Authority, Heat Balance Diagrams, 47K1110-001 through 47K1110-018, Revision 0.

---

*Benchmarking Results at Various Power Levels*

Table 3-1 Steady State Comparisons at 100% Reactor Power			
Parameter	RELAP5	PLANT DATA	% ERR.
STEAMLINE MASS FLOW (Mlbm/hr)	13.54	13.349 <sup>2</sup>	1.43
STEAM DOME PRESSURE (psia)	1024.35	1020.0 <sup>1</sup>	0.43
DOWNCOMER LIQUID LEVEL (in)	32.95	33.0 <sup>3</sup>	-0.15
REACTOR FEEDPUMP SPEED (rpm)	4865.9	4848.5 <sup>1</sup>	0.36
CONDENSATE PUMP INLET TEMP (°F)	101.10	101.14 <sup>2</sup>	-
DRAIN COOLER OUTLET TEMP (°F)	130.34	130.20 <sup>2</sup>	-
HEATER #5 OUTLET TEMP (°F)	186.61	182.96 <sup>2</sup>	-
HEATER #4 OUTLET TEMP (°F)	244.23	239.37 <sup>2</sup>	-
HEATER #3 OUTLET TEMP (°F)	298.21	298.09 <sup>2</sup>	-
HEATER #2 OUTLET TEMP (°F)	330.81	330.63 <sup>2</sup>	-
CONDENSATE BOOSTER PUMP OUTLET PRESSURE (psia)	298.66	305 <sup>2</sup>	-2.08
INLET PRESS AT FEEDPUMPS (psia)	231.69	245 <sup>2</sup>	-5.43
OUTLET PRESS AT FEEDPUMPS (psia)	1104.7	1102.3 <sup>2</sup>	0.22
FEEDWATER TEMPERATURE (°F)	377.00	376.97 <sup>2</sup>	-
PRESSURE AT TCV (psia)	978.58	974.0 <sup>2</sup>	0.47

---

<sup>1</sup> Tennessee Valley Authority, RETRAN model "BE2RPT" for CY6, Browns Ferry.

## 75% Reactor Power

The results of the 75% steady state power model compared with plant data are compared in the table below.

Table 3-2 Steady State Comparisons at 75% Reactor Power			
PARAMETER	RELAP5	PLANT DATA	% ERR.
REACTOR POWER (%)	75.836	75.00	1.11
CORE MASS FLOW (Mlbm/hr)	62.845	61.5 <sup>1</sup>	2.19
FEEDWATER MASS FLOW (Mlbm/hr)	9.9204	9.6962 <sup>2</sup>	2.31
STEAMLINE MASS FLOW (Mlbm/hr)	9.8405	9.746 <sup>2</sup>	0.97
STEAM DOME PRESSURE (psia)	996.602	993 <sup>3</sup>	0.36
DOWNCOMER LIQUID LEVEL (in)	32.98	33.0 <sup>4</sup>	-0.01
REACTOR FEEDPUMP SPEED (rpm)	4297.7	4242.0 <sup>2</sup>	1.31
CONDENSATE PUMP INLET TEMP (°F)	101.10	101.14 <sup>2</sup>	-
DRAIN COOLER OUTLET TEMP (°F)	126.38	126.45 <sup>2</sup>	-
HEATER #5 OUTLET TEMP (°F)	175.97	172.54 <sup>2</sup>	-

---

<sup>1</sup> Mayfield, T., "Operating Instruction 2-OI-68, Reactor Recirculation System", Revision 33, Tennessee Valley Authority, Browns Ferry Nuclear Plant, July 26, 1993.

<sup>2</sup> Tennessee Valley Authority, Heat Balance Diagrams, 47K1110-001 through 47K1110-018, Revision 0.

<sup>3</sup> Screen prints from Integrated Computer System taken on site at Browns Ferry, Unit 2 on December 21, 1993.

<sup>4</sup> Tennessee Valley Authority, RETRAN model "BE2RPT" for CY6, Browns Ferry.

Table 3-2 Steady State Comparisons at 75% Reactor Power			
PARAMETER	RELAP5	PLANT DATA	% ERR.
HEATER #4 OUTLET TEMP (OF)	229.64	225.41 <sup>2</sup>	-
HEATER #3 OUTLET TEMP (OF)	281.63	280.75 <sup>2</sup>	-
HEATER #2 OUTLET TEMP (OF)	311.64	310.88 <sup>2</sup>	-
OUTLET PRESS AT FEEDPUMPS (psia)	1042.8	1049 <sup>3</sup>	-0.59
FEEDWATER TEMPERATURE ( F )	354.57	354.40 <sup>2</sup>	-
PRESSURE AT TCV (psia)	970.70	967.0 <sup>3</sup>	0.38

## 50% Reactor Power

The results of the 50% steady state power model compared with plant data are compared in the table below.

Table 3-3 Steady State Comparison at 50% Reactor Power			
PARAMETER	RELAP5	PLANT DATA	% ERR.
REACTOR POWER (%)	50.34	51.2 <sup>1</sup>	-1.67
CORE MASS FLOW (Mlbm/hr)	56.687	56.3 <sup>1</sup>	0.68
FEEDWATER MASS FLOW (Mlbm/hr)	6.3179	6.13 <sup>1</sup>	3.06
STEAMLINE MASS FLOW (Mlbm/hr)	6.3158	6.2 <sup>1</sup>	1.87

---

<sup>1</sup> Screen prints from Integrated Computer System taken on site at Browns Ferry, Unit 2 on December 21, 1993.

Table 3-3 Steady State Comparison at 50% Reactor Power			
PARAMETER	RELAP5	PLANT DATA	% ERR.
STEAM DOME PRESSURE (psia)	974.20	977.1 <sup>1</sup>	-0.30
DOWNCOMER LIQUID LEVEL (in)	32.94	33.0 <sup>1</sup>	-0.18
REACTOR FEEDPUMP SPEED (rpm)	3871	3950 <sup>2</sup>	-2.00
FEEDWATER TEMPERATURE (F)	329.76	317.5 <sup>1</sup>	-
CONDENSATE PUMP INLET TEMP (O_F)	101.10	101.10 <sup>3</sup>	-
DRAIN COOLER OUTLET TEMP (O_F)	117.84	119.2 <sup>4</sup>	-
HEATER #5 OUTLET TEMP (O_F)	161.33	157.3 <sup>4</sup>	-
HEATER #4 OUTLET TEMP (O_F)	210.79	207.0 <sup>4</sup>	-
HEATER #3 OUTLET TEMP (O_F)	261.00	258.8 <sup>4</sup>	-
HEATER #2 OUTLET TEMP (O_F)	289.03	286.8 <sup>4</sup>	-
PRESSURE AT TCV (psia)	962.59	967 <sup>1</sup>	-0.46
OUTLET PRESS AT FEEDPUMPS (psia)	991.45	1016 <sup>1</sup>	-2.41

---

<sup>1</sup> Tennessee Valley Authority, RETRAN model "BE2RPT" for CY6, Browns Ferry.

<sup>2</sup> Screen prints from Integrated Computer System taken on site at Browns Ferry, Unit 2 on December 21, 1993. This value taken at 55.8% reactor power.

<sup>3</sup> Tennessee Valley Authority, Heat Balance Diagrams, 47K1110-001 through 47K1110-018, Revision 0.

### 30% Reactor Power

The results of the 30% steady state power model compared with plant data are compared in the table below.

Table 3-4 Steady State Comparison at 30% Reactor Power			
PARAMETER	RELAP5	PLANT DATA	% ERR.
REACTOR POWER (%)	31.37	30.0	4.57
CORE MASS FLOW (Mlbm/hr)	38.30	37.9 <sup>1</sup>	1.05
FEEDWATER MASS FLOW (Mlbm/hr)	3.692	3.494 <sup>2</sup>	5.67
STEAMLINE MASS FLOW (Mlbm/hr)	3.701	3.544 <sup>2</sup>	4.43
DOWNCOMER LIQUID LEVEL (in)	32.85	33.0 <sup>3</sup>	-0.45
REACTOR FEEDPUMP SPEED (rpm)	3685.39	3830 <sup>2</sup>	-3.78
CONDENSATE PUMP INLET TEMP (°F)	101.10	101.10 <sup>2</sup>	-
DRAIN COOLER OUTLET TEMP (°F)	111.08	112.2 <sup>2</sup>	-
HEATER #5 OUTLET TEMP (°F)	144.86	132.4 <sup>2</sup>	-
HEATER #4 OUTLET TEMP (°F)	190.16	175.8 <sup>2</sup>	-
HEATER #3 OUTLET TEMP (°F)	195.17	221.3 <sup>2</sup>	-

---

<sup>1</sup> Mayfield, T., "Operating Instruction 2-OI-68, Reactor Recirculation System", Revision 33, Tennessee Valley Authority, Browns Ferry Nuclear Plant, July 26, 1993.

<sup>2</sup> Tennessee Valley Authority, Heat Balance Diagrams, 47K1110-001 through 47K1110-018, Revision 0.

<sup>3</sup> Tennessee Valley Authority, RETRAN model "BE2RPT" for CY6, Browns Ferry.

Table 3-4 Steady State Comparison at 30% Reactor Power			
PARAMETER	RELAP5	PLANT DATA	% ERR.
HEATER #2 OUTLET TEMP (°F)	249.87	245.7 <sup>2</sup>	-
FEEDWATER TEMPERATURE ( F)	262.45	280.90 <sup>2</sup>	-
PRESSURE AT TCV (psia)	956.74	965.0 <sup>2</sup>	-0.86

Some of the discrepancies at this power level can be accounted for due to the differences in power levels. Percentage differences at this level are more extreme due to the relatively large percentage effect of small changes at a lower power level. Also, the RELAP5 model does not include CRD flows into the vessel, therefore the feedwater system in the model maintains a higher flow than would actually be the case in the plant. This effect is negligible at high powers, but becomes more significant at lower power levels. The flow numbers are consistent with the higher 31.37% power level for the most part.



# 4

## MODEL BENCHMARK TRANSIENTS

---

This section describes benchmark transients run on the new stand alone model. The results were then compared with the transients run during the Dynamic Factory Acceptance Test (FAT) for the Browns Ferry digital Reactor Feedwater Control System. The results are presented below.

### Single Reactor Feedwater Pump Trip

The following figure shows the vessel level response to a trip of Reactor Feedwater Pump (RFP) C from 100% power. The data shown was taken from the dynamic FAT and the current stand alone (S.A.) model. The trips occur at 10 seconds.




Figure 4-1 Single RFP Trip, Reactor Level

---

### *Model Benchmark Transients*

As can be seen in Figure 4-1, the FAT transient exhibited a slightly deeper drop in level and less overshoot past the setpoint of 33 inches. The reason for this response is best understood as a consequence of the output range for the feedpump speed controls within the Foxboro I/A System. Originally, the output of the three and single element controllers within I/A was within 600 and 5400 RPM. The idea was to limit the potential for feedpump runout due to a controls failure. When the FAT transient was run, these limits were in use. Later, a series of control blocks were written in I/A to prevent runout while allowing a larger controller range, from 600 to 5600 RPM. The tuning parameters were not adjusted.

Since the PID block within I/A sets output based on tuning parameters and automatically adjusts for the ratio between block output and input ranges, the effective proportional and integral terms were increased by a factor of 1.042 for the same magnitude error. Since the error is a function of time, this would tend to increase the responsiveness of the operable feedpumps. For this transient, this would increase overshoot and cause overshoot to occur slightly earlier in the transient. Since this represents the system as delivered (as opposed to as tested in this transient, and most others), the current output range was used for these transients.

Figures 4-2 to 4-4 show how the feedpump speed response varies. Note that in both cases, the speeds peak at just below the top of the output ranges for the I/A System's speed controller. For the FAT, this was 5400 RPM; it was 5600 after the FAT and in the stand alone model.




Figure 4-2 Single RFP Trip, RFP A Speed




Figure 4-3 Single RFP Trip, RFP B Speed

Note also that the initial and final speeds for the pumps are slightly higher in the stand alone version, since it was initialized to a slightly higher power.

Figure 4-4 shows the coastdown of RFP C.




Figure 4-4 Single RFP Trip, RFP C Speed

---

### *Model Benchmark Transients*

Figure 4-5 shows the pressure transient following the RFP trip.




Figure 4-5 Single RFP Trip, Reactor Pressure

Figure 4-6 shows the total feed flow during the transients. As previously discussed, the higher operating feed pump speeds during the transient in the stand alone model result in higher feed flows.




Figure 4-6 Single RFP Trip, Total Feedwater Flow

---

#### *Model Benchmark Transients*

Figures 4-7 to 4-11 show the Feedwater Heater levels for the A train during the transient. There was no benchmark transients to compare this data to, so only the stand alone data is presented.




Figure 4-7 Single RFP Trip, Feed Heater A1




Figure 4-8 Single RFP Trip, Feed Heater A2




Figure 4-9 Single RFP Trip, Feed Heater A3




Figure 4-10 Single RFP Trip, Feed Heater A4




Figure 4-11 Single RFP Trip, Feed Heater A5 Level

The largest level transient is in the A3 heater (and B3 heater) due to the heater having only a drain valve and no bypass valve.

## Dual Reactor Recirculation Pump Runback

The following transient was a dual Reactor Recirculation Pump (RRP) runback from 100% power. Data from the stand alone model is again compared to data from the FAT.

Figure 4-12 shows the vessel level response to the transient. The secondary level peak above the 33 inch setpoint in the FAT transient was higher and lasted longer than the same transient from the stand alone model. This is again due to the faster response of the feedpumps in the stand alone model with the larger controller output range.




Figure 4-12 Dual RRP Runback, Reactor Level

Figure 4-13 shows the RFP A speed response. The stand alone speed starts out higher, and stays higher by about the same margin throughout the transient.




Figure 4-13 Dual RRP Runback, RFP A Speed

Figure 4-14 shows the total feed flows observed during this transient.




Figure 4-14 Dual RRP Runback, Total Feedwater Flow

---

#### *Model Benchmark Transients*

Figure 4-15 shows reactor pressure during the transient. Again, good agreement was obtained, with the stand alone version having a slightly higher pressure due to operating at a slightly higher power level.




Figure 4-15 Dual RRP Runback, Reactor Pressure

Figures 4-16 to 4-20 show the feedwater heater level responses to the transient. Again, only the stand alone results are presented.




Figure 4-16 Dual RRP Runback, FW Heater A1 Level




Figure 4-17 Dual RRP Runback, FW Heater A2 Level




Figure 4-18 Dual RRP Runback, FW Heater A3 Level




Figure 4-19 Dual RRP Runback, FW Heater A4 Level




Figure 4-20 Dual RRP Runback, FW Heater A5 Level

### Single Recirculation Pump Trip

A single Reactor Recirculation Pump (RRP) trip was also run for both the dynamic FAT and the stand alone model. Again, both trips began at 10 seconds.

The reactor level response is shown in Figure 4-21. Note that the secondary level peak in the FAT run was actually larger than the primary level peak. This discrepancy in the FAT results remains unexplained, and the stand alone model's run may be more believable. Also, note that the initial peaks agree very well.




Figure 4-21 Single RRP Trip, Reactor Level

Figure 4-22 shows the response of total feedwater flow to the trip. The FAT results show a faster decrease due to level swell, followed by a sudden, marked increase with a very small level error. This leads to a level overshoot greater in magnitude than the original level swell. This also remains unexplained. The stand alone results seem to be more reasonable.




Figure 4-22 Single RRP Trip, Total Feedwater Flow

The pressure response is shown in Figure 4-23.




Figure 4-23 Single RRP Trip, Reactor Pressure

The responses of RFP speed (Figure 4-24) show the same results as discussed for the total feedwater flow.




Figure 4-24 Single RRP Trip, RFP A Speed

---

#### *Model Benchmark Transients*

Figures 4-25 to 4-29 show the transient responses of the feedwater heater levels in the stand alone model.




Figure 4-25 Single RRP Trip, FW Heater A1 Level




Figure 4-26 Single RRP Trip, FW Heater A2 Level




Figure 4-27 Single RRP Trip, FW Heater A3 Level




Figure 4-28 Single RRP Trip, FW Heater A4 Level




Figure 4-29 Single RRP Trip, FW Heater A5 Level

### Single Condensate Booster Pump Trip

Figures 4-30 to 4-33 represent the FAT and stand alone model response to a single Condensate Booster Pump (CBP) trip. In both transients, CBP A was tripped off at 10 seconds problem time. Again, the stand alone model exhibits more responsiveness, probably due to the increased output range of the Foxboro I/A controller.




Figure 4-30 Single CBP Trip, Reactor Level




Figure 4-31 Single CBP Trip, Total Feedwater Flow




Figure 4-32 Single CBP Trip, Reactor Pressure




Figure 4-33 Single CBP Trip, RFP A Speed

There was very little change in feedwater heater level, so they are not plotted in this report

# 5

## TRANSIENTS AND FAILURE ANALYSIS

---

After completion of the benchmark transients, the model was subjected to a series of transients designed to determine possible improvements to the control system and the effects of changes in model parameters. For instance, the effects of response times of the level instruments in the heaters was examined.

### **Effect of Heater Level Instrument Time Constants**

In this transient, the effect of the level instrument time constants was examined. First, a change in heater level setpoint was made in the baseline model. All heater level instruments were assumed to have a time constant of 0.05 second in the baseline model. Then, the heater level instruments' time constants were changed to 0.1 second, and the level setpoint change was run again. The results were then compared.

As shown in the figure below, there was very little effect on doubling the lag time constant for the simulated level instrument for Feedwater Heater A1. In both cases, at approximately 10 seconds, the level setpoint was changed from 16 to 13 inches. At about 160 seconds, the level setpoint was returned to 16 inches. A slight increase in overshoot was observed in the long lag time run.

The level instrument with a lag time constant of 0.05 second is labeled as "fast lvl" in the figure; the run using a lag time constant of 0.1 second is labeled as "slow lvl".




Figure 5-1 A1 Feedwater Heater Level for Setpoint Changes

### **Effect of Heater Drain and Bypass Valve Time Constants**

In this transient, both the level instrument and the heater valve time constants were doubled from 0.05 to 0.1 second. The responses to level setpoint changes were then compared.

The figure below shows the effect of doubling both the heater valve and level instrument time constants on level upsets. In both cases, at approximately 10 seconds, the level setpoint was changed from 16 to 13 inches. At about 160 seconds, the level setpoint was returned to 16 inches. A slight increase in overshoot was observed in the run with longer lag times.

The level instrument with a lag time constant of 0.05 second is labeled as "fast lvl" in the figure; the run using a lag time constant of 0.1 second is labeled as "slow lvl".

These results show that as long as the instrument and valve response time constants are small compared with the sample time (in this case, controller update times were 0.5 second), they have very little effect. Very similar results were observed with valve lag

time constants equal to 0.2 second. If the instrument time constants become larger than the sample time, a much larger effect would be observed.




Figure 5-2. A1 Feedwater Heater Level for Setpoint Changes

### **Effect of Inadvertently Placing Level Controllers in Manual**

In this case, placing a heater 3 level controller in manual and leaving it in this position was simulated. A single feedpump trip in another train was then simulated to determine the effects both on heater levels and the overall plant response. These results were then compared with the single RFP trip results from Section 4.

In order to test this effect, the A3 heater controller was placed in manual during steady state operations at 100% power. Level in the A3 heater was steady at 18 inches. This simulated placing a controller in manual at the last good automatic output, followed by a feedwater pump trip. At 10 seconds, the A3 controller was placed in manual by placing its MAN/AUTO button in MAN. The output was maintained at the last automatic value, freezing the A3 drain valve. The B RFP was then immediately tripped. The transient was allowed to proceed without interference from there. Figure 5-3 shows the results for reactor level.




Figure 5-3 Single RFP Trip, Reactor Level Transients

As the figure shows, there is very little effect on reactor level. In fact, there was little effect on any plant parameters other than feedwater heater levels. The A3 heater emptied within 78 seconds of pump trip, as shown in Figure 5-4. Again, the feedpump trip took place at 10 seconds.




Figure 5-4 Single RFP Trip, Htr A3 Level, Drain in Manual

It should be noted that TVA has used level switches in the past to isolate a train of heaters on high level in a heater. At present, these switches have not been re-connected in the new control system. If used, placing a controller in manual and inadvertently leaving it there prior to a transient which causes heater level to increase could lead to isolation of a feed train. This would increase the difficulty of recovering from the transient.

### Effect of Power Level

A setpoint change for heater A1 from 16 to 13 inches was performed at 100% power and at 50% power. All three trains were in operation at both power levels. Once level steadied out, the setpoint was once again changed to 16 inches.

Response of A1 heater level to these changes at 100% power are shown in Figure 5-1 above. Response time is defined as the time from setpoint change to level reaching 10% of the difference between initial and setpoint levels. Rise time is defined as the time level reaches 10% to 90%. Overshoot is the distance level overshoots the new setpoint. At 100% power, for a setpoint change from 16 to 13 inches, rise time is about 6 seconds;

this represents the time from setpoint change to level < 15.9 inches, because the transient began with level equal to 16.28 inches. The rise time was about 24 seconds. Overshoot was 1.67 inches to a level of 11.33 inches. The secondary overshoot was 0.54 inches at 13.54 inches. This meant that damping was  $0.54/3.28$  or 0.165; this is better than quarter wave damping which is usually considered acceptable.

On the increase in setpoint transient, the setpoint was changed back to 16 inches at a problem time of 162 seconds and a level of 13.30 inches. The “response time” was based on an increase to 13.57 inches or more. Response time was 2.5 seconds. Rise time up to 15.73 inches was 21 seconds. Overshoot was 1.04 inches, up to 17.04 inches. The secondary valley was 15.54 inches, or 0.46 inches below setpoint. This resulted in damping equal to  $0.46/2.7$  or 0.17.

The same transient was run at 50% power, as shown in Figure 5.5 below.




Figure 5-5 Heater A1 Setpoint Changes at 50% Power

When the level setpoint was changed from 16 to 13 inches at 10 seconds problem time, level was equal to 15.98 inches. Response time to a level of 15.68 was 1.5 seconds. Rise time was 15.5 seconds. Overshoot was 1.12 inches. The secondary peak was at a level of 13.23, or 0.23 inch. Damping was therefore  $0.23/2.98$  or 0.077.

On the subsequent change to a 16 inch setpoint, the transient began at 104 seconds problem time with level equal to 13.21 inches. Response time to 13.49 inches was 2 seconds. Rise time was 12 seconds. Overshoot was 0.93 inch, with a secondary valley at 15.79 inches. The damping was therefore equal to  $0.21/2.79$  or 0.075.

Obviously, the response to the A1 tuning parameters was much better at 50% power level. Based on this response, the 100% tuning parameters might be changed in order to maximize transient response at 100% power. This would mean setting up different tuning parameters based on power level. Power measurement is available on another Foxboro I/A system controlling vessel level. Interconnection of the two systems via the Foxboro node bus is possible. This would allow use of power or feed flow dependent tuning parameters for heater controllers.

To demonstrate the effect of tuning parameters on overshoot, the gain was increased and reset time was changed to 22.7 seconds from 17.9 seconds. Note that these parameters do not include the ratio between input and output ranges; they are normalized to 0 to 100%. The following figure shows the results. Generally, the response and rise times increased, while the overshoot decreased.




Figure 5-6 Heater A1 Level Responses to Setpoint Changes, Increased Gain and Reset Time

# 6

## RECIRCULATION PUMP CONTROLS CHANGES

---

The recirculation pump controls in RELAP5 were rewritten to simulate variable speed motors. This will replace the oil vortex fluid couplings currently used in the Browns Ferry plant. The variable speed motor characteristics were not used in the test cases presented in Sections 3, 4, and 5.

### Changes to Control Variables

Except the speed demand signal from the LabVIEW interface, all of the recirculation pump controls are simulated within RELAP5 by the use of control variables. Therefore, the change to variable speed drives was simulated entirely within RELAP5. The following changes were made to the control variables.

Control variables were deleted starting with those which had simulated the linearization of controller output to those which covered the recirculation pump generator speed based on oil vortex coupling. In addition, those control variables covering the drive motor speed were deleted.

In their place, generator speeds were directly coupled to controller outputs. The remainder of the control variables which determined pump speeds were left the same.

The following table lists those control variables which were deleted.

Table 6-1 Deleted Recirculation Pump Control Variables	
Number	Description
222	Recirc Pump A Speed Controller Linearization
223	Recirc Pump B Speed Controller Linearization
224	Recirc Pump A Scoop Tube Natural Frequency
225	Recirc Pump B Scoop Tube Natural Frequency
226	Delay Spd Controller Function Generator, A

Table 6-1 Deleted Recirculation Pump Control Variables	
<b>Number</b>	<b>Description</b>
227	Delay Spd Controller Function Generator, B
228	Scoop Tube Actuator A Position Error
229	Scoop Tube Actuator B Position Error
230	Natural Freq **2 times Scoop Tube A Position Error
231	Natural Freq **2 times Scoop Tube B Position Error
232	Actuator Recirc Pump A Term 1
233	Actuator Recirc Pump B Term 1
234	Actuator Recirc Pump A Term 2
235	Actuator Recirc Pump B Term 2
236	Actuator Recirc Pump A Term 3
237	Actuator Recirc Pump B Term 3
238	Recirc Pump A Coupler Position
239	Recirc Pump B Coupler Position
240	Recirc Pump A Coupler Slip
241	Recirc Pump B Coupler Slip
242	Recirc Pump A Empirical Coupler Torque Term 1
243	Recirc Pump B Empirical Coupler Torque Term 1
244	Recirc Pump A Coupler Torque
245	Recirc Pump B Coupler Torque
246	Recirc Pump A Motor Power
247	Recirc Pump B Motor Power
248	Recirc Pump A Generator Torque

Table 6-1 Deleted Recirculation Pump Control Variables	
Number	Description
249	Recirc Pump B Generator Torque
250	Recirc Pump A Generator Delta Torque
251	Recirc Pump B Generator Delta Torque
270	Recirc DM % Synchronous Spd
271	Recirc DM % Synchronous Spd
272	Recirc DM Torque
273	Recirc DM Torque
274	Recirc DM Speed Ratio
275	Recirc DM Speed Ratio
276	Recirc DM Coupler Input Torque
277	Recirc DM Coupler Input Torque
278	Recirc DM Torque Difference
279	Recirc DM Torque Difference
280	Recirc DM Speed
281	Recirc DM Speed

The terms developing the generator speed based on a torque balance between the pump and oil vortex which powered the generator are among those deleted. The terms for the drive motor for the vortex were also deleted. Control variables 252 and 253 were formerly the generator speed integrals based on torque imbalance. They have been converted to generator speeds expressed as first order lags of speed controller variables converted from 0 to 100% to 0 to 1800 RPM.

Appendix B contains the new model listing for the RELAP5 model with variable speed recirculation pump controls.



# A

## RELAP5 MODEL INPUT DECK WITH NEW FEEDWATER HEATER SYSTEM

---

```
= brown's ferry relap5 plant model
* Full implementation of 3-train FW heaters
*
*card prob type transnt/stdy-st
*0000100 new stdy-st
0000100 new transnt
*0000100 restart transnt
*
*card inp-chk/run
0000101 run
*0000101 unp-chk
*
*card input units output units
0000102 british british
*103 3
*
* restart file
*0000104 none *remove asterisk at beginning
*
*card reference elev fluid name
0000120 100010000 8.750 h2o primary
0000121 960030000 597.020833 h2o 'FW-HTRS'
*
*
*-----
* time step control cards
*-----
*card end min max cntrl minor major restrt
0000201 0.10 1.e-6 0.025 00003 1000 2000 5000
0000201 500. 1.e-6 6.25e-3 00003 9000 14000 14000
*0000202 250. 1.e-6 0.025 00003 1000 2000 5000
*0000203 350. 1.e-6 0.025 00003 50 4000 4000 *remove
*
*-----
```

\* minor edits  
\*-----  
\*  
\*0000301 cntrlvar 675 \*stand alone  
\*0000301 cntrlvar 646 \*labview  
\*0000302 cntrlvar 650  
\*0000303 cntrlvar 689  
\*0000305 mflowj 610012200 \*HTR-A1 Feedwater flow (lb/sec)  
\*0000306 tempf 605010000 \*HTR-A1 RFW outlet temperature  
\*0000310 cntrlvar 0306 \*HTR-A1 level  
\*0000311 cntrlvar 0324 \*HTR-A1 drain valve position  
\*0000312 cntrlvar 0811 \*HTR-A1 power  
\*  
\*0000320 mflowj 588010000 \*HTR-A2 Feedwater flow (lb/sec)  
\*0000321 tempf 595010000 \*HTR-A2 RFW outlet temperature  
\*0000322 cntrlvar 0331 \*HTR-A2 level  
\*0000323 cntrlvar 0349 \*HTR-A2 drain valve position  
\*0000324 cntrlvar 0812 \*HTR-A2 power  
\*  
\*0000330 mflowj 550010000 \*HTR-A3 Feedwater flow (lb/sec)  
\*0000331 tempf 555010000 \*HTR-A3 RFW outlet temperature  
\*0000332 cntrlvar 0361 \*HTR-A3 level  
\*0000333 cntrlvar 0379 \*HTR-A3 drain valve position  
\*0000334 cntrlvar 0813 \*HTR-A3 power  
\*  
\*0000335 mflowj 540010000 \*HTR-A4 Feedwater flow (lb/sec)  
\*0000336 tempf 545010000 \*HTR-A4 RFW outlet temperature  
\*0000337 cntrlvar 0381 \*HTR-A4 level  
\*0000338 cntrlvar 0399 \*HTR-A4 drain valve position  
\*0000339 cntrlvar 0814 \*HTR-A4 power  
\*  
\*0000340 mflowj 530010000 \*HTR-A5 Feedwater flow (lb/sec)  
\*0000341 tempf 535010000 \*HTR-A5 RFW outlet temperature  
\*0000342 cntrlvar 0410 \*HTR-A5 level  
\*0000343 cntrlvar 0411 \*HTR-A5 level lagged  
\*0000344 cntrlvar 0429 \*HTR-A5 drain valve position  
\*0000345 cntrlvar 0815 \*HTR-A5 power  
\*  
\*-----  
\* variable trip cards  
\*-----  
\*  
\* vessel level trips  
0000401 cntrlvar 2 le null 0 -1.2200e+02 n -1.0

0000402 cntrlvar 2 le null 0 -4.5000e+01 n -1.0  
0000403 cntrlvar 6 le null 0 1.1200e+01 n -1.0  
0000404 cntrlvar 7 le null 0 2.7000e+01 n -1.0  
0000405 cntrlvar 6 ge null 0 5.1000e+01 n -1.0  
0000406 cntrlvar 6 ge null 0 5.5000e+01 l -1.0  
\* ref. 55  
\*  
\* main turbine trips  
0000407 cntrlvar 115 ge null 0 1.0000e-01 l -1.0  
\*  
\* always true trip for tmdpjuns  
0000408 time 0 ge null 0 .0000e+00 l .0  
\*  
\* always false for msiv open trip  
0000409 time 0 ge null 0 1.0000e+06 l -1.0  
\*  
\* msiv fast closure trips (all valves)  
0000411 cntrlvar 500 le null 0 8.5770e+02 l -1.0  
\* ref. 351, 358  
\*  
\* msiv single valve fast closure  
0000415 cntrlvar 116 ge null 0 1.0000e-01 l -1.0  
\*  
\* msiv single valve fast closure for dual msiv trip  
0000416 cntrlvar 117 ge null 0 1.0000e-01 l -1.0  
\*  
\* 30% permissive  
0000417 mflowj 430000000 ge null 0 1.1151e+03 n .0  
\* ref. 349  
\*  
\* recirc pump trips (both)  
0000420 time 0 ge timeof 402 1.7500e-01 l -1.0  
0000421 cntrlvar 90 ge null 0 1.1327e+03 n -1.0  
0000422 time 0 ge timeof 421 1.3500e-01 l -1.0  
0000423 cntrlvar 114 ge null 0 1.0000e-01 l -1.0  
0000424 time 0 ge timeof 640 1.6500e-01 l -1.0  
\* time for trip 424 based on 0.03 sec to tsv close setpt and 0.135 sec delay  
\* for recirc pump trip  
\*  
\* recirc pump a trip (single)  
0000425 cntrlvar 113 ge null 0 1.0000e-01 l -1.0  
\*  
\* 28% recirc pump runbacks (both)  
0000427 mflowj 605040000 lt null 0 7.4340e+02 n -1.0

0000430 time 0 ge timeof 427 1.5000e+01 n -1.0  
\*  
\* RRP a 28% runback  
0000431 cntrlvar 118 ge null 0 1.0000e-01 n -1.0  
\*  
\* RRP b 28% runback  
0000432 cntrlvar 119 ge null 0 1.0000e-01 n -1.0  
\*  
\* RRP a seizure  
0000433 cntrlvar 120 ge null 0 1.0000e-01 l -1.0  
\*  
\* 75% recirc runback conditions  
0000434 mflowj 570020000 lt null 0 2.4780e+02 n -1.0  
0000435 mflowj 571020000 lt null 0 2.4780e+02 n -1.0  
0000436 mflowj 572020000 lt null 0 2.4780e+02 n -1.0  
\*  
\* feedwater single pump manual trips  
0000437 cntrlvar 104 le null 0 1.0000e-01 n -1.0  
0000438 cntrlvar 105 le null 0 1.0000e-01 n -1.0  
0000439 cntrlvar 106 le null 0 1.0000e-01 n -1.0  
\*  
\* manual hpci initiation  
0000440 cntrlvar 121 ge null 0 1.0000e-01 l -1.0  
\*  
\*manual RCIC initiation  
0000442 cntrlvar 122 ge null 0 1.0000e-01 l -1.0  
\*  
\* scram variable trips  
0000445 time 0 ge timeof 403 7.0000e-02 l -1.0  
0000446 cntrlvar 90 ge null 0 1.0577e+03 n -1.0  
0000447 time 0 ge timeof 605 4.5000e-01 l -1.0  
\* trip 447 assumes 4 sec msiv closure on trip, ref. 351 states 3 - 5 seconds  
0000448 cntrlvar 123 ge null 0 1.0000e-01 l -1.0  
0000449 time 0 ge timeof 640 8.0000e-02 l -1.0  
0000450 cntrlvar 14 ge null 0 1.1800e+02 l -1.0  
0000451 time 0 ge timeof 450 9.0000e-02 l -1.0  
0000452 time 0 ge timeof 446 7.0000e-02 l -1.0  
\* time delays on scram, except manual scram, include 0.05 sec time delay for  
\* scram solenoid deenergization per ref. 349  
\*  
\* srv setpoints  
0000455 p 400010000 ge null 0 1.1197e+03 n -1.0  
0000456 p 400010000 ge null 0 1.1297e+03 n -1.0  
0000457 p 400010000 le null 0 1.0860e+03 n .0

0000458 p 400010000 le null 0 1.0960e+03 n .0  
\*  
\* condensate pump trips  
0000460 cntrlvar 100 le null 0 1.0000e-01 n -1.0  
0000461 cntrlvar 101 le null 0 1.0000e-01 n -1.0  
\*  
\* condensate booster pump trips  
0000465 cntrlvar 102 le null 0 1.0000e-01 n -1.0  
0000466 cntrlvar 103 le null 0 1.0000e-01 n -1.0  
\*  
\* small loca  
0000468 cntrlvar 124 ge null 0 1.0000e-01 1 -1.0  
\*  
\* single element, feedwater pump control trips  
0000470 cntrlvar 646 ge null 0 9.0000e-01 n -1.0  
\* use 1st line with Labview, next line without Labview  
0000471 cntrlvar 631 lt null 0 2.6762e+00 n -1.0 \* steam flow lt 20%  
\*0000471 cntrlvar 630 lt null 0 2.6762e+00 n -1.0 \* steam flow lt 20%  
\*  
\* trips to open minimum recirc valves in rfp trains  
0000475 mflowj 570020000 le null 0 1.6667e+02 n -1.0 \* ref. 55  
0000476 mflowj 571020000 le null 0 1.6667e+02 n -1.0 \* ref. 55  
0000477 mflowj 572020000 le null 0 1.6667e+02 n -1.0 \* ref. 55  
\*  
\* trips to close minimum recirc valves in rfp trains  
0000478 mflowj 570020000 ge null 0 3.4444e+02 n .0 \* ref. 55  
0000479 mflowj 571020000 ge null 0 3.4444e+02 n .0 \* ref. 55  
0000480 mflowj 572020000 ge null 0 3.4444e+02 n .0 \* ref. 55  
\*  
\* runback reset trip  
0000490 cntrlvar 125 ge null 0 .9000e+00 n -1.0 \* when true, resets  
\*  
\* additional pump trips  
0000501 time 0 le timeof 614 .0000e+00 n .0  
0000502 time 0 le timeof 612 .0000e+00 n .0  
0000506 time 0 le timeof 460 .0000e+00 n .0  
0000507 time 0 le timeof 461 .0000e+00 n .0  
0000508 time 0 le timeof 465 .0000e+00 n .0  
0000509 time 0 le timeof 466 .0000e+00 n .0  
\*  
\* feed pump speed trips  
0000510 pmpvel 570 lt null 0 500. n  
0000511 pmpvel 571 lt null 0 500. n  
0000512 pmpvel 572 lt null 0 500. n

\*

\* scram pump selection criteria

0000515 cntrlvar 7 le null 0 1.1000e+01 n -1.0 \* set scram response

0000516 time 0 le timeof 649 6.0000e+01 n -1.0 \* set scram response

0000517 cntrlvar 7 gt cntrlvar 108 0.8 n -1.0 \* reset scram response

0000518 time 0 gt timeof 675 300. 1 -1.0 \* reset scram response

\*

0000520 cntrlvar 675 gt null 0 63. n -1.0 \*scram resp.

\*

\*-----

\* logic trip cards

\*-----

\*

\* main turbine trip

0000601 407 or 406 1 -1.0

\*

\* msiv fast closure (all vlvs)

0000605 401 or 411 1 -1.0

\*

\* recirc pumps trip (both)

0000610 420 or 422 1 -1.0

0000611 424 or 423 1 -1.0

0000612 610 or 611 1 -1.0

\*

\* recirc pump a trip

0000614 612 or 425 1 -1.0

\*

\* fw pump trips

0000618 437 or 406 n -1.0

0000619 438 or 406 n -1.0

0000620 439 or 406 n -1.0

\*

\* 28% recirc pump runback, pump a

0000621 431 or 430 n -1.0

\*

\* 28% recirc pump runback, pump b

0000622 432 or 430 n -1.0

\*

\* 75% recirc pump runback

0000623 435 or 434 n -1.0

0000624 623 or 436 n -1.0

0000625 624 and 404 n -1.0

\*

\* hpci initiation

0000629 440 or 402 n -1.0  
0000630 631 or 629 n -1.0  
0000631 630 and -405 n -1.0

\*

\* inverse fwp trips for shell side ms tmdpjn's

632 -618 or -618 n -1.0  
633 -619 or -619 n -1.0  
634 -620 or -620 n -1.0

\*

\* rcic initiation

0000635 402 or 442 n -1.0  
0000636 637 or 635 n -1.0  
0000637 636 and -405 n -1.0

\*

\* turbine stop valve closure and ge 30% flow

0000640 601 and 417 l -1.0

\*

\* reactor scram

0000645 445 or 447 l -1.0  
0000646 448 or 449 l -1.0  
0000647 451 or 452 l -1.0  
0000648 645 or 646 l -1.0  
0000649 647 or 648 l -1.0

\*

\* srv grp 1 lifted

0000655 656 or 455 n -1.0  
0000656 655 and -457 n -1.0

\*

\* srv grp 2 lifted

0000660 661 or 456 n -1.0  
0000661 660 and -458 n -1.0

\*

\* msiv single closure indication

0000665 415 or 605 l -1.0 \* single closure, ok

\*

\* msiv single closure for dual msiv trip w/ trip 665

0000666 416 or 605 l -1.0 \* single closure for dual trip, ok

\*

\* single element feed pump control

0000671 470 or 471 n -1.0

\*

\* feed pump scram response

0000675 515 and 516 l -1.0 \* starts scram response

0000676 517 or 518 n -1.0 \* resets response, allowing pump restoration

0000677 675 and -676 n -1.0 \* initially sets max pump speeds, all pumps

0000678 675 and 676 l -1.0 \* reset response in past

0000679 677 and -678 n -1.0 \* imposes max pump speeds

\*

\* pump b response to scram

0000681 675 and -512 l -1.0 \* initially drive b to 600 rpm

\*

\* pump a response to scram

0000682 -512 or -511 n 0.0 \* true if pmp b or c >500 rpm

0000684 682 and 675 l -1.0 \* initially drives pmp a to 600 rpm

\*

\* additional runback trips to incorporate new reset button

\* 28% runback trips, pump a

0000685 621 or 686 n 0.0 \* used to init runback

0000686 685 and -490 n -1.0

\* 28% runback trips, pump b

0000687 622 or 688 n 0.0 \* used to init runback

0000688 687 and -490 n -1.0

\*\* 75 % runback trips

0000689 625 or 690 n 0.0 \* used to init runback

0000690 689 and -490 n -1.0

\*

0000691 510 or 684 n -1.0

0000692 511 or 681 n -1.0

\*

\*-----

\* control system general tables

\*-----

\*

\* recirc pmp speed controller function gen output (%) vs. spd controller outpt

\*----- ref. 349

20222000 reac-t

20222001 0. 0.

20222002 58.3 25.

20222003 84.2 50.

20222004 91.8367 69.64874

20222005 95.46 100.

20222006 97.04 160.

\*

\* recirc coupler torque first term vs. coupler slip, ref. 349

\*-----

20224200 reac-t

20224201 0. 0.

20224202 4.1667e-2 2.0e-4

20224203 8.3333e-2 4.0046e-4

20224204 1.25e-1 6.0234e-4

20224205 2.0833e-1 1.0181e-3

20224206 2.5e-1 1.2375e-3

20224207 3.3333e-1 1.7185e-3

20224208 0.5 3.0e-3

20224209 0.75 6.6375e-3

20224210 .97982 1.3551e-2

\*

\* "normalized" recirc pump motor torque vs. % synchronous speed, ref. 349

\*-----

20225400 reac-t

20225401 0. 0.8

20225402 40. 0.9

20225403 80. 1.6

20225404 95.6 2.2

20225405 98.0 1.0

20225406 100. 0.

20225407 102. -1.

20225408 104.4 -2.2

20225409 120. -1.6

20225410 160. -0.9

20225411 200. -0.8

\*

\* recirc pump motor torque multiplier vs generator rpm

\*-----

20225800 reac-t

20225801 0. 0.

20225802 501.83 0.4015

20225803 607.11 0.5554

20225804 825. 1.0

\*

\* normalized load torque vs. % main turbine speed, ref. 349

\*-----

20230000 reac-t

20230001 1. -3.

20230002 94. -2.

20230003 96. -1.

20230004 98. 0.

20230005 100. 1.

20230006 102. 2.

20230007 199. 3.

\*

\* turbine control vlv linearization (function generator), ref. 349 and 17

\*-----

20252000 reac-t

20252001 0.0 0.0  
20252002 51. 20.  
20252003 91. 40.  
20252004 100. 52.2  
20252005 102. 60.  
20252006 111. 100.

\*

\* turbine control valve position multiplier vs. time since turbine trip

\*-----

20252700 reac-t

20252701 0.0 1.0  
20252702 0.1 0.0

\*

\* turbine normalized steam flow vs tcv position in %, ref. 349

\*-----

20253500 reac-t

20253501 0.0 0.0  
20253502 20. 0.51  
20253503 40. 0.91  
20253504 52.2 1.0  
20253505 60. 1.02  
20253506 100. 1.11

\*

\* single element controller gain based on # pumps and stm flow

\*-----

20261700 reac-t

20261701 100.0 0.36364  
20261702 101.338 0.36364  
20261703 104.04 0.83333  
20261704 116.0 0.83333  
20261705 200.0 0.5  
20261706 204.014 0.5  
20261707 206.69 0.66667  
20261708 210.04 0.74074  
20261709 216.0 0.74074  
20261710 300.0 0.57143  
20261711 306.69 0.57143  
20261712 310.04 0.74074  
20261713 313.38 0.86957

\*

\* three element level controller gain based on steam flow in Mlbm/hr

\*-----

20261800 reac-t  
20261801 4.014 0.83333  
20261802 6.690 0.74074  
20261803 10.04 0.74074  
20261804 13.38 0.86957

\*

\* three element steam/feed flow controller gain based on # pumps

\*-----

20261900 reac-t  
20261901 100.0 0.16667  
20261902 216.0 0.16667  
20261903 300.0 0.20  
20261904 316.0 0.20

\*

\* lp delta enthalpy in turbine vs inlet pressure

\*-----

20266300 reac-t  
20266301 1.25 0.0  
20266302 40.0 154.0  
20266303 70.0 179.5  
20266304 100. 199.0  
20266305 130. 212.0  
20266306 160. 220.0  
20266307 180. 225.0  
20266308 200.0 228.0  
20266309 214.0 230.0  
20266310 917. 222.  
20266311 967. 264.5

\*

\*

\*-----

\* control variables

\*-----

\*20500000 999

\*

\* wide range level

\*-----

\*

\* instantaneous wide range level

20500100 instwr sum 1.000e+00 3.3058701e+01 0

20500101 -528.00 380.638 voidf 140010000

20500102 152.868 voidf 150010000 \* inst zero @ 528 inches per ref 195

20500103 74.004 voidf 160010000

20500104 1.0 cntrlvar 866

\*  
\*  
20586600 addlevel sum 2.678e+02 0.0 1 .000e+00  
20586601 -0.05 1.0 voidf 190010000  
\*  
\* lagged yarway wide range level  
\* this level detector also used for yarway narrow range control functions  
20500200 wrlevel lag 1.000e+00 3.3052502e+01 0 3 -1.550e+02 6.000e+01  
20500201 1.0 cntrlvar 001 \* ref. 349  
\*  
\* narrow range level  
\*-----  
\*  
\* lagged narrow range level  
20500600 nrlevel lag 1.00 33.0 0 3 -10. 70.  
20500601 0.5 cntrlvar 001 \*lag time const. per ref. 349  
\*  
\* dummy return control variable for labview to return level signal in  
\* stand alone mode  
20500700 levelret constant 3.3000000e+01  
\*  
\* aprm scram setpoint  
\*-----  
\*  
\* total reactor power (lagged) in %, sensed rx power  
20501000 rxpwr lag 3.037e-08 1.0059400e+02 0  
20501001 0.03 rktpow 0 \* 100% = 3293mw, ref. 349  
\*  
\* combined recirc pump mass flows (lb/sec)  
20501100 rcrcflow sum 2.205e+00 9.7047197e+03 0  
20501101 0.0 1.0 mflowj 230010000 \* ref. 349  
20501102 1.0 mflowj 280010000  
\*  
\* sensed percentage recirc flow  
20501200 perrecrc lag 1.053e-02 1.0219100e+02 0  
20501201 0.5 cntrlvar 011 \* ref. 349  
\*  
\* flow bias in percent  
20501300 flobias sum 1.000e+00 0.0 3 .000e+00 5.800e+01  
20501301 58. -.58 cntrlvar 012 \* aprm scram setpt per ref. 359, per  
\* bob stegl?  
\*  
\* aprm in percent including flow bias  
20501400 aprmflo sum 1.000e+00 1.0059400e+02 0

```
20501401 0.0    1.0  cntrlvar 010 * ref. 349, 359
20501402      1.0  cntrlvar 013
*
* reactor steam dome pressure (lagged)
*-----
20509000 rxpress   lag 1.450e-04 1.0233800e+03 0
20509001 0.5    p 190010000 * ref. 349
*
* dummy return control variable for labview to return pressure signal in
* stand alone mode
20509100 pressret constant 1.0233300e+03
*
*
* problem control inputs
*-----
* note: some of these will not activate trips within the trip section
* until the deck is altered for use with labview in the testing mode.
*
* condensate pump a control
20510000 condacnt constant 1.0000000e+00 * 1.0 equals "run", 0.0 equals "tripped"
*
* condensate pump b/c control
20510100 condbcnt constant 1.0000000e+00 * 1.0 equals "run", 0.0 equals "tripped"
*
* condensate booster pump a control
20510200 cndbacnt constant 1.0000000e+00 * 1.0 equals "run", 0.0 equals "tripped"
*
* condensate booster pump b/c control
20510300 cndbbcnt constant 1.0000000e+00 * 1.0 equals "run", 0.0 equals "tripped"
*
* feedwater pump a control
20510400 rfpacont constant 1.0000000e+00 * 1.0 equals "run", 0.0 equals "tripped"
*
* feedwater pump b control
20510500 rfpbcont constant 1.0000000e+00 * 1.0 equals "run", 0.0 equals "tripped"
*
* feedwater pump c control
20510600 rfpcccont constant 1.0000000e+00 * 1.0 equals "run", 0.0 equals "tripped"
*
* manual speed setpoint, both recirc pumps
20510700 rrpmansp constant 9.7659264e+01
*
* level setpoint
20510800 lvlsetpt constant 3.3000000e+01 * ref. 348
```

\*  
\* rod reactivity insertion rate (positive or negative)  
20510900 reactrat constant 0.  
\*  
\* single rrp trip  
20511300 sirrptrp constant 0.\*0. equals ok, 1.0 equals trip  
\*  
\* dual rrp trip  
20511400 durrptrp constant 0.\*0. equals ok, 1.0 equals trip  
\*  
\* main turbine trip  
20511500 mturbtrp constant 0.\*0. equals ok, 1.0 equals trip  
\*  
\* single msiv trip  
20511600 msiv1trp constant 0.\*0. equals ok, 1.0 equals trip  
\*  
\* single msiv trip  
20511700 msiv2trp constant 0.\*0. equals ok, 1.0 equals trip  
\*  
\* rrp a runback trip  
20511800 rrparptrp constant 0.\*0. equals ok, 1.0 equals trip  
\*  
\* rrp b runback trip  
20511900 rrpbrtrp constant 0.\*0. equals ok, 1.0 equals trip  
\*  
\* rrp seizure trip  
20512000 rrpseize constant 0.\*0. equals ok, 1.0 equals trip  
\*  
\* hpci trip  
20512100 hpci\_trp constant 0.\*0. equals ok, 1.0 equals trip  
\*  
\* rcic trip  
20512200 rcic\_trp constant 0.\*0. equals ok, 1.0 equals trip  
\*  
\* scram trip  
20512300 scramtrp constant 0.\*0. equals ok, 1.0 equals trip  
\*  
\* loca trip  
20512400 loca\_trp constant 0.\*0. equals ok, 1.0 equals trip  
\*  
\* runback reset  
20512500 runbkrst constant 0.\*0. equals no reset action  
\*  
\*

\* inverse scram response tripunit  
20520000 negscrtr tripunit 1.0 1. 0  
20520001 -679  
\*  
\* recirc pump speeds, all ref. 349 uno  
\*-----  
\*  
\* tripunit for large torque during pump a seizure  
20520200 seizurea tripunit 1.500e+05 0. 0 \* s is adjustable  
20520201 433  
\*  
\*  
\* recirc pumps speed demand limiters  
\*  
\* 28% runback trip unit, pump a  
20520800 trip28a tripunit 1.000e+00 0. 0  
20520801 685  
\*  
\* 28% runback trip unit, pump b  
20520900 trip28b tripunit 1.000e+00 0. 0  
20520901 687  
\*  
\* 28% limiter, pump a  
20521000 lim28a sum 1.000e+00 1.2800000e+02 0  
20521001 128.0 -100. cntrlvar 208 \*=128 for no runback, 28 @ runback  
\*  
\* 28% limiter, pump b  
20521100 lim28b sum 1.000e+00 1.2800000e+02 0  
20521101 128.0 -100. cntrlvar 209 \*=128 for no runback, 28 @ runback  
\*  
\* 75% runback trip unit  
20521200 trip75 tripunit 1.000e+00 0. 0  
20521201 689  
\*  
\* 75% limiter, both pumps  
20521300 lim75 sum 1.000e+00 1.7500000e+02 0  
20521301 175. -100. cntrlvar 212 \* 175 for no runback, 75 @ runback  
\*  
\* recirc pump a demand limiter (in %)  
20521400 admdlim stdfnctn 1.000e+00 9.7659302e+01 0  
20521401 min cntrlvar 213  
20521402 cntrlvar 210  
20521403 cntrlvar 107  
\*

\* recirc pump b demand limiter (in %)  
20521500 bdmdlim stdfnctn 1.000e+00 9.7659302e+01 0  
20521501 min cntrlvar 213  
20521502 cntrlvar 211  
20521503 cntrlvar 107  
\*  
\* recirc pumps speed controllers  
\*  
\* recirc pump a speed error  
20521600 rrpaspde sum 1.000e+00 3.6342631e-04 0 3 -1.000e+01 1.000e+01  
20521601 0.0 1.0 cntrlvar 214  
20521602 -.0906924 cntrlvar 252  
\*  
\* recirc pump b speed error  
20521700 rrpbspde sum 1.000e+00 3.6342631e-04 0 3 -1.000e+01 1.000e+01  
20521701 0.0 1.0 cntrlvar 215  
20521702 -.0906924 cntrlvar 253  
\*  
\* recirc pump a speed controller integral term  
20521800 rpascint integral 2.712e-02 8.9533699e+01 0 \* jam  
20521801 cntrlvar 216  
\*  
\* recirc pump b speed controller integral term  
20521900 rpbscint integral 2.712e-02 8.9533699e+01 0 \* jam  
20521901 cntrlvar 217  
\*  
\* recirc pump a speed controller  
20522000 rpascont sum 1.000e+00 8.9533798e+01 0  
20522001 0.0 0.3 cntrlvar 216 \* jam  
20522002 1.0 cntrlvar 218  
\*  
\* recirc pump b speed controller  
20522100 rpbscont sum 1.000e+00 8.9533798e+01 0  
20522101 0.0 0.3 cntrlvar 217 \* jam  
20522102 1.0 cntrlvar 219  
\*  
\* recirc pump a speed controller linearization  
20522200 rpaliner function 1.000e+00 6.3723598e+01 0  
20522201 cntrlvar 220 220  
\*  
\* recirc pump b speed controller linearization  
20522300 rpbliner function 1.000e+00 6.3723598e+01 0  
20522301 cntrlvar 221 220  
\*

\* recirc pump coupler positions  
\*  
\* recirc pump a scoop tube natural frequency in rad/sec  
20522400 rpaomega sum 1.000e+00 1.7433600e+00 0 3 1.000e-01 2.000e+00  
20522401 -0.5 2.08333e-3 cntrlvar 252  
\*  
\* recirc pump b scoop tube natural frequency in rad/sec  
20522500 rpbomega sum 1.000e+00 1.7433600e+00 0 3 1.000e-01 2.000e+00  
20522501 -0.5 2.08333e-3 cntrlvar 253  
\*  
\* delay speed controller function generator, pump a  
20522600 rrpadel a delay 1.000e+00 6.3723598e+01 0  
20522601 cntrlvar 222 0.5 5  
\*  
\* delay speed controller function generator, pump b  
20522700 rrpbdela delay 1.000e+00 6.3723598e+01 0  
20522701 cntrlvar 223 0.5 5  
\*  
\* scoop tube actuator a position error  
20522800 scoopaer sum 1.000e+00 1.3683370e-05 0  
20522801 0.0 1.0 cntrlvar 226  
20522802 -1.0 cntrlvar 238  
\*  
\* scoop tube actuator b position error  
20522900 scoopber sum 1.000e+00 1.3683370e-05 0  
20522901 0.0 1.0 cntrlvar 227  
20522902 -1.0 cntrlvar 239  
\*  
\* natural freq \*\*2 times scoop tube a position error  
20523000 scpaome2 mult 1.000e+00 4.1587929e-05 0  
20523001 cntrlvar 228 cntrlvar 224 cntrlvar 224  
\*  
\* natural freq \*\*2 times scoop tube b position error  
20523100 scpboome2 mult 1.000e+00 4.1587929e-05 0  
20523101 cntrlvar 229 cntrlvar 225 cntrlvar 225  
\*  
\* actuator recirc pump a term 1  
20523200 scpatrm1 sum 1.000e+00 1.9645161e-06 0  
20523201 0.0 1.0 cntrlvar 230  
20523202 -1.0 cntrlvar 236  
\*  
\* actuator recirc pump b term 1  
20523300 scpbtrm1 sum 1.000e+00 1.9645161e-06 0  
20523301 0.0 1.0 cntrlvar 231

20523302 -1.0 cntrlvar 237  
\*  
\* actuator recirc pump a term 2  
20523400 scpatrm2 integral 1.000e+00 1.9078579e-05 0 3 -2.000e+01 2.000e+01  
20523401 cntrlvar 232  
\*  
\* actuator recirc pump b term 2  
20523500 scpbtm2 integral 1.000e+00 1.9078579e-05 0 3 -2.000e+01 2.000e+01  
20523501 cntrlvar 233  
\*  
\* actuator recirc pump a term 3  
20523600 scpatrm3 mult 1.200e+00 3.9913000e-05 0  
20523601 cntrlvar 234 cntrlvar 224  
\*  
\* actuator recirc pump b term 3  
20523700 scpatrm3 mult 1.200e+00 3.9913000e-05 0  
20523701 cntrlvar 235 cntrlvar 225  
\*  
\* recirc pump a coupler position  
20523800 rpacplps integral 1.000e+00 6.3723598e+01 0 3 .000e+00 1.750e+02  
20523801 cntrlvar 236 \* jam - retran value was 69.781  
\*  
\* recirc pump b coupler position  
20523900 rpbcpplps integral 1.000e+00 6.3723598e+01 0 3 .000e+00 1.750e+02  
20523901 cntrlvar 237  
\*  
\* recirc pumps coupler torques  
\*  
\* recirc pump a coupler slip  
20524000 acplrslp sum 8.333e-04 8.2611509e-02 0  
20524001 0. 1.0 cntrlvar 280 -1.0 cntrlvar 252  
\*  
\* recirc pump b coupler slip  
20524100 bcplrslp sum 8.333e-04 8.2611509e-02 0  
20524101 0. 1.0 cntrlvar 281 -1.0 cntrlvar 253  
\*  
\* recirc pump a empirical coupler torque term 1  
20524200 rpacplt1 function 1.000e+00 3.9698879e-04 0  
20524201 cntrlvar 240 242  
\*  
\* recirc pump b empirical coupler torque term 1  
20524300 rpbcpplt1 function 1.000e+00 3.9698879e-04 0  
20524301 cntrlvar 241 242  
\*

\* recirc pump a coupler torque in lbf\*ft  
\* scaling factor = 347.372/2 since two pumps in this model  
20524400 rpacpltq mult 3.474e+02 3.5686898e+04 0  
20524401 cntrlvar 242 cntrlvar 238 cntrlvar 238 cntrlvar 238  
\*  
\* recirc pump b coupler torque in lbf\*ft  
20524500 rpbcppltq mult 3.474e+02 3.5686898e+04 0  
20524501 cntrlvar 243 cntrlvar 239 cntrlvar 239 cntrlvar 239  
\*  
\*  
\* recirc pump generator speeds  
\*  
\* recirc pump a motor power in units of lbf\*ft\*rpm  
20524600 ramtrpwr mult 9.549e+00 3.6494040e+07 0  
20524601 cntrlvar 260 pmpvel 230 \* s= conversion factor from rad/s to rpm  
\*  
\* recirc pump b motor power in units of lbf\*ft\*rpm  
20524700 rbmtrpwr mult 9.549e+00 3.6494040e+07 0  
20524701 cntrlvar 261 pmpvel 280 \* s= conversion factor from rad/s to rpm  
\*  
\* recirc pump a generator torque in lbf\*ft  
20524800 rpagentq div 1.053e+00 3.5686898e+04 0  
20524801 cntrlvar 252 cntrlvar 246 \* jam-retran was 1.7469e4  
\*  
\* recirc pump b generator torque in lbf\*ft  
20524900 rpbgentq div 1.053e+00 3.5686898e+04 0  
20524901 cntrlvar 253 cntrlvar 247  
\*  
\* recirc pump a generator delta torque  
20525000 rpagnadtq sum 1.000e+00 -2.6091021e-03 0  
20525001 0. 1. cntrlvar 244  
20525002 -1. cntrlvar 248  
\*  
\* recirc pump b generator delta torque  
20525100 rpbgnadtq sum 1.000e+00 -2.6091021e-03 0  
20525101 0.0 1.0 cntrlvar 245  
20525102 -1.0 cntrlvar 249  
\*  
\* recirc pump a generator speed in rpm  
\* s={(60/2pi)(32.174)[(14,915.5 lb\*ft\*\*2)\*\*(-1)]}, generator i is assumed  
\* from ref. 349  
20525200 rpagensp integral 1.030e-02 1.0768101e+03 0  
20525201 cntrlvar 250  
\*

\* recirc pump b generator speed in rpm  
\*  $s = \{(60/2\pi)(32.174)[(14,915.5 \text{ lb*ft}^2)^{-1}\}]$ , generator i is assumed  
\* from ref. 349  
20525300 rpbgensp integral 1.030e-02 1.0768101e+03 0  
20525301 cntrlvar 251  
\*  
\* recirc pump motor torques  
\*  
\* recirc pump a percent of synchronous speed  
\*  $s = (\text{gen synch speed @ no load}) / (\text{mtr synch speed at no load}) * 100 * (60/2\pi)$   
\* generator no load speed is 1200 rpm, mtr no load synch speed is 1800 rpm,  
\* 100 converts to percent and (60/2\pi) converts pmpvel from rad/s to rpm.  
20525400 rpasynch div 6.366e+02 9.7945000e+01 0  
20525401 cntrlvar 252 pmpvel 230  
\*  
\* recirc pump b percent of synchronous speed  
\*  $s = (\text{gen synch speed @ no load}) / (\text{mtr synch speed at no load}) * 100 * (60/2\pi)$   
\* generator no load speed is 1200 rpm, mtr no load synch speed is 1800 rpm,  
\* 100 converts to percent and (60/2\pi) converts pmpvel from rad/s to rpm.  
20525500 rpbsynch div 6.366e+02 9.7945000e+01 0  
20525501 cntrlvar 253 pmpvel 280  
\*  
\* recirc pump a motor torque in lbf\*ft at 100% speed  
\*  $s = 0.5$  (value from ref. 349) since single pump instead of double pump  
20525600 rpamtrtq function 2.245e+04 2.3067900e+04 0  
20525601 cntrlvar 254 254  
\*  
\* recirc pump b motor torque in lbf\*ft at 100% speed  
\*  $s = 0.5$  (value from ref. 349) since single pump instead of double pump  
20525700 rpbmtrtq function 2.245e+04 2.3067900e+04 0  
20525701 cntrlvar 255 254  
\*  
\* recirc pump a motor torque multiplier for speed  
20525800 ratrqlmul function 1.000e+00 1.0000000e+00 0  
20525801 cntrlvar 252 258  
\*  
\* recirc pump b motor torque multiplier for speed  
20525900 rbtrqlmul function 1.000e+00 1.0000000e+00 0  
20525901 cntrlvar 253 258  
\*  
\* recirc pump a motor torque  
20526000 rpamtrtq mult 1.000e+00 2.3067900e+04 0  
20526001 cntrlvar 256 cntrlvar 258  
\*

\* recirc pump b motor torque  
20526100 rpbmtrtq mult 1.000e+00 2.3067900e+04 0  
20526101 cntrlvar 257 cntrlvar 259  
\*  
\*  
\* recirc pump speeds (with no trip)  
\*  
\* recirc pump a torque difference in lbf\*ft  
20526200 rpadlttq sum 1.000e+00 -4.8878230e-03 0  
20526201 0.0 1.0 cntrlvar 260  
20526202 0.7376 pmptrq 230 \* conversion factor is n\*m to lbf\*ft  
20526203 -1.0 cntrlvar 202 \* applies large stopping torque for  
\* seizure of pump a  
\*  
\* recirc pump b torque difference in lbf\*ft  
20526300 rpbdllttq sum 1.000e+00 -4.8878230e-03 0  
20526301 0.0 1.0 cntrlvar 261  
20526302 0.7376 pmptrq 280 \* conversion factor is n\*m to lbf\*ft  
\*  
\* recirc pump a speed with no pump trip  
\*  $s = \{(60/2\pi)(32.174)[(19,175 \text{ lb*ft}^{**2})^{**(-1)}]\}$ , pump and motor i is assumed  
\* to be 17,044 lb\*ft\*\*2 based on 1/2 of ref. 349 value, which lists 2 values  
20526400 rpaspeed integral 1.602e-02 1.5820800e+03 0  
20526401 cntrlvar 262  
\*  
\* recirc pump b speed with no pump trip  
\*  $s = \{(60/2\pi)(32.174)[(17,044 \text{ lb*ft}^{**2})^{**(-1)}]\}$ , pump and motor i is assumed  
\* to be 17,044 lb\*ft\*\*2 based on 1/2 of ref. 349 value, which lists 2 values  
20526500 rpbspeed integral 1.602e-02 1.5820800e+03 0  
20526501 cntrlvar 263  
\*  
\* recirc dm %synchronous spd  
20527000 dmsynchs mult 8.333e-02 9.7992104e+01 0  
20527001 cntrlvar 280  
\*  
\* recirc dm %synchronous spd  
20527100 dmsynchb mult 8.333e-02 9.7992104e+01 0  
20527101 cntrlvar 281  
\*  
\* recirc dm torque in lbf-ft  
20527200 dmtorque function 3.255e+04 3.2678400e+04 0  
20527201 cntrlvar 270 254  
\*  
\* recirc dm torque in lbf-ft

20527300 dmtorqub function 3.255e+04 3.2678400e+04 0  
20527301 cntrlvar 271 254  
\*  
\* recirc dm speed ratio  
20527400 dmsspdrat div 1.000e+00 9.1569602e-01 0  
20527401 cntrlvar 280 cntrlvar 252  
\*  
\* recirc dm speed ratio  
20527500 dmsspdrab div 1.000e+00 9.1569602e-01 0  
20527501 cntrlvar 281 cntrlvar 253  
\*  
\* recirc dm coupler input torque  
20527600 dmcouptq mult 1.000e+00 3.2678400e+04 0  
20527601 cntrlvar 274 cntrlvar 244  
\*  
\* recirc dm coupler input torque  
20527700 dmcouptb mult 1.000e+00 3.2678400e+04 0  
20527701 cntrlvar 275 cntrlvar 245  
\*  
\* recirc dm torque difference  
20527800 dmdelttq sum 1.000e+00 -3.6762829e-03 0  
20527801 0.0 1.0 cntrlvar 272 -1.0 cntrlvar 276  
\*  
\* recirc dm torque difference  
20527900 dmdelttb sum 1.000e+00 -3.6762829e-03 0  
20527901 0.0 1.0 cntrlvar 273 -1.0 cntrlvar 277  
\*  
\* recirc dm speed  
20528000 dmspeed integral 1.173e-02 1.1759500e+03 0  
20528001 cntrlvar 278  
\*  
\* recirc dm speed  
20528100 dmspeeb integral 1.173e-02 1.1759500e+03 0  
20528101 cntrlvar 279  
\*  
\* rod reactivity, cumulative  
\*-----  
\*  
20530000 rodrctdm integral 5.000e-02 0.0 3 -2.300e+01 3.000e+00  
20530001 cntrlvar 109  
\*  
\* normalized scram curve  
\* s is the inverse of 28.9308, the scram shutdown reactivity margin  
20530100 normscrem function 3.457e-02 0.0

```
20530101 time    0      200
*
* scram multiplier
* this term will remove the rod reactivity added by cntrlvar 300 at the same
* rate as scram reactivity is inserted.
20530200 scrmmult   sum 1.000e+00 1.0000000e+00 0
20530201 1.0      1.0      cntrlvar 301
*
* rod reactivity, including provision to disable following a scram
20530300 rodreact   mult 1.000e+00 0.0
20530301 cntrlvar 302      cntrlvar 300
*
*
* feedwater heater level controls
*-----
*
* cntrlvar 305: RFW HTA1 collapsed liquid level (inches above lower tap)
20530500 'HTRA1LVL'  sum 12. 16.0  1
20530501 -2.6641    1.3307 voidf 722010000
20530502      2.6667 voidf 721030000
20530503      2.6667 voidf 721020000
*20530504      10.4596 voidf 721010000
*20530505      13.7904 voidf 720010000
*
* heater A1 level out to LabVIEW
20530600 a1lvlout  lag 1.00    16.0     0 3 0. 32. *prb
20530601 0.05    cntrlvar 305 *lag time const.
*
* instant drain vlv position in %, A1
20532300 a1drinst constant    32.0
*
* drain vlv position, heater a1, normalized to 1.0
20532400 a1drnpos  lag 0.01    0.32     0
20532401 0.05    cntrlvar 323
*
* cntrlvar 0330: RFW HTA2 collapsed liquid level (inches above lower tap)
20533000 'HTRA2LVL'  sum 12. 18.0  1
20533001 -6.9974    5.4974 voidf 733010000
20533002      3.0000 voidf 732020000
20533003      3.0000 voidf 732010000
*20533004      8.8763 voidf 731010000
*20533005      10.2904 voidf 730010000
*
* heater A2 level out to LabVIEW
```

20533100 a2lvlout lag 1.00 18.0 0 3 0. 36. \*prb  
20533101 0.05 cntrlvar 330 \*lag time const.  
\*  
\* instant drain vlv position in %, A2  
20534800 a2drinst constant 44.0  
\*  
\* drain vlv position, heater a2  
20534900 a2drnpos lag 0.01 0.44 0  
20534901 0.05 cntrlvar 348  
\*  
\* instant A2 bypass vlv position, in %  
20535400 a2byinst constant 0.0 \*prb 01-18-96 10:09am  
\*  
\* bypass vlv position, heater a2, normalized to 1.0  
20535500 a2byppos lag 0.01 0.0 0 \*prb 01-18-96 10:10am  
20535501 0.05 cntrlvar 354  
\*  
\* cntrlvar 0360: RFW HTA3 collapsed liquid level (inches above lower tap)  
20536000 'HTA3LVL' sum 12. 18.0 1  
20536001 -15.6068 7.0534 voidf 742040000  
20536002 7.0534 voidf 742030000  
20536003 3.0000 voidf 742020000  
20536004 3.0000 voidf 742010000  
\*20536005 11.1133 voidf 741010000  
\*20536006 12.4284 voidf 740010000  
\*  
\* heater A3 level out to LabVIEW  
20536100 a3lvlout lag 1.00 18.0 0 3 0. 36. \*prb  
20536101 0.05 cntrlvar 360 \*lag time const.  
\*  
\* instant drain vlv position, A3 in %  
20537800 a3drinst constant 34.0  
\*  
\* drain vlv position, heater a3  
20537900 a3drnpos lag 0.01 0.34 0  
20537901 0.05 cntrlvar 378  
\*  
\* cntrlvar 0380: RFW HTA4 collapsed liquid level (inches above shell bottom)  
20538000 'HTA4LVL' sum 12. 16.9375 1  
20538001 0.0 0.1667 voidf 751010000 \* upper tap 2" above centerline  
20538002 2.9375 voidf 752010000 \* shell radius  
\*  
\* heater A4 level out to LabVIEW  
20538100 a4lvlout lag 1.00 16.9375 0 3 0. 37.25 \*prb  
20538101 0.05 cntrlvar 380 \*lag time const.

\*  
\* instant drain vlv position, A4 in %  
20539800 a4drinst constant 40.0  
\*  
\* drain vlv position, heater a4  
20539900 a4drnpos lag 0.01 0.40 0  
20539901 0.05 cntrlvar 398  
\*  
\* instant bypass vlv position, A4 in %  
20540400 a4byinst constant 0.0 \*prb 01-24-96 10:34am  
\*  
\* bypass vlv position, heater a4, normalized to 1.0  
20540500 a4byppos lag 0.01 0.0 0 \*prb 01-24-96 10:35am  
20540501 0.05 cntrlvar 404  
\*  
\* cntrlvar 0410: RFW HTA5 collapsed liquid level (inches above shell bottom)  
20541000 'HTA5LVL' sum 12. 15.0 0  
20541001 -5.2188 2.500 voidf 760030000 \* level taps are at top  
20541002 5.2188 voidf 760040000 \* & bottom of collector tank  
\*  
\* heater A5 level out to LabVIEW  
20541100 a5lvlout lag 1.00 15.0 0 3 0. 30. \*prb  
20541101 0.05 cntrlvar 410 \*lag time const.  
\*  
\* instant drain vlv position, A5 in %  
20542800 a5drinst constant 40.0  
\*  
\* drain vlv position, heater a5, normalized to 1.0  
20542900 a5drnpos lag 0.01 0.40 0  
20542901 0.05 cntrlvar 428  
\*  
\* instant bypass vlv position, A5 in %  
20543400 a5byinst constant 0.0 \*prb 01-25-96 09:08pm  
\*  
\* bypass vlv position, heater a5, normalized to 1.0  
20543500 a4byppos lag 0.01 0.0 0 \*prb 01-25-96 09:09pm  
20543501 0.05 cntrlvar 434  
\*  
\* cntrlvar 440: RFW HTRB1 collapsed liquid level (inches above lower tap)  
20544000 'HTRB1LVL' sum 12. 16.0 1  
20544001 -2.6641 1.3307 voidf 822010000  
20544002 2.6667 voidf 821030000  
20544003 2.6667 voidf 821020000  
\*20544004 10.4596 voidf 821010000  
\*20544005 13.7904 voidf 820010000

\*

\* heater b1 level out to LabVIEW  
20544100 b1lvlout lag 1.00 33.0 0 3 0. 44.  
20544101 0.05 cntrlvar 440 \*lag time const.

\*

\* auto vlv position demand, b1 drain vlv  
20544900 b1draut constant 32.0

\*

\* drain vlv position, heater b1, normalized to 1.0  
20545000 b1drnpos lag 0.01 0.32 0  
20545001 0.05 cntrlvar 449

\*

\* cntrlvar 0451: RFW HTRB2 collapsed liquid level (inches above lower tap)  
20545100 'HTRB2LVL' sum 12. 18.0 1  
20545101 -6.9974 5.4974 voidf 833010000  
20545102 3.0000 voidf 832020000  
20545103 3.0000 voidf 832010000  
\*205045104 8.8763 voidf 831010000  
\*205045105 10.2904 voidf 830010000

\*

\* heater b2 level out to LabVIEW  
\*205045200 b2lvlout lag 1.00 33.0 0 3 0. 36. \*prb  
20545200 b2lvlout lag 1.00 18.0 0 3 0. 36. \*prb  
20545201 0.05 cntrlvar 451 \*lag time const.

\*

\* auto vlv position demand, b2 drain vlv  
20545700 b2draut constant 44.0

\*

\* drain vlv position, heater b2, normalized to 1.0  
20545800 b2drnpos lag 0.01 0.44 0  
20545801 0.05 cntrlvar 457

\*

\* auto vlv position demand, b2 bypass vlv  
20545900 b2byaut constant 0.0

\*

\* bypass vlv position, heater b2, normalized to 1.0  
20546000 b2byppos lag 0.01 0.0 0 \*prb 01-23-96 01:10pm  
20546001 0.05 cntrlvar 459

\*

\* cntrlvar 0465: RFW HTRB3 collapsed liquid level (inches above lower tap)  
20546500 'HTRB3LVL' sum 12. 18.0 0  
20546501 -15.6068 7.0534 voidf 842040000  
20546502 7.0534 voidf 842030000  
20546503 3.0000 voidf 842020000  
20546504 3.0000 voidf 842010000

```
*20504655      11.1133 voidf 841010000
*20504656      12.4284 voidf 840010000
*
* heater b3 level out to LabVIEW
20546600 b3lvlout lag 1.00    18.0     0 3 0. 36.
20546601 0.05 cntrlvar 465 *lag time const.
*
* auto vlv position demand, b3 drain vlv, in %
20547100 b3draut constant   34.
*
* drain vlv position, heater b3
20547200 b3drnpos lag 0.01    0.34     0
20547201 0.05 cntrlvar 471
*
* cntrlvar 0475: RFW HTRB4 collapsed liquid level (inches above shell bottom)
20547500 'HTRB4LVL' sum 12. 16.9375 0
20547501 0.0 0.1667 voidf 851010000 * upper tap 2" above centerline
20547502 2.9375 voidf 852010000 * shell radius
*
* heater b4 level out to LabVIEW
20547600 b4lvlout lag 1.00    16.9375 0 3 0. 37.25 *prb
20547601 0.05 cntrlvar 475 *lag time const.
*
* auto vlv position demand, b4 drain vlv, in %
20548100 b4draut constant   40.
*
* drain vlv position, heater b4, normalized to 1.0
20548200 b4drnpos lag 0.01    0.40     0
20548201 0.05 cntrlvar 481
*
* auto vlv position demand, b4 bypass vlv, in %
20548300 b4byaut constant   0.0
*
* bypass vlv position, heater b4, normalized to 1.0
20548400 b4byppos lag 0.01    0.5      0
20548401 0.05 cntrlvar 483
*
* cntrlvar 0486: RFW HTRB5 collapsed liquid level (inches above shell bottom)
20548600 'HTRB5LVL' sum 12. 15.0 0
20548601 -5.2188 2.500 voidf 860030000 * level taps are at top
20548602      5.2188 voidf 860040000 * & bottom of collector tank
*
* heater b5 level out to LabVIEW
20548700 b5lvlout lag 1.00    15.0     0 3 0. 30. *prb
20548701 0.05 cntrlvar 486 *lag time const.
```

\*

\* auto vlv position demand, b5 drain vlv, in %  
20549200 b5draut constant 40.

\*

\* drain vlv position, heater b5, normalized to 1.0  
20549300 b5drnpos lag 0.01 0.40 0  
20549301 0.05 cntrlvar 492

\*

\* auto vlv position demand, b5 bypass vlv, in %  
20549400 b5byaut constant 0.0

\*

\* bypass vlv position, heater b5, normalized to 1.0  
20549500 b5byppos lag 0.01 0.0 0 \*prb 01-25-96 09:13pm  
20549501 0.05 cntrlvar 494

\*

\*

\* turbine control valve flow

-----

\*

\* pressure control unit (other units not modelled since pressure control is  
\* sufficient for transients of interest)

\*

\* steam line pressure (psia)  
20550000 slpress lag 1.450e-04 9.7806598e+02 0  
20550001 0.5 p 420030000 \* ref. 349 for time constant, ref. 13

\*

\* pressure error signal (psid)  
20550100 presserr sum 1.000e+00 3.0066700e+01 0  
20550101 -947.99951 1.0 cntrlvar 500 \* pressure setpoint from ref. 349  
\* also ref. 361, 13, 14

\*

\* lead-lag press error signal  
20550200 ldlgpres lead-lag 3.333e+00 1.0019800e+02 0  
20550201 2.0 5.0 cntrlvar 501 \* ref. 14, 349, 361

\*

\* inverse turbine trip, load limiter & max combined flow limiter  
\* assumed that load limiter is set to 110. & max combined flow = 125.  
20550400 invtrip tripunit 1.100e+02 1.1000000e+02 0  
20550401 -601 \* ref. 15, 349, 361

\*

\* pressure control unit signal (lvg output)  
20550600 pcusignl stdfnctn 1.000e+00 1.0019800e+02 0  
20550601 min cntrlvar 502  
20550602 cntrlvar 504 \* ref. 15, 349, 361

\*

\* turbine control valves (tcv) relay  
20550800 tcvrelay lag 1.000e+00 1.0019800e+02 0  
20550801 0.02 cntrlvar 506 \* ref. 349

\*

\* tcv delay function  
20551000 tcvdelay delay 1.000e+00 1.0019800e+02 0  
20551001 cntrlvar 508 0.1 2 \* ref. 349

\*

\* turbine control valve linearization (dfg board output)  
20551200 tcvliner function 1.000e+00 5.2970501e+01 0  
20551201 cntrlvar 510 520 \* ref. 17, 349

\* normalized shape of the curve from ref. 349 is the same as the dfg board  
\* output voltage vs. input voltage signal shown on ref. 17; values from ref.  
\* 349 are used in the table.

\*

\* lagged tcv servo position demand in % open  
20551400 tcvsrvpd lag 1.000e+00 5.2970299e+01 0 3 .000e+00 1.000e+02  
20551401 0.1 cntrlvar 512 \* ref. 16, 349

\*

\* max tcv positive position change in % open in this time step  
20551600 tcvcghmx mult 1.000e+01 5.0000000e-01 0  
20551601 dt 0 \* ref. 349

\*

\* tcv position max value in this time step  
20551800 tcnposmx sum 1.000e+00 5.3470299e+01 0  
20551801 0.0 1.0 cntrlvar 516  
20551802 1.0 cntrlvar 524 \* ref. 349

\*

\* minimum of tcv position demand & max posit  
20552000 tcvmn1 stdfnctn 1.000e+00 5.2970299e+01 0  
20552001 min cntrlvar 514  
20552002 cntrlvar 518

\*

\* tcv position minimum value in % open in this time step  
20552200 tcnposmn sum 1.000e+00 5.2260300e+01 0  
20552201 0.0 -1.42 cntrlvar 516 \* max closure rate is 14.2% per second  
20552202 1.0 cntrlvar 524 \* ref. 349

\*

\* tcv current position with no turbine trip  
20552400 postcvnt stdfnctn 1.000e+00 5.2970299e+01 0 3 .000e+00 1.000e+02  
20552401 max cntrlvar 520  
20552402 cntrlvar 522

\*

\* turbine trip  
20552500 turbtrip tripunit 1.000e+00 0.0  
20552501 601  
\*  
\* time since turbine trip  
20552600 turbtrpt integral 1.000e+00 0.0  
20552601 cntrlvar 525  
\*  
\* tcv position multiplier with turbine trip  
20552700 trbtmult function 1.000e+00 1.0000000e+00 0  
20552701 cntrlvar 526 527 \* tcv closure on trip in 0.1 sec, ref. 349  
\*  
\* tcv position in current time step  
20552800 tcvposit mult 1.000e+00 5.2970299e+01 0  
20552801 cntrlvar 524 cntrlvar 527  
\*  
\* steam flow in lb/sec for 978.00 psia (100% turbine inlet pressure)  
20553200 untbflow function 3.717e+03 3.7243401e+03 0 \* s= 100% flow in lb/s  
20553201 cntrlvar 528 535 \* ref. 349 for table  
\*  
\* steam flow through tcv in lb/sec  
\* multiplicative constant s= 1.45038e-4 \* 1/978psia, or conversion factor for  
\* pa to psia divided by 978 psia. this gives tcv steam flow at any pressure.  
20553600 tcvflow mult 1.483e-07 3.7255500e+03 0  
20553601 cntrlvar 532 \* ref. 349  
20553602 p 420030000  
\*  
\* convert tcv mass flow to velocity  
\*  
20553700 tcvrhoa mult 6.720e-01 2.4019800e+01 0  
20553701 rho 420030000 avol 420030000  
\*  
20553800 tcvvel div 1.000e+00 1.5510300e+02 0  
20553801 cntrlvar 537 cntrlvar 536  
\*  
\*  
\* turbine bypass valve steam flow in lb/sec  
\*-----  
\*  
\* pressure regulator and low value gate signal difference in %  
20554000 ploaddif sum 1.000e+00 -2.5000000e+00 0  
20554001 -2.5 1.0 cntrlvar 502 \* ref. 15, 349, 361  
20554002 -1.0 cntrlvar 506 \* -2.5 is small closing bias  
\*

\* combined maximum flow limiter in %  
20554200 maxflolm sum 1.000e+00 2.4802401e+01 0  
20554201 125. -1.0 cntrlvar 506 \* ref. 16, 349, 361  
\*  
\* bypass valve control signal, lvg output  
20554400 bpvsig stdfnctn 1.000e+00 0.0 3 .000e+00 2.620e+01  
20554401 min cntrlvar 540 \* ref. 16, 349, 361  
20554402 cntrlvar 542  
\*  
\* delayed bypass valve control signal  
20554600 bpvsgdel delay 1.000e+00 0.0  
20554601 cntrlvar 544 0.1 5 \* ref. 349  
\*  
\* bpv position error signal  
20554700 bpverror sum 2.000e+01 0.0 3 -1.050e+02 1.050e+02  
20554701 0.0 1.0 cntrlvar 546 \* ref. 16, 349, 361  
20554702 -1.0 cntrlvar 548  
\*  
\* bpv servo position  
20554800 bpvposit integral 1.000e+00 0.0 3 .000e+00 2.620e+01  
20554801 cntrlvar 547  
\*  
\* bpv steam flow in lb/sec  
\* multiplicative factor is equal to conversion factor from pa to psia times  
\* (1/978 psia) times 0.01 to convert from percentage flow at 978 psia. s =  
\* (1.45038e-4)\*(1/978)\* 0.01.  
20555000 tbpvmflo mult 5.512e-06 0.0  
20555001 p 420030000 \* ref. 349  
20555002 cntrlvar 548  
\*  
\* convert tbpv mdot to velocity  
\*  
20555200 tbpvvel div 1.000e+00 0.0  
20555201 cntrlvar 537 cntrlvar 550  
\*  
\*  
\* feedwater flow controller  
\*-----  
\*  
\* feedpumps above min speed (in auto)  
\*  
\* rfp a above min speed tripunit  
20558000 rfpauto tripunit 1.0 1.0 0  
20558001 -691

\*

\* rfp b above min speed tripunit  
20558100 rfpbauto tripunit 1.0 1.0 0  
20558101 -692

\*

\* rfp c above min speed tripunit  
20558200 rfpcauto tripunit 1.0 1.0 0  
20558201 -512

\*

\* **woodward governor a error term**  
\* (in percent or error/100)  
20558600 woodaerr sum 0.02 0.0 0  
20558601 0.0 1.0 cntrlvar 689  
20558602 -9.549 pmpvel 570

\*

\* **woodward governor b error term**  
20558700 woodberr sum 0.02 0.0 0  
20558701 0.0 1.0 cntrlvar 686  
20558702 -9.549 pmpvel 571

\*

\* **woodward governor c error term**  
20558800 woodcerr sum 0.02 0.0 0  
20558801 0.0 1.0 cntrlvar 683  
20558802 -9.549 pmpvel 572

\*

\* **fsubn a**  
20559500 fsubn\_a lag 1.0 0.0 0  
20559501 0.1 cntrlvar 586

\*

\* **fsubn b**  
20559600 fsubn\_b lag 1.0 0.0 0  
20559601 0.1 cntrlvar 587

\*

\* **fsubn c**  
20559700 fsubn\_c lag 1.0 0.0 0  
20559701 0.1 cntrlvar 588

\*

\*

\*

\* level signal, level error

\*

\* level error in inches  
20560200 lvlerror sum 1.000e+00 -5.6445029e-02 0  
20560201 0.0 1.0 cntrlvar 108

```
20506022      -1.0      cntrlvar  007  * use with labview
*
* bypass valve control
*
* bypass vlv control multiplier
20560400 byponoff constant 0. * equal 1.0 in bypass vlv auto control
*
* bypass proportional error
20560600 bypprope mult 1.000e+00 0.0
20560601 cntrlvar 602      cntrlvar 604 * s = tuning parameter
*
* bypass integral term
20560800 bypinter integral 1.667e-02 0.0 3 0. 100. * s=tuning parameter in 1/sec
20560801 cntrlvar 606
*
* bypass valve controller lc-3-53 output
20560900 lc-3-53 sum 1.000e-02 0.0 * s converts 100% demand to 1.0 position dmd
20560901 0.0    1.0    cntrlvar 606
20560902    1.0    cntrlvar 608 * ref. 104, 363
*
* bypass valve controller lc-3-53 switch
20561000 lc353swh mult 1.0    0.0    0
20561001 cntrlvar 604      cntrlvar 609 * used to simulate manual closing when not in
use
*
* bypass valve position (normalized)
20561100 bypposit lag 1.000e+00 0.0 3 .000e+00 1.000e+00
20561101 2.0    cntrlvar 610 * time constant is a guess
*
* variable feedwater pump controller gains
*
* tripunit for feedpump a
20561300 rfpatrip tripunit 1.    1.    0
20561301 -618
*
* tripunit for feedpump b
20561400 rfpbtrip tripunit 1.    1.    0
20561401 -619
*
* tripunit for feedpump c
20561500 rfpctrip tripunit 1.    1.    0
20561501 -620
*
* dependent variable for single element gain
```

20561600 e1vargnx sum 1. 313.405 0  
20561601 0.0 100. cntrlvar 580  
20561602 100. cntrlvar 581  
20561603 100. cntrlvar 582  
20506164 1. cntrlvar **631** \* use with Labview  
\*  
\* single element gain  
20561700 e1vargny function 1. 0.86957 0 \* tuning parameter  
20561701 cntrlvar 616 617  
\*  
\* three element gain, level controller  
20561800 e3vargny function 1. 0.86957 0 \* tuning parameter  
20506181 cntrlvar **631** 618 \* use with Labview  
\*  
\* three element gain, sf/fw mismatch controller  
20561900 e3misgan function 1. 0.86957 0 \* tuning parameter  
20561901 cntrlvar 616 619  
\*  
\* feedwater flow signal  
\*  
\* lagged feedwater mass flow in Mlbm/hr  
\* s= conversion factor from kg/sec to Mlb/hr; flow is sum of lagged flows  
\* through feedwater lines a and b. lag time constant is from ref. 349.  
20562200 lmflowfw lag 7.938e-03 1.3405000e+01 0  
20562201 0.5 mflowj 605040000  
\*  
\* return feedwater mass flow from LabVIEW  
20562300 labfwflo constant 1.34050000e+01  
\*  
\* steam flow signal  
\*  
\* steam mass flow for use without LabVIEW  
20563000 stmflow sum 1.000e+00 1.3400000e+01 0  
20563001 0.0 1.0 cntrlvar 900  
20563002 1.0 cntrlvar 901  
20563003 1.0 cntrlvar 902  
\*  
\* return steam mass flow from LabVIEW  
20563100 labstflo constant 1.34050000e+01  
\*  
\*  
\* single or three element control selection  
\*  
\* bypass valve not being controlled multiplier

\* = 1 when bypass valve is not used to control level, 0 when in use.  
20563400 bypassnot sum 1.000e+00 1.0000000e+00 0  
20563401 1.0 -1.0 cntrlvar 604  
\*  
\* operator selected single element feed pump control  
\* = 1 when selected, 0 otherwise  
20564600 e1selctd constant 0.  
\*  
\* single element feed pump control multiplier  
\* = 1 when operator selected or tripped, 0 otherwise  
20564800 sngelmlt tripunit 1.000e+00 0.0  
20564801 671  
\*  
\* operator selected three element feed pump control  
\* = 1 when operator selected, 0 otherwise  
20565000 elem3sel constant 1.0000000e+00  
\*  
\* single element inverse tripunit  
\* = 1 when single element feed pump control is not selected or tripped  
20565200 notsingle tripunit 1.000e+00 1.0000000e+00 0  
20565201 -671  
\*  
\* three element level controller  
\*  
\* level pi zeroing error for 1e operation  
20563200 e3lvlzer mult -1.0 0.0 0  
20563201 cntrlvar 655 cntrlvar 648  
\*  
\* level error term for three element control  
20565300 e3lvlerr mult 1.0 0.0 0  
20565301 cntrlvar 602 cntrlvar 652  
20565302 cntrlvar 634  
\*  
\* proportional error term for three element control  
20565400 e3proper mult 0.2 0.0 0 \* **jam 11/10 s = 16M#/hr/80"**  
20565401 cntrlvar 653 cntrlvar 618  
\*  
\* three element level error signal (1e or 3e)  
20565500 e3lvler1 sum 1.0 0.0 0  
20565501 0.0 1.0 cntrlvar 632  
20565502 1.0 cntrlvar **654**  
\*  
\* three element level integrand  
20565600 e3integd integral 9.5238e-03 0.0 0 3 **-16.** 16.

20565601 cntrlvar 655  
\*  
\* steam flow in 3e, 0 otherwise  
20565700 e3stmflo mult 1.0 13.407 0  
20506571 cntrlvar **631** cntrlvar 650 cntrlvar 652 \* use with Labview  
\*  
\* feed flow in 1e, 0 otherwise  
20565800 e1fdflo mult 1.0 0. 0  
20506581 cntrlvar 648 cntrlvar **623** \* use with labview  
\*  
\* three element controller when in 3e or tracking in 1e  
20565900 e3-e3cnt sum 1.0 13.407 0 3 0. 16.  
20565901 0.0 1.0 cntrlvar 654  
20565902 1.0 cntrlvar 656  
20565903 1.0 cntrlvar 657  
20565904 1.0 cntrlvar 658  
\*  
\*  
\* steam flow feedwater flow mismatch  
\*  
\* level controller + steam flow minus feed flow  
20566000 fwstmdel sum 1.000e+00 0.000 0 \* equals 0 when not in 3e  
20566001 0.0 1.0 cntrlvar 659 \* level pi + stm flow, ff in 1e  
20506602 -1.0 cntrlvar **623** \* feedflow (with Labview)  
\*  
\* feed flow proportional error  
20566100 ffproerr mult **6.250e+00** 0.0 0 \*jam 11/10 s = 100%/16M#/hr  
20566101 cntrlvar 660 cntrlvar 619  
\*  
\* track 1e error  
20566200 e1errtr sum 1.0 0.0 0  
20566201 0.0 1.0 cntrlvar 682  
20566202 -1.0 cntrlvar 665  
\*  
\* track 1e error times 1e multiplier  
20566300 e1ertrp mult 1.0 0.0 0  
20566301 cntrlvar 662 cntrlvar 648  
\*  
\* total error for sf\_fw integral  
20566400 sffwerr sum 1.0 0.0 0  
20566401 0.0 1.0 cntrlvar 663  
20566402 1.0 cntrlvar **661**  
\*  
\* three element sf\_fw integrand

```
20566500 sffwintg integral 2.3813-01 84.324      0 3 0. 100.  
20566501 cntrlvar 664  
*  
* three element sf_fw controller output  
20566600 sffwout    sum 1.0     84.324      0 3 0. 100.  
20566601 0.0     1.0     cntrlvar 665  
20566602     1.0     cntrlvar 661  
*  
*  
* single element controller  
*  
* level error term for single element control  
20566700 e1vlerr   mult 1.0     0.0       0  
20566701 cntrlvar 602     cntrlvar 648  
20566702 cntrlvar 634     cntrlvar 200  
*  
* proportional error term for single element control  
20566800 e1proper   mult 1.25    0.0       0 *jam 11/10 s= 100%/80"  
20566801 cntrlvar 667     cntrlvar 617  
*  
* three element tracking error  
20566900 e3trerr    sum 1.0     0.0       0  
20566901 0.0     1.0     cntrlvar 666  
20566902     -1.0    cntrlvar 675  
*  
* three element tracking error when in 3e  
20567000 e3trerrrt  mult 1.0     0.0       0  
20567001 cntrlvar 669 cntrlvar 650 cntrlvar 652  
*  
* single element integral error term  
20567100 e1err     sum 1.0     0.0       0  
20567101 0.0     1.0     cntrlvar 670  
20567102     1.0     cntrlvar 668  
20567103     1.0     cntrlvar 804  
*  
* single element integrand  
20567400 e1integd  integral 1.667e-2 84.324      0 3 0. 100.  
20567401 cntrlvar 671  
*  
* single element controller  
20567500 e1-e1cnt   sum 1.0     84.324      0 3 0. 100.  
20567501 0.0     1.0     cntrlvar 668  
20567502     1.0     cntrlvar 674  
*
```

\* track 3E selection  
20567600 track3el mult 1.0 84.324 1  
20567601 cntrlvar 652 cntrlvar 666  
\*  
\* track 1E selection  
20567700 track1el mult 1.0 0. 0  
20567701 cntrlvar 648 cntrlvar 675  
\*  
\* controller output in 1e or 3e  
20567800 e1-e1e3o sum 1.0 84.324 0 3 0. 100.  
20567801 0.0 1.0 cntrlvar 677  
20567802 1.0 cntrlvar 676  
\*  
\* scram response tripunit  
20567900 scrrespt tripunit 37.0 0. 0  
20567901 679 \* = 37 when scram respnse in, 0 otherwise  
\*  
\* max controller output following a scram response  
20568000 scrrspmx sum 1.0 100. 0  
20568001 100. -1.0 cntrlvar 679 \* 63. when response in  
\*  
\* single element controller out in 1e/3e w/ scram response  
20568100 e1scram stdfnctn 1.0 84.324 0  
20568101 min cntrlvar 680 cntrlvar 678  
\*  
\* controller output with bypass zero feature  
20568200 i\_apiout mult 1.0 84.324 0  
20568201 cntrlvar 681 cntrlvar 634  
\*  
\* conversion of demand signal to speed demand  
20568300 spddmd sum 1.0 4816.2 0  
20568301 600. 50. cntrlvar 682  
\*  
\* individual pump responses  
\*  
\* pump b speed limiter tripunit  
20568400 b600rpm tripunit 9400. 0.0 0  
20568401 681 \* s = amt subtracted from large # to give limit  
\*  
\* pump b speed limit following scram response  
20568500 b600limt sum 1.0 10000. 0  
20568501 10000. -1.0 cntrlvar 684  
\*  
\* pump b speed controller output

20568600 bcontout stdfnctn 1.0 4816.2 0  
20568601 min cntrlvar 685 cntrlvar 683 \* controller output to pump b  
\*  
\* pump a speed limiter tripunit  
20568700 a600rpm tripunit 9400. 0.0 0  
20568701 684 \* s = amt subtracted from large # to give limit  
\*  
\* pump a speed limit following scram response  
20568800 a600limt sum 1.0 10000. 0  
20568801 10000. -1.0 cntrlvar 687  
\*  
\* pump a speed controller output  
20568900 acontout stdfnctr 1.0 4816.2 0  
20568901 min cntrlvar 688 cntrlvar 683 \* controller output to pump a  
\*  
\*  
\* mathematical models of governors  
\*  
\* **woodward a governor differential term**  
20569000 woodadif diffreni 3.5 0.0 0  
20569000 woodadif diffreni .35 0.0 0  
20569001 cntrlvar 595  
\*  
\* **woodward b governor differential term**  
20569100 woodbdif diffreni .35 0.0 0  
20569101 cntrlvar 596  
\*  
\* **woodward c governor differential term**  
20569200 woodcdif diffreni .35 0.0 0  
20569201 cntrlvar 597  
\*  
\* woodward a governor integral term  
20569600 woodaint integral **2.8e+00** 37.983 0 3 0. 100.  
20569601 cntrlvar **595**  
\*  
\* woodward b governor integral term  
20569700 woodbint integral **2.8e+00** 37.983 0 3 0. 100.  
20569701 cntrlvar **596**  
\*  
\* woodward c governor integral term  
20569800 woodcint integral **2.8e+00** 37.983 0 3 0. 100.  
20569801 cntrlvar **597**  
\*  
\* woodward a output in valve poppet dmd (sec op cyl pos)

\* s= (6.37"/100%)  
20569900 woodaout sum 6.370e-02 2.4195099e+00 0 3 .000e+00 6.370e+00  
20569901 0.0 **7.00** cntrlvar **595**  
**20569902** 1.0 cntrlvar **690**  
**20569903** 1.0 cntrlvar **696**  
\*  
\* woodward b output in valve poppet dmd (sec op cyl pos)  
\* s= (6.37"/100%)  
20570000 woodbout sum 6.370e-02 2.4195099e+00 0 3 .000e+00 6.370e+00  
20570001 0.0 **7.00** cntrlvar **596**  
20570002 1.0 cntrlvar **697**  
**20570003** 1.0 cntrlvar **691**  
\*  
\* woodward c output in valve poppet dmd (sec op cyl pos)  
\* s= (6.37"/100%)  
20570100 woodcout sum 6.370e-02 2.4195099e+00 0 3 .000e+00 6.370e+00  
20570101 0.0 **7.00** cntrlvar **597**  
20570102 1.0 cntrlvar **698**  
**20570103** 1.0 cntrlvar **692**  
\*  
\* woodward a output w/ pump tripunit  
20570500 rfpasctr mult 1.0 2.4195700e+00 0  
20570501 cntrlvar 613 cntrlvar **699**  
\*  
\* woodward b output w/ pump tripunit  
20570600 rfpbsctr mult 1.0 2.4195700e+00 0  
20570601 cntrlvar 614 cntrlvar **700**  
\*  
\* woodward c output w/ pump tripunit  
20570700 rfpccstr mult 1.0 2.4195700e+00 0  
20570701 cntrlvar 615 cntrlvar **701**  
\*  
\* rfpt a secondary operating cylinder position (valve position)  
20570800 secopaps lag 1.000e+00 2.4195700e+00 0  
20570801 0.1 cntrlvar **705** \* lag time constant is a guess to acct for  
\* valve response to sec op cyl position  
\*  
\* rfpt b secondary operating cylinder position (valve position)  
20570900 secopbps lag 1.000e+00 2.4187300e+00 0  
20570901 0.2 cntrlvar **706** \* lag time constant is from governor tuning  
\*  
\* rfpt c secondary operating cylinder position (valve position)  
20571000 secopcps lag 1.000e+00 2.4187300e+00 0  
20571001 0.2 cntrlvar **707** \* lag time constant is from governor tuning

\*  
\* steam inlet valve and turbine math models  
\*  
\* rfp a instantaneous lp steam mass flow in klbm/hr at 198.6 psia inlet p  
\* flow at fully open lp poppets from ref. 378; secondary cylinder travel  
\* from ref. 74  
20571100 rfpamdot sum 2.911e+01 6.6794998e+01 0 3 .000e+00 8.020e+01  
20571101 -1.25 1.0 cntrlvar 708 \* cntrlvar 708 is sec cyl travel  
\*  
\* rfp b instantaneous lp steam mass flow in klbm/hr at 198.6 psia inlet p  
\* flow at fully open lp poppets from ref. 378; secondary cylinder travel  
\* from ref. 74  
20571200 rfpbmdot sum 2.911e+01 6.6770401e+01 0 3 .000e+00 8.020e+01  
20571201 -1.25 1.0 cntrlvar 709 \* cntrlvar 709 is sec cyl travel  
\*  
\* rfp c instantaneous lp steam mass flow in klbm/hr at 198.6 psia inlet p  
\* flow at fully open lp poppets from ref. 378; secondary cylinder travel  
\* from ref. 74  
20571300 rfpcmdot sum 2.911e+01 6.6770500e+01 0 3 .000e+00 8.020e+01  
20571301 -1.25 1.0 cntrlvar 710 \* cntrlvar 710 is sec cyl travel  
\*  
\* rfp a instantaneous hp steam mass flow in klbm/hr at 965.0 psia inlet p  
\* flow at fully open hp poppets from ref. 378; secondary cylinder travel  
\* from ref. 74  
20571400 rfpahpfl sum 2.381e+01 0.0 1 .000e+00  
20571401 -2.88 1.0 cntrlvar 708 \* cntrlvar 708 is sec cyl travel  
\*  
\* rfp b instantaneous hp steam mass flow in klbm/hr at 965.0 psia inlet p  
\* flow at fully open hp poppets from ref. 378; secondary cylinder travel  
\* from ref. 74  
20571500 rfpbhpfl sum 2.381e+01 0.0 1 .000e+00  
20571501 -2.88 1.0 cntrlvar 709 \* cntrlvar 709 is sec cyl travel  
\*  
\* rfp c instantaneous hp steam mass flow in klbm/hr at 965.0 psia inlet p  
\* flow at fully open hp poppets from ref. 378; secondary cylinder travel  
\* from ref. 74  
20571600 rfpchpfl sum 2.381e+01 0.0 1 .000e+00  
20571601 -2.88 1.0 cntrlvar 710 \* cntrlvar 710 is sec cyl travel  
\*  
\* lp poppet inlet pressure, based on steam flow, see curves developed by saic  
\* from heat balance information  
20571700 lppopptp sum 1.427e+01 1.9357700e+02 0 1 1.470e+01  
20571701 0.1510 1.0 cntrlvar 900  
20571702 1.0 cntrlvar 901

20571703        1.0     cntrlvar 902  
\*  
\* multiplicative factor for low press flow based on inlet pressure  
\* assumed linear with p-inlet  
20571800 flowmult mult 5.035e-03 9.7465998e-01 0  
20571801 cntrlvar 717  
\*  
\* multiplicative factor for high press flow based on inlet pressure  
\* assumed linear with p-inlet  
20571900 hflomult mult 1.503e-07 1.0138201e+00 0  
20571901 p       420030000 \* s = (1/965psia)(1.450383-4 psi/pa)  
\*  
\* lp delta enthalpy across rfpt in btu/lbm vs. inlet pressure  
20572000 rfptenth function 1.000e+00 2.2703700e+02 0  
20572001 cntrlvar 717     663  
\*  
\* hp delta enthalpy across rfpt in btu/lbm vs. inlet pressure  
20572100 hpdlength function 1.000e+00 2.6450000e+02 0  
20572101 p       420030000 663  
\*  
\* rfp a instantaneous turbine power output in hp from lp valves  
20572200 talpipwr mult 3.930e-01 5.8087798e+03 0  
20572201 cntrlvar 720     cntrlvar 718  
20572202 cntrlvar 711  
\*  
\* rfp b instantaneous turbine power output in hp from lp valves  
20572300 tlpipwr mult 3.930e-01 5.8066401e+03 0  
20572301 cntrlvar 720     cntrlvar 718  
20572302 cntrlvar 712  
\*  
\* rfp c instantaneous turbine power output in hp from lp valves  
20572400 tclpipwr mult 3.930e-01 5.8066499e+03 0  
20572401 cntrlvar 720     cntrlvar 718  
20572402 cntrlvar 713  
\*  
\* rfp a instantaneous turbine power output in hp from hp valves  
20572500 tahpipwr mult 3.930e-01 0.0  
20572501 cntrlvar 721     cntrlvar 719  
20572502 cntrlvar 714  
\*  
\* rfp b instantaneous turbine power output in hp from hp valves  
20572600 tbhpipwr mult 3.930e-01 0.0  
20572601 cntrlvar 721     cntrlvar 719  
20572602 cntrlvar 715

\*

\* rfp c instantaneous turbine power output in hp from hp valves  
20572700 tchpipwr mult 3.930e-01 0.0  
20572701 cntrlvar 721 cntrlvar 719  
20572702 cntrlvar 716

\*

\* rfp a instantaneous turbine power output in hp  
20573000 rfptaipw sum 1.000e+00 5.8087798e+03 0  
20573001 0.0 1.0 cntrlvar 725  
20573002 1.0 cntrlvar 722

\*

\* rfp b instantaneous turbine power output in hp  
20573100 rfptbipw sum 1.000e+00 5.8066401e+03 0  
20573101 0.0 1.0 cntrlvar 726  
20573102 1.0 cntrlvar 723

\*

\* rfp c instantaneous turbine power output in hp  
20573200 rfptcipw sum 1.000e+00 5.8066499e+03 0  
20573201 0.0 1.0 cntrlvar 727  
20573202 1.0 cntrlvar 724

\*

\* rfp a turbine power output in hp  
20573500 rfptapwr lag 1.000e+00 5.8088701e+03 0  
20573501 0.05 cntrlvar 730

\*

\* rfp b turbine power output in hp  
20573600 rfptbpwr lag 1.000e+00 5.8067700e+03 0  
20573601 0.05 cntrlvar 731

\*

\* rfp c turbine power output in hp  
20573700 rfptcpwr lag 1.000e+00 5.8067798e+03 0  
20573701 0.05 cntrlvar 732

\*

\* rfp a load power,pl, in hp  
20574000 rfpalpwr mult 1.341e-03 -5.8111099e+03 0  
20574001 pmpvel 570 pmptrq 570

\*

\* rfp b load power,pl, in hp  
20574100 rfpblpwr mult 1.341e-03 -5.8104702e+03 0  
20574101 pmpvel 571 pmptrq 571

\*

\* rfp c load power,pl, in hp  
20574200 rfpclpwr mult 1.341e-03 -5.8104800e+03 0  
20574201 pmpvel 572 pmptrq 572

\*

\* rfp a differential power  
20574500 rfpadpwr sum 1.000e+00 -2.2463901e+00 0  
20574501 0.0 1.0 cntrlvar 735  
20574502 1.0 cntrlvar 740

\*

\* rfp b differential power  
20574600 rfpbdpwr sum 1.000e+00 -3.7010801e+00 0  
20574601 0.0 1.0 cntrlvar 736  
20574602 1.0 cntrlvar 741

\*

\* rfp c differential power  
20574700 rfpcdpwr sum 1.000e+00 -3.7016301e+00 0  
20574701 0.0 1.0 cntrlvar 737  
20574702 1.0 cntrlvar 742

\*

\* rfp a net angular acceleration, in rpm/sec  
20575000 rfpalpha div 3.806e+02 -1.7738999e-01 0 \* (550lbf-ft/hp-sec)(32.17lbm-ft\*\*2)/{(4239lbm-ft\*\*2)(2pi)\*\*2} = s  
20575001 cntrlvar 756 cntrlvar 745 \* sec\*\*2)(60sec/min)\*\*2

\*

\* rfp b net angular acceleration, in rpm/sec  
20575100 rfpbeta div 3.806e+02 -2.9226699e-01 0  
20575101 cntrlvar 757 cntrlvar 746

\*

\* rfp c net angular acceleration, in rpm/sec  
20575200 rfpgamma div 3.806e+02 -2.9231101e-01 0  
20575201 cntrlvar 758 cntrlvar 747

\*

\* rfp a delta rpm  
20575300 rfpadrpm mult 1.000e+00 -8.8695129e-03 0  
20575301 cntrlvar 750 dt 0

\*

\* rfp b delta rpm  
20575400 rfpbdrpm mult 1.000e+00 -1.4613370e-02 0  
20575401 cntrlvar 751 dt 0

\*

\* rfp c delta rpm  
20575500 rfpcdrpm mult 1.000e+00 -1.4615540e-02 0  
20575501 cntrlvar 752 dt 0

\*

\* rfp a current rpm  
20575600 rfpaprm sum 1.000e+00 4.8197402e+03 0  
20575601 0.0 1.0 cntrlvar 753

20575602 1.0 cntrlvar 756  
\*  
\* rfp b current rpm  
20575700 rfpbrpm sum 1.000e+00 4.8196499e+03 0  
20575701 0.0 1.0 cntrlvar 754  
20575702 1.0 cntrlvar 757  
\*  
\* rfp c current rpm  
20575800 rfpcrpm sum 1.000e+00 4.8196499e+03 0  
20575801 0.0 1.0 cntrlvar 755  
20575802 1.0 cntrlvar 758  
\*  
20580200 output01 tripunit 1.0 0. 0  
20580201 520  
\*  
20580300 scramerr sum 7.5 0. 0  
20580301 63. -1.0 cntrlvar 675  
\*  
20580400 scramer1 mult .027027 0. 0  
20580401 cntrlvar 679 cntrlvar 802 cntrlvar 803  
\*  
\*-----  
\* additional rfwcs output control variables \*  
\*-----  
\* mass flow rate, steam line a, in mlbm/hr  
20590000 stmfloa mult 7.938e-03 3.3373001e+00 0  
20590001 mflowj 412000000 \* constant = (2.205 lbm/kg)(3600sec/hr)(1.e-6)  
\*  
\* mass flow rate, steam line b, in mlbm/hr  
20590100 stmflob mult 7.938e-03 3.3373001e+00 0  
20590101 mflowj 411000000 \* constant = (2.205 lbm/kg)(3600sec/hr)(1.e-6)  
\*  
\* mass flow rate, steam line c/d, in mlbm/hr  
20590200 stmflocd mult 7.938e-03 6.7396998e+00 0  
20590201 mflowj 410000000 \* constant = (2.205 lbm/kg)(3600sec/hr)(1.e-6)  
\*  
\* reactor scram signal  
20590600 scarmsig tripunit 1.000e+00 0. 0  
20590601 649  
\*  
\* level 8 signal (trips all rfps)  
20590700 lvl8\_sig tripunit 1.000e+00 0. 0  
20590701 406

```
*  
* problem time  
20590800 probtime mult 1.000e+00 1.0000000e+03 0  
20590801 time 0  
*  
*  
20591000 rfpalpm mult 9.549e+00 4.8196001e+03 0  
20591001 pmpvel 570  
*  
20591100 rfpalpm mult 9.549e+00 4.8195098e+03 0  
20591101 pmpvel 571  
*  
20591200 rfpalpm mult 9.549e+00 4.8195098e+03 0  
20591201 pmpvel 572  
*  
* cntrlvar 940: RFW HTRC1 collapsed liquid level (inches above lower tap)  
20594000 'HTRC1LVL' sum 12. 16.0 1  
20594001 -2.6641 1.3307 voidf 922010000  
20594002 2.6667 voidf 921030000  
20594003 2.6667 voidf 921020000  
*20509404 10.4596 voidf 921010000  
*20509405 13.7904 voidf 920010000  
*  
* heater c1 level out to LabVIEW  
20594100 c1lvlout lag 1.00 33.0 0 3 0. 44.  
20594101 0.5 cntrlvar 940 *lag time const.  
*  
* auto vlv position demand, c1 drain vlv, in %  
20594900 c1draut constant 32.  
*  
* drain vlv position, heater c1  
20595000 c1drnpos lag 0.01 0.32 0  
20595001 0.05 cntrlvar 949  
*  
* cntrlvar 0951: RFW HTRC2 collapsed liquid level (inches above lower tap)  
20595100 'HTRC2LVL' sum 12. 18.0 1  
20595101 -6.9974 5.4974 voidf 933010000  
20595102 3.0000 voidf 932020000  
20595103 3.0000 voidf 932010000  
*20509514 8.8763 voidf 931010000  
*20509515 10.2904 voidf 930010000  
*  
* heater c2 level out to LabVIEW  
20595200 c2lvlout lag 1.00 18.0 0 3 0. 36. *prb
```

20595201 0.5 cntrlvar 951 \*lag time const.  
\*  
\* auto vlv position demand, c2 drain vlv, in %  
20595700 c2draut constant 44.  
\*  
\* drain vlv position, heater c2  
20595800 c2drnpos lag 0.01 0.44 0  
20595801 0.05 cntrlvar 957  
\*  
\* auto vlv position demand, c2 bypass vlv, in %  
20595900 c2byaut constant 0.0  
\*  
\* bypass vlv position, heater c2, normalized to 1.0  
20596000 c2byppos lag 0.01 0.0 0  
20596001 0.05 cntrlvar 959  
\*  
\* cntrlvar 0965: RFW HTRC3 collapsed liquid level (inches above lower tap)  
20596500 'HTRC3LVL' sum 12. 18.0 0  
20596501 -15.6068 7.0534 voidf 942040000  
20596502 7.0534 voidf 942030000  
20596503 3.0000 voidf 942020000  
20596504 3.0000 voidf 942010000  
\*20509655 11.1133 voidf 941010000  
\*20509656 12.4284 voidf 940010000  
\*  
\* heater c3 level out to LabVIEW  
20596600 c3lvlout lag 1.00 18.0 0 3 0. 36. \*prb  
20596601 0.5 cntrlvar 965 \*lag time const.  
\*  
\* auto vlv position demand, c3 drain vlv, in %  
20597100 c3draut constant 34.  
\*  
\* drain vlv position, heater c3  
20597200 c3drnpos lag 0.01 0.34 0  
20597201 0.05 cntrlvar 971  
\*  
\* cntrlvar 0975: RFW HTRC4 collapsed liquid level (inches above shell bottom)  
20597500 'HTRC4LVL' sum 12. 16.9375 0  
20597501 0.0 0.1667 voidf 951010000 \* upper tap 2" above centerline  
20597502 2.9375 voidf 952010000 \* shell radius  
\*  
\* heater c4 level out to LabVIEW  
20597600 c4lvlout lag 1.00 16.9375 0 3 0. 37.25 \*prb  
20597601 0.05 cntrlvar 975 \*lag time const.  
\*

\* auto vlv position demand, c4 drain vlv, in %  
20598100 c4draut constant 40.  
\*  
\* drain vlv position, heater c4, normalized to 1.0  
20598200 c4drnpos lag 0.01 0.40 0  
20598201 0.05 cntrlvar 981  
\*  
\* auto vlv position demand, c4 bypass vlv, in %  
20598300 c4byaut constant 0.0  
\*  
\* bypass vlv position, heater c4, normalized to 1.0  
20598400 c4byppos lag 0.01 0.0 0 \*prb 01-24-96 10:46am  
20598401 0.05 cntrlvar 983  
\*  
\* cntrlvar 0986: RFW HTRC5 collapsed liquid level (inches above shell bottom)  
20598600 'HTRC5LVL' sum 12. 15.0 0  
20598601 -5.2188 2.500 voidf 960030000 \* level taps are at top  
20598602 5.2188 voidf 960040000 \* & bottom of collector tank  
\*  
\* heater c5 level out to LabVIEW  
20598700 c5lvlout lag 1.00 15.0 0 3 0. 30. \*prb  
20598701 0.05 cntrlvar 986 \*lag time const.  
\*  
\* auto vlv position demand, c5 drain vlv, in %  
20599200 c5draut constant 40.  
\*  
\* drain vlv position, heater c5, normalized to 1.0  
20599300 c5drnpos lag 0.01 0.40 0  
20599301 0.05 cntrlvar 992  
\*  
\* auto vlv position demand, c5 bypass vlv, in %  
20599400 c5byaut constant 0.0  
\*  
\* bypass vlv position, heater c5, normalized to 1.0  
20599500 c5byppos lag 0.01 0.0 0 \*prb 01-25-96 09:22pm  
20599501 0.05 cntrlvar 994  
\*  
\*-----  
\* hydrodynamic components  
\*-----  
\*-----  
\* reactor vessel  
\*-----

\* note: initial conditions are taken from the output  
\* of a steady state calculation run for 1000 sec.  
\*  
\* the brown's ferry retran input deck is  
\* reference [349]  
\*-----  
\*(100) entrance volume to core  
\*-----  
1000000 lplenum branch  
\*card jun vel/flow  
1000001 1 0  
\*  
\*card vol flow area vol length vol of vol az angle  
1000101 0.0 17.534 2230.000 0.  
\*card inc angle elev change roughness hyd dia pvbfe  
1000102 90. 17.534 5.e-6 .8628 00000  
\*-----  
\* volume length, volume, elev change, hyd dia are from ref. [349].  
\*-----  
\*card ebt press ul ug alpha  
1000200 0 1.0450000e+03 5.1590997e+02 1.1091000e+03 0.  
\*  
\* jun (100-01) lower plenum to core inlet  
\*-----  
\*card from to area kf kr fvcahs  
1001101 100010000 110000000 37.503 0.0000 9.1510 001000  
\*-----  
\* junction area is from ref. [349]  
\* kf: modelling assumption  
\* kr: ref. [349]  
\*-----  
\*card int. liq flow int. vap flow int vel  
1001201 1.5436000e+01 1.7542999e+01 0.  
\*  
\*-----  
\*(110) core inlet  
\*-----  
\*card name type  
1100000 corein branch  
\*  
\*card jun vel/flow  
1100001 2 0  
\*  
\*card vol flow area vol length vol of vol az angle

```
1100101    0.0      0.492      37.710   0.  
*card inc angle elev change roughness hyd dia pvbfe  
1100102    90.     0.492      5.e-6     0.04461 00000  
*-----  
* volume length, volume, elev change, hyd dia are from ref. [349].  
*-----  
*card ebt press ul ug alpha  
1100200 0 1.0417000e+03 5.1590997e+02 1.1092000e+03 0.  
*-----  
* jun (110-01) core inlet to reactor core  
*-----  
*card from to area kf kr fvcahs  
1101101 110010000 120000000 83.9636 0.615385 0.07692 001000  
*-----  
* junction area, kf, and kr are from ref. [349].  
*-----  
*card int. liq flow int. vap flow inter. vel  
1101201 6.0906000e+00 9.3687000e+00 0.  
1102201 1.0246000e+02 1.0581000e+02 0.  
*-----  
* jun (110-02) core inlet to core bypass  
*-----  
*card from to area kf kr fvcahs  
1102101 110010000 130000000 0.6590 0.084 0.648 001000  
*-----  
* junction area is from ref. [349].  
* kf: modelling assumption used to achieve a 0.119 bypass ratio  
* kr: ref. [349]  
*-----  
*-----  
* (111) loca time dependent junction  
*-----  
*card component name type  
1110000 locajun tmdpjun  
1110101 100000000 113000000 0.  
1110200 1 468  
1110201 -1.0 0.0 0.0 0.0  
1110202 0.0 40.0 0.0 0.0  
*-----  
*-----  
* (112) single junction: core region (120) - core exit (170)  
*-----
```

```
*card component name type
1120000 singjun sngljun
*
*card from vol to vol jun area f loss r loss fvcahs
1120101 120010000 170000000 84.9744 0.10000 7.11200 001000
*-----
* junction area, kf, and kr are from ref. [349].
*-----
*
*card vel/flow int liq flow int vapor flow interface vel
1120201 0 1.6455999e+01 2.8388000e+01 0.
*
*-----
* (113) loca time dependent volume
*-----
*card component name type
1130000 locavol tmdpvol
1130101 0. 1. 1. 0. 0. 0. 0. 0. 00000
1130200 001
1130201 0.0 526. 0.
*
*-----
* (120) core region (pipe)
*-----
*card component type
1200000 core pipe
*
*card num vol
1200001 5
*card vol flow area vol
1200101 0.0 5
*card jun flow area jun
1200201 0.0 4
*card vol length vol
1200301 2.7386 5
*card vol of vol vol
1200401 232.7108 5
*card azimuthal angle vol
1200501 0.0 5
*card inclination angle vol
1200601 90.0 5
*card elevation change vol
1200701 2.7386 5
*card wall roughness hyd dia vol
```

```
1200801      5.e-6    0.0446    5
*-----
* vol length, vol, elev change are calculated in
* appendix a. hyd dia from ref. [349].
*-----
*card      f loss coeff   r loss coeff   jun
1200901      2.0000      0.2500      4
*-----
* kf and kr are calculated in appendix a
*-----
*card      pvbfe        vol
1201001      11100       5
*
*card      fvcahs        jun
1201101      001000      4
*
*card      ebt press     ul      ug      alpha      w5      vol
1201201 0 1.0410000e+03 5.3301001e+02 1.1092000e+03 1.1264000e-01 .0 1
1201202 0 1.0395000e+03 5.4077002e+02 1.1093000e+03 3.7233001e-01 .0 2
1201203 0 1.0377000e+03 5.4346002e+02 1.1093000e+03 4.7633001e-01 .0 3
1201204 0 1.0356000e+03 5.4379999e+02 1.1094000e+03 5.1504999e-01 .0 4
1201205 0 1.0334000e+03 5.4351001e+02 1.1095000e+03 6.8190002e-01 .0 5
*
*card      vel/flow
1201300 0
*
*card      int liq flow   int vap flow   inter vel jun
1201301  6.8456001e+00 1.0574000e+01 0.      1
1201302  9.4076996e+00 1.5172000e+01 0.      2
1201303  1.0775000e+01 2.3551001e+01 0.      3
1201304  1.1115000e+01 3.1582001e+01 0.      4
*
*-----
* (130) core bypass (branch)
*-----
*card      component name   type
1300000  coreby        branch
*
*card      num jun        vel/flow
1300001      1      0
*
*card      vol flow area   vol length   vol of vol   az angle
1300101      0.0      13.693     952.140     0.0
*card      inc angle   elev change   roughness   hyd dia   pvbfe
```

```
1300102    90.0    13.693    5.0e-6    0.1867    00000
*-----
* vol length, vol, elev change, hyd dia are from ref. [349].
*-----
*card ebt press ul ug alpha
1300200 0 1.0351000e+03 5.1590997e+02 1.1094000e+03 0.
*
* jun (130-01) core bypass - core exit
*-----
*card from vol to vol jun area f loss r loss fvcahs
1301101 130010000 170000000 46.5040 0.747 0.374 001000
*
* junction area, kf, kr are from the ref. [349].
*-----
*card int liq flow int vap flow inter vel
1301201 1.4520000e+00 6.1647000e+00 0.
*
*-----
* (140) lower downcomer (branch)
*-----
*card component name type
1400000 lowerdc branch
*card num jun vel/flow
1400001 2 0
*
*card vol flow area vol length vol of vol az angle
1400101 0.0 21.330 2004.467 0.0
*card inc angle elev change rough hyd dia pvbfe
1400102 -90.0 -21.330 5.e-6 1.9452 00000
*
* vol length, vol, elev change are calculated in app a
* hyd dia from ref. [349]
*-----
*card ebt press ul ug alpha
1400200 0 1.0323000e+03 5.1578003e+02 1.1095000e+03 0.
*
* jun (140-01) lower downcomer to recirculation pump suction(a)
*-----
*card from vol to vol jun area f loss r loss fvcahs
1401101 140010000 220000000 3.5410 0.005 1.00 001000
*
* junction area from ref. [349], kf modelling assumption,
* kr from ref. [349]
*
```

```
*card int liquid flow int vapor flow inter vel
1401201 2.8816000e+01 3.0966000e+01 0.
1402201 2.8816000e+01 3.0966000e+01 0.
*
* jun (140-02) lower downcomer to recirculation pump suction(b)
*-----
*card from vol to vol jun area f loss r loss fvcahs
1402101 140010000 270000000 3.5410 0.005 1.00 001000
*
*-----  
* junction area from ref. [349], kf modelling assumption,
* kr from ref. [349]
*-----  
*-----  
* (150) middle downcomer (branch)
*-----  
*card component name type
1500000 middledc branch
*card num jun vel/flow
1500001 1 0
*
*card vol flow area vol length vol of vol az angle
1500101 0.0 12.739 1411.466 0.0
*card inc angle elev change roughness hyd dia pvbfe
1500102 -90.0 -12.739 5.e-6 2.716 00000
*-----  
* see note with card 1400101
*-----  
*card ebt press ul ug alpha
1500200 0 1.0266000e+03 5.1595001e+02 1.1097000e+03 0.
*
* jun (150-01) middle downcomer to lower downcomer
*-----  
*card from vol to vol jun area f loss r loss fvcahs
1501101 150010000 140000000 87.0380 0.00 0.00 001000
*
*-----  
* junction area, kf, kr from ref. [349]
*-----  
*card int liquid flow int vapor flow inter vel
1501201 2.3452001e+00 2.9754000e+00 0.
*
*-----  
* (160) upper downcomer
*-----
```

```
*card name type
1600000 uppdc branch
*
*card jun vel/flow
1600001 1 0
*
*card area length of vol vol of vol az angle
1600101 0. 6.167 965.359 0.0
*card inc angle elev change roughness hyd dia pvbfe
1600102 -90. -6.167 5.e-6 0.8132 00000
*-----
* see note with card 1400101
*-----
*card ebt press ul ug alpha
1600200 0 1.0242000e+03 5.2938000e+02 1.1099000e+03 6.2769002e-01
*
* jun (160-01) upper downcomer to middle downcomer
*-----
*card from to area kf kr fvcahs
1601101 160010000 150000000 156.536 0.00 0.00 001000
*
* junction area, kf, kr from ref. [349]
*-----
*card int liq flow int vap flow inter. vel.
1601201 -1.8235701e-04 -1.7219000e+00 0.
*
*-----
*(170) core exit (branch)
*-----
*card component name type
1700000 uplenum branch
*card num jun vel/flow
1700001 0 0
*
*card vol flow area vol length vol of vol az angle
1700101 0.0 12.739 1330.250 0.0
*card inc angle elev change roughness hyd dia pvbfe
1700102 90.0 12.739 5.e-6 0.5054 10000
*-----
* vol length, vol, elev change, hyd dia from ref. [349]
*-----
*card ebt press ul ug alpha
1700200 0 1.0315000e+03 5.4301001e+02 1.1095000e+03 5.4667002e-01
*
```

```
*-----
* (180) steam separator (branch:separator)
*-----
*card component name type
1800000 seprt separatr
*
*card num jun vel/flow
1800001 3 0
*
*card vol flow area vol length vol of vol az angle
1800101 0.0 6.167 461.676 0.0
*card inc angle elev change roughness hyd dia pvbfe
1800102 90.0 6.167 5.e-6 0.7658 00010
*-----
* vol length, vol, elev change, hyd dia from ref. [349]
*-----
*card ebt pres ul ug vapor void fraction
1800200 0 1.0251000e+03 5.4235999e+02 1.1096000e+03 6.9423002e-01
*
* jun (180-01) separator - steam dome
*-----
*card from vol to vol jun area f loss r loss fvcahs void
1801101 180010000 190000000 280.478 150. 150. 001000 0.5 * kwr
*-----
* junction area is set equal to the volume flow area of the steam dome
* kf, kr from ref. [349]
*-----
*card int liq flow int vap flow inter vel
1801201 3.4347999e-01 5.7609000e+00 0.
1802201 8.6007996e+00 8.6309996e+00 0.
1803201 1.0917000e+01 2.7964001e+01 0.
*
* jun (180-02) separator to middle downcomer
*-----
*card from vol to vol jun area f loss r loss fvcahs void
1802101 180000000 150000000 60.0000 3. 3. 001000 0.15 * kwr
*-----
* junction area from ref. [349] (50.6358) was too small and restricted
* flow to the middle downcomer, so a new value was used that would allow
* the required mass flow to the middle downcomer. kf and kr from ref.
* [349]
*-----
* jun (180-03) core exit to steam separator
```

```
*-----
*card from vol to vol jun area f loss r loss fvcahs
1803101 170010000 180000000 104.423 13.4 13.4 001000 * kwr
*-----
* junction area from ref. [349]. kf and kr: modelling assumption
* used to achieve the required flow
*-----
*
*-----
* (190) steam dome (branch)
*-----
*card component name type
1900000 stdome branch
*
*card num jun vel/flow
1900001 2 0
*1900001 3 0
*
*card vol flow area vol length vol of vol az angle
1900101 0.0 22.318 6259.714 0.0
*card inc angle elev change roughness hyd dia pvbfe
1900102 90.0 22.318 5.e-6 17.932 11000
*-----
* vol length, vol, elev change, hyd dia from the retran input deck
*-----
*card ebt press ul ug alpha
1900200 0 1.0236000e+03 5.4206000e+02 1.1097000e+03 9.9997002e-01
*
* jun (190-01) steam dome to main streamline
*-----
*card from to area kf kr fvcahs
1901101 190010000 400000000 12.6713 1.6937 1.6937 001000
*1901101 190010000 400000000 12.6713 1.2000 1.0000 001000
*-----
* junction area from retran input deck. kf and kr: modelling
* assumption used to achieve the required flow
*-----
*card int. liq flow int vap flow inter. vel
1901201 1.2182000e+02 1.2764000e+02 0.
1902201 2.6910000e+00 -2.8625701e-04 0.
*1903201 3.4839001e+00 -3.3684799e-05 0.0000000e+00
*
* jun (190-02) steam dome to upper downcomer
*-----
```

```
*card from to area kf kr fvcahs
1902101 190000000 160000000 136.0630 0.00 0.00 001000
*-----
* junction area, kf, kr from ref. [349]
*-----
*
*-----
* jet pumps and recirculation loops
*-----
* loop a
*-----
*-----
*****(200) jet pump (a) (branch:*****jetmixer)
*-----
*card component name type
2000000 jetpa jetmixer
*card num jun vel/flow
2000001 3 0
*
*card vol flow area vol length vol of vol az angle
2000101 0.0 7.0000 27.840 0.0
*card inc angle elev change roughness hyd dia pvbfe
2000102 -90.0 -7.0000 5.e-6 5.0 00000
*-----
* see calculations in appendix c for vol length, vol, elev change.
* hyd dia from ref. [349]
*-----
*card ebt press ul ug alpha
2000200 0 1.0118000e+03 5.1594000e+02 1.1101000e+03 0.
*
* jun (200-01) recirculation discharge (a) to jetpump (a)
*-----
*card from vol to vol jun area f loss r loss fvcahs
2001101 240010000 200000000 0.8226 1.1 1.100 001000
*-----
* junction area, kf and kr used to achieve required flow.
*-----
*card int liq flow int vapor flow inter vel
2001201 1.2392000e+02 1.2392000e+02 0.
2002201 6.7608002e+01 7.0873001e+01 0.
2003201 7.8358002e+01 8.2028000e+01 0.
*
* jun (200-02) middle downcomer to jet pump (a)
*-----
```

```
*card from vol to vol jun area f loss r loss fvcahs
2002101 150010000 200000000 2.7724 0.24 5.000 001000
*
*-----  
* junction area, kf and kr used to achieve required flow.
*-----  
* jun (200-03) jet pump (a) to jet pump diffuser
*-----  
*card from vol to vol jun area f loss r loss fvcahs
2003101 200010000 210000000 3.6950 0.0 0.0 001000
*
*-----  
* junction area from ref. [349], kf and kr used to achieve required flow.
*-----  
*-----  
* (210) jet pump diffuser (a)
*-----  
*card name type
2100000 diffa branch
*
*-----  
*card jun vel/flow
2100001 1 0
*-----  
*card area length volume az angle
2100101 0.0 7.1851 83.520 0.0
*-----  
*card incl angle dz rough dh pvbfe
2100102 -90.0 -7.1851 5.e-6 0.0 00000
*-----  
* see calculations in appendix c
*-----  
*-----  
*card ebt press ul ug alpha
2100200 0 1.0379000e+03 5.1594000e+02 1.1093000e+03 0.
*
*-----  
* jun (210-01) jet pump diffuser (a) to lower plenum
*-----  
*-----  
*card from to area kf kr fvcahs
2101101 210010000 100010000 19.689 0.15 0.15 001000
*
*-----  
* junction area from ref. [349]. kf and kr: modelling
*-----  
* assumption used to achieve the required pressure and flow.
*-----  
*-----  
*card init liq flow init vap flow inter vel
2101201 1.4702000e+01 1.6590000e+01 0.
*
*-----  
*-----  
* (220) recirculation suction (a)
```

```
*-----
*card component type
2200000 recira snglvol
*
*card vol flow area vol length vol of vol az angle
2200101 0.0 47.427 167.939 0.0
*card inc angle elev change roughness hyd dia pvbfe
2200102 -28.95 -41.499 5.e-6 1.0617 01000
*-----
* see calculations in appendix c.
*-----
*card ebt press ul ug alpha
2200200 0 1.0375000e+03 5.1578998e+02 1.1093000e+03 0. 0.
*
*-----
* (230) recirculation pump (a)
*-----
*card component type
2300000 pumpa pump
*
*card vol flow area vol length vol of vol az angle
2300101 0.0 28.235 76.344 0.0
*card inc angle elev change pvbfe
2300102 13.22 6.457 00000
*-----
* see calculations in appendix c.
*-----
* 
*pump junction geometry cards:
*card from vol jun area f loss cof r loss cof vcahs
2300108 220010000 0.0 1.000 1.000 00000
*card to vol jun area f loss cof r loss cof vcahs
2300109 240000000 0.0 10.00 10.00 00000
*-----
* kf and kr from ref. [349]
*-----
*pump initial condition cards:
*card ebt press ul ug alpha
2300200 0 1.1499000e+03 5.1589001e+02 1.1059000e+03 0. 0.
*card vel/flow int liquid flow int vapor flow inter
2300201 0 3.7737000e+01 3.7737000e+01 0.
2300202 0 3.9660000e+01 3.9660000e+01 0.
*
*pump index and option card
```

```
*card indic 2p 2pd motor pump torq tdp vel pump trip rev
2300301 280 -1 -3 -1 0 408 0
*
*pump description card (from ref. [1] pg 6i)
*card pump vel ratio flow head torque inertia
2300302 1.6200000e+03 9.7660494e-01 4.5200000e+04 7.6325000e+02 2.1326699e+04
2300303 1.9174500e+04
*card density motor torw w1 w2 w3 w4
2300304 47.167 0.0 1122.5 0.0 0.0 0.0
*
*-----*
* since this model has two loops the flow, torque, and inertia values
* from ref. [349] were divided in half.
*-----
* speed table
2306100 501 cntrlvar 264
2306101 0.0.
2306102 1.e4 1.e4
*
*-----
* (240) recirculation discharge (a)
*-----
*card component type
2400000 discha snglvol
*
*card vol flow area vol length vol of vol az angle
2400101 0.0 115.912 297.963 0.0
*card inc angle elev change roughness hyd dia pvbfe
2400102 29.10 56.372 5.e-6 0.949 01000
*
*-----*
* see calculations in appendix c.
*-----
*card ebt press ul ug alpha
2400200 0 1.1711000e+03 5.1591998e+02 1.1053000e+03 0.0.
*
*-----*
* !jet pumps and recirculation loops
*-----
* loop b
*-----
*-----*
* (250) jet pump (b) (branch:jet mixer)
*
```

\* see card 200 for reference.

\*

\*card component name type

2500000 jetpb jetmixer

\*card num jun vel/flow

2500001 3 0

\*

\*card vol flow area vol length vol of vol az angle

2500101 0.0 7.0000 27.840 0.0

\*card inc angle elev change roughness hyd dia pvbfe

2500102 -90.0 -7.0000 5.0e-6 5.0 00000

\*

\*card ebt press ul ug alpha

2500200 0 1.0118000e+03 5.1594000e+02 1.1101000e+03 0.

\*

\* jun (250-01) recirculation discharge (b) to jetpump (b)

\*

\*card from vol to vol jun area f loss r loss fvcahs

2501101 290010000 250000000 0.8226 1.1 1.100 001000

\*

\*card int liquid flow int vapor flow inter vel

2501201 1.2392000e+02 1.2392000e+02 0.

2502201 6.7608002e+01 7.0873001e+01 0.

2503201 7.8358002e+01 8.2028000e+01 0.

\*

\* jun (250-02) middle downcomer to jet pump (b)

\*

\*card from vol to vol jun area f loss r loss fvcahs

2502101 150010000 250000000 2.7724 0.24 5.000 001000

\*

\*

\* jun (250-03) jet pump (b) to jet pump diffuser

\*

\*card from vol to vol jun area f loss r loss fvcahs

2503101 250010000 260000000 3.695 0.0 0.0 001000

\*

\*

\* (260) jet pump diffuser (b)

\*

\* see card 210 for references.

\*

\*card name type

2600000 diffb branch

\*

---

```

*card    jun    vel/flow
2600001      1      0
* card    area    length   volume   az angle
2600101      0.0    7.1851  83.520    0.0
*card    incl angle  dz    rough    dh    pvbfe
2600102    -90.0   -7.1851  5.e-6    0.0    00000
*
*card    ebt    press   ul    ug    alpha
2600200  0 1.0379000e+03 5.1594000e+02 1.1093000e+03 0.
*
* jun (260-01) jet pump diffuser (b) to lower plenum
*-----
*card    from    to     area   kf    kr    fvcahs
2601101 260010000 100010000 19.689 0.15  0.15  001000
*
*card    init liq flow init vap flow inter vel
2601201  1.4702000e+01 1.6590000e+01 0.
*
*-----
* (270) recirculation suction (b)
*-----
* see card 220 for references.
*-----
*card    component    type
2700000    recirb    snglvol
*
*card    vol flow area    vol length   vol of vol   az angle
2700101      0.0    47.427   167.939    0.0
*card    inc angle   elev change  roughness   hyd dia  pvbfe
2700102    -28.95   -41.499   5.0e-6    1.0617  01000
*card    ebt    press   ul    ug    alpha
2700200  0 1.0375000e+03 5.1578998e+02 1.1093000e+03 0. 0.
*
*-----
* (280) recirculation pump (b) (pump)
*-----
*see card 230 for references, unless otherwise noted.
*-----
*card    component    type
2800000    pumpb    pump
*
*card    vol flow area    vol length   vol of vol   az angle
2800101      0.0    28.235   76.344    0.0
*card    inc angle   elev change  pvbfe

```

2800102 13.22 6.457 00000

\*

\*pump junction geometry cards:

\*card from vol jun area f loss cof r loss cof vcahs

2800108 270010000 0.0 1.000 1.000 00000

\*card to vol jun area f loss cof r loss cof vcahs

2800109 290000000 0.0 10.00 10.00 00000

\*

\*pump initial condition cards:

\*card ebt press ul ug alpha

2800200 0 1.1499000e+03 5.1589001e+02 1.1059000e+03 0. 0.

\*

\*card vel/flow int liquid flow int vapor flow inter vel

2800201 0 3.7737000e+01 3.7737000e+01 0.

2800202 0 3.9660000e+01 3.9660000e+01 0.

\*

\*pump index and option card

\*card indic 2p 2pd m pump torq tdp vel pump trip rev

2800301 0 -1 -3 -1 0 408 0

\*

\*pump description card

\*card pump vel ratio flow head torque iner

2800302 1.6200000e+03 9.7660494e-01 4.5200000e+04 7.6325000e+02 2.1326699e+04

2800303 1.9174500e+04

\*card density motor torw w1 w2 w3 w4

2800304 47.167 0.0 1122.5 0.0 0.0 0.0

\*

\* single phase homologous curves (from ref. [349])

\*

\* pump head curves

\*card type regime phead1 phead2 phead1 phead2

2801100 1 1 0.0 1.41 0.25 1.365

2801101 0.33 1.345 0.50 1.280

2801102 0.67 1.195 0.75 1.150

2801103 1.00 1.00

\*

2801200 1 2 0.2 -0.32 0.25 -0.290

2801201 0.33 -0.230 0.40 -0.170

2801202 0.50 -0.05 0.60 0.100

2801203 0.67 0.230 0.75 0.390

2801204 0.80 0.500 1.00 1.000

\*

2801300 1 3 -1. 1.920 -0.80 1.725

2801301 -0.67 1.625 -0.50 1.540

2801302			-0.33	1.480	-0.25	1.465
2801303			-0.01	1.420	0.00	1.410
*						
2801400	1	4	-1.00	2.24	-0.66	1.180
2801401			-0.50	0.800	-0.24	0.64
*						
2801500	1	5	0.00	0.926	0.25	0.882
2801501			0.33	0.884	0.50	0.908
2801502			0.67	0.948	0.75	0.960
2801503			1.00	1.00		
*						
2801600	1	6	0.20	-0.314	0.25	-0.250
2801601			0.33	-0.140	0.40	-0.051
2801602			0.50	0.100	0.60	0.275
2801603			0.67	0.387	0.75	0.530
2801604			0.80	0.627	1.00	1.00
*						
2801700	1	7	-1.00	-1.880	-0.67	1.450
2801701			-0.50	1.270	-0.33	1.140
2801702			-0.25	1.070	-0.01	0.930
2801703			0.00	0.926		
*						
2801800	1	8	-1.00	1.760	0.66	1.080
2801801			-0.50	0.920	-0.24	0.720
*						

\* pump torque curves

*card	type	regime	ptork1	ptork2	ptork1	ptork2
2801900	2	1	0.0	0.930	0.25	0.870
2801901			0.33	0.890	0.50	0.900
2801902			0.67	0.960	0.75	0.950
2801903			1.00	1.000		
*						
2802000	2	2	0.20	-7.84	0.25	-4.000
2802001			0.33	-1.16	0.40	-0.320
2802002			0.50	0.40	0.60	0.820
2802003			0.67	0.87	0.75	1.000
2802004			0.80	0.98	0.99	0.999
*						
2802100	2	3	-1.00	1.88	-0.67	1.450
2802101			-0.50	1.27	-0.33	1.140
2802102			-0.25	1.07	-0.01	0.930
*						
2802200	2	4	-0.99	1.760	-0.66	2.400
2802201			-0.50	3.840	-0.24	12.500

\*

2802300	2	5	0.00	-0.720	0.30	-0.600
2802301			0.42	-0.400	0.50	-0.050
2802302			0.75	0.250	1.00	0.57

\*

2802400	2	6	0.00	1.44	0.10	1.400
2802401			0.22	1.20	0.33	1.100
2802402			0.55	1.00	0.80	0.80
2802403			1.00	0.57		

\*

2802500	2	7	-1.00	-2.00	-0.30	-1.500
2802501			-0.18	-1.35	-0.07	-1.000
2802502			0.00	-0.92		

\*

2802600	2	8	-1.00	-2.00	-0.25	-1.800
2802601			-0.12	-1.50	-0.08	-1.400
2802602			0.00	-1.00		

\*

\* speed table

2806100 502 cntrlvar 265

2806101 0. 0.

2806102 1.e4 1.e4

\*

\* tmp - use simple target-core-flow controller

\*2806100 408 cntrlvar 831

\*

\* tmp - ramp pump speed from somewhere to somewhere else and hold

\*2806100 408

\*2806101 0. 1581.48 60. 982.

\*

-----

\* (290) recirculation discharge piping (b)

-----

\* see card 240 for references.

-----

\*card component type

2900000 dischb snglvol

\*card vol flow area vol length vol of vol az angle

2900101 0.00 115.912 297.963 0.0

\*card inc angle elev change roughness hyd dia pvbfe

2900102 29.10 56.372 5.0e-6 0.949 01000

\*

\*card ebt press ul ug alpha

2900200 0 1.1711000e+03 5.1591998e+02 1.1053000e+03 0. 0.

```
*  
*-----  
* hpci and rcic systems  
*-----  
*-----  
*(300) hpci and rcic supply  
*-----  
*card name type  
3000000 rcicvola tmdpvol  
*  
*card flow area length of vol vol of vol az angle  
3000101 5.0 10.0 0.0 0.0  
*card incl. angle elev change roughness hyd dia pvbfe  
3000102 90. 10.0 0.00015 1.0 00010  
*-----  
* length, vol, elev change, hyd dia values are assumed.  
*-----  
*card ebt trip no.  
3000200 001 408  
*card search variable temp quality  
3000201 0. 99.99 0.0  
*-----  
* the thermodynamic values are based on nominal pool temperature  
*-----  
*  
*-----  
*(301) hpci and rcic supply  
*-----  
*card name type  
3010000 rcicvole tmdpvol  
*  
*card flow area length of vol vol of vol az angle  
3010101 5.0 10.0 0.0 0.0  
*card incl. angle elev change roughness hyd dia pvbfe  
3010102 90. 10.0 0.00015 1.0 00010  
*-----  
* length, vol, elev change, hyd dia values are assumed.  
*-----  
*card ebt trip no.  
3010200 001 408  
*card search variable temp quality  
3010201 0. 99.99 0.0  
*-----  
* the thermodynamic values are based on nominal pool temperature
```

```
*-----
*  
*  
*-----  
*(310) hpci supply valve  
*-----  
*card    name      type  
3100000  hpcijun   tmdpjun  
*  
*card    from      to      jun area  
3100101 301000000 150000000 1.  
*card    control word table trip  
3100200 1       631  
*card    search var. liq vel/flow vap vel/flow inter. vel  
3100201 -1.      0.      0.      0.  
3100202 0.       0.      0.      0.  
3100203 20.      694.    0.      0.  
*  
*-----  
*(320) rcic supply valve  
*-----  
*card    name      type  
3200000  rcicjun   tmdpjun  
*  
*card    from      to      jun area  
3200101 300000000 150000000 1.  
*card    control word table trip  
3200200 1       637  
*card    search var. liq vel/flow vap vel/flow inter. vel  
3200201 -1.      0.      0.      0.  
3200202 0.       0.      0.      0.  
3200203 20.      82.4    0.      0.  
*  
*-----  
*(350) hpci and rcic exhaust  
*-----  
*card    name      type  
3500000  exhausta  tmdpvol  
*  
*card    flow area  length of vol  vol of vol  az angle  
3500101 5.0       10.0      0.0      0.0  
*card    incl. angle elev change roughness hyd dia pvbfe  
3500102 90.        10.0     0.00015  1.0    00010  
*-----
```

\* length, vol, elev change, hyd dia values are assumed.  
\*-----  
\*card ebt trip no.  
3500200 001 408  
\*card search variable temp quality  
3500201 0. 212.0 1.0  
\*-----  
\* the thermodynamic values are for steam at atmospheric conditions  
\*-----  
\*  
\*-----  
\*(351) hpci and rcic exhaust  
\*-----  
\*card name type  
3510000 exhaustb tmdpvol  
\*  
\*card flow area length of vol vol of vol az angle  
3510101 5.0 10.0 0.0 0.0  
\*card incl. angle elev change roughness hyd dia pvbfe  
3510102 90. 10.0 0.00015 1.0 00010  
\*-----  
\* length, vol, elev change, hyd dia values are assumed.  
\*-----  
\*card ebt trip no.  
3510200 001 408  
\*card search variable temp quality  
3510201 0. 212.0 1.0  
\*-----  
\* the thermodynamic values are for steam at atmospheric conditions  
\*-----  
\*  
\*-----  
\*(360) hpci turbine supply  
\*-----  
\*card name type  
3600000 hpciturb tmdpjun  
\*  
\*card from to jun area  
3600101 190000000 351000000 1.  
\*card control word table trip  
3600200 1 631  
\*card search var. liq vel/flow vap vel/flow inter. vel  
3600201 -1. 0. 0. 0.  
3600202 0. 0. 58.3 0.

```
*  
*-----  
*(370) rcic turbine supply  
*-----  
*card name type  
3700000 rcicturb tmdpjun  
*  
*card from to jun area  
3700101 190000000 350000000 1.  
*card control word table trip  
3700200 1 636  
*card search var. liq vel/flow vap vel/flow inter. vel  
3700201 -1. 0. 0. 0.  
3700202 0. 0. 9.17 0.  
*  
*-----  
* main steam system  
*-----  
*-----  
*(400) main steam line  
*-----  
*card component type  
4000000 steamln snglvol  
*  
*card vol flow area length vol of vol az angle  
4000101 0.0 116.770 1507.501 0.0  
*card incl angle elev change roughness hyd dia pvbfe  
4000102 33.777 64.720 5.e-6 8.108 11000  
*-----  
* see calculations in appendix c.  
*-----  
*card ebt press ul ug alpha  
4000200 0 1.0120000e+03 5.4041998e+02 1.1095000e+03 9.9992001e-01 0.  
*  
*-----  
* main steam valve double (representative of 2 msivs)  
*-----  
*  
4100000 msiv_d valve  
*  
*card from vol to vol jun area f loss r loss fvcahs  
4100101 400010000 420000000 6.4550 4.0 4.5 001020  
*-----  
* junction flow area is representative of 2 msiv's. see calculations
```

\* in appendix c. kf and kr are assumed.

\*-----

\*card flag int liq flow int vap flow inter vel  
4100201 0 1.2715000e+02 1.2715000e+02 0.

\*

\*card valve type  
4100300 mtrvlv

\*

\*card open trip close trip vel change rate init pos table  
4100301 409 666 0.25 1. 545

\* valve closes in 4 sec. -- initial position = 1.0; fully open

\*

\* table defined to give negligible form loss  
4100401 0. 1.e6 1.e6  
4100402 1. 1.e6 1.e6

\*

\*-----

\* main steam valve single 1 (representative of 1 msiv)

\*-----

\*

4110000 msiv\_s1 valve

\*

\*card from vol to vol jun area f loss r loss fvcahs  
4110101 400010000 420000000 3.227 4.10 4.5 001020

\*-----

\* junction flow area is representative of 1 msiv. see calculations

\* in appendix c. kf and kr are assumed.

\*-----

\*

\*card flag int liq flow int vap flow inter vel  
4110201 0 1.2594000e+02 1.2594000e+02 0.

\*

\*card valve type  
4110300 mtrvlv

\*

\*card open trip close trip vel change rate init pos table  
4110301 409 665 0.25 1. 545

\* valve closes in 4 sec. -- initial position = 1.0; fully open

\*

\* table defined to give negligible form loss  
4110401 0. 1.e6 1.e6  
4110402 1. 1.e6 1.e6

\*

\*-----

\* main steam valve single 2 (representative of 1 msiv)  
\*-----  
\*  
4120000 msiv\_s2 valve  
\*  
\*card from vol to vol jun area f loss r loss fvcahs  
4120101 400010000 420000000 3.227 4.10 4.5 001020  
\*-----  
\* junction flow area is representative of 1 msiv. see calculations  
\* in appendix c. kf and kr are assumed.  
\*-----  
\*  
\*card flag int liq flow int vap flow inter vel  
4120201 0 1.2594000e+02 1.2594000e+02 0.  
\*  
\*card valve type  
4120300 mtrvlv  
\*  
\*card open trip close trip vel change rate init pos table  
4120301 409 605 0.25 1. 545  
\* valve closes in 4 sec. -- initial position = 1.0; fully open  
\*  
\* table defined to give negligible form loss  
4120401 0. 1.e6 1.e6  
4120402 1. 1.e6 1.e6  
\*  
\*-----  
\* (420) main steam header to turbine -- 4 line  
\*-----  
\* name type  
4200000 turbine pipe  
\*  
\*card number of vols  
4200001 3  
\*  
\*card vol area vol number  
4200101 0.0 3  
\*  
\*card init jun flow area jun number  
4200201 10.875 2  
\*  
\*card pipe vol length vol number  
4200301 58.271 1  
4200302 35.670 2

```
4200303    12.000      3
*
*card  vol of vol    vol number
4200401    633.529      1
4200402    387.911      2
4200403    130.494      3
*
*card  az angle    vol number
4200501    0.0          3
*
*card  incl. angle  vol number
4200601    0.0          1
4200602    90.00         3
*
*card  elev change  vol number
4200701    0.0          1
4200702    35.670         2
4200703    12.000        3
*
*card  roughness   hyd dia  vol number
4200801    5.0e-6       7.442      3
*-----
* see calculations in appendix c for vol length, vol, elev change
* and hyd dia.
*-----
*card  kf       kr       jun number
4200901    2.500       2.500      1
4200902    0.000       1.710      2
*
*-----
* kf and kr values were used that would maintain the pressure in
* volume 420-03 equal to 970 psi.
*-----
*card  pvbfe    vol number
4201001    11000        3
*card  fvcahs   jun number
4201101    001020       2
*card  ebt  press  ul  ug  alpha
4201201 0 9.9373999e+02 5.3834998e+02 1.1090000e+03 9.9984998e-01 .0 1
4201202 0 9.7894000e+02 5.3546997e+02 1.1101000e+03 9.9967003e-01 .0 2
4201203 0 9.7832001e+02 5.3535999e+02 1.1103000e+03 9.9963999e-01 .0 3
*
*card  pipe vol control word
4201300 0
*card  init liq flow  init vap flow  inter vel  jun number
```

```
4201301 1.5260001e+02 1.5260001e+02 0.      1
4201302 1.5496001e+02 1.5496001e+02 0.      2
*
*
*-----
*(430) turbine control and stop valve
*-----
*card name type
4300000 tcs-valv tmddpjun
*card from to area
4300101 420010000 450000000 10.875
*-----
* area set equal to area of volume 420-03.
*-----
*card vel/flow table trip # var req num var req
4300200 0        408      cntrlvar 538
*card search var init liq vel init vap vel inter vel
4300201 -1.      152.99    152.99    0.
4300203 0.        0.        0.        0.
4300204 1.e+4    1.e+4    1.e+4    0.
*
*-----
*(440) turbine bypass valve
*-----
4400000 bypsvlv tmddpjun
4400101 420010000 451000000 0.
4400200 0 408 cntrlvar 552
*
4400201 -1. 0. 0. 0.
4400202 0. 0. 0. 0.
4400203 1.e+4 1.e+4 1.e+4 0.
*
*-----
* (450) main condenser (steam exhaust)
*-----
*card name type
4500000 condns1a tmddpvol
*card vol flow area length vol of vol az angle
4500101 1.0+6    0.0    1.0+6    0.0
*card incl angle elev change roughness hyd dia pvbfe
4500102 0.0      0.0    0.0     0.0   00010
*
*-----  
* vol flow area, vol, elev change, hyd dia are assumed.  
*-----
```

```
*card ebt trip #
4500200 003 401
*card search var press temp
4500201 0.0 916.0 544.
*-----
* thermodynamic values are assumed.
*-----
*-----
* (451) main condenser (steam exhaust)
*-----
*card name type
4510000 condns1b tmdpvol
*card vol flow area length vol of vol az angle
4510101 1.0+6 0.0 1.0+6 0.0
*card incl angle elev change roughness hyd dia pvbfe
4510102 0.0 0.0 0.0 0.0 00010
*-----
* vol flow area, vol, elev change, hyd dia are assumed.
*-----
*card ebt trip #
4510200 003 408
*card search var press temp
4510201 0.0 14.7 212.
*-----
* thermodynamic values are for steam at atmospheric conditions.
*-----
* (460) suppression pool
*-----
*card name type
4600000 spool1a tmdpvol
*card area length vol of vol az angle
4600101 1.0e+6 0.0 1.0e+6 0.0
*card incl angle elev change roughness hyd dia pvbfe
4600102 0.0 0.0 0.0 0.0 00010
*-----
* vol flow area, vol, elev change, hyd dia are assumed.
*-----
*card ebt trip #
4600200 003 408
*card search var. press temp
```

4600201 0.0 14.7 212.

\*

\* thermodynamic values are for steam at atmospheric conditions.

\*

\*

\*

\* (461) suppression pool

\*

\*card name type

4610000 spool1b tmdpvol

\*card area length vol of vol az angle

4610101 1.0e+6 0.0 1.0e+6 0.0

\*card incl angle elev change roughness hyd dia pvbfe

4610102 0.0 0.0 0.0 0.0 00010

\*

\* vol flow area, vol, elev change, hyd dia are assumed.

\*

\*card ebt trip #

4610200 003 408

\*card search var. press temp

4610201 0.0 14.7 212.

\*

\* thermodynamic values are for steam at atmospheric conditions.

\*

\*

\* s/rv valves

\*

\*

\* (470) safety relief valve #1

\*

4700000 srv1 valve

4700101 400000000 460000000 0.4300 1.0 1.0 000100

\* valve area required to achieve correct mass flow through

\* each valve. valves max flow = 950,000 lb/hr each.

\* mass flow through bank #1 should be equal to 1056 lb/s.

4700201 0 0. 0. 0.

4700300 trpvlv

4700301 656

\*

\*

\* (480) safety relief valve #2

\*

4800000 srv2 valve  
4800101 400000000 461000000 0.9800 1.0 1.0 000100  
4800201 0 0. 0. 0.  
\* valve area required to achieve correct mass flow through  
\* each valve. valves max flow = 950,000 lb/hr each.  
\* mass flow through bank #2 should be equal to 2375 lb/s.  
4800300 trpvlv  
4800301 661  
\*  
\*  
\*  
\*----- |  
\* heat structures |  
\*----- |  
\*-----  
\* (1) nuclear heat structures (core region)  
\*-----  
\*card num hs mesh pts geom type int flag left coord  
11201000 5 4 2 0 .00000e+00  
\*  
\*card loc flag format flag  
11201100 0 1  
\*  
\*card num intervals right coordinate  
11201101 1 .01708 \* uo-2 pellet  
11201102 1 .01745 \* he-gap  
11201103 1 .020117 \* zircaloy-2 clad  
\*-----  
\* coordinates from ref. [349]  
\*-----  
\*card comp num interval num  
11201201 1 1  
11201202 -2 2 \* neg sign added - kwr  
11201203 -3 3 \* neg sign added - kwr  
\*  
\*card source value interval num (ref [1] pg 18)  
11201301 1.00 1  
11201302 0.00 3  
\*  
11201400 -1  
11201401 1.8951e+03 1.1451e+03 6.1207e+02 5.6766e+02  
11201402 2.4940e+03 1.3402e+03 6.3223e+02 5.7362e+02  
11201403 2.5437e+03 1.3544e+03 6.3439e+02 5.7483e+02  
11201404 2.1243e+03 1.2240e+03 6.2057e+02 5.7044e+02

```
11201405 1.3737e+03 9.4812e+02 5.9176e+02 5.6189e+02
*
*
*
*card      temperature   mesh pt num
*-----
* initial temperatures taken from the output of the steady state
* calculation after 1000 seconds.
*-----
*
*card  left vol  incr  b.cond  sa code  area/factor  hs
11201501    0     0     0       0        0.0      5
*
*card  right vol  incr  b.cond  sa code  area/factor  hs
11201601 120010000 10000   1     0       14974.10    5
*-----
* see calculations in appendix c for area/factor.
*-----
*card      source type  mult    heat left  heat right  hs
11201701    1000    .1825    0.0      0.0      1
11201702    1000    .2424    0.0      0.0      2
11201703    1000    .2465    0.0      0.0      3
11201704    1000    .2066    0.0      0.0      4
11201705    1000    .1220    0.0      0.0      5
*-----
* see calculations in appendix c for axial mult.
*
* note -- 1000 in card 701-703 specifies total reactor power from
* the reactor kinetics calculation
*-----
*
*card      source type  mult    heat left  heat right  hs
*11201701  10099    .1825    0.0      0.0      1
*11201702  10099    .2424    0.0      0.0      2
*11201703  10099    .2465    0.0      0.0      3
*11201704  10099    .2066    0.0      0.0      4
*11201705  10099    .1220    0.0      0.0      5
*
* card  eqv dia    length hlr gslf gslr glcf glcr lbf  hs
11201801  0.0      10.0   10.0  0.0  0.0  0.0  0.0  1.0  5
11201901  0.0      10.0   10.0  0.0  0.0  0.0  0.0  0.0  1.0  5
*
*-----
* additional reactor vessel heat structures
```

```
* see calculations in appendix c
*-----
*-----
*(1001) vessel bottom head
*-----
*card num hs mesh pts geom type int flag left coord
11001000 1 2 2 0 1.04583e+01
*
*card loc flag format flag
11001100 0 1
*
*card num intervals right coordinate
11001101 1 10.9948
*
*card comp num interval num
11001201 5 1
*
*card source value interval num
11001301 0.00 1
*
11001400 -1
11001401 5.2595e+02 5.2293e+02
*
*
*card left vol incr b.cond sa code area/factor hs
11001501 100010000 0 1 1 687.23 1
*
*card right vol incr b.cond sa code area/factor hs
11001601 -100 0 3101 1 687.23 1
*
*card source type
11001701 0 0 0 0 1
*
*card qv dia length hlr gslf gslr glcf glcr lbf hs
11001801 0.0 10.0 10.0 0.0 0.0 0.0 0.0 1.0 1
11001901 0.0 10.0 10.0 0.0 0.0 0.0 0.0 0.0 1.0 1
*
*
*-----
*(1401) lower downcomer
*-----
```

\*card num hs mesh pts geom type int flag left coord  
11401000 1 2 2 0 1.04583e+01

```
*card loc flag format flag
11401100 0 1
*
*card num intervals right coordinate
11401101 1 10.9948
*
*card comp num interval num
11401201 5 1
*
*card source value interval num
11401301 0.00 1
*
11401400 -1
11401401 5.2640e+02 5.2322e+02
*
*
*card left vol incr b.cond sa code area/factor hs
11401501 140010000 0 1 1 1401.625 1
*
*card right vol incr b.cond sa code area/factor hs
11401601 -100 0 3101 1 1401.625 1
*
*card source type
11401701 0 0 0 0 1
*
* card eqv dia length hlr gslf gslr glcf glcr lbf hs
11401801 0.0 10.0 10.0 0.0 0.0 0.0 0.0 1.0 1
11401901 0.0 10.0 10.0 0.0 0.0 0.0 0.0 1.0 1
*
*-----
*(1501) middle downcomer vessel barrel
*-----
*card num hs mesh pts geom type int flag left coord
11501000 1 2 2 0 1.04583e+01
*
*card loc flag format flag
11501100 0 1
*
*card num intervals right coordinate
11501101 1 10.9948
*
*card comp num interval num
11501201 5 1
*
```

```
*card source value interval num
11501301 0.00      1
*
11501400 -1
11501401 5.2655e+02 5.2330e+02
*
*
*card left vol incr b.cond sa code area/factor hs
11501501 150010000 0   1   1     837.098  1
*
*card right vol incr b.cond sa code area/factor hs
11501601 -100    0   3101  1     837.098  1
*
*card source type
11501701 0 0 0 0 1
*
* card eqv dia length hlr gslf gslr glcf glcr lbf hs
11501801 0.0    10.0 10.0 0.0 0.0 0.0 0.0 1.0 1
11501901 0.0    10.0 10.0 0.0 0.0 0.0 0.0 1.0 1
*
*-----
* (1601) upper downcomer vessel barrel
*-----
*card num hs mesh pts geom type int flag left coord
11601000 1 2 2 0 1.04583e+01
*
*card loc flag format flag
11601100 0      1
*
*card num intervals right coordinate
11601101    1    10.9948
*
*card comp num interval num
11601201    5    1
*
*card source value interval num
11601301 0.00      1
*
11601400 -1
11601401 5.3686e+02 5.3481e+02
*
*
*card left vol incr b.cond sa code area/factor hs
11601501 160010000 0   1   1     405.242  1
```

```
*  
*card right vol incr b.cond sa code area/factor hs  
11601601 -100 0 3101 1 405.242 1  
*  
*card source type  
11601701 0 0 0 0 1  
*  
* card eqv dia length hlr gslf gslr glcf glcr lbf hs  
11601801 0.0 10.0 10.0 0.0 0.0 0.0 0.0 1.0 1  
11601901 0.0 10.0 10.0 0.0 0.0 0.0 0.0 1.0 1  
*  
*-----  
*(1901) steam dome  
*-----  
*card num hs mesh pts geom type int flag left coord  
11901000 1 2 2 0 1.04583e+01  
*  
*card loc flag format flag  
11901100 0 1  
*  
*card num intervals right coordinate  
11901101 1 10.9948  
*  
*card comp num interval num  
11901201 5 1  
*  
*card source value interval num  
11901301 0.00 1  
*  
11901400 -1  
11901401 5.4718e+02 5.4300e+02  
*  
*  
*card left vol incr b.cond sa code area/factor hs  
11901501 190010000 0 1 1 687.230 1  
*  
*card right vol incr b.cond sa code area/factor hs  
11901601 -100 0 3101 1 687.230 1  
*  
*card source type  
11901701 0 0 0 0 1  
*  
* card eqv dia length hlr gslf gslr glcf glcr lbf hs  
11901801 0.0 10.0 10.0 0.0 0.0 0.0 0.0 1.0 1
```

```
11901901 0.0    10.0 10.0 0.0 0.0 0.0 0.0 1.0 1
*
* temperature
*-----
20210000 temp
20210001 0. 135.
*-----
* from section 4.2.4.9 of the fsar (bfnp-7)
* outside air temperature
*-----
*
* heat transfer coefficient
*-----
20210100 htc-t
20210101 -1.0  5.3458e-5
20210102  0.0  5.3458e-5
20210103  1.0e6 5.3458e-5
*-----
* see calculations in app. c
* from section 4.2.4.9 of the fsar (bfnp-7)
*-----
*
*-----
* point kinetics
*-----
30000000 point separabl
*
*      total   init. delay/ f.p. u238
*      power   react. prompt yield yield
30000001 gamma 3293.e+6 0. 165.000 1. 1.
*-----
* above values are from ref. [349]
*-----
*
* scram
30000011 200
*
* rod insertion
30000012 10300 *jam steady-state
*
* density reactivity feedback
*      density reactivity
*      (lb/ft3) (dollars)
*-----
```

\* see calculations in app. c

30000501 0. -9.

30000502 47.2 0.

\* density feedback adjusted to give good power response to changes

\* in core flow

\*

\* doppler reactivity feedback

\* temperature reactivity

\* (deg f) (dollars)

30000601 500. 0.

30000602 4172. -1.6

\*

\* see calculations in app. c

\*

\* doppler feedback adjusted to give good power response to changes

\* in core flow

\*

\* volume weighting factors

\*30000701 120010000 0 .1583 0.

\*30000702 120020000 0 .2795 0.

\*30000703 120030000 0 .2887 0.

\*30000704 120040000 0 .2028 0.

\*30000705 120050000 0 .0707 0.

30000701 120020000 0 1. 0.

\*

\* heat structure weighting factors

\*30000801 1201001 0 .1583 0.

\*30000802 1201002 0 .2795 0.

\*30000803 1201003 0 .2887 0.

\*30000804 1201004 0 .2028 0.

\*30000805 1201005 0 .0707 0.

30000801 1201002 0 1. 0.

\*

\* see calculations in appendix c for vol weighting factors and

\* heat structure weighting factors.

\*

\* weighting tied to the most dynamic hydro cell and fuel segment

\* to give good power response to changes in core flow

\*

\* reactor scram curve

\*

\*card table type trip no.

20220000 reac-t 649

\*

*card	argument	function
20220001	-1.0	0.
20220002	.270	0.
20220003	.620	-0.7859
20220004	.970	-1.3479
20220005	1.337	-2.2928
20220006	1.703	-4.0022
20220007	2.070	-6.7163
20220008	2.445	-10.7728
20220009	2.820	-17.0824
20220010	3.195	-24.6860
20220011	3.570	-28.4429
20220012	3.945	-28.9308
20220013	1.0e+6	-28.9308

-----\*

\* scram curve is from fig 3.6-13 of the fsar (bfnp-7).

-----\*

\*

\*

\*

-----\*

-----\*

\* heat structure thermal property data

-----\*

-----\*

\* u0-2 fuel table (1)

-----\*

* card	material type	format flag	vol heat cap flag
20100100	tbl/fctn	1	1

\*

\* thermal conductivity data

-----\*

*card	temp	thermal cond	temp	thermal cond
20100101	500.0	9.281e-4	650.0	8.253e-4
20100102	800.0	7.436e-4	950.0	6.775e-4
20100103	1100.0	6.228e-4	1250.0	5.772e-4
20100104	1400.0	5.389e-4	1550.0	5.064e-4
20100105	1700.0	4.789e-4	1850.0	4.553e-4
20100106	2000.0	4.272e-4	2150.0	4.186e-4
20100107	2300.0	4.047e-4	2450.0	3.931e-4
20100108	2600.0	3.839e-4	3100.0	3.675e-4
20100109	3600.0	3.703e-4	4100.0	3.906e-4
20100110	4600.0	4.272e-4	5100.0	4.806e-4

20100111 1.0e+6 4.806e-4

\*

\* data from ref. [349]

\*

\*

\*volumetric heat capacity data

\*

\*card temp vol heat cap temp vol heat cap

20100151 32.0 34.45 122.0 38.35

20100152 212.0 40.95 392.0 43.55

20100153 752.0 46.80 2012.0 51.35

20100154 2732.0 52.65 3092.0 56.55

20100155 3452.0 63.05 3812.0 72.80

20100156 4352.0 89.70 4532.0 94.25

20100157 4532.1 98.15 4892.0 100.10

20100158 5144.0 101.40 1.0e+6 101.40

\*

\* data from ref. [349]

\*

\*

\*

\* he-gap table (2)

\*

\* card material type format flag vol heat cap flag

20100200 tbl/fctn 1 1

\*

\* thermal conductivity data

\*

\*card thermal cond

20100201 3.09410e-5

\*

\* data from ref. [349]

\*

\*

\*volumetric heat capacity data

\*

\*card vol heat cap

20100251 0.010

\*

\* data from ref. [349]

\*

\*

\*

```
* zircaloy table (3)
* -----
* card    material type   format flag    vol heat cap flag
20100300    tbl/fctn      1            1
*
* thermal conductivity data
* -----
*card    temp    thermal cond    temp    thermal cond
20100301    32.0    2.170e-3    212.0   2.220e-3
20100302    392.0   2.280e-3    572.0   2.440e-3
20100303    752.0   2.650e-3    932.0   2.889e-3
20100304   1112.0   3.119e-3   1292.0   3.469e-3
20100305   1472.0   3.661e-3   1652.0   3.881e-3
20100306   1832.0   4.111e-3   2012.0   4.481e-3
20100307   2192.0   4.939e-3   2372.0   5.461e-3
20100308   2552.0   6.050e-3   2732.0   6.681e-3
20100309   3092.0   8.031e-3   3360.0   9.200e-3
20100310   1.0e+6   9.200e-3
*
* -----
* data from ref. [349]
* -----
*
* volumetric heat capacity data
* -----
*card    temp    vol heat cap    temp    vol heat cap
20100351    0.0     28.39    1480.3   34.48
20100352  1675.0    85.18    1787.5   34.48
20100353  1.0e+6    34.48
*
* -----
* data from ref. [349]
* -----
*
* steel table (5)
* -----
* card    material type   format flag    vol heat cap flag
20100500    tbl/fctn      1            1
*
* thermal conductivity data
* -----
*card    temp    thermal cond    temp    thermal cond
20100501    0.0    2.500e-3    200.0   2.500e-3
20100502  1600.0   4.167e-3   1.0e+6   4.167e-3
*
* -----
* data from ref. [349]
```

```
*-----
*
*volumetric heat capacity data
*-----
*card      temp   vol heat cap      temp   vol heat cap
20100551  200.0   60.00          2200.0  80.00
20100552  1.0e+6   80.00
*-----
* data from ref. [349]
*-----
*
*
*****
* table for normal valve area vs. stem position
*****  

*  

* the following table gives valve flow area vs stem position  

* valve area = ( stem position )**3.  

*  

20254500    normarea
20254501    .0      .0
20254502    .16675   .059
20254503    .3334    .089
20254504    .43339   .098
20254505    .5       .457
20254506    .583375  .667
20254507    .6666    .819
20254508    .79435   1.
20254509    1.      1.
*  

*  

*-----
* feedwater train
*-----
*  

* feedwater train hydro components
*-----
*  

*** condensate supply (at the base of the condensers) ***
* press. and temp. per refs. [368] and [188], respectively
*  

*  

5000000 condensr tmdpvol
5000101 0. 100. 1.e6 0. 0. 0.
5000102 0. 0. 0.0010
```

5000200 003

5000201 0. 0.9824 101.1

\*

\*\*\* piping from condensers to condensate pumps \*\*\*

\* 3 36" dia. sch. 40 pipes 100' long are represented here. see app. d

\* for reasoning elev. change per ref. [285 & 368].

\*

**5020000** cnd\_pmp branch

**5020001** 1 0

**5020101** 19.4754 100. 0. 0. -5.3 -9.20 0.00015 2.8750 01000

**5020200** 0 2.8822999e+00 6.9094002e+01 1.0562000e+03 0.

**5021101** 500000000 502000000 0. 0. 0. 001000

**5021201** 3.0864000e+00 3.0864000e+00 0.

\*

\*\*\* condensate pump (single) \*\*\*

\* geometry and performance from ref. [90] as per calculations of app. d.

\*

**5050000** cndpmp\_s pump

**5050101** 0. 50.2 277. 0. 0. 0. 00000

**5050108** **502010000** 7.069 0. 0. 001000

**5050109** **508000000** 3.142 262. 1.e99 001000

**5050200** 0 7.2176003e+01 6.9154999e+01 1.1005000e+03 0. 0.

**5050201** 0 2.8364000e+00 2.8364000e+00 0.

**5050202** 0 6.3801999e+00 6.3801999e+00 0.

**5050301** 0 -1 -3 -1 0 460 0

**5050302** 1.1700000e+03 1.0000000e+00 1.0830000e+04 2.8400000e+02

\* need correct inertia

**5050303** 3983. 1355. 62.4 0.

**5050304** 0. 0. 0. 0.

\* han

**5051100** 1 1

**5051101** 0. 1.276421

**5051102** 0.05 1.270980

**5051103** 0.1 1.262995

**5051104** 0.15 1.253315

**5051105** 0.2 1.242654

**5051106** 0.25 1.231591

**5051107** 0.3 1.220570

**5051108** 0.35 1.209902

**5051109** 0.4 1.199759

**5051110** 0.45 1.190182

**5051111** 0.5 1.181074

**5051112** 0.55 1.172205

**5051113** 0.6 1.163208

**5051114** 0.65 1.153582

**5051115** 0.7 1.142693

**5051116** 0.75 1.129767

**5051117** 0.8 1.113900

**5051118** 0.85 1.094051

**5051119** 0.9 1.069043

**5051120** 0.95 1.037564

**5051121** 1. 1.

\* hvn

**5051200** 1 2

**5051201** 0.52 0. \*jam

**5051202** 0.75 0.434464

**5051203** 0.775 0.489052

**5051204** 0.8 0.541027

**5051205** 0.825 0.592472

**5051206** 0.85 0.644935

**5051207** 0.875 0.699426

**5051208** 0.9 0.756421

**5051209** 0.925 0.815858

**5051210** 0.95 0.877137

**5051211** 0.975 0.939126

**5051212** 1. 1.

\* had and hvd (incomplete but sufficient - only normal modes of pump

\* operation are of concern)

**5051300** 1 3 0. 1.276421

**5051400** 1 4 0. 1.276421

\* ban

**5051500** 2 1

**5051501** 0. 0.658983

**5051502** 0.05 0.657930

**5051503** 0.1 0.660392

**5051504** 0.15 0.666062

**5051505** 0.2 0.674639

**5051506** 0.25 0.685835

**5051507** 0.3 0.699368

**5051508** 0.35 0.714969

**5051509** 0.4 0.732377

**5051510** 0.45 0.751340

**5051511** 0.5 0.771615

**5051512** 0.55 0.792970

**5051513** 0.6 0.815183

**5051514** 0.65 0.838039

**5051515** 0.7 0.861334

**5051516** 0.75 0.884874

**5051517** 0.8 0.908474  
**5051518** 0.85 0.931959  
**5051519** 0.9 0.955161  
**5051520** 0.95 0.977925  
**5051521** 1. 1.  
\* bvn  
**5051600** 2 2  
**5051601** 0.35 0. \* extrapolated value  
**5051602** 0.75 0.617190  
**5051603** 0.775 0.659431  
**5051604** 0.8 0.697266  
**5051605** 0.825 0.733179  
**5051606** 0.85 0.768990  
**5051607** 0.875 0.805856  
**5051608** 0.9 0.844273  
**5051609** 0.925 0.884074  
**5051610** 0.95 0.924429  
**5051611** 0.975 0.963845  
**5051612** 1. 1.  
\* bad and bvd (incomplete but sufficient - only normal modes of pump  
\* operation are of concern)  
**5051700** 2 3 0. 0.658983  
**5051800** 2 4 0. 0.658983  
\*  
\* velocity table  
**5056100** 506  
**5056101** 0. 1170.  
\*  
\*\*\* condensate pump (double) \*\*\*  
\* geometry and performance from ref. [90] as per calculations of app. d.  
\*  
**5060000** cndpmp\_d pump  
**5060101** 0. 50.2 554. 0. 0. 0. 0.00000  
**5060108** 502010000 14.138 0. 0. 001000  
**5060109** 508000000 6.284 262. 1.e99 001000  
**5060200** 0 7.2193001e+01 6.9154999e+01 1.1005000e+03 0. 0.  
**5060201** 0 2.8334000e+00 2.8334000e+00 0.  
**5060202** 0 6.3734002e+00 6.3734002e+00 0.  
**5060301** 505 -1 -3 -1 0 461 0  
**5060302** 1.1700000e+03 1.0000000e+00 2.1660000e+04 2.8400000e+02  
**5060303** 7966. 2710. 62.4 0.  
**5060304** 0. 0. 0. 0.  
\*  
\* velocity table

**5066100** 507

**5066101** 0. 1170.

\*

\*\*\* piping from condensate pumps to condensate booster pumps \*\*\*

\* 3 18" dia. sch. 40 pipes 100' long are represented here. see app. d

\* for explanation. elev. change per ref. [285 & 327].

\*

**5080000** pmp\_pmp branch

**5080001** 0 0

**5080101** 4.6599 100. 0. 0. 3.3 5.75 0.00015 1.4063 01000

**5080200** 0 6.5344002e+01 6.9155998e+01 1.0992000e+03 0.

\*

\*\*\* condensate booster pump (single) \*\*\*

\* pump performance from "turbine cycle performance monitoring instruction

\* unit 2", 2-ti-266 rev. 0004 as per calculations of app. d.

\*

**5100000** bstpmp\_s pump

\* need true length/volume

**5100101** 1.5533 0. 20. 0. 0. 0. 00000

**5100108** **508010000** 1.5533 0. 0. 001000

**5100109** **515000000** 1.5533 0. 1.e99 001000

**5100200** 0 1.8571001e+02 6.9267998e+01 1.1128000e+03 0. 0.

**5100201** 0 1.2955000e+01 1.2955000e+01 0.

**5100202** 0 1.2951000e+01 1.2951000e+01 0.

**5100301** 0 -1 -3 -1 0 465 0

\* need true inertia

**5100302** 1.7800000e+03 1.0000000e+00 1.0800000e+04 5.3500000e+02 4.8920000e+03

**5100303** 9.0000000e+02 6.2099998e+01

**5100304** 0. 0. 0. 0. 0.

\* han

**5101100** 1 1

**5101101** 0. 1.192908

**5101102** 0.05 1.186873

**5101103** 0.1 1.181114

**5101104** 0.15 1.175519

**5101105** 0.2 1.169975

**5101106** 0.25 1.164371

**5101107** 0.3 1.158596

**5101108** 0.35 1.152542

**5101109** 0.4 1.146100

**5101110** 0.45 1.139163

**5101111** 0.5 1.131625

**5101112** 0.55 1.123380

**5101113** 0.6 1.114325

**5101114** 0.65 1.104356

**5101115** 0.7 1.093370

**5101116** 0.75 1.081268

**5101117** 0.8 1.067948

**5101118** 0.85 1.053312

**5101119** 0.9 1.037261

**5101120** 0.95 1.019698

**5101121** 1. 1.

\* hvn

**5101200** 1 2

**5101201** 0.60 0. \*jam

**5101202** 0.75 0.432022

**5101203** 0.775 0.496009

**5101204** 0.8 0.555960

**5101205** 0.825 0.612788

**5101206** 0.85 0.667405

**5101207** 0.875 0.720723

**5101208** 0.9 0.773656

**5101209** 0.925 0.827115

**5101210** 0.95 0.882014

**5101211** 0.975 0.939264

**5101212** 1. 1.

\* had and hvd (incomplete but sufficient - only normal modes of pump

\* operation are of concern)

**5101300** 1 3 0. 1.192908

**5101400** 1 4 0. 1.192908

\* ban

**5101500** 2 1

**5101501** 0. 0.557646

**5101502** 0.05 0.572111

**5101503** 0.1 0.586739

**5101504** 0.15 0.601668

**5101505** 0.2 0.617028

**5101506** 0.25 0.632941

**5101507** 0.3 0.649524

**5101508** 0.35 0.666885

**5101509** 0.4 0.685126

**5101510** 0.45 0.704341

**5101511** 0.5 0.724618

**5101512** 0.55 0.746038

**5101513** 0.6 0.768675

**5101514** 0.65 0.792593

**5101515** 0.7 0.817854

**5101516** 0.75 0.844509

**5101517** 0.8 0.872603  
**5101518** 0.85 0.902176  
**5101519** 0.9 0.933257  
**5101520** 0.95 0.965871  
**5101521** 1. 1.  
\* bvn  
**5101600** 2 2  
**5101601** 0.05 0. \*jam  
**5101602** 0.85 0.833692  
**5101603** 0.875 0.858738  
**5101604** 0.9 0.883908  
**5101605** 0.925 0.909902  
**5101606** 0.95 0.937417  
**5101607** 0.975 0.967152  
**5101608** 1. 1.  
\* bad and bvd (incomplete but sufficient - only normal modes of pump  
\* operation are of concern)  
**5101700** 2 3 0. 0.557646  
**5101800** 2 4 0. 0.557646  
\*  
\* velocity table  
**5106100** 508  
**5106101** 0. 1780.  
\*  
\*\*\* condensate booster pump (double) \*\*\*  
\* pump performance from "turbine cycle performance monitoring instruction  
\* unit 2", 2-ti-266 rev. 0004 as per calculations of app. d.  
\*  
**5110000** bstpmp\_d pump  
\* need true length/volume  
**5110101** 3.1066 0. 40. 0. 0. 0. 0.00000  
**5110108** 508010000 3.1066 0. 0. 0.001000  
**5110109** 515000000 3.1066 0. 1.e99 001000  
**5110200** 0 1.8573000e+02 6.9268997e+01 1.1128000e+03 0. 0.  
**5110201** 0 1.2868000e+01 1.2868000e+01 0.  
**5110202** 0 1.2864000e+01 1.2864000e+01 0.  
**5110301** 510 -1 -3 -1 0 466 0  
\* need true inertia  
**5110302** 1.7800000e+03 1.0000000e+00 2.1600000e+04 5.3500000e+02 9.7840000e+03  
**5110303** 1.8000000e+03 6.2099998e+01  
**5110304** 0. 0. 0. 0. 0.  
\*  
\* velocity table  
**5116100** 509

**5116101** 0. 1780.

\*

\*\*\* piping from condensate booster pumps to drain coolers \*\*\*

\* 3 18" dia. sch. 40 pipes 100' long are represented here. see app. d

\* for explanation. elev. change per ref. [327].

\*

**5150000** pmp\_dc branch

**5150001** 3 0

**5150101** 4.6599 100. 0. 0. 0.3 30. 0.00015 1.4063 01000

**5150200** 0 3.0087000e+02 6.9269997e+01 1.1172000e+03 0.

**5151101** **515010000** 520000000 0. 0. 0. 001000

**5152101** **515010000** 521000000 0. 0. 0. 001000

**5153101** **515010000** 522000000 0. 0. 0. 001000

**5151201** 5.5050998e+00 5.5050998e+00 0.

**5152201** 5.5050998e+00 5.5050998e+00 0.

**5153201** 5.5050998e+00 5.5050998e+00 0.

\*

\*\*\* drain cooler A \*\*\*

\* geometry per vendor spec shts. included with app. d

**5200000** 'drcool-A' snglvol

**5200101** 3.65 92. 0. 0. 0.

**5200102** 0. 5.e-6 0.0567 01000

**5200200** 0 2.9114999e+02 9.8335999e+01 1.1170000e+03 0. 0.

\*

\*\*\* drain cooler B \*\*\*

\* geometry per vendor spec shts. included with app. d

**5210000** 'drcool-B' snglvol

**5210101** 3.65 92. 0. 0. 0.

**5210102** 0. 5.e-6 0.0567 01000

**5210200** 0 2.9114999e+02 9.8335999e+01 1.1170000e+03 0. 0.

\*

\*\*\* drain cooler C \*\*\*

\* geometry per vendor spec shts. included with app. d

**5220000** 'drcool-C' snglvol

**5220101** 3.65 92. 0. 0. 0.

**5220102** 0. 5.e-6 0.0567 01000

**5220200** 0 2.9114999e+02 9.8335999e+01 1.1170000e+03 0. 0.

\*

\*\*\* piping from drain cooler A to heater A5 \*\*\*

\* geometry per refs. [324, 326, 327, & 328]

**5250000** 'DC-HTRA5' pipe

**5250001** 1

**5250101** 1.5533 1

**5250301** 14. 1

5250401 0. 1  
5250501 0. 1  
5250601 42.7 1  
5250701 9.5 1  
5250801 0.00015 1.4063 1  
5251001 01000 1  
5251201 0 2.8410001e+02 9.8336998e+01 1.1168000e+03 0. .0 1  
\*  
\*\*\* piping from drain cooler B to heater B5 \*\*\*  
\* geometry per refs. [324, 326, 327, & 328]  
5260000 'DC-HTRB5' pipe  
5260001 1  
5260101 1.5533 1  
5260301 14. 1  
5260401 0. 1  
5260501 0. 1  
5260601 42.7 1  
5260701 9.5 1  
5260801 0.00015 1.4063 1  
5261001 01000 1  
5261201 0 2.8410001e+02 9.8336998e+01 1.1168000e+03 0. .0 1  
\*  
\*\*\* piping from drain cooler C to heater C5 \*\*\*  
\* geometry per refs. [324, 326, 327, & 328]  
5270000 'DC-HTRC5' pipe  
5270001 1  
5270101 1.5533 1  
5270301 14. 1  
5270401 0. 1  
5270501 0. 1  
5270601 42.7 1  
5270701 9.5 1  
5270801 0.00015 1.4063 1  
5271001 01000 1  
5271201 0 2.8410001e+02 9.8336998e+01 1.1168000e+03 0. .0 1  
\*  
\*  
\* component 530 - RFW Heater A5 Tubes  
5300000 'HTRA5-p' pipe  
\*  
\* nv  
5300001 8  
\*  
\* varea vn

5300101 3.0778 8 \*1832 tubes, 5/8" OD, .035" wall, 20BWG  
\*  
\* jarea jn  
5300201 3.0778 7  
\*  
\* vlength vn  
5300301 9.7917 8 \* total tube length = (2)(39' 2")  
\*  
\* volume vn  
5300401 0.0 8  
\*  
\* incl vn  
5300601 0.0 8  
\*  
\* roughness dhyd vn  
5300801 1.5e-4 0.0462 8  
\*  
\* kf kr jn  
5300901 0.0 0.0 7  
\*  
\* pvbfe vn  
5301001 00000 8  
\*  
\* fvcahs jn  
5301101 001000 7  
\*  
\* ebt press. temp. vn  
5301201 3 281.31 147.046 0. 0. 0. 1  
5301202 3 279.96 160.125 0. 0. 0. 2  
5301203 3 278.61 169.237 0. 0. 0. 3  
5301204 3 277.26 174.520 0. 0. 0. 4  
5301205 3 275.92 180.835 0. 0. 0. 5  
5301206 3 274.57 184.710 0. 0. 0. 6  
5301207 3 273.22 186.605 0. 0. 0. 7  
5301208 3 271.87 187.884 0. 0. 0. 8  
\*  
\* vel/flow  
5301300 0  
\*  
\* liq-flo vap-flo int jn  
5301301 6.5111 6.5111 0. 1  
5301302 6.5184 6.5184 0. 2  
5301303 6.5268 6.5268 0. 3  
5301304 6.5343 6.5343 0. 4  
5301305 6.5723 6.5723 0. 5

5301306 6.5960 6.5960 0. 6  
5301307 6.6071 6.6071 0. 7  
\*  
\*  
\* component 531 - RFW Heater B5 Tubes  
5310000 'HTRB5-p' pipe  
\*  
\* nv  
5310001 8  
\*  
\* varea vn  
5310101 3.0778 8 \*1832 tubes, 5/8" OD, .035" wall, 20BWG  
\*  
\* jarea jn  
5310201 3.0778 7  
\*  
\* vlength vn  
5310301 9.7917 8 \* total tube length = (2)(39' 2")  
\*  
\* volume vn  
5310401 0.0 8  
\*  
\* incl vn  
5310601 0.0 8  
\*  
\* roughness dhyd vn  
5310801 1.5e-4 0.0462 8  
\*  
\* kf kr jn  
5310901 0.0 0.0 7  
\*  
\* pvbfe vn  
5311001 00000 8  
\*  
\* fvcahs jn  
5311101 001000 7  
\*  
\* ebt press. temp. vn  
5311201 3 281.31 147.046 0. 0. 0. 1  
5311202 3 279.96 160.125 0. 0. 0. 2  
5311203 3 278.61 169.237 0. 0. 0. 3  
5311204 3 277.26 174.520 0. 0. 0. 4  
5311205 3 275.92 180.835 0. 0. 0. 5  
5311206 3 274.57 184.710 0. 0. 0. 6  
5311207 3 273.22 186.605 0. 0. 0. 7

5311208 3 271.87 187.884 0. 0. 0. 8  
\*  
\* vel/flow  
5311300 0  
\*  
\* liq-flo vap-flo int jn  
5311301 6.5111 6.5111 0. 1  
5311302 6.5184 6.5184 0. 2  
5311303 6.5268 6.5268 0. 3  
5311304 6.5343 6.5343 0. 4  
5311305 6.5723 6.5723 0. 5  
5311306 6.5960 6.5960 0. 6  
5311307 6.6071 6.6071 0. 7  
\*  
\*  
\* component 532 - RFW Heater C5 Tubes  
5320000 'HTRC5-p' pipe  
\*  
\* nv  
5320001 8  
\*  
\* varea vn  
5320101 3.0778 8 \*1832 tubes, 5/8" OD, .035" wall, 20BWG  
\*  
\* jarea jn  
5320201 3.0778 7  
\*  
\* vlength vn  
5320301 9.7917 8 \* total tube length = (2)(39' 2")  
\*  
\* volume vn  
5320401 0.0 8  
\*  
\* incl vn  
5320601 0.0 8  
\*  
\* roughness dhyd vn  
5320801 1.5e-4 0.0462 8  
\*  
\* kf kr jn  
5320901 0.0 0.0 7  
\*  
\* pvbfe vn  
5321001 00000 8  
\*

```
* fvcahs jn
5321101 001000    7
*
* ebt press. temp.          vn
5321201 3 281.31 147.046 0.  0.  0.  1
5321202 3 279.96 160.125 0.  0.  0.  2
5321203 3 278.61 169.237 0.  0.  0.  3
5321204 3 277.26 174.520 0.  0.  0.  4
5321205 3 275.92 180.835 0.  0.  0.  5
5321206 3 274.57 184.710 0.  0.  0.  6
5321207 3 273.22 186.605 0.  0.  0.  7
5321208 3 271.87 187.884 0.  0.  0.  8
*
* vel/flow
5321300 0
*
* liq-flo    vap-flo    int   jn
5321301 6.5111    6.5111      0.   1
5321302 6.5184    6.5184      0.   2
5321303 6.5268    6.5268      0.   3
5321304 6.5343    6.5343      0.   4
5321305 6.5723    6.5723      0.   5
5321306 6.5960    6.5960      0.   6
5321307 6.6071    6.6071      0.   7
*
*** piping from heater A5 to heater A4 ***
* geometry per refs. [324, 326, 327, & 328]
5350000 'htrA5_4'    pipe
5350001 1
5350101 1.5533 1
5350301 21. 1
5350401 0. 1
5350501 0. 1
5350601 0. 1
5350701 0. 1
5350801 0.00015 1.4063 1
5351001 01000 1
5351201 0 2.7210001e+02 1.5058000e+02 1.1165000e+03 0. .0 1
*
*** piping from heater B5 to heater B4 ***
* geometry per refs. [324, 326, 327, & 328]
5360000 'htrB5_4'    pipe
5360001 1
5360101 1.5533 1
```

5360301 21. 1  
5360401 0. 1  
5360501 0. 1  
5360601 0. 1  
5360701 0. 1  
5360801 0.00015 1.4063 1  
5361001 01000 1  
5361201 0 2.7210001e+02 1.5058000e+02 1.1165000e+03 0. .0 1  
\*  
\*\*\* piping from heater C5 to heater C4 \*\*\*  
\* geometry per refs. [324, 326, 327, & 328]  
5370000 'htrC5\_4' pipe  
5370001 1  
5370101 1.5533 1  
5370301 21. 1  
5370401 0. 1  
5370501 0. 1  
5370601 0. 1  
5370701 0. 1  
5370801 0.00015 1.4063 1  
5371001 01000 1  
5371201 0 2.7210001e+02 1.5058000e+02 1.1165000e+03 0. .0 1  
\*  
\*  
\* component 540 - RFW Heater A4 Tubes  
\*  
5400000 'HTRA4-p' pipe  
\*  
\* nv  
5400001 10  
\*  
\* varea vn  
5400101 2.9736 10 \*1770 tubes, 5/8" OD, .035" wall, 20BWG  
\*  
\* jarea jn  
5400201 2.9736 9  
\*  
\* vlengt hn  
5400301 7.8333 10 \* total tube length = (2)(39' 2")  
\*  
\* volume vn  
5400401 0.0 10  
\*  
\* incl vn  
5400601 0.0 10

\*

\* roughness dhyd vn  
5400801 1.5e-4 0.0462 10

\*

\* kf kr jn  
5400901 0.0 0.0 9

\*

\* pvbfe vn  
5401001 00000 10

\*

\* fvcahs jn  
5401101 001000 9

\*

\* ebt press. temp. vn  
5401201 3 273.96 189.940 0. 0. 0. 1  
5401202 3 272.49 195.815 0. 0. 0. 2  
5401203 3 271.03 212.726 0. 0. 0. 3  
5401204 3 269.56 224.282 0. 0. 0. 4  
5401205 3 268.09 231.955 0. 0. 0. 5  
5401206 3 266.61 237.355 0. 0. 0. 6  
5401207 3 265.13 240.458 0. 0. 0. 7  
5401208 3 263.66 242.113 0. 0. 0. 8  
5401209 3 262.18 242.934 0. 0. 0. 9  
5401210 3 260.70 243.473 0. 0. 0. 10

\*

\* vel/flow  
5401300 1

\*

\* liq-flo vap-flo int jn  
5401301 1232.9 0.0 0. 9

\*

\*

\* component 541 - RFW Heater B4 Tubes

\*

5410000 'HTRB4-p' pipe

\*

\* nv  
5410001 10

\*

\* varea vn  
5410101 2.9736 10 \*1770 tubes, 5/8" OD, .035" wall, 20BWG

\*

\* jarea jn  
5410201 2.9736 9

\*

```
*      vlength    vn
5410301 7.8333     10    * total tube length = (2)(39' 2")
*
*      volume     vn
5410401 0.0       10
*
*      incl       vn
5410601 0.0       10
*
*      roughness   dhyd  vn
5410801 1.5e-4     0.0462 10
*
*      kf   kr   jn
5410901 0.0   0.0   9
*
*      pvbfe      vn
5411001 00000     10
*
*      fvcahs     jn
5411101 001000    9
*
*      ebt press. temp.          vn
5411201 3   273.96 189.940 0.  0.  0.  1
5411202 3   272.49 195.815 0.  0.  0.  2
5411203 3   271.03 212.726 0.  0.  0.  3
5411204 3   269.56 224.282 0.  0.  0.  4
5411205 3   268.09 231.955 0.  0.  0.  5
5411206 3   266.61 237.355 0.  0.  0.  6
5411207 3   265.13 240.458 0.  0.  0.  7
5411208 3   263.66 242.113 0.  0.  0.  8
5411209 3   262.18 242.934 0.  0.  0.  9
5411210 3   260.70 243.473 0.  0.  0.  10
*
*      vel/flow
5411300 1
*
*      liq-flo    vap-flo    int   jn
5411301 1232.9     0.0       0.   9
*
*
* component 542 - RFW Heater C4 Tubes
*
5420000 'HTRC4-p'    pipe
*
*      nv
```

5420001 10  
\*  
\* varea vn  
5420101 2.9736 10 \*1770 tubes, 5/8" OD, .035" wall, 20BWG  
\*  
\* jarea jn  
5420201 2.9736 9  
\*  
\* vlength vn  
5420301 7.8333 10 \* total tube length = (2)(39' 2")  
\*  
\* volume vn  
5420401 0.0 10  
\*  
\* incl vn  
5420601 0.0 10  
\*  
\* roughness dhyd vn  
5420801 1.5e-4 0.0462 10  
\*  
\* kf kr jn  
5420901 0.0 0.0 9  
\*  
\* pvbfe vn  
5421001 00000 10  
\*  
\* fvcahs jn  
5421101 001000 9  
\*  
\* ebt press. temp. vn  
5421201 3 273.96 189.940 0. 0. 0. 1  
5421202 3 272.49 195.815 0. 0. 0. 2  
5421203 3 271.03 212.726 0. 0. 0. 3  
5421204 3 269.56 224.282 0. 0. 0. 4  
5421205 3 268.09 231.955 0. 0. 0. 5  
5421206 3 266.61 237.355 0. 0. 0. 6  
5421207 3 265.13 240.458 0. 0. 0. 7  
5421208 3 263.66 242.113 0. 0. 0. 8  
5421209 3 262.18 242.934 0. 0. 0. 9  
5421210 3 260.70 243.473 0. 0. 0. 10  
\*  
\* vel/flow  
5421300 1  
\*  
\* liq-flo vap-flo int jn

5421301 1232.9      0.0      0.      9  
\*  
\*  
\*\*\* piping from heater A4 to heater A3 \*\*\*  
\* geometry per refs. [324, 326, 327, & 328]  
5450000 'htrA4\_3'    pipe  
5450001 1  
5450101 1.5533 1  
5450301 116. 1  
5450401 0. 1  
5450501 0. 1  
5450601 -3.6 1  
5450701 -7.25 1  
5450801 0.00015 1.4063 1  
5451001 01000 1  
5451201 0 2.6126001e+02 2.0678999e+02 1.1162000e+03 0. .0 1  
\*  
\*\*\* piping from heater B4 to heater B3 \*\*\*  
\* geometry per refs. [324, 326, 327, & 328]  
5460000 'htrB4\_3'    pipe  
5460001 1  
5460101 1.5533 1  
5460301 116. 1  
5460401 0. 1  
5460501 0. 1  
5460601 -3.6 1  
5460701 -7.25 1  
5460801 0.00015 1.4063 1  
5461001 01000 1  
5461201 0 2.6126001e+02 2.0678999e+02 1.1162000e+03 0. .0 1  
\*  
\*\*\* piping from heater C4 to heater C3 \*\*\*  
\* geometry per refs. [324, 326, 327, & 328]  
5470000 'htrC4\_3'    pipe  
5470001 1  
5470101 1.5533 1  
5470301 116. 1  
5470401 0. 1  
5470501 0. 1  
5470601 -3.6 1  
5470701 -7.25 1  
5470801 0.00015 1.4063 1  
5471001 01000 1  
5471201 0 2.6126001e+02 2.0678999e+02 1.1162000e+03 0. .0 1

```
*  
*  
* component 550 - RFW Heater A3 Tubes  
5500000 'HTRA3-p' pipe  
*  
* nv  
5500001 12  
*  
* varea vn  
5500101 3.1315 12 *1864 tubes, 5/8" OD, .035" wall, 20BWG  
*  
* jarea jn  
5500201 3.1315 11  
*  
* vlengt hn vn  
5500301 7.0534 1 *  
5500302 7.0534 2 *  
5500303 3.0000 3 *volume center = lower level tap  
5500304 3.0000 4 *volume center = upper level tap  
5500305 11.1133 5 *remaining 35.5' total tube length  
5500306 11.1133 6 *remaining 35.5' total tube length  
5500307 11.1133 7 *remaining 35.5' total tube length  
5500308 11.1133 8 *remaining 35.5' total tube length  
5500309 3.0000 9 *volume center = lower level tap  
5500310 3.0000 10 *volume center = upper level tap  
5500311 7.0534 11 *  
5500312 7.0534 12 *  
*  
* volume vn  
5500401 0.0 12  
*  
* incl vn  
5500601 90.0 6  
5500602 -90.0 12  
*  
* roughness dhyd vn  
5500801 1.5e-4 0.0462 12  
*  
* kf kr jn  
5500901 0.0 0.0 11  
*  
* pvbfe vn  
5501001 00000 12  
*  
* fvcahs jn
```

5501101 001000 11  
\*  
\* ebt press. temp. vn  
5501201 3 259.34 244.415 0. 0. 0. 1  
5501202 3 255.25 246.066 0. 0. 0. 2  
5501203 3 252.33 247.155 0. 0. 0. 3  
5501204 3 250.59 254.653 0. 0. 0. 4  
5501205 3 246.53 272.296 0. 0. 0. 5  
5501206 3 240.14 283.712 0. 0. 0. 6  
5501207 3 238.21 291.042 0. 0. 0. 7  
5501208 3 240.73 295.669 0. 0. 0. 8  
5501209 3 242.32 296.721 0. 0. 0. 9  
5501210 3 242.99 297.405 0. 0. 0. 10  
5501211 3 244.12 297.600 0. 0. 0. 11  
5501212 3 245.70 297.363 0. 0. 0. 12  
\*  
\* vel/flow  
5501300 1  
\*  
\* liq-flo vap-flo int jn  
5501301 1232.9 0.0 0. 11  
\*  
\*  
\* component 551 - RFW Heater B3 Tubes  
5510000 'HTRB3-p' pipe  
\*  
\* nv  
5510001 12  
\*  
\* varea vn  
5510101 3.1315 12 \*1864 tubes, 5/8" OD, .035" wall, 20BWG  
\*  
\* jarea jn  
5510201 3.1315 11  
\*  
\* vlength vn  
5510301 7.0534 1 \*  
5510302 7.0534 2 \*  
5510303 3.0000 3 \*volume center = lower level tap  
5510304 3.0000 4 \*volume center = upper level tap  
5510305 11.1133 5 \*remaining 35.5' total tube length  
5510306 11.1133 6 \*remaining 35.5' total tube length  
5510307 11.1133 7 \*remaining 35.5' total tube length  
5510308 11.1133 8 \*remaining 35.5' total tube length  
5510309 3.0000 9 \*volume center = lower level tap

5510310 3.0000 10 \*volume center = upper level tap  
5510311 7.0534 11 \*  
5510312 7.0534 12 \*  
\*  
\* volume vn  
5510401 0.0 12  
\*  
\* incl vn  
5510601 90.0 6  
5510602 -90.0 12  
\*  
\* roughness dhyd vn  
5510801 1.5e-4 0.0462 12  
\*  
\* kf kr jn  
5510901 0.0 0.0 11  
\*  
\* pvbfe vn  
5511001 00000 12  
\*  
\* fvcahs jn  
5511101 001000 11  
\*  
\* ebt press. temp. vn  
5511201 3 259.34 244.415 0. 0. 0. 1  
5511202 3 255.25 246.066 0. 0. 0. 2  
5511203 3 252.33 247.155 0. 0. 0. 3  
5511204 3 250.59 254.653 0. 0. 0. 4  
5511205 3 246.53 272.296 0. 0. 0. 5  
5511206 3 240.14 283.712 0. 0. 0. 6  
5511207 3 238.21 291.042 0. 0. 0. 7  
5511208 3 240.73 295.669 0. 0. 0. 8  
5511209 3 242.32 296.721 0. 0. 0. 9  
5511210 3 242.99 297.405 0. 0. 0. 10  
5511211 3 244.12 297.600 0. 0. 0. 11  
5511212 3 245.70 297.363 0. 0. 0. 12  
\*  
\* vel/flow  
5511300 1  
\*  
\* liq-flo vap-flo int jn  
5511301 1232.9 0.0 0. 11  
\*  
\*  
\* component 552 - RFW Heater C3 Tubes

5520000 'HTRC3-p' pipe  
\*  
\* nv  
5520001 12  
\*  
\* varea vn  
5520101 3.1315 12 \*1864 tubes, 5/8" OD, .035" wall, 20BWG  
\*  
\* jarea jn  
5520201 3.1315 11  
\*  
\* vlength vn  
5520301 7.0534 1 \*  
5520302 7.0534 2 \*  
5520303 3.0000 3 \*volume center = lower level tap  
5520304 3.0000 4 \*volume center = upper level tap  
5520305 11.1133 5 \*remaining 35.5' total tube length  
5520306 11.1133 6 \*remaining 35.5' total tube length  
5520307 11.1133 7 \*remaining 35.5' total tube length  
5520308 11.1133 8 \*remaining 35.5' total tube length  
5520309 3.0000 9 \*volume center = lower level tap  
5520310 3.0000 10 \*volume center = upper level tap  
5520311 7.0534 11 \*  
5520312 7.0534 12 \*  
\*  
\* volume vn  
5520401 0.0 12  
\*  
\* incl vn  
5520601 90.0 6  
5520602 -90.0 12  
\*  
\* roughness dhyd vn  
5520801 1.5e-4 0.0462 12  
\*  
\* kf kr jn  
5520901 0.0 0.0 11  
\*  
\* pvbfe vn  
5521001 00000 12  
\*  
\* fvcahs jn  
5521101 001000 11  
\*  
\* ebt press. temp. vn

5521201 3 259.34 244.415 0. 0. 0. 1  
5521202 3 255.25 246.066 0. 0. 0. 2  
5521203 3 252.33 247.155 0. 0. 0. 3  
5521204 3 250.59 254.653 0. 0. 0. 4  
5521205 3 246.53 272.296 0. 0. 0. 5  
5521206 3 240.14 283.712 0. 0. 0. 6  
5521207 3 238.21 291.042 0. 0. 0. 7  
5521208 3 240.73 295.669 0. 0. 0. 8  
5521209 3 242.32 296.721 0. 0. 0. 9  
5521210 3 242.99 297.405 0. 0. 0. 10  
5521211 3 244.12 297.600 0. 0. 0. 11  
5521212 3 245.70 297.363 0. 0. 0. 12

\*

\* vel/flow

5521300 1

\*

\* liq-flo vap-flo int jn

5521301 1232.9 0.0 0. 11

\*

\*

\*\*\* piping from heaters 3 to feed pumps \*\*\*

\* geometry per refs. [216, 324, 326, 327, 328]

5550000 htr3\_pmp branch

5550001 4 0

5550101 4.6599 12. 0. 0. 0. 0. 0.00015 1.4063 01000

5550200 0 2.5089999e+02 2.6672000e+02 1.1158000e+03 0.

5551101 550010000 555000000 0. 0. 0. 0.001000

5552101 551010000 555000000 0. 0. 0. 0.001000

5553101 552010000 555000000 0. 0. 0. 0.001000

5554101 555010000 557000000 0.3491 7.301 7.417 001000

5551201 6.9323001e+00 6.9323001e+00 0.

5552201 6.9323001e+00 6.9323001e+00 0.

5553201 6.9323001e+00 6.9323001e+00 0.

5554201 6.0248899e-06 6.0249299e-06 0.

\*

\* feedwater bypass valve inlet

5570000 bypinlet snglvol

5570101 0.3491 40. 0. 0. 20.55 14.04 .00015 0. 01000

5570200 0 2.4930000e+02 2.6673999e+02 1.1158000e+03 0. 0.

\*

\* feedwater bypass valve

5580000 bypvalve valve

5580101 557010000 559000000 0.3491 4.76 9.99e+99 000100

5580201 0 0. 0. 0.

**5580300** srvv1v

**5580301** 611

\*

\* feedwater bypass valve outlet

**5590000** bypotlet snglvol

**5590101** 0.3491 40. 0. 0. 20.55 14.04 .00015 0. 01000

**5590200** 0 1.0997000e+03 2.6729001e+02 1.1074000e+03 0. 0.

\*

\*\*\* feed pump (a) inlet volume

**5600000** apmpin branch

**5600001** 1 0

**5600101** 1.5533 67. 0. 0. 24.78 28.08 0.00015 1.4063 01000

**5600200** 0 2.4492000e+02 2.6673001e+02 1.1156000e+03 0.

**5601101** 555010000 **560000000** 1.5533 0. 0. 001000

**5601201** 1.3924000e+01 1.3924000e+01 0.

\*

\*\*\* feed pump (b) inlet volume

**5610000** bpmpin branch

**5610001** 1 0

**5610101** 1.5533 67. 0. 0. 24.78 28.08 0.00015 1.4063 01000

**5610200** 0 2.4492000e+02 2.6673001e+02 1.1156000e+03 0.

**5611101** 555010000 **561000000** 1.5533 0. 0. 001000

**5611201** 1.3923000e+01 1.3923000e+01 0.

\*

\*\*\* feed pump (c) inlet volume

**5620000** cpmpin branch

**5620001** 1 0

**5620101** 1.5533 67. 0. 0. 24.78 28.08 0.00015 1.4063 01000

**5620200** 0 2.4492000e+02 2.6673001e+02 1.1156000e+03 0.

**5621101** 555010000 **562000000** 1.5533 0. 0. 001000

**5621201** 1.3923000e+01 1.3923000e+01 0.

\*

\*\*\* reactor feed pump (a) \*\*\*

\* performance from ref. [bfm-vtd-p025-0050] as per calcs. of app. d.

**5700000** fdpmp\_a pump

\* need true volume

**5700101** 1.5533 0. 30. 0. 0. 0. 00000

**5700108** 560010000 1.5533 0. 0. 001000

**5700109** 575000000 1.5533 4. 0. 001000

**5700200** 0 6.7017999e+02 2.6726001e+02 1.1173000e+03 0. 0.

**5700201** 0 1.3924000e+01 1.3924000e+01 0.

**5700202** 0 1.3907000e+01 1.3907000e+01 0.

**5700301** 0 -1 -3 -1 0 408 0

**5700302** 5.5000000e+03 8.7630910e-01 1.1200000e+04 2.8000000e+03

**5700303** 8279. 4239. 57.2 0.

**5700304** 0. 0. 0. 0.

\* han

**5701100** 1 1

**5701101** 0. 1.197067

**5701102** 0.05 1.184067

**5701103** 0.1 1.173948

**5701104** 0.15 1.166099

**5701105** 0.2 1.159951

**5701106** 0.25 1.154979

**5701107** 0.3 1.150703

**5701108** 0.35 1.146687

**5701109** 0.4 1.142538

**5701110** 0.45 1.137910

**5701111** 0.5 1.132499

**5701112** 0.55 1.126046

**5701113** 0.6 1.118334

**5701114** 0.65 1.109195

**5701115** 0.7 1.098501

**5701116** 0.75 1.086169

**5701117** 0.8 1.072161

**5701118** 0.85 1.056483

**5701119** 0.9 1.039186

**5701120** 0.95 1.020363

**5701121** 1. 1.

\* hvn

**5701200** 1 2

**5701201** 0.618 0. \* extrapolated value

**5701202** 0.725 0.384958

**5701203** 0.75 0.447154

**5701204** 0.775 0.504118

**5701205** 0.8 0.557846

**5701206** 0.825 0.609998

**5701207** 0.85 0.661900

**5701208** 0.875 0.714540

**5701209** 0.9 0.768575

**5701210** 0.925 0.824324

**5701211** 0.95 0.881772

**5701212** 0.975 0.940568

**5701213** 1. 1.

\* had and hvd (incomplete but sufficient - only normal modes of pump

\* operation are of concern)

**5701300** 1 3 0. 1.197067

**5701400** 1 4 0. 0.7 \* jam

\* ban

**5701500** 2 1

**5701501** 0. 0.482838  
**5701502** 0.05 0.500041  
**5701503** 0.1 0.520557  
**5701504** 0.15 0.543522  
**5701505** 0.2 0.568180  
**5701506** 0.25 0.593886  
**5701507** 0.3 0.620100  
**5701508** 0.35 0.646396  
**5701509** 0.4 0.672452  
**5701510** 0.45 0.698057  
**5701511** 0.5 0.723108  
**5701512** 0.55 0.747612  
**5701513** 0.6 0.771684  
**5701514** 0.65 0.795547  
**5701515** 0.7 0.819534  
**5701516** 0.75 0.844086  
**5701517** 0.8 0.869753  
**5701518** 0.85 0.897194  
**5701519** 0.9 0.927177  
**5701520** 0.95 0.960578  
**5701521** 1. 1.

\* bvn

**5701600** 2 2

**5701601** 0.27 0. \*jam  
**5701602** 0.725 0.579497  
**5701603** 0.75 0.613313  
**5701604** 0.775 0.646402  
**5701605** 0.8 0.679301  
**5701606** 0.825 0.712545  
**5701607** 0.85 0.746670  
**5701608** 0.875 0.782212  
**5701609** 0.9 0.819708  
**5701610** 0.925 0.859692  
**5701611** 0.95 0.902700  
**5701612** 0.975 0.949269  
**5701613** 1. 1.

\* bad and bvd (incomplete but sufficient - only normal modes of pump

\* operation are of concern)

**5701700** 2 3 0. 0.482838

**5701800** 2 4 0. 0.8 \* jam

\*

\* velocity table

**5706100** 408 cntrlvar 756

**5706101** 0. 0. 10000. 10000.

\*

\*\*\* reactor feed pump (b) \*\*\*

\* performance from ref. [bfm-vtd-p025-0050] as per calcs. of app. d.

**5710000** fdmpump\_b pump

\* need true volume

**5710101** 1.5533 0. 30. 0. 0. 0. 00000

**5710108** 561010000 1.5533 0. 0. 001000

**5710109** 576000000 1.5533 4. 0. 001000

**5710200** 0 6.7017999e+02 2.6726001e+02 1.1173000e+03 0. 0.

**5710201** 0 1.3923000e+01 1.3923000e+01 0.

**5710202** 0 1.3906000e+01 1.3906000e+01 0.

**5710301** 570 -1 -3 -1 0 408 0

**5710302** 5.5000000e+03 8.7630910e-01 1.1200000e+04 2.8000000e+03

**5710303** 8279. 4239. 57.2 0.

**5710304** 0. 0. 0. 0.

\*

\* velocity table

**5716100** 408 cntrlvar 757

**5716101** 0. 0. 10000. 10000.

\*

\*\*\* reactor feed pump (c) \*\*\*

\* performance from ref. [bfm-vtd-p025-0050] as per calcs. of app. d.

**5720000** fdmpump\_c pump

\* need true flow area and length

**5720101** 1.5533 0. 30. 0. 0. 0. 00000

**5720108** 562010000 1.5533 0. 0. 001000

**5720109** 577000000 1.5533 4. 0. 001000

**5720200** 0 6.7017999e+02 2.6726001e+02 1.1173000e+03 0. 0.

**5720201** 0 1.3923000e+01 1.3923000e+01 0.

**5720202** 0 1.3906000e+01 1.3906000e+01 0.

**5720301** 570 -1 -3 -1 0 408 0

**5720302** 5.5000000e+03 8.7630910e-01 1.1200000e+04 2.8000000e+03

\* moment of inertia per Bill Babb, GE

**5720303** 8279. 4239. 57.2 0.

**5720304** 0. 0. 0. 0.

\*

\* velocity table

**5726100** 408 cntrlvar 758

**5726101** 0. 0. 10000. 10000.

\*

\*\*\* feed pump (a) outlet volume (with check valve function) \*\*\*

\* large loss coef. in reverse direction serves check valve function

**5750000** apmpout branch

**5750001** 1 0

**5750101** 1.5533 5. 0. 0. 0. 0.00015 1.4063 01000

**5750200** 0 1.0966000e+03 2.6726999e+02 1.1075000e+03 0.

**5751101** **575010000** **588000000** 1.5533 0. 1.e99 001000

**5751201** 1.3886000e+01 1.3886000e+01 0.

\*

\*\*\* feed pump (b) outlet volume (with check valve function) \*\*\*

\* large loss coef. in reverse direction serves check valve function

**5760000** bpmpout branch

**5760001** 1 0

**5760101** 1.5533 5. 0. 0. 0. 0.00015 1.4063 01000

**5760200** 0 1.0966000e+03 2.6726999e+02 1.1075000e+03 0.

**5761101** **576010000** **588000000** 1.5533 0. 1.e99 001000

**5761201** 1.3885000e+01 1.3885000e+01 0.

\*

\*\*\* feed pump (c) outlet volume (with check valve function) \*\*\*

\* large loss coef. in reverse direction serves check valve function

**5770000** cpmpout branch

**5770001** 1 0

**5770101** 1.5533 5. 0. 0. 0. 0.00015 1.4063 01000

**5770200** 0 1.0966000e+03 2.6726999e+02 1.1075000e+03 0.

**5771101** **577010000** **588000000** 1.5533 0. 1.e99 001000

**5771201** 1.3885000e+01 1.3885000e+01 0.

\*

\*\*\* min. recirc. valve (a) \*\*\*

\* this is a trip type valve with choked flow logic enabled, and

\* abrupt area change logic invoked. the area of this valve is

\* best defined as the area of the orifice placed in min. recirc.

\* piping. this area has been estimated from consideration of

\* ref. [178]. it corresponds to a diameter of 2".

**5800000** recirc\_a valve

**5800101** **575010000** **581000000** 0.0014 6.4764 6.4764 000100

**5800201** 0 0. 0. 0.

**5800300** mtrvlv \*jam

**5800301** 475 478 1. 0. \*jam

\*

\*\*\* min. recirc. (a) sink \*\*\*

\* fluid conditions of condensers (see comp. 500)

**5810000** sink\_a tmdpvol

**5810101** 0. 100. 1.e6 0. 0. 0.

**5810102** 0. 0. 0.00010

**5810200** 003

**5810201** 0. 0.9824 101.1

\*

\*\*\* min. recirc. valve (b) \*\*\*

\* (see note of component 580)

**5820000** recirc\_b valve

**5820101** 576010000 583000000 0.0014 6.4764 6.4764 000100

**5820201** 0 0. 0. 0.

**5820300** mtrvlv \*jam

**5820301** 476 479 1. 0. \*jam

\*

\*\*\* min. recirc. (b) sink \*\*\*

\* fluid conditions of condensers (see comp. 500)

**5830000** sink\_b tmdpvol

**5830101** 0. 100. 1.e6 0. 0. 0.

**5830102** 0. 0. 00010

**5830200** 003

**5830201** 0. 0.9824 101.1

\*

\*\*\* min. recirc. valve (c) \*\*\*

\* (see note of component 580)

**5840000** recirc\_c valve

**5840101** 577010000 585000000 0.0014 6.4764 6.4764 000100

**5840201** 0 0. 0. 0.

**5840300** mtrvlv \*jam

**5840301** 477 480 1. 0. \*jam

\*

\*

\*\*\* min. recirc. (c) sink \*\*\*

\* fluid conditions of condensers (see comp. 500)

**5850000** sink\_c tmdpvol

**5850101** 0. 100. 1.e6 0. 0. 0.

**5850102** 0. 0. 00010

**5850200** 003

**5850201** 0. 0.9824 101.1

\*

\*\*\* piping from feed pumps to heaters 2 \*\*\*

\* geometry per ref. [216]

\*

**5880000** pmp\_htr2 branch

**5880001** 4 0

**5880101** 4.6599 220.14 0. 0. -7.2 -27.75 0.00015 1.4063 01000

**5880200** 0 1.1017000e+03 2.6726999e+02 1.1074000e+03 0.

**5881101** 588010000 590000000 0. 0. 0. 001000

**5882101** 588010000 591000000 0. 0. 0. 001000

**5883101** 588010000 592000000 0. 0. 0. 001000

5884101 559010000 588000000 0.3491 8.229 1.e+99 001000  
5881201 7.5832000e+00 7.5832000e+00 0.  
5882201 7.5832000e+00 7.5832000e+00 0.  
5883201 7.5832000e+00 7.5832000e+00 0.  
5884201 0. 0. 0.  
\*  
\*  
\* component 590 - RFW Heater A2 Tubes  
5900000 'HTRA2-p' pipe  
\*  
\* nv  
5900001 10  
\*  
\* varea vn  
5900101 2.8872 10 \*1906 tubes, 5/8" OD, .049" wall, 18BWG  
\*  
\* jarea jn  
5900201 2.8872 9  
\*  
\* vlength vn  
5900301 5.4974 1 \*  
5900302 3.0000 2 \*volume center = lower level tap  
5900303 3.0000 3 \*volume center = upper level tap  
5900304 8.8763 7 \*remaining 35.5' total tube length  
5900305 3.0000 8 \*volume center = lower level tap  
5900306 3.0000 9 \*volume center = upper level tap  
5900307 5.4974 10 \*  
\*  
\* volume vn  
5900401 0.0 10  
\*  
\* incl vn  
5900601 90.0 5  
5900602 -90.0 10  
\*  
\* roughness dhyd vn  
5900801 1.5e-4 0.0439 10 \*.527" ID  
\*  
\* kf kr jn  
5900901 0.0 0.0 9  
\*  
\* pvbfe vn  
5901001 00000 10  
\*

```
* fvcahs jn
5901101 001000 9
*
* ebt press. temp. vn
5901201 3 1110.0 301.969 0. 0. 0. 1
5901202 3 1107.4 303.527 0. 0. 0. 2
5901203 3 1105.5 309.131 0. 0. 0. 3
5901204 3 1101.9 319.624 0. 0. 0. 4
5901205 3 1096.4 325.800 0. 0. 0. 5
5901206 3 1094.5 329.305 0. 0. 0. 6
5901207 3 1096.0 331.281 0. 0. 0. 7
5901208 3 1097.0 331.801 0. 0. 0. 8
5901209 3 1097.5 331.601 0. 0. 0. 9
5901210 3 1098.3 330.416 0. 0. 0. 10
*
* vel/flow
5901300 1
*
* liq-flo vap-flo int jn
5901301 1232.9 0.0 0. 9
*
*
* component 591 - RFW Heater B2 Tubes
5910000 'HTRB2-p' pipe
*
* nv
5910001 10
*
* varea vn
5910101 2.8872 10 *1906 tubes, 5/8" OD, .049" wall, 18BWG
*
* jarea jn
5910201 2.8872 9
*
* vlengt hn
5910301 5.4974 1 *
5910302 3.0000 2 *volume center = lower level tap
5910303 3.0000 3 *volume center = upper level tap
5910304 8.8763 7 *remaining 35.5' total tube length
5910305 3.0000 8 *volume center = lower level tap
5910306 3.0000 9 *volume center = upper level tap
5910307 5.4974 10 *
*
* volume vn
5910401 0.0 10
```

\*  
\* incl vn  
5910601 90.0 5  
5910602 -90.0 10  
\*  
\* roughness dhyd vn  
5910801 1.5e-4 0.0439 10 \*.527" ID  
\*  
\* kf kr jn  
5910901 0.0 0.0 9  
\*  
\* pvbfe vn  
5911001 00000 10  
\*  
\* fvcahs jn  
5911101 001000 9  
\*  
\* ebt press. temp. vn  
5911201 3 1110.0 301.969 0. 0. 0. 1  
5911202 3 1107.4 303.527 0. 0. 0. 2  
5911203 3 1105.5 309.131 0. 0. 0. 3  
5911204 3 1101.9 319.624 0. 0. 0. 4  
5911205 3 1096.4 325.800 0. 0. 0. 5  
5911206 3 1094.5 329.305 0. 0. 0. 6  
5911207 3 1096.0 331.281 0. 0. 0. 7  
5911208 3 1097.0 331.801 0. 0. 0. 8  
5911209 3 1097.5 331.601 0. 0. 0. 9  
5911210 3 1098.3 330.416 0. 0. 0. 10  
\*  
\* vel/flow  
5911300 1  
\*  
\* liq-flo vap-flo int jn  
5911301 1232.9 0.0 0. 9  
\*  
\*  
\* component 592 - RFW Heater C2 Tubes  
\*  
5920000 'HTRC2-p' pipe  
\*  
\* nv  
5920001 10  
\*  
\* varea vn  
5920101 2.8872 10 \*1906 tubes, 5/8" OD, .049" wall, 18BWG

\*  
\* jarea jn  
5920201 2.8872 9  
\*  
\* vlength vn  
5920301 5.4974 1 \*  
5920302 3.0000 2 \*volume center = lower level tap  
5920303 3.0000 3 \*volume center = upper level tap  
5920304 8.8763 7 \*remaining 35.5' total tube length  
5920305 3.0000 8 \*volume center = lower level tap  
5920306 3.0000 9 \*volume center = upper level tap  
5920307 5.4974 10 \*  
\*  
\* volume vn  
5920401 0.0 10  
\*  
\* incl vn  
5920601 90.0 5  
5920602 -90.0 10  
\*  
\* roughness dhyd vn  
5920801 1.5e-4 0.0439 10 \*.527" ID  
\*  
\* kf kr jn  
5920901 0.0 0.0 9  
\*  
\* pvbfe vn  
5921001 00000 10  
\*  
\* fvcahs jn  
5921101 001000 9  
\*  
\* ebt press. temp. vn  
5921201 3 1110.0 301.969 0. 0. 0. 1  
5921202 3 1107.4 303.527 0. 0. 0. 2  
5921203 3 1105.5 309.131 0. 0. 0. 3  
5921204 3 1101.9 319.624 0. 0. 0. 4  
5921205 3 1096.4 325.800 0. 0. 0. 5  
5921206 3 1094.5 329.305 0. 0. 0. 6  
5921207 3 1096.0 331.281 0. 0. 0. 7  
5921208 3 1097.0 331.801 0. 0. 0. 8  
5921209 3 1097.5 331.601 0. 0. 0. 9  
5921210 3 1098.3 330.416 0. 0. 0. 10  
\*  
\* vel/flow

**5921300 1**

\*

\* liq-flo vap-flo int jn  
5921301 1232.9 0.0 0. 9

\*

\*

\*\*\* piping from heater A2 to heater A1 \*\*\*

\* geometry per ref. [215 & 216]

**5950000 'htrA2\_1' pipe**

**5950001 1**

**5950101 1.755 1**

**5950301 2. 1**

**5950401 0. 1**

**5950501 0. 1**

**5950601 0. 1**

**5950701 0. 1**

**5950801 0.00015 1.4948 1**

**5951001 01000 1**

**5951201 0 1.0973000e+03 2.9884000e+02 1.1075000e+03 0. .0 1**

\*

\*\*\* piping from heater B2 to heater B1 \*\*\*

\* geometry per ref. [215 & 216]

**5960000 'htrB2\_1' pipe**

**5960001 1**

**5960101 1.755 1**

**5960301 2. 1**

**5960401 0. 1**

**5960501 0. 1**

**5960601 0. 1**

**5960701 0. 1**

**5960801 0.00015 1.4948 1**

**5961001 01000 1**

**5961201 0 1.0973000e+03 2.9884000e+02 1.1075000e+03 0. .0 1**

\*

\*\*\* piping from heater C2 to heater C1 \*\*\*

\* geometry per ref. [215 & 216]

**5970000 'htrC2\_1' pipe**

**5970001 1**

**5970101 1.755 1**

**5970301 2. 1**

**5970401 0. 1**

**5970501 0. 1**

**5970601 0. 1**

**5970701 0. 1**

5970801 0.00015 1.4948 1  
5971001 01000 1  
5971201 0 1.0973000e+03 2.9884000e+02 1.1075000e+03 0. .0 1  
\*  
\*  
\* component 600 - RFW Heater A1 Tubes  
6000000 'HTRA1-p' pipe  
\*  
\* nv  
6000001 10  
\*  
\* varea vn  
6000101 2.8872 10 \*1906 tubes, 5/8" OD, .049" wall, 18BWG  
\*  
\* jarea jn  
6000201 2.8872 9  
\*  
\* vlength vn  
6000301 1.3307 1 \*  
6000302 2.6667 2 \*volume center = lower level tap  
6000303 2.6667 3 \*volume center = upper level tap  
6000304 10.4596 7 \*remaining 41.8' total tube length  
6000305 2.6667 8 \*volume center = lower level tap  
6000306 2.6667 9 \*volume center = upper level tap  
6000307 1.3307 10 \*  
\*  
\* volume vn  
6000401 0.0 10  
\*  
\* incl vn  
6000601 90.0 5  
6000602 -90.0 10  
\*  
\* roughness dhyd vn  
6000801 1.0e-7 0.0439 10 \*.527" ID  
\*  
\* kf kr jn  
6000901 0.0 0.0 9  
\*  
\* pvbfe vn  
6001001 00000 10  
\*  
\* fvcahs jn  
6001101 001000 9  
\*

```
*      ebt press. temp.          vn
6001201 3  1089.5 331.600 0.  0.  0.  1
6001202 3  1088.5 335.810 0.  0.  0.  2
6001203 3  1087.1 340.290 0.  0.  0.  3
6001204 3  1083.6 352.648 0.  0.  0.  4
6001205 3  1078.1 362.143 0.  0.  0.  5
6001206 3  1076.6 368.635 0.  0.  0.  6
6001207 3  1079.1 372.725 0.  0.  0.  7
6001208 3  1080.7 373.688 0.  0.  0.  8
6001209 3  1081.4 373.683 0.  0.  0.  9
6001210 3  1081.9 373.013 0.  0.  0.  10
*
*      vel/flow
6001300 1
*
*      liq-flo    vap-flo    int   jn
6001301 1232.9     0.0       0.   9
*
*
* component 601 - RFW Heater B1 Tubes
6010000 'HTRB1-p' pipe
*
*      nv
6010001 10
*
*      varea      vn
6010101 2.8872     10    *1906 tubes, 5/8" OD, .049" wall, 18BWG
*
*      jarea      jn
6010201 2.8872     9
*
*      vlengt    vn
6010301 1.3307     1    *
6010302 2.6667     2    *volume center = lower level tap
6010303 2.6667     3    *volume center = upper level tap
6010304 10.4596    7    *remaining 41.8' total tube length
6010305 2.6667     8    *volume center = lower level tap
6010306 2.6667     9    *volume center = upper level tap
6010307 1.3307    10    *
*
*      volume      vn
6010401 0.0        10
*
*      incl       vn
6010601 90.0       5
```

```
6010602 -90.0      10
*
*      roughness   dhyd  vn
6010801 1.0e-7     0.0439 10    *.527" ID
*
*      kf   kr   jn
6010901 0.0   0.0   9
*
*      pvbfe     vn
6011001 00000      10
*
*      fvcahs     jn
6011101 001000      9
*
*      ebt press. temp.          vn
6011201 3   1089.5 331.600 0.  0.  0.  1
6011202 3   1088.5 335.815 0.  0.  0.  2
6011203 3   1087.1 340.290 0.  0.  0.  3
6011204 3   1083.6 352.648 0.  0.  0.  4
6011205 3   1078.1 362.143 0.  0.  0.  5
6011206 3   1076.6 368.635 0.  0.  0.  6
6011207 3   1079.1 372.725 0.  0.  0.  7
6011208 3   1080.7 373.688 0.  0.  0.  8
6011209 3   1081.4 373.683 0.  0.  0.  9
6011210 3   1081.9 373.013 0.  0.  0.  10
*
*      vel/flow
6011300 1
*
*      liq-flo     vap-flo     int   jn
6011301 1232.9     0.0       0.   9
*
*
* component 602 - RFW Heater C1 Tubes
6020000 'HTRC1-p'   pipe
*
*      nv
6020001 10
*
*      varea     vn
6020101 2.8872     10    *1906 tubes, 5/8" OD, .049" wall, 18BWG
*
*      jarea     jn
6020201 2.8872     9
*
```

```
*      vlength    vn
6020301 1.3307    1    *
6020302 2.6667    2    *volume center = lower level tap
6020303 2.6667    3    *volume center = upper level tap
6020304 10.4596   7    *remaining 41.8' total tube length
6020305 2.6667    8    *volume center = lower level tap
6020306 2.6667    9    *volume center = upper level tap
6020307 1.3307   10    *
*
*      volume    vn
6020401 0.0       10
*
*      incl     vn
6020601 90.0      5
6020602 -90.0     10
*
*      roughness  dhyd  vn
6020801 1.0e-7    0.0439 10  *.527" ID
*
*      kf  kr  jn
6020901 0.0  0.0  9
*
*      pvbfe     vn
6021001 00000     10
*
*      fvcahs    jn
6021101 001000    9
*
*      ebt press. temp.          vn
6021201 3  1089.5 331.600 0.  0.  0.  1
6021202 3  1088.5 335.815 0.  0.  0.  2
6021203 3  1087.1 340.290 0.  0.  0.  3
6021204 3  1083.6 352.648 0.  0.  0.  4
6021205 3  1078.1 362.143 0.  0.  0.  5
6021206 3  1076.6 368.635 0.  0.  0.  6
6021207 3  1079.1 372.725 0.  0.  0.  7
6021208 3  1080.7 373.688 0.  0.  0.  8
6021209 3  1081.4 373.683 0.  0.  0.  9
6021210 3  1081.9 373.013 0.  0.  0.  10
*
*      vel/flow
6021300 1
*
*      liq-flo    vap-flo    int   jn
6021301 1232.9    0.0      0.    9
```

\*

\*

\*\*\* piping from heaters 1 to reactor \*\*\*

\* geometry per ref. [215]

**6050000 htr1\_rx branch**

**6050001 4 0**

**6050101 5.0724 255.58 0. 0. 6.1 27.21 0.00015 1.7970 01000**

**6050200 0 1.0818000e+03 3.4728000e+02 1.1080000e+03 0.**

**6051101 600010000 605000000 0. 0. 0. 001000**

**6052101 601010000 605000000 0. 0. 0. 001000**

**6053101 602010000 605000000 0. 0. 0. 001000**

**6054101 605010000 150000000 5.0724 49. 0. 001000**

\* / \

\* loss coef. specified to effect the flow losses attributable to  
\* the feedwater sparger - see calc. of app. d.

\*

**6051201 7.9503999e+00 7.9503999e+00 0.**

**6052201 7.9503999e+00 7.9503999e+00 0.**

**6053201 7.9503999e+00 7.9503999e+00 0.**

**6054201 1.3383000e+01 1.3383000e+01 0.**

\*

\*\*\* miscellaneous junctures \*\*\*

\* no flow losses or area restrictions

**6100000 misc\_jun mtpljun**

**6100001 24 1**

\*

*	from	to	juna	kf	kr	fvcahs	incr1	incr2	jn	
<b>6100011</b>	<b>520010000</b>	<b>525000000</b>	<b>0.</b>	<b>0.</b>	<b>0.</b>	<b>001000</b>	<b>1.</b>	<b>1.</b>	<b>0</b>	<b>0 1</b>
<b>6100021</b>	<b>521010000</b>	<b>526000000</b>	<b>0.</b>	<b>0.</b>	<b>0.</b>	<b>001000</b>	<b>1.</b>	<b>1.</b>	<b>0</b>	<b>0 2</b>
<b>6100031</b>	<b>522010000</b>	<b>527000000</b>	<b>0.</b>	<b>0.</b>	<b>0.</b>	<b>001000</b>	<b>1.</b>	<b>1.</b>	<b>0</b>	<b>0 3</b>
<b>6100041</b>	<b>525010000</b>	<b>530000000</b>	<b>0.</b>	<b>0.</b>	<b>0.</b>	<b>001000</b>	<b>1.</b>	<b>1.</b>	<b>0</b>	<b>0 4</b>
<b>6100051</b>	<b>526010000</b>	<b>531000000</b>	<b>0.</b>	<b>0.</b>	<b>0.</b>	<b>001000</b>	<b>1.</b>	<b>1.</b>	<b>0</b>	<b>0 5</b>
<b>6100061</b>	<b>527010000</b>	<b>532000000</b>	<b>0.</b>	<b>0.</b>	<b>0.</b>	<b>001000</b>	<b>1.</b>	<b>1.</b>	<b>0</b>	<b>0 6</b>
<b>6100071</b>	<b>530010000</b>	<b>535000000</b>	<b>0.</b>	<b>0.</b>	<b>0.</b>	<b>001000</b>	<b>1.</b>	<b>1.</b>	<b>0</b>	<b>0 7</b>
<b>6100081</b>	<b>531010000</b>	<b>536000000</b>	<b>0.</b>	<b>0.</b>	<b>0.</b>	<b>001000</b>	<b>1.</b>	<b>1.</b>	<b>0</b>	<b>0 8</b>
<b>6100091</b>	<b>532010000</b>	<b>537000000</b>	<b>0.</b>	<b>0.</b>	<b>0.</b>	<b>001000</b>	<b>1.</b>	<b>1.</b>	<b>0</b>	<b>0 9</b>
<b>6100101</b>	<b>535010000</b>	<b>540000000</b>	<b>0.</b>	<b>0.</b>	<b>0.</b>	<b>001000</b>	<b>1.</b>	<b>1.</b>	<b>0</b>	<b>0 10</b>
<b>6100111</b>	<b>536010000</b>	<b>541000000</b>	<b>0.</b>	<b>0.</b>	<b>0.</b>	<b>001000</b>	<b>1.</b>	<b>1.</b>	<b>0</b>	<b>0 11</b>
<b>6100121</b>	<b>537010000</b>	<b>542000000</b>	<b>0.</b>	<b>0.</b>	<b>0.</b>	<b>001000</b>	<b>1.</b>	<b>1.</b>	<b>0</b>	<b>0 12</b>
<b>6100131</b>	<b>540010000</b>	<b>545000000</b>	<b>0.</b>	<b>0.</b>	<b>0.</b>	<b>001000</b>	<b>1.</b>	<b>1.</b>	<b>0</b>	<b>0 13</b>
<b>6100141</b>	<b>541010000</b>	<b>546000000</b>	<b>0.</b>	<b>0.</b>	<b>0.</b>	<b>001000</b>	<b>1.</b>	<b>1.</b>	<b>0</b>	<b>0 14</b>
<b>6100151</b>	<b>542010000</b>	<b>547000000</b>	<b>0.</b>	<b>0.</b>	<b>0.</b>	<b>001000</b>	<b>1.</b>	<b>1.</b>	<b>0</b>	<b>0 15</b>
<b>6100161</b>	<b>545010000</b>	<b>550000000</b>	<b>0.</b>	<b>0.</b>	<b>0.</b>	<b>001000</b>	<b>1.</b>	<b>1.</b>	<b>0</b>	<b>0 16</b>
<b>6100171</b>	<b>546010000</b>	<b>551000000</b>	<b>0.</b>	<b>0.</b>	<b>0.</b>	<b>001000</b>	<b>1.</b>	<b>1.</b>	<b>0</b>	<b>0 17</b>

6100181	547010000	552000000	0.	0.	001000	1. 1. 1. 0	0	0 18
6100191	590010000	595000000	0.	0.	001000	1. 1. 1. 0	0	0 19
6100201	591010000	596000000	0.	0.	001000	1. 1. 1. 0	0	0 20
6100211	592010000	597000000	0.	0.	001000	1. 1. 1. 0	0	0 21
6100221	595010000	600000000	0.	0.	001000	1. 1. 1. 0	0	0 22
6100231	596010000	601000000	0.	0.	001000	1. 1. 1. 0	0	0 23
6100241	597010000	602000000	0.	0.	001000	1. 1. 1. 0	0	0 24

\*

*	liq-flo	vap-flo	jn
6101011	1244.8	0.	1
6101021	1244.8	0.	2
6101031	1244.8	0.	3
6101041	1244.8	0.	4
6101051	1244.8	0.	5
6101061	1244.8	0.	6
6101071	1244.8	0.	7
6101081	1244.8	0.	8
6101091	1244.8	0.	9
6101101	1244.8	0.	10
6101111	1244.8	0.	11
6101121	1244.8	0.	12
6101131	1244.8	0.	13
6101141	1244.8	0.	14
6101151	1244.8	0.	15
6101161	1244.8	0.	16
6101171	1244.8	0.	17
6101181	1244.8	0.	18
6101191	1244.8	0.	19
6101201	1244.8	0.	20
6101211	1244.8	0.	21
6101221	1244.8	0.	22
6101231	1244.8	0.	23
6101241	1244.8	0.	24

\*

\*

\*

---

\* Train A Feedwater Heaters - Shellside

\*

---

\*

\* component 701 - RFW HTR A1 Steam Supply

7010000 'STM-src1' tmdpvol

\*

*	area	length	vol	azmth	incl	elev	rough	hyd	fe
7010101	5.0	10.0	0.0	0.0	90.0	10.0	0.0	0.0	10

\*

\* ebt trip variable  
7010200 002 0 cntrlvar 010 \*RX Power, % \*prb 01-26-96 11:55pm

\*

\* %pwr press qual.  
7010201 0.0 7.545 0.9107 \*extrapolated \*prb 01-26-96 10:38pm  
7010202 25.0 55.019 0.9022 \*prb 01-26-96 10:38pm  
7010203 50.0 110.02 0.8907 \*prb 01-26-96 10:38pm  
7010204 75.0 153.73 0.8837 \*prb 01-26-96 10:38pm  
7010205 90.0 186.86 0.8791 \*prb 01-26-96 10:38pm  
7010206 100.0 209.01 0.8765 \*prb 01-26-96 10:38pm

\*

\*

\* component 702 - RFW HTR A2 Steam Supply  
7020000 'STM-src2' tmdpvol

\*

\* area length vol azmth incl elev rough hyd fe  
7020101 5.0 10.0 0.0 0.0 0.0 0.0 0.0 10

\*

\* ebt trip variable  
7020200 002 0 cntrlvar 010 \*RX Power, % \*prb 01-26-96 11:55pm

\*

\* %pwr press qual.  
7020201 0.0 3.43 0.9607 \*extrapolated \*prb 01-26-96 11:55pm  
7020202 25.0 31.30 0.9587 \*prb 01-26-96 11:55pm  
7020203 50.0 61.70 0.9533 \*prb 01-26-96 11:55pm  
7020204 75.0 88.31 0.9530 \*prb 01-26-96 11:55pm  
7020205 90.0 107.20 0.9508 \*prb 01-26-96 11:55pm  
7020206 100.0 119.81 0.9495 \*prb 01-26-96 11:55pm

\*

\*

\* component 703 - RFW HTR A3 Steam Supply  
7030000 'STM-src3' tmdpvol

\*

\* area length vol azmth incl elev rough hyd fe  
7030101 5.0 10.0 0.0 0.0 0.0 0.0 0.0 10

\*

\* ebt trip variable  
7030200 002 0 cntrlvar 010 \*RX Power, % \*prb 01-26-96 11:55pm

\*

\* %pwr press qual.  
7030201 0.0 1.99 0.9421 \*extrapolated \*prb 01-26-96 11:55pm  
7030202 25.0 19.80 0.9389 \*prb 01-26-96 11:55pm  
7030203 50.0 38.70 0.9316 \*prb 01-26-96 11:55pm  
7030204 75.0 55.97 0.9305 \*prb 01-26-96 11:55pm

7030205 90.0 67.71 0.9276 \*prb 01-26-96 11:55pm  
7030206 100.0 75.51 0.9259 \*prb 01-26-96 11:55pm  
\*  
\*  
\* component 704 - RFW HTR A4 Steam Supply #1  
7040000 'STMsric4A' tmdpvol  
\*  
\* area length vol azmth incl elev rough hyd fe  
7040101 2.8229 10.0 0.0 0.0 0.0 0.0 0.0 10  
\*  
\* ebt trip variable  
7040200 002 0 cntrlvar 010 \*RX Power, % \*prb 01-27-96 10:08am  
\* \*prb 01-27-96 10:08am  
\* %pwr press qual. \*prb 01-27-96 10:08am  
7040201 0.0 0.75 0.6576 \*extrapolated \*prb 01-27-96 10:08am  
7040202 25.0 7.66 0.7094 \*prb 01-27-96 10:08am  
7040203 50.0 14.80 0.8077 \*prb 01-27-96 10:08am  
7040204 75.0 21.59 0.8363 \*prb 01-27-96 10:08am  
7040205 90.0 26.05 0.8437 \*prb 01-27-96 10:08am  
7040206 100.0 29.00 0.8482 \*prb 01-27-96 10:08am  
\*  
\*  
\* component 705 - RFW HTR A4 Steam Supply #2  
7050000 'STMsric4B' tmdpvol  
\*  
\* area length vol azmth incl elev rough hyd fe  
7050101 2.8229 10.0 0.0 0.0 0.0 0.0 0.0 10  
\*  
\* ebt trip variable  
7050200 002 0 cntrlvar 010 \*RX Power, % \*prb 01-27-96 10:08am  
\* \*prb 01-27-96 10:08am  
\* %pwr press qual. \*prb 01-27-96 10:08am  
7050201 0.0 1.127 0.3577 \*extrapolated \*prb 01-27-96 10:08am  
7050202 25.0 12.30 0.4394 \*prb 01-27-96 10:08am  
7050203 50.0 24.00 0.5701 \*prb 01-27-96 10:08am  
7050204 75.0 34.91 0.6273 \*prb 01-27-96 10:08am  
7050205 90.0 42.24 0.6434 \*prb 01-27-96 10:08am  
7050206 100.0 47.12 0.6485 \*prb 01-27-96 10:08am  
\*  
\*  
\* component 706 - RFW HTR A5 Steam Supply #1 (From "B" LP Turbine, point MR5)  
7060000 'STMsric5A' tmdpvol  
\*  
\* area length vol azmth incl elev rough hyd fe  
7060101 9.0164 10.0 0.0 0.0 0.0 0.0 0.0 10

\*

\* ebt trip variable

7060200 002 0 cntrlvar 010 \*RX Power, % \*prb 01-27-96 12:31pm  
\* \*prb 01-27-96 12:31pm

\* %pwr press qual. \*prb 01-27-96 12:31pm

7060201 0.0 0.30 0.064 \*extrapolated \*prb 01-27-96 12:31pm  
7060202 25.0 4.59 0.1630 \*prb 01-27-96 12:31pm  
7060203 50.0 8.88 0.2620 \*prb 01-27-96 12:31pm  
7060204 75.0 13.01 0.5389 \*prb 01-27-96 12:31pm  
7060205 90.0 15.71 0.5008 \*prb 01-27-96 12:31pm  
7060206 100.0 17.49 0.4806 \*prb 01-27-96 12:31pm

\*

\*

\* component 707 - RFW HTR A5 Steam Supply #2 (From "C" LP Turbine, point #5)

7070000 'STMsrc5B' tmdpvol

\*

\* area length vol azmth incl elev rough hyd fe

7070101 9.0164 10.0 0.0 0.0 0.0 0.0 0.0 10

\*

\* ebt trip variable

7070200 002 0 cntrlvar 010 \*RX Power, % \*prb 01-27-96 12:31pm  
\* \*prb 01-27-96 12:31pm

\* %pwr press qual. \*prb 01-27-96 12:31pm

7070201 0.0 0.45 0.2807 \*extrapolated \*prb 01-27-96 12:31pm  
7070202 25.0 2.69 0.4153 \*prb 01-27-96 12:31pm  
7070203 50.0 5.05 0.5633 \*prb 01-27-96 12:31pm  
7070204 75.0 7.23 0.6912 \*prb 01-27-96 12:31pm  
7070205 90.0 8.66 0.7368 \*prb 01-27-96 12:31pm  
7070206 100.0 9.60 0.7545 \*prb 01-27-96 12:31pm

\*

\*

\* component 708 - Moisture Separator

7080000 'Mois-Sep' tmdpvol

\*

\* area length vol azmth incl elev rough hyd fe

7080101 5.0 10.0 0.0 0.0 0.0 0.0 0.0 10

\*

\* ebt trip variable \*prb 01-26-96 11:47pm

7080200 001 0 cntrlvar 010 \*RX Power, % \*prb 01-26-96 11:47pm  
\*

\* %pwr temp qual. \*prb 01-26-96 11:47pm

7080201 0.0 253.12 0.0 \*extrapolated \*prb 01-26-96 11:47pm  
7080202 25.0 286.00 0.0 \*prb 01-26-96 11:47pm  
7080203 50.0 333.40 0.0 \*prb 01-26-96 11:47pm  
7080204 75.0 359.02 0.0 \*prb 01-26-96 11:47pm

---

7080205 90.0 374.74 0.0 \*prb 01-26-96 11:47pm  
 7080206 100.0 384.07 0.0 \*prb 01-26-96 11:47pm  
 \*  
 \*  
**\* component 709: Moisture Separator Drain to HTR A2**  
 7090000 'MS-drain' tmdpjun  
 7090101 708000000 731000000 1.3963  
 \*  
 \* trip variable \*prb 01-26-96 11:47pm  
 \*7090200 1 0 cntrlvar 010 \*RX Power, % \*prb 01-26-96 11:47pm  
 7090200 1 632 cntrlvar 010 \*RX Power, % \*jam 7-27-96  
 \*  
 \* %pwr liq.flow . \*prb 01-26-96 11:47pm  
 7090201 0.0 0.0 0.0 0.0 \*prb 01-26-96 11:47pm  
 7090202 25.0 22.4352 0.0 0.0 \*242,300/3 lb/hr \*prb 01-26-96 11:47pm  
 7090203 50.0 54.9444 0.0 0.0 \*593,400/3 lb/hr \*prb 01-26-96 11:47pm  
 7090204 75.0 82.8714 0.0 0.0 \*895,011/3 lb/hr \*prb 01-26-96 11:47pm  
 7090205 90.0 105.3094 0.0 0.0 \*1,137,342/3 lb/hr \*prb 01-26-96 11:47pm  
 7090206 100.0 120.7569 0.0 0.0 \*1,304,175/3 lb/hr \*prb 01-26-96  
 \*  
**\* component 710 - RFW Heater A1 steam supply vlv - jam 7-27-96**  
 7100000 a1stmvlv valve \*jam 7-27-96  
 \* from to juna kf kr fvcahs  
 7100101 701000000 720000000 1.3417 15.7355 15.7355 000000 \*jam 7-27-96  
 \* liq\_vel vap\_vel vel.int.  
 7100201 0 60.166 118.13 0.0 \*jam 7-26-96  
 7100300 trpvlv \*jam 7-26-96  
 7100301 632 \*jam 7-26-96  
 \*  
**\* component 720 - RFW Heater A1 Steam Dome (top of vertical shell)**  
 7200000 'HTRA1-s1' branch  
 \*  
 \* #juns vel/flow  
 \*7200001 2 0  
 7200001 1 0 \*jam 7-27-96  
 \*  
 \* area length vol theta phi elev rough hyd pvbfe  
 7200101 12.34 13.7904 0. 0. -90.0 -13.7904 1.5e-4 0.0772 00100  
 \*  
 \* ebt press Uf Uv voidv  
 7200200 000 198.29 354.09 1113.5 0.99410  
 \*  
 \* from to juna kf kr fvcahs  
 \*7201101 701000000 720000000 1.3417 15.7355 15.7355 000000 \*jam 7-27-96  
 \*7202101 720010000 721000000 0. 0. 0. 101000 \*jam 7-27-96

```
7201101 720010000    721000000    0.   0.   0.   101000    *jam 7-27-96
*
*   jun_Dh      flood  gas-int slope
*720110 0.0        0.0   1.0   1.0                      *jam 7-27-96
*7202110 0.0772    0.0   1.0   1.0                      *jam 7-27-96
7201110 0.0772    0.0   1.0   1.0
*
*   liq_vel    vap_vel      vel.int.
*7201201 60.166    118.13     0.                      *jam 7-27-96
*7202201 7.3903    8.4137     0.                      *jam 7-27-96
7201201 7.3903    8.4137     0.                      *jam 7-27-96
*
*
* component 721 - RFW Heater A1 Shellside middle volumes
7210000 'HTRA1-s2'  pipe
*
*   nv
7210001 3
*
*   flowa      vn
7210101 12.34      3      *Shell area (60.75" ID) minus tube area (5/8"OD)
*                           *tube area = (2)(1906 tubes)(tube area)
*
*   flowl      vn
7210301 10.4596    1
7210302 2.6667      3      *same as corresponding primary tube length
*
*   volume      vn
7210401 0.0         3
*
*   incl       vn
7210601 -90.0       3
*
*   roughness    dhyd  vn
7210801 1.5e-4      0.0772 3
*
*   kf   kr   jn
7210901 0.0   0.0   2
*
*   pvbfe      vn
7211001 00100      3
*
*   fvcahs      jn
7211101 101000     2
*
```

```
* ebt press. Uf      Uv      voidv      VN
7211201 0    198.33 354.09    1113.5  0.99189    0.   1
7211202 0    198.36 354.05    1113.5  0.96348    0.   2
7211203 0    198.89 336.85    1113.6  2.33801e-02  0.   3
*
* vel/flow
7211300 0
*
* liq-flo vap-flo vel.int jn
7211301 11.168  2.4853  0.       1
7211302 3.0088  5.32454e-02 0.       2
*
* jun_Dh     flood     gas-int     slope jn
7211401 0.0772  0.0       1.0       1.0   2
*
*
* component 722 - RFW Heater A1 Tubesheet Shellside (bottom of vertical shell)
7220000 'HTRA1-s3' branch
*
* #juns vel/flow
7220001 1    0
*
* area length vol theta phi elev rough hyd pvbfe
7220101 12.34  1.3307 0.   0.   -90.0 -1.3307 1.5e-4 0.0772 00100
*
* ebt press. Uf      Uv      voidv
7220200 000  199.30 338.19    1113.6  0.0
*
* from      to      juna kf kr fvcahs
7221101 721010000 722000000 0.   0.0  0.   101000
*
* jun_Dh     flood gas-int slope
7221110 0.0772  0.0   1.0   1.0
*
* liq_vel    vap_vel    vel.int.
7221201 0.11251 -1.1900  0.
*
*
* component 723 - RFW Heater A1 Drain Piping
7230000 'HTRA1drn' branch
*
* #juns vel/flow
7230001 1    0
*
* area length vol theta phi elev rough hyd pvbfe
```

7230101 0.3474 10.0 0. 0. 82.6 9.9167 1.5e-4 0.0 00000  
\*  
\* ebt press. Uf Uv voidv  
7230200 000 199.30 338.19 1113.6 0.0  
\*  
\* from to juna kf kr fvcahs  
7231101 722010000 723000000 0.3474 0.0 0. 000100  
\*  
\* liq\_vel vap\_vel vel.int.  
7231201 3.7345 3.7345 0.  
\*  
\*  
\* component 725 - RFW HTRA1 Drain Valve  
7250000 'LCV6-1' valve  
\*  
\* from to juna kf kr fvcahs  
7250101 723010000 731000000 0.0873 39.0223 39.0223 000000  
\*  
7250201 0 15.463 15.465 0. \* 819,483/3 lb/hr  
\*  
7250300 srvvlv  
\*  
7250301 0324 \* valve position demand from htr A1 level control system  
\*  
7250400 1.0 288.0 \* max Cv = 288.0 per BFN-VTD-K125-0060 for  
\* 4" linear double-seated full-port  
7250401 0.0 0.0001 0.0001 \* Assume linear Cv vs stroke for globe  
7250402 1.0 1.0 1.0 \* valve  
\*  
\* component 711 - RFW Heater A2 steam supply vlv - jam 7-27-96  
7110000 a2stmvlv valve \*jam 7-27-96  
\* from to juna kf kr fvcahs  
7110101 702000000 730000000 0.7854 14.1087 14.1087 000000 \*jam 7-27-96  
\* liq\_vel vap\_vel vel.int.  
7110201 0 74.200 202.58 0.0 \*jam 7-26-96  
7110300 trpvlv \*jam 7-26-96  
7110301 632 \*jam 7-26-96  
\*  
\* component 730 - RFW Heater A2 Steam Dome (top of vertical shell)  
7300000 'HTRA2-s1' branch  
\*  
\* #juns vel/flow  
\*7300001 2 0 \*jam 9-27-96  
7300001 1 0 \*jam 9-27-96  
\*

```
* area length vol theta phi elev rough hyd pvbfe
7300101 12.34 10.2904 0. 0. -90.0 -10.2904 1.5e-4 0.0772 00100
*
* ebt press Uf Uv voidv
7300200 000 109.21 304.89 1106.3 0.99832
*
* from to juna kf kr fvcahs
*7301101 702000000 730000000 0.7854 14.1087 14.1087 000001 *jam 9-27-96
*7302101 730010000 731000000 12.34 0. 0. 101000 *jam 9-27-96
7301101 730010000 731000000 12.34 0. 0. 101000 *jam 9-27-96
*
* jun_Dh flood gas-int slope
*7301110 0.0 0.0 1.0 1.0 *jam 9-27-96
*7302110 0.0772 0.0 1.0 1.0 *jam 9-27-96
7301110 0.0772 0.0 1.0 1.0 *jam 9-27-96
*
* liq_vel vap_vel vel.int.
*7301201 74.200 202.58 0. *jam 9-27-96
*7302201 12.027 7.9267 0. *jam 9-27-96
7301201 12.027 7.9267 0. *jam 9-27-96
*
*
* component 731 - RFW Heater A2 drain junction volume
7310000 'HTRA2-s2' branch
*
* #juns vel/flow
7310001 1 0
*
* area length vol theta phi elev rough hyd pvbfe
7310101 12.34 8.8763 0. 0. -90.0 -8.8763 1.5e-4 0.0772 00100
*
* ebt press Uf Uv voidv
7310200 000 109.23 305.04 1106.4 0.97393
*
* from to juna kf kr fvcahs
7311101 731010000 732000000 12.34 0. 0. 101000
*
* jun_Dh flood gas-int slope
7311110 0.0772 0.0 1.0 1.0
*
* liq_vel vap_vel vel.int.
7311201 10.895 3.4280 0.
*
*
* component 732 - RFW Heater A2 Shellside middle volumes
```

7320000 'HTRA2-s2' pipe  
\*  
\* nv  
7320001 2  
\*  
\* flowa vn  
7320101 12.34 2 \*Shell area (60.75" ID) minus tube area (5/8"OD)  
\* \*tube area = (2)(1906 tubes)(tube area)  
\*  
\* flowl vn  
7320301 3.0000 2 \*same as corresponding primary tube length  
\*  
\* volume vn  
7320401 0.0 2  
\*  
\* incl vn  
7320601 -90.0 2  
\*  
\* roughness dhyd vn  
7320801 1.5e-4 0.0772 2  
\*  
\* kf kr jn  
7320901 0.0 0.0 1  
\*  
\* pvbfe vn  
7321001 00100 2  
\*  
\* fvcahs jn  
7321101 101000 1  
\*  
\* ebt press. Uf Uv voidv VN  
7321201 000 109.25 304.86 1106.4 0.91724 0. 1  
7321202 000 109.87 298.86 1106.4 5.89169e-02 0. 2  
\*  
\* vel/flow  
7321300 0  
\*  
\* liq-flo vap-flo vel.int jn  
7321301 4.2183 0.30784 0. 1  
\*  
\* jun\_Dh flood gas-int slope jn  
7321401 0.0772 0.0 1.0 1.0 1  
\*

\* component 733 - RFW Heater A2 Tubesheet Shellside (bottom of vertical shell)

7330000 'HTRA2-s3' branch  
\*  
\* #juns vel/flow  
7330001 1 0  
\*  
\* area length vol theta phi elev rough hyd pvbfe  
7330101 12.34 5.4974 0. 0. -90.0 -5.4974 1.5e-4 0.0772 00100  
\*  
\* ebt press. Uf Uv voidv  
7330200 000 111.52 291.80 1106.6 0.0  
\*  
\* from to juna kf kr fvcahs  
7331101 732010000 733000000 12.34 0.0 0. 101000  
\*  
\* jun\_Dh flood gas-int slope  
7331110 0.0772 0.0 1.0 1.0  
\*  
\* liq\_vel vap\_vel vel.int.  
7331201 0.42029 -0.82167 0.  
\*  
\*  
\* component 734 - RFW Heater A2 Drain Piping  
7340000 'HTRA2drn' branch  
\*  
\* #juns vel/flow  
7340001 1 0  
\*  
\* area length vol theta phi elev rough hyd pvbfe  
7340101 0.5475 25.0 0. 0. 65.0 22.6667 1.5e-4 0.0 00000  
\*  
\* ebt press. Uf Uv voidv  
7340200 000 199.30 338.19 1113.6 0.0  
\*  
\* from to juna kf kr fvcahs  
7341101 733010000 734000000 0.5475 0.0 0. 000100  
\*  
\* liq\_vel vap\_vel vel.int.  
7341201 8.2628 7.7109 0.  
\*  
\*  
\* component 735 - RFW HTRA2 Drain Valve  
7350000 'LCV6-4A' valve  
\*  
\* from to juna kf kr fvcahs  
7350101 734010000 741000000 0.3491 22.8653 22.8653 000000

\*  
7350201 1 228.5294 0.0 0. \*2,468,117/3 lb/hr  
\*  
7350300 srvv1v  
\*  
7350301 0349 \* valve position demand based from htr A2 level control  
\*  
7350400 1.0 950.0 \* max Cv = 950.0 per BFN-VTD-K125-0060 for  
\* 8" linear double-seated full-port  
7350401 0.0 0.0001 0.0001 \* Assume linear Cv vs stroke for globe  
7350402 1.0 1.0 1.0 \* valve  
\*  
\*  
\* component 737 - RFW HTRA2 Bypass Valve \*prb 01-18-96  
10:16am  
7370000 'LCV6-4B' valve \*prb 01-18-96 10:16am  
\* \*prb 01-18-96 10:16am  
\* from to juna kf kr fvcahs \*prb 01-18-96 10:16am  
\*7370101 734010000 738000000 0.3491 0.0 0.0 000000 \*prb 01-18-96  
10:16am  
7370101 734010000 738000000 0.3491 22.8653 22.8653 000000 \*jam 7-26-96  
\* \*prb 01-18-96 10:16am  
7370201 1 0.0 0.0 0.0 \*prb 01-18-96 10:16am  
\* \*prb 01-18-96 10:16am  
7370300 srvv1v \*prb 01-18-96 10:16am  
\*  
7370301 0355 \* valve position demand \*prb 01-18-96 10:16am  
\* \*prb 01-18-96 10:16am  
7370400 1.0 950.0 \* max Cv = 950.0 per BFN-VTD-K125-0060 for \*prb  
01-18-96 10:16am  
\* 8" linear double-seated full-port \*prb 01-18-96 10:16am  
7370401 0.0 0.0001 0.0001 \* Assume linear Cv vs stroke for globe \*prb 01-18-96  
10:16am  
7370402 1.0 1.0 1.0 \* valve \*prb 01-18-96 10:16am  
  
\* component 738 - RFW bank 2 bypass drain piping to condenser \*prb  
01-18-96 10:28am  
7380000 'HTR2byp' branch \*prb 01-18-96 10:28am  
\*  
\* #juns vel/flow \*prb 01-18-96 10:28am  
7380001 1 0 \*prb 01-18-96 10:28am  
\*  
\* area length vol theta phi elev rough hyd pvbfe \*prb 01-18-96  
10:28am

---

```

*7380101 1.0472 50.0 0. 0. -17.72 -37.887 1.5e-4 0.6667 00000 *prb 01-23-96
01:02pm
7380101 1.0472 10.0 0. 0. -90.00 -10.000 1.5e-4 0.6667 00000 *jam 7-28-96
*
* ebt press. temp *prb 01-18-96 10:28am
7380200 003 1.0 101.14 *prb 01-18-96 10:28am
*
* from to juna kf kr fvcahs *prb 01-18-96 10:28am
*7381101 738010000 969010000 1.0472 0.0 0.0 000000 *prb 01-18-96
10:28am
7381101 738010000 971000000 1.0472 0.0 0.0 001000 *jam 7-28-96
*
* liq_vel vap_vel vel.int. *prb 01-18-96 10:28am
7381201 0.0 0.0 0. *prb 01-18-96 10:28am
*
* component 712 - RFW Heater A3 steam supply vlv - jam 7-27-96
7120000 a3stmvlv valve *jam 7-27-96
* from to juna kf kr fvcahs
7120101 703000000 740000000 3.1416 23.4899 23.4899 000000 *jam 7-27-96
* liq_vel vap_vel vel.int.
7120201 0 7.7263 124.84 0.0 *jam 7-26-96
7120300 trpvlv *jam 7-26-96
7120301 632 *jam 7-26-96
*
* component 740 - RFW Heater A3 Steam Dome (top of vertical shell)
7400000 'HTRA3-s1' branch
*
* #juns vel/flow
*7400001 2 0 *jam 7-26-96
7400001 1 0 *jam 7-26-96
*
* area length vol theta phi elev rough hyd pvbfe
7400101 13.5335 12.4284 0. 0. -90.0 -12.4284 1.5e-4 0.0864 00100
*
* ebt press Uf Uv voidv
7400200 000 69.300 271.84 1099.9 0.99613
*
* from to juna kf kr fvcahs
*7401101 703000000 740000000 3.1416 23.4899 23.4899 000000 *jam 7-26-96
*7402101 740010000 741000000 13.5335 0. 0. 101000 *jam 7-26-96
7401101 740010000 741000000 13.5335 0. 0. 101000 *jam 7-26-96
*
* jun_Dh flood gas-int slope
*7401110 0.0 0.0 1.0 1.0 *jam 7-26-96
*7402110 0.0864 0.0 1.0 1.0 *jam 7-26-96

```

```
7401110 0.0864      0.0   1.0   1.0                  *jam 7-26-96
*
*   liq_vel  vap_vel      vel.int.
*7401201 7.7263     124.84      0.                  *jam 7-26-96
*7402201 8.9171     19.266      0.                  *jam 7-26-96
7401201 8.9171     19.266      0.                  *jam 7-26-96
*
*
* component 741 - RFW Heater A3 drain junction volume
7410000 'HTRA3-s2' branch
*
*   #juns  vel/flow
7410001 1      0
*
*   area  length vol  theta phi elev  rough hyd  pvbfe
7410101 13.5335 11.1133 0.    0.   -90.0 -11.1133 1.5e-4 0.0864 00100
*
*   ebt  press  Uf      Uv      voidv
7410200 000   69.309 271.88   1100.0   0.96083
*
*   from      to      juna  kf   kr   fvcahs
7411101 741010000   742000000 13.5335 0.    0.   101000
*
*   jun_Dh      flood  gas-int slope
7411110 0.0864      0.0   1.0   1.0
*
*   liq_vel  vap_vel      vel.int.
7411201 9.3922     5.8524      0.
*
*
* component 742 - RFW Heater A3 Shellside middle & lower volumes
7420000 'HTRA3-s3' pipe
*
*   nv
7420001 4
*
*   flowa      vn
7420101 13.5335      1
7420102 6.7667      4      *volumes 2-4 share space with subcooling zone
*
*   flowl      vn
7420301 3.0000      2      *same as corresponding primary tube length
7420302 7.0534      4      *same as corresponding primary tube length
*
*   volume      vn
```

```
7420401 0.0      4
*
*   incl      vn
7420601 -90.0     4
*
*   roughness    dhyd  vn
7420801 1.5e-4    0.0864 4
*
*   kf   kr   jn
7420901 0.0   0.0   3
*
*   pvbfe      vn
7421001 00100     4
*
*   fvcahs      jn
7421101 101000     3
*
*   ebt  press. Uf      Uv      voidv      VN
7421201 000  69.322 271.84  1100.0  0.98918  0.  1
7421202 000  69.529 271.38  1099.9  0.16248  0.  2
7421203 000  72.030 269.21  1100.5  2.68060e-06 0.  3
7421204 000  74.835 267.04  1101.0  8.83757e-06 0.  4
*
*   vel/flow
7421300 0
*
*   liq-flo  vap-flo      vel.int      jn
7421301 70.794  0.44862  0.        1
7421302 0.75643 -0.90429  0.        2
7421303 0.63162  0.77799  0.        3
*
*   jun_Dh      flood      gas-int      slope jn
7421401 0.0864    0.0      1.0      1.0  3
*
*
* component 743 - RFW Heater A3 Subcooling Zone
7430000 'HTRA3-s4'  pipe
*
*   nv
7430001 3
*
*   flowa      vn
7430101 6.7667     3
*
*   flowl      vn
```

```
7430301 3.0000      1      *same as corresponding primary tube length
7430302 7.0534      3      *same as corresponding primary tube length
*
*      volume      vn
7430401 0.0          3
*
*      incl       vn
7430601 -90.0        3
*
*      roughness   dhyd  vn
7430801 1.5e-4       0.0864 3
*
*      kf      kr      jn
7430901 0.0          0.0    2
*
*      pvbfe      vn
7431001 00100        3
*
*      fvcahs     jn
7431101 101000       2
*
*      ebt      press. Uf      Uv      voidv      VN
7431201 000  69.415 233.60  1100.1  8.99481e-02  0.  1
7431202 000  71.404 226.39  1100.4  1.57683e-07  0.  2
7431203 000  74.264 242.61  1100.9  3.17648e-06  0.  3
*
*      vel/flow
7431300 0
*
*      liq-flo    vap-flo    vel.int    jn
7431301 3.53376e-02 -1.6814      0.      1
7431302 3.03089e-02 3.099473e-02  0.      2
*
*      jun_Dh      flood      gas-int      slope jn
7431401 0.0864      0.0      1.0      1.0    2
*
*
* component 744 - RFW Heater A3 Drain Piping
7440000 'HTRA3drn' branch
*
*      #juns vel/flow
7440001 1      1
*
*      area      length vol      theta phi elev      rough hyd      pvbfe
7440101 0.5475 5.0  0.  0.  0.  0.  1.5e-4 0.0  00000
```

\*  
\* ebt press. Uf Uv voidv  
7440200 000 199.30 338.19 1113.6 0.0  
\*  
\* from to juna kf kr fvcahs  
7441101 743010000 744000000 0.5475 0.0 0. 000100  
\*  
\* liq\_vel vap\_vel vel.int.  
7441201 228.5294 0.0 0.  
\*  
\*  
\* component 745 - RFW HTRA3 Drain Valve  
7450000 'LCV6-7' valve  
\*  
\* from to juna kf kr fvcahs  
7450101 744010000 752000000 0.3491 7.4816 7.4816 000000  
\*  
7450201 0 12.689 44.886 0. \*2,468,117/3 lb/hr target  
\*  
7450300 srvvlv  
\*  
7450301 0379 \* valve position demand based on htr A3 level error  
\*  
7450400 1.0 950.0 \* max Cv = 950.0 per BFN-VTD-K125-0060 for  
\* 8" linear double-seated full-port  
7450401 0.0 0.0001 0.0001 \* Assume linear Cv vs stroke for globe  
7450402 1.0 1.0 1.0 \* valve  
\*  
\*  
7470000 'HTRA3jun' mtpljun  
7470001 2 0  
\*  
\* from to juna kf kr fvcahs incr1 incr2 jn  
7470011 742020004 743010003 .1 5. 5. 001000 1. 1. 1. 0 0 0 1  
7470021 742040004 743030003 1. 5. 5. 001000 1. 1. 1. 0 0 0 2  
\*  
\* liq-flo vap-flo jn  
7471011 4.0946 4.0946 1  
7471021 0.0 0.0 2  
\*  
\* component 713 - RFW Heater A4 steam supply vlv - jam 7-27-96  
7130000 a4stvlv1 valve \*jam 7-27-96  
\* from to juna kf kr fvcahs  
7130101 705000000 750000000 2.8229 6197.85 6197.85 000000 \*jam 7-27-96  
\* liq\_vel vap\_vel vel.int.

7130201 0 0.83437 24.814 0.0 \*jam 7-26-96  
7130300 trpvlv \*jam 7-26-96  
7130301 632 \*jam 7-26-96  
\*  
\*  
\* component 750 - RFW Heater A4 (top of shell nearest tubesheet)  
7500000 'HTRA4-s1' branch  
\*  
\* #juns vel/flow  
\*7500001 2 0 \*jam 7-26-96  
7500001 1 0 \*jam 7-26-96  
\*  
\* area length vol theta phi elev rough hyd pvbfe  
7500101 0.0 2.9375 153.2704 0. -90.0 -2.9375 1.5e-4 0.1309 00100  
\*  
\* ebt press Uf Uv voidv  
7500200 000 27.276 213.37 1086.4 0.99962  
\*  
\* from to juna kf kr fvcahs  
\*7501101 705000000 750000000 2.8229 6197.85 6197.85 000000 \*jam 7-27-96  
\*7502101 750010000 751000000 9.7832 0. 0. 001003 \*jam 7-27-96  
7501101 750010000 751000000 9.7832 0. 0. 001003 \*jam 7-27-96  
\*  
\* jun\_Dh flood gas-int slope  
\*7501110 0.0 0.0 1.0 1.0 \*jam 7-27-96  
\*7502110 0.1309 0.0 1.0 1.0 \*jam 7-27-96  
7501110 0.1309 0.0 1.0 1.0 \*jam 7-27-96  
\*  
\* liq\_vel vap\_vel vel.int.  
\*7501201 0.83437 24.814 0. \*jam 7-27-96  
\*7502201 9.1016 8.7249 0. \*jam 7-27-96  
7501201 9.1016 8.7249 0. \*jam 7-27-96  
\*  
\* component 714 - RFW Heater A4 steam supply vlv - jam 7-27-96  
7140000 a4stvlv2 valve \*jam 7-27-96  
\* from to juna kf kr fvcahs  
7140101 704000000 751000000 2.8229 4.4554 4.4554 000000 \*jam 7-27-96  
\* liq\_vel vap\_vel vel.int.  
7140201 0 41.854 271.59 0.0 \*jam 7-26-96  
7140300 trpvlv \*jam 7-26-96  
7140301 632 \*jam 7-26-96  
\*  
\* component 751 - RFW Heater A4 (top of shell furthest from tubesheet)

7510000 'HTRA4-s2' branch  
\*  
\* #juns vel/flow  
\*7510001 2 0 \*jam 7-27-96  
7510001 1 0 \*jam 7-27-96  
\*  
\* area length vol theta phi elev rough hyd pvbfe  
7510101 0.0 2.9375 265.4972 0. -90.0 -2.9375 1.5e-4 0.1309 00100  
\*  
\* ebt press Uf Uv voidv  
7510200 000 27.276 213.38 1086.4 0.99996  
\*  
\* from to juna kf kr fvcahs  
\*7511101 704000000 751000000 2.8229 4.4554 4.4554 000000 \*jam 7-27-96  
\*7512101 751010000 752000000 153.4359 0. 0. 101000 \*jam 7-27-96  
7511101 751010000 752000000 153.4359 0. 0. 101000 \*jam 7-27-96  
\*  
\* jun\_Dh flood gas-int slope  
\*7511110 0.0 0.0 1.0 1.0 \*jam 7-27-96  
\*7512110 0.1309 0.0 1.0 1.0 \*jam 7-27-96  
7511110 0.1309 0.0 1.0 1.0 \*jam 7-27-96  
\*  
\* liq\_vel vap\_vel vel.int.  
\*7511201 41.854 271.59 0. \*jam 7-27-96  
\*7512201 38.784 4.5911 0. \*jam 7-27-96  
7511201 38.784 4.5911 0. \*jam 7-27-96  
\*  
\*  
\* component 752 - RFW Heater A4 (bottom of shell furthest from tubesheet)  
7520000 'HTRA4-s3' branch  
\*  
\* #juns vel/flow  
7520001 0 0  
\*  
\* area length vol theta phi elev rough hyd pvbfe  
7520101 0.0 2.9375 265.4972 0. -90.0 -2.9375 1.5e-4 0.1309 00100  
\*  
\* ebt press Uf Uv voidv  
7520200 000 27.292 209.34 1086.4 0.52487  
\*  
\*  
\* component 753 - RFW Heater A4 Subcooling Zone  
7530000 'HTRA4-s4' branch  
\*  
\* #juns vel/flow

```
7530001 1    0
*
*   area  length  vol   theta  phi  elev   rough  hyd   pvbfe
7530101 9.7832 15.6667 0.0   0.  0.0  0.0   1.5e-4 0.1309 00100
*
*   ebt  press  Uf      Uv      voidv
7530200 000  26.746 170.92   1086.2  2.46992e-02
*
*   from      to      juna   kf     kr     fvcahs
7531101 752010000 753000000 1.7671 5.0   5.0   001000
*
*   jun_Dh    flood  gas-int slope
7531110 0.1309    0.0  1.0   1.0
*
*   liq_vel  vap_vel      vel.int.
7531201 6.4784   37.792      0.
*
*
* component 754 - RFW Heater A4 Drain Piping
7540000 'HTRA4drn' branch
*
*   #juns  vel/flow
7540001 1    0
*
*   area  length  vol   theta  phi  elev   rough  hyd   pvbfe
7540101 1.6230 10.0  0.  0.  50.15 7.6771  1.5e-4 0.0  00000
*
*   ebt  press. Uf      Uv      voidv
7540200 000  26.326 174.57   1085.9  7.05438e-04
*
*   from      to      juna   kf     kr     fvcahs
7541101 753010000 754000000 1.6230 0.0   0.  000100
*
*   liq_vel  vap_vel      vel.int.
7541201 3.1304   4.5777      0.
*
*
* component 755 - RFW HTRA4 Drain Valve
7550000 'LCV6-11A' valve
*
*   from      to      juna   kf     kr     fvcahs
7550101 754010000 760010003 0.7854  23.7848 23.7848 000000
*
7550201 0      7.5514   7.5514 0.  *3,184,100/3 lb/hr target
*
```

7550300 srvv1v  
\*  
7550301 0399 \* valve position demand based on htr A4 level error  
\*  
7550400 1.0 2180.0 \* max Cv = 2180.0 per BFN-VTD-K125-0060 for  
\* 12" linear double-seated full-port  
7550401 0.0 0.0001 0.0001 \* Assume linear Cv vs stroke for globe  
7550402 1.0 1.0 1.0 \* valve  
\*  
\*  
\* component 757 - RFW HTRA4 Bypass Valve \*prb 01-24-96  
10:22am  
7570000 'LCV6-11B' valve \*prb 01-24-96 10:22am  
\* \*prb 01-24-96 10:22am  
\* from to juna kf kr fvcahs \*prb 01-24-96 10:22am  
\*7570101 754010000 758000000 0.7854 0.0 0.0 000000 \*prb 01-24-96  
10:22am  
7570101 754010000 758000000 0.7854 23.7848 23.7848 000000 \*jam 7-26-96  
\* \*prb 01-24-96 10:22am  
7570201 1 0.0 0.0 0.0 \*prb 01-24-96 10:22am  
\* \*prb 01-24-96 10:22am  
\*  
7570300 srvv1v \*prb 01-24-96 10:22am  
\*  
7570301 0405 \* valve position demand \*prb 01-24-96 10:22am  
\*  
7570400 1.0 2180.0 \* max Cv = 2180.0 per BFN-VTD-K125-0060 for \*prb  
01-24-96 10:22am  
\* 12" linear double-seated full-port \*prb 01-24-96 10:22am  
7570401 0.0 0.0001 0.0001 \* Assume linear Cv vs stroke for globe \*prb 01-24-96  
10:22am  
7570402 1.0 1.0 1.0 \* valve \*prb 01-24-96 10:22am  
\*  
\*  
\* component 758 - RFW bank 4 bypass drain piping to condenser \*prb  
01-24-96 10:22am  
7580000 'HTR4byp' branch \*prb 01-24-96 10:22am  
\*  
\* #juns vel/flow \*prb 01-24-96 10:22am  
7580001 1 0 \*prb 01-24-96 10:22am  
\* \*prb 01-24-96 10:22am  
\* area length vol theta phi elev rough hyd pvbfe \*prb 01-24-96  
10:22am  
7580101 2.3562 25.0 0. 0. -27.0 -11.40625 1.5e-4 1.0 00000 \*prb 01-24-96  
10:22am  
\* \*prb 01-24-96 10:22am

```
* ebt press. temp *prb 01-24-96 10:22am
7580200 003 1.0 101.14 *prb 01-24-96 10:22am
*
* from to juna kf kr fvcahs *prb 01-24-96 10:22am
*7581101 758010000 969010000 2.3562 0.0 0.0 000000 *prb 01-24-96
10:22am
7581101 758010000 969010000 2.3562 0.0 0.0 001000 *jam 7-26-96
*
* liq_vel vap_vel vel.int. *prb 01-24-96 10:22am
7581201 0.0 0.0 0. *prb 01-24-96 10:22am
*
*
* component 760 - RFW Heater A5 Flash Tank
7600000 'FL-TankA' pipe
*
* nv
7600001 4
*
* flowa vn
7600101 16.4988 4
*
* flowl vn
7600301 1.4583 1
7600302 2.9583 2
7600303 2.500 3
7600304 5.2188 4
*
* volume vn
7600401 0.0 4
*
* incl vn
7600601 -90.0 4
*
* roughness dhyd vn
7600801 0.0 0.0 4
*
* kf kr jn
7600901 0.0 0.0 3
*
* pvbfe vn
7601001 00010 4
*
* fvcahs jn
7601101 101000 3
*
```

```
* ebt press. Uf      Uv      voidv      VN
7601201 000  9.6940 160.59    1071.8  0.98351   0.   1
7601202 000  9.6954 159.92    1071.8  0.99883   0.   2
7601203 000  9.9628 160.43    1072.2  0.53140   0.   3
7601204 000  12.394 159.48    1075.2  0.00000e+00  0.   4
*
* vel/flow
7601300 0
*
* liq-flo vap-flo      vel.int      jn
7601301 19.581 0.27746     0.       1
7601302 282.58 0.63630     0.       2
7601303 0.63560 -4.2606    0.       3
*
* jun_Dh      flood      gas-int      slope jn
7601401 0.0     0.0        1.0        1.0   3
*
*
* component 761 - RFW Heater A5 Drain Piping
7610000 'HTRA5drn' branch
*
* #juns vel/flow
7610001 1     0
*
* area length vol theta phi elev rough hyd pvbfe
7610101 2.9483 10.0 0. 0. 0.0 0.0 1.5e-4 0.0 00000
*
* ebt press. Uf      Uv      voidv
7610200 000  13.552 159.14    1076.4  0.0
*
* from      to      juna kf      kr      fvcahs
7611101 760010000 761000000 2.9483 0.0 0. 000100
*
* liq_vel vap_vel      vel.int.
7611201 1.6705 1.9099     0.
*
* component 715 - RFW Heater A5 steam supply vlv - jam 7-27-96
7150000 a5stvlv1 valve *jam 7-27-96
* from      to      juna kf      kr      fvcahs
7150101 706000000 762000000 9.0164 6243.8 6243.8 000000 *jam 7-27-96
* liq_vel vap_vel      vel.int.
7150201 0 0.49198 22.264     0.0          *jam 7-26-96
7150300 trpvlv                               *jam 7-26-96
7150301 632                               *jam 7-26-96
*
```

\*

\* component 762 - RFW Heater A5 (top of shell nearest tubesheet)  
7620000 'HTRA5-s1' branch

\*

\* #juns vel/flow

\*7620001 3 0 \*jam 7-27-96  
7620001 2 0 \*jam 7-27-96

\*

\* area length vol theta phi elev rough hyd pvbfe  
7620101 0.0 2.8333 170.5096 0. -90.0 -2.8333 1.5e-4 0.1128 00100

\*

\* ebt press Uf Uv voidv  
7620200 000 9.4593 158.61 1071.3 0.99998

\*

\* from to juna kf kr fvcahs  
\*7621101 706000000 762000000 9.0164 6243.8 6243.8 001000  
\*jam 7-27-96  
\*7622101 762010000 763000000 8.7069 0. 0. 001003  
\*jam 7-27-96  
7621101 762010000 763000000 8.7069 0. 0. 001003  
\*jam 7-27-96  
\*7623101 760000000 762000000 0.7530 1.50 1.50 001000  
\*jam 7-27-96  
7622101 760000000 762000000 0.7530 1.50 1.50 001000  
\*jam 7-27-96

\*

\* jun\_Dh flood gas-int slope  
\*7621110 2.3958 0.0 1.0 1.0 \*jam 7-27-96  
\*7622110 0.1128 0.0 1.0 1.0 \*jam 7-27-96  
7621110 0.1128 0.0 1.0 1.0 \*jam 7-27-96  
\*7623110 0.0 0.0 1.0 1.0 \*jam 7-27-96  
7622110 0.0 0.0 1.0 1.0 \*jam 7-27-96

\*

\* liq\_vel vap\_vel vel.int.  
\*7621201 0.49198 22.264 0. \*jam 7-27-96  
\*7622201 -31.397 -26.477 0. \*jam 7-27-96  
7621201 -31.397 -26.477 0. \*jam 7-27-96  
\*7623201 -30.730 237.56 0. \*jam 7-27-96  
7622201 -30.730 237.56 0. \*jam 7-27-96

\*

\* component 716 - RFW Heater A5 steam supply vlv - jam 7-27-96  
7160000 a5stvlv2 valve \*jam 7-27-96

\* from to juna kf kr fvcahs  
7160101 707000000 763000000 9.0164 2.9489 2.9489 000000 \*jam 7-27-96

\* liq\_vel vap\_vel vel.int.

7160201 0 26.337 161.50 0.0 \*jam 7-26-96  
7160300 trpvlv \*jam 7-26-96  
7160301 632 \*jam 7-26-96  
\*  
\*  
\* component 763 - RFW Heater A5 (top of shell furthest from tubesheet)  
7630000 'HTRA5-s2' branch  
\*  
\* #juns vel/flow  
\*7630001 2 0 \*jam 7-27-96  
7630001 1 0 \*jam 7-27-96  
\*  
\* area length vol theta phi elev rough hyd pvbfe  
7630101 0.0 2.8333 128.8119 0. -90.0 -2.8333 1.5e-4 0.1128 00100  
\*  
\* ebt press Uf Uv voidv  
7630200 000 9.4589 158.60 1071.4 0.99992  
\*  
\* from to juna kf kr fvcahs  
\*7631101 707000000 763000000 9.0164 2.9489 2.9489 001000 \*jam 9-27-96  
\*7632101 763010000 764000000 83.8342 0. 0. 001000 \*jam 9-27-96  
7631101 763010000 764000000 83.8342 0. 0. 001000 \*jam 9-27-96  
\*  
\* jun\_Dh flood gas-int slope  
\*7631110 2.3958 0.0 1.0 1.0 \*jam 9-27-96  
\*7632110 0.1128 0.0 1.0 1.0 \*jam 9-27-96  
7631110 0.1128 0.0 1.0 1.0 \*jam 9-27-96  
\*  
\* liq\_vel vap\_vel vel.int.  
\*7631201 26.337 161.50 0. \*jam 9-27-96  
\*7632201 34.542 8.5995 0. \*jam 9-27-96  
7631201 34.542 8.5995 0. \*jam 9-27-96  
\*  
\*  
\* component 764 - RFW Heater A5 (bottom of shell furthest from tubesheet)  
7640000 'HTRA5-s3' branch  
\*  
\* #juns vel/flow  
7640001 2 0  
\*  
\* area length vol theta phi elev rough hyd pvbfe  
7640101 0.0 2.8333 128.8119 0. -90.0 -2.8333 1.5e-4 0.1128 00100  
\*  
\* ebt press Uf Uv voidv  
7640200 000 9.6340 148.68 1071.7 0.39598

\*

\* from to juna kf kr fvcahs  
7641101 764010004 765010003 8.7069 0. 0. 001000  
7642101 764010000 766000000 0.8685 1.5 100.0 001001 \* discourage reverse  
flow  
\*  
\* jun\_Dh flood gas-int slope  
7641110 0.1128 0.0 1.0 1.0  
7642110 0.6651 0.0 1.0 1.0  
\*  
\* liq\_vel vap\_vel vel.int.  
7641201 3.4725 -8.5376 0.  
7642201 0.47271 -9.3520 0.  
\*  
\*  
\* component 765 - RFW Heater A5 (bottom of shell nearest tubesheet)  
7650000 'HTRA5-s4' branch  
\*  
\* #juns vel/flow  
7650001 2 0  
\*  
\* area length vol theta phi elev rough hyd pvbfe  
7650101 0.0 2.8333 170.5096 0. -90.0 -2.8333 1.5e-4 0.1128 00100  
\*  
\* ebt press Uf Uv voidv  
7650200 000 9.4996 134.05 1071.5 0.44943  
\*  
\* from to juna kf kr fvcahs  
7651101 762010000 765000000 110.9722 0.0 0.0 001000  
7652101 765010000 766000000 0.8685 1.5 100.0 001001 \* discourage reverse  
flow  
\*  
\* jun\_Dh flood gas-int slope  
7651110 0.1128 0.0 1.0 1.0  
7652110 0.6651 0.0 1.0 1.0  
\*  
\* liq\_vel vap\_vel vel.int.  
7651201 37.265 5.8851 0.  
7652201 -0.42722 -10.256 0.  
\*  
\*  
\* component 766 - RFW Heater A5 Collector  
7660000 'Coll-A5' branch  
\*  
\* #juns vel/flow

7660001 1 0  
\*  
\* area length vol theta phi elev rough hyd pvbfe  
7660101 4.9087 0.0 145.2255 0. 0.0 0.0 1.5e-4 0.0 00000  
\*  
\* ebt press Uf Uv voidv  
7660200 000 9.9594 146.78 1072.2 0.10641  
\*  
\* from to juna kf kr fvcahs  
7661101 766010002 760030003 4.9087 1.0 0.50 031000  
\*  
\* jun\_Dh flood gas-int slope  
7661110 2.5 0.0 1.0 1.0  
\*  
\* liq\_vel vap\_vel vel.int.  
7661201 -0.18014 -1.3910 0.  
\*  
\*  
\* component 767 - RFW HTRA5 Drain Valve  
\*  
7670000 'LCV6-14A' valve  
\*  
\* from to juna kf kr fvcahs  
7670101 761010000 969000000 0.7854 5.6209 5.6209 001000  
\*  
7670201 0 9.4 9.4 0. \*3,184,100/3 lb/hr target  
\*  
7670300 srvlv  
\*  
7670301 0429 \* valve position demand based on htr A5 level error  
\*  
7670400 1.0 2180.0 \* max Cv = 2180.0 per BFN-VTD-K125-0060 for  
\* 12" linear double-seated full-port  
7670401 0.0 0.0001 0.0001 \* Assume linear Cv vs stroke for globe  
7670402 1.0 1.0 \* valve  
\*  
\*  
\* component 768 - RFW HTRA5 Bypass Valve \*prb 01-24-96  
10:22am  
7680000 'LCV6-14B' valve \*prb 01-24-96 10:22am  
\* \*prb 01-24-96 10:22am  
\* from to juna kf kr fvcahs \*prb 01-24-96 10:22am  
\*7680101 761010000 969000000 0.7854 0.0 0.0 000000 \*prb 01-24-96  
10:22am  
7680101 761010000 969000000 0.7854 0.0 5.6209 001000 \*jam 7-26-96

```
*                                *prb 01-24-96 10:22am
7680201 1      0.0      0.0      0.0          *prb 01-24-96 10:22am
*
*                                *prb 01-24-96 10:22am
7680300 srvvlv          *prb 01-24-96 10:22am
*
*                                *prb 01-24-96 10:22am
7680301 0435 * valve position demand          *prb 01-24-96 10:22am
*
*                                *prb 01-24-96 10:22am
7680400 1.0    2180.0  * max Cv = 2180.0 per BFN-VTD-K125-0060 for  *prb
01-24-96 10:22am
*
*                                12" linear double-seated full-port *prb 01-24-96 10:22am
7680401 0.0    0.0001   0.0001 * Assume linear Cv vs stroke for globe *prb 01-24-96
10:22am
7680402 1.0    1.0      1.0      * valve          *prb 01-24-96 10:22am
*
*
*-----
* Train B Feedwater Heaters - Shellside
*-----
*
* component 801 - RFW HTR B1 Steam Supply
8010000 'STM-src1'  tmdpvol
*
*      area  length  vol  azmth  incl  elev  rough  hyd  fe
8010101 5.0   10.0   0.0   0.0   90.0  10.0   0.0   0.0   10
*
*      ebt  trip  variable
8010200 002   0     cntrlvar 010  *RX Power, %          *prb 01-25-96 11:25pm
*
*      %pwr  press  qual.
8010201 0.0   7.545  0.9107  *extrapolated          *prb 01-26-96 10:38pm
8010202 25.0  55.019  0.9022          *prb 01-26-96 10:38pm
8010203 50.0  110.02  0.8907          *prb 01-26-96 10:38pm
8010204 75.0  153.73  0.8837          *prb 01-26-96 10:38pm
8010205 90.0  186.86  0.8791          *prb 01-26-96 10:38pm
8010206 100.0 209.01  0.8765          *prb 01-26-96 10:38pm
*
*
* component 802 - RFW HTR B2 Steam Supply
8020000 'STM-src2'  tmdpvol
*
*      area  length  vol  azmth  incl  elev  rough  hyd  fe
8020101 5.0   10.0   0.0   0.0   0.0   0.0   0.0   0.0   10
*
*      ebt  trip  variable
```

---

```

8020200 002  0  cntrlvar 010  *RX Power, %           *prb 01-26-96 11:55pm
*
*   %pwr  press  qual.          *prb 01-26-96 11:55pm
8020201  0.0  3.43  0.9607    *extrapolated      *prb 01-26-96 11:55pm
8020202  25.0  31.30  0.9587   *prb 01-26-96 11:55pm
8020203  50.0  61.70  0.9533   *prb 01-26-96 11:55pm
8020204  75.0  88.31  0.9530   *prb 01-26-96 11:55pm
8020205  90.0  107.20 0.9508   *prb 01-26-96 11:55pm
8020206 100.0  119.81 0.9495   *prb 01-26-96 11:55pm
*
*
* component 803 - RFW HTR B3 Steam Supply
8030000 'STM-src3'  tmdpvol
*
*   area  length vol  azmth incl  elev  rough  hyd  fe
8030101 5.0   10.0  0.0   0.0   0.0   0.0   0.0   0.0   10
*
*   ebt  trip  variable
8030200 002  0  cntrlvar 010  *RX Power, %           *prb 01-26-96 11:55pm
*
*   %pwr  press  qual.          *prb 01-26-96 11:55pm
8030201  0.0  1.99  0.9421    *extrapolated      *prb 01-26-96 11:55pm
8030202  25.0  19.80  0.9389   *prb 01-26-96 11:55pm
8030203  50.0  38.70  0.9316   *prb 01-26-96 11:55pm
8030204  75.0  55.97  0.9305   *prb 01-26-96 11:55pm
8030205  90.0  67.71  0.9276   *prb 01-26-96 11:55pm
8030206 100.0  75.51  0.9259   *prb 01-26-96 11:55pm
*
*
* component 804 - RFW HTR B4 Steam Supply #1
8040000 'STMsrc4A'  tmdpvol
*
*   area  length vol  azmth incl  elev  rough  hyd  fe
8040101 2.8229 10.0  0.0   0.0   0.0   0.0   0.0   0.0   10
*
*   ebt  trip  variable
8040200 002  0  cntrlvar 010  *RX Power, %           *prb 01-27-96 10:08am
*
*   %pwr  press  qual.          *prb 01-27-96 10:08am
8040201  0.0  0.75  0.6576    *extrapolated      *prb 01-27-96 10:08am
8040202  25.0  7.66  0.7094   *prb 01-27-96 10:08am
8040203  50.0  14.80  0.8077   *prb 01-27-96 10:08am
8040204  75.0  21.59  0.8363   *prb 01-27-96 10:08am
8040205  90.0  26.05  0.8437   *prb 01-27-96 10:08am
8040206 100.0  29.00  0.8482   *prb 01-27-96 10:08am

```

\*  
\*  
\* component 805 - RFW HTR B4 Steam Supply #2  
8050000 'STMsric4B' tmdpvol  
\*  
\* area length vol azmth incl elev rough hyd fe  
8050101 2.8229 10.0 0.0 0.0 0.0 0.0 0.0 0.0 10  
\*  
\* ebt trip variable  
8050200 002 0 cntrlvar 010 \*RX Power, % \*prb 01-27-96 10:08am  
\* \*prb 01-27-96 10:08am  
\* %pwr press qual. \*prb 01-27-96 10:08am  
8050201 0.0 1.127 0.3577 \*extrapolated \*prb 01-27-96 10:08am  
8050202 25.0 12.30 0.4394 \*prb 01-27-96 10:08am  
8050203 50.0 24.00 0.5701 \*prb 01-27-96 10:08am  
8050204 75.0 34.91 0.6273 \*prb 01-27-96 10:08am  
8050205 90.0 42.24 0.6434 \*prb 01-27-96 10:08am  
8050206 100.0 47.12 0.6485 \*prb 01-27-96 10:08am  
\*  
\*  
\* component 806 - RFW HTR B5 Steam Supply #1 (From "B" LP Turbine, point MR5)  
8060000 'STMsric5A' tmdpvol  
\*  
\* area length vol azmth incl elev rough hyd fe  
8060101 9.0164 10.0 0.0 0.0 0.0 0.0 0.0 0.0 10  
\*  
\* ebt trip variable  
8060200 002 0 cntrlvar 010 \*RX Power, % \*prb 01-27-96 12:31pm  
\* \*prb 01-27-96 12:31pm  
\* %pwr press qual. \*prb 01-27-96 12:31pm  
8060201 0.0 0.30 0.064 \*extrapolated \*prb 01-27-96 12:31pm  
8060202 25.0 4.59 0.1630 \*prb 01-27-96 12:31pm  
8060203 50.0 8.88 0.2620 \*prb 01-27-96 12:31pm  
8060204 75.0 13.01 0.5389 \*prb 01-27-96 12:31pm  
8060205 90.0 15.71 0.5008 \*prb 01-27-96 12:31pm  
8060206 100.0 17.49 0.4806 \*prb 01-27-96 12:31pm  
\*  
\*  
\* component 807 - RFW HTR B5 Steam Supply #2 (From "C" LP Turbine, point #5)  
8070000 'STMsric5B' tmdpvol  
\*  
\* area length vol azmth incl elev rough hyd fe  
8070101 9.0164 10.0 0.0 0.0 0.0 0.0 0.0 0.0 10  
\*  
\* ebt trip variable

---

```

8070200 002  0  cntrlvar 010  *RX Power, %          *prb 01-27-96 12:31pm
*
*   %pwr  press  qual.          *prb 01-27-96 12:31pm
8070201  0.0  0.45  0.2807    *extrapolated        *prb 01-27-96 12:31pm
8070202  25.0  2.69  0.4153      *prb 01-27-96 12:31pm
8070203  50.0  5.05  0.5633      *prb 01-27-96 12:31pm
8070204  75.0  7.23  0.6912      *prb 01-27-96 12:31pm
8070205  90.0  8.66  0.7368      *prb 01-27-96 12:31pm
8070206 100.0  9.60  0.7545      *prb 01-27-96 12:31pm
*
*
* component 808 - Moisture Separator
8080000 'Mois-Sep'  tmdpvol
*
*   area  length  vol  azmth  incl  elev  rough  hyd  fe
8080101 5.0   10.0  0.0   0.0   0.0   0.0   0.0   10
*
*   ebt  trip  variable          *prb 01-26-96 11:47pm
8080200 001  0  cntrlvar 010  *RX Power, %          *prb 01-26-96 11:47pm
*
*   %pwr  temp  qual.          *prb 01-26-96 11:47pm
8080201  0.0  253.12  0.0    *extrapolated        *prb 01-26-96 11:47pm
8080202  25.0  286.00  0.0      *prb 01-26-96 11:47pm
8080203  50.0  333.40  0.0      *prb 01-26-96 11:47pm
8080204  75.0  359.02  0.0      *prb 01-26-96 11:47pm
8080205  90.0  374.74  0.0      *prb 01-26-96 11:47pm
8080206 100.0  384.07  0.0      *prb 01-26-96 11:47pm
*
*
* component 809: Moisture Separator Drain to HTR B2
8090000 'MS-drain'  tmdpjun
8090101 808000000  831000000  1.3963
*
*   trip  variable          *prb 01-26-96 11:47pm
*8090200 1  0  cntrlvar 010  *RX Power, %          *prb 01-26-96 11:47pm
8090200 1  633  cntrlvar 010  *RX Power, %          *jam 7-27-96
*
*   %pwr  liq.flow  .          *prb 01-26-96 11:47pm
8090201  0.0  0.0   0.0   0.0          *prb 01-26-96 11:47pm
8090202  25.0  22.4352  0.0   0.0   *242,300/3 lb/hr  *prb 01-26-96 11:47pm
8090203  50.0  54.9444  0.0   0.0   *593,400/3 lb/hr  *prb 01-26-96 11:47pm
8090204  75.0  82.8714  0.0   0.0   *895,011/3 lb/hr  *prb 01-26-96 11:47pm
8090205  90.0  105.3094  0.0   0.0   *1,137,342/3 lb/hr  *prb 01-26-96 11:47pm
8090206 100.0  120.7569  0.0   0.0   *1,304,175/3 lb/hr  *prb 01-26-96 11:47pm
*
```

\*

\* component 810 - RFW Heater A1 steam supply vlv - jam 7-27-96  
8100000 b1stmvlv valve \*jam 7-27-96  
\* from to juna kf kr fvcahs  
8100101 801000000 820000000 1.3417 15.7355 15.7355 000000 \*jam 7-27-96  
\* liq\_vel vap\_vel vel.int.  
8100201 0 60.166 118.13 0.0 \*jam 7-26-96  
8100300 trpvlv \*jam 7-26-96  
8100301 633 \*jam 7-26-96  
\*

\* component 820 - RFW Heater A1 Steam Dome (top of vertical shell)  
8200000 'HTRB1-s1' branch  
\*

\* #juns vel/flow  
\*8200001 2 0  
8200001 1 0 \*jam 7-27-96  
\*

\* area length vol theta phi elev rough hyd pvbfe  
8200101 12.34 13.7904 0. 0. -90.0 -13.7904 1.5e-4 0.0772 00100  
\*

\* ebt press Uf Uv voidv  
8200200 000 198.29 354.09 1113.5 0.99410  
\*

\* from to juna kf kr fvcahs  
\*8201101 801000000 820000000 1.3417 15.7355 15.7355 000000 \*jam 7-27-96  
\*8202101 820010000 821000000 0. 0. 0. 101000 \*jam 7-27-96  
8201101 820010000 821000000 0. 0. 0. 101000 \*jam 7-27-96  
\*

\* jun\_Dh flood gas-int slope  
\*8201110 0.0 0.0 1.0 1.0 \*jam 7-27-96  
\*8202110 0.0772 0.0 1.0 1.0 \*jam 7-27-96  
8201110 0.0772 0.0 1.0 1.0  
\*

\* liq\_vel vap\_vel vel.int.  
\*8201201 60.166 118.13 0.0 \*jam 7-27-96  
\*8202201 7.3903 8.4137 0.0 \*jam 7-27-96  
8201201 7.3903 8.4137 0.0 \*jam 7-27-96  
\*

\* component 821 - RFW Heater B1 Shellside middle volumes  
8210000 'HTRB1-s2' pipe  
\*

\* nv  
8210001 3  
\*

\* flowa vn

8210101 12.34 3 \*Shell area (60.75" ID) minus tube area (5/8"OD)  
\* \*tube area = (2)(1906 tubes)(tube area)  
\*  
\* flowl vn  
8210301 10.4596 1  
8210302 2.6667 3 \*same as corresponding primary tube length  
\*  
\* volume vn  
8210401 0.0 3  
\*  
\* incl vn  
8210601 -90.0 3  
\*  
\* roughness dhyd vn  
8210801 1.5e-4 0.0772 3  
\*  
\* kf kr jn  
8210901 0.0 0.0 2  
\*  
\* pvbfe vn  
8211001 00100 3  
\*  
\* fvcahs jn  
8211101 101000 2  
\*  
\* ebt press. Uf Uv voidv VN  
8211201 0 198.33 354.09 1113.5 0.99189 0. 1  
8211202 0 198.36 354.05 1113.5 0.96348 0. 2  
8211203 0 198.89 336.85 1113.6 2.33801e-02 0. 3  
\*  
\* vel/flow  
8211300 0  
\*  
\* liq-flo vap-flo vel.int jn  
8211301 11.168 2.4853 0. 1  
8211302 3.0088 5.32454e-02 0. 2  
\*  
\* jun\_Dh flood gas-int slope jn  
8211401 0.0772 0.0 1.0 1.0 2  
\*  
\* component 822 - RFW Heater B1 Tubesheet Shellside (bottom of vertical shell)  
8220000 'HTRB1-s3' branch  
\*  
\* #juns vel/flow

```
8220001 1    0
*
*   area  length  vol  theta  phi  elev  rough  hyd  pvbfe
8220101 12.34  1.3307 0.  0.  -90.0 -1.3307 1.5e-4 0.0772 00100
*
*   ebt  press. Uf      Uv      voidv
8220200 000  199.30 338.19  1113.6  0.0
*
*   from      to      juna  kf   kr   fvcahs
8221101 821010000 822000000 0.  0.0  0.  101000
*
*   jun_Dh      flood  gas-int slope
8221110 0.0772     0.0  1.0  1.0
*
*   liq_vel    vap Vel vel.int.
8221201 0.11251  -1.1900      0.
*
*
* component 823 - RFW Heater B1 Drain Piping
8230000 'HTRB1drn' branch
*
*   #juns  vel/flow
8230001 1    0
*
*   area  length  vol  theta  phi  elev  rough  hyd  pvbfe
8230101 0.3474 10.0  0.  0.  82.6  9.9167 1.5e-4 0.0  00000
*
*   ebt  press. Uf      Uv      voidv
8230200 000  199.30 338.19  1113.6  0.0
*
*   from      to      juna  kf   kr   fvcahs
8231101 822010000 823000000 0.3474 0.0  0.  000100
*
*   liq_vel    vap Vel vel.int.
8231201 3.7345  3.7345      0.
*
*
* component 825 - RFW HTRB1 Drain Valve
8250000 'LCV6-19' valve
*
*   from      to      juna  kf   kr   fvcahs
8250101 823010000 831000000 0.0873 39.0223 39.0223 000000
*
8250201 0      15.463  15.465 0.  * 819,483/3 lb/hr
*
```

8250300 srvv1v  
\*  
8250301 0450 \* valve position demand from htr B1 level control system  
\*  
8250400 1.0 288.0 \* max Cv = 288.0 per BFN-VTD-K125-0060 for  
\* 4" linear double-seated full-port  
8250401 0.0 0.0001 0.0001 \* Assume linear Cv vs stroke for globe  
8250402 1.0 1.0 1.0 \* valve  
\*  
\* component 811 - RFW Heater B2 steam supply vlv - jam 7-27-96  
8110000 b2stmvlv valve \*jam 7-27-96  
\* from to juna kf kr fvcahs  
8110101 802000000 830000000 0.7854 14.1087 14.1087 000000 \*jam 7-27-96  
\* liq\_vel vap\_vel vel.int.  
8110201 0 74.200 202.58 0.0 \*jam 7-26-96  
8110300 trpv1v \*jam 7-26-96  
8110301 633 \*jam 7-26-96  
\*  
\* component 830 - RFW Heater A2 Steam Dome (top of vertical shell)  
8300000 'HTRB2-s1' branch  
\*  
\* #juns vel/flow  
\*8300001 2 0 \*jam 9-27-96  
8300001 1 0 \*jam 9-27-96  
\*  
\* area length vol theta phi elev rough hyd pvbfe  
8300101 12.34 10.2904 0. 0. -90.0 -10.2904 1.5e-4 0.0772 00100  
\*  
\* ebt press Uf Uv voidv  
8300200 000 109.21 304.89 1106.3 0.99832  
\*  
\* from to juna kf kr fvcahs  
\*8301101 802000000 830000000 0.7854 14.1087 14.1087 000001 \*jam 9-27-96  
\*8302101 830010000 831000000 12.34 0. 0. 101000 \*jam 9-27-96  
8301101 830010000 831000000 12.34 0. 0. 101000 \*jam 9-27-96  
\*  
\* jun\_Dh flood gas-int slope  
\*8301110 0.0 0.0 1.0 1.0 \*jam 9-27-96  
\*8302110 0.0772 0.0 1.0 1.0 \*jam 9-27-96  
8301110 0.0772 0.0 1.0 1.0 \*jam 9-27-96  
\*  
\* liq\_vel vap\_vel vel.int.  
\*8301201 74.200 202.58 0. \*jam 9-27-96  
\*8302201 12.027 7.9267 0. \*jam 9-27-96  
8301201 12.027 7.9267 0. \*jam 9-27-96

```
*  
*  
* component 831 - RFW Heater B2 drain junction volume  
8310000 'HTRB2-s2' branch  
*  
* #juns vel/flow  
8310001 1 0  
*  
* area length vol theta phi elev rough hyd pvbfe  
8310101 12.34 8.8763 0. 0. -90.0 -8.8763 1.5e-4 0.0772 00100  
*  
* ebt press Uf Uv voidv  
8310200 000 109.23 305.04 1106.4 0.97393  
*  
* from to juna kf kr fvcahs  
8311101 831010000 832000000 12.34 0. 0. 101000  
*  
* jun_Dh flood gas-int slope  
8311110 0.0772 0.0 1.0 1.0  
*  
* liq_vel vap_vel vel.int.  
8311201 10.895 3.4280 0.  
*  
*  
* component 832 - RFW Heater B2 Shellside middle volumes  
8320000 'HTRB2-s2' pipe  
*  
* nv  
8320001 2  
*  
* flowa vn  
8320101 12.34 2 *Shell area (60.75" ID) minus tube area (5/8"OD)  
* *tube area = (2)(1906 tubes)(tube area)  
*  
* flowl vn  
8320301 3.0000 2 *same as corresponding primary tube length  
*  
* volume vn  
8320401 0.0 2  
*  
* incl vn  
8320601 -90.0 2  
*  
* roughness dhyd vn  
8320801 1.5e-4 0.0772 2
```

---

```

*
*   kf   kr   jn
8320901 0.0  0.0  1
*
*   pvbfe      vn
8321001 00100    2
*
*   fvcahs     jn
8321101 101000    1
*
*   ebt  press. Uf      Uv      voidv          VN
8321201 000  109.25 304.86  1106.4  0.91724    0.  1
8321202 000  109.87 298.86  1106.4  5.89169e-02  0.  2
*
*   vel/flow
8321300 0
*
*   liq-flo  vap-flo  vel.int     jn
8321301 4.2183  0.30784  0.        1
*
*   jun_Dh      flood      gas-int      slope jn
8321401 0.0772    0.0       1.0       1.0  1
*
*
* component 833 - RFW Heater B2 Tubesheet Shellside (bottom of vertical shell)
8330000 'HTRB2-s3' branch
*
*   #juns vel/flow
8330001 1    0
*
*   area  length vol  theta phi elev  rough hyd  pvbfe
8330101 12.34  5.4974 0.  0.  -90.0 -5.4974 1.5e-4 0.0772 00100
*
*   ebt  press. Uf      Uv      voidv
8330200 000  111.52 291.80  1106.6  0.0
*
*   from      to      juna  kf   kr   fvcahs
8331101 832010000  833000000 12.34 0.0  0.  101000
*
*   jun_Dh      flood  gas-int slope
8331110 0.0772    0.0   1.0   1.0
*
*   liq_vel    vap_vel      vel.int.
8331201 0.42029  -0.82167    0.
*
```

```
*  
* component 834 - RFW Heater B2 Drain Piping  
8340000 'HTRB2drn' branch  
*  
* #juns vel/flow  
8340001 1 0  
*  
* area length vol theta phi elev rough hyd pvbfe  
8340101 0.5475 25.0 0. 0. 65.0 22.6667 1.5e-4 0.0 00000  
*  
* ebt press. Uf Uv voidv  
8340200 000 199.30 338.19 1113.6 0.0  
*  
* from to juna kf kr fvcahs  
8341101 833010000 834000000 0.5475 0.0 0. 000100  
*  
* liq_vel vap_vel vel.int.  
8341201 8.2628 7.7109 0.  
*  
*  
* component 835 - RFW HTRB2 Drain Valve  
8350000 'LCV6-22A' valve  
*  
* from to juna kf kr fvcahs  
8350101 834010000 841000000 0.3491 22.8653 22.8653 000000  
*  
8350201 1 228.5294 0.0 0. *2,468,117/3 lb/hr  
*  
8350300 srvvlv  
*  
8350301 0458 * valve position demand based from htr B2 level control *prb  
01-24-96 10:40am  
*  
8350400 1.0 950.0 * max Cv = 950.0 per BFN-VTD-K125-0060 for  
* 8" linear double-seated full-port  
8350401 0.0 0.0001 0.0001 * Assume linear Cv vs stroke for globe  
8350402 1.0 1.0 1.0 * valve  
*  
*  
* component 837 - RFW HTRB2 Bypass Valve *prb 01-23-96  
01:05pm  
8370000 'LCV6-4B' valve *prb 01-23-96 01:05pm  
* *prb 01-23-96 01:05pm  
* from to juna kf kr fvcahs *prb 01-23-96 01:05pm
```

---

```

*8370101 834010000 738000000 0.3491 0.0 0.0 000000 *prb 01-23-96
01:05pm
8370101 834010000 738000000 0.3491 22.8653 22.8653 000000 *prb 01-23-96
01:05pm
*
8370201 1 0.0 0.0 0.0 *prb 01-23-96 01:05pm
*prb 01-23-96 01:05pm
8370300 srvv1v *prb 01-23-96 01:05pm
*prb 01-23-96 01:05pm
8370301 0460 * valve position demand *prb 01-23-96 01:05pm
*prb 01-23-96 01:05pm
8370400 1.0 950.0 * max Cv = 950.0 per BFN-VTD-K125-0060 for *prb
01-23-96 01:05pm
* 8" linear double-seated full-port *prb 01-23-96 01:05pm
8370401 0.0 0.0001 0.0001 * Assume linear Cv vs stroke for globe *prb 01-23-96
01:05pm
8370402 1.0 1.0 1.0 * valve *prb 01-23-96 01:05pm
*
* component 812 - RFW Heater B3 steam supply vlv - jam 7-27-96
8120000 b3stmvlv valve *jam 7-27-96
* from to juna kf kr fvcahs
8120101 803000000 840000000 3.1416 23.4899 23.4899 000000 *jam 7-27-96
* liq_vel vap Vel vel.int.
8120201 0 7.7263 124.84 0.0 *jam 7-26-96
8120300 trpv1v *jam 7-26-96
8120301 633 *jam 7-26-96
*
* component 840 - RFW Heater A3 Steam Dome (top of vertical shell)
8400000 'HTRB3-s1' branch
*
* #juns vel/flow
*8400001 2 0 *jam 7-26-96
8400001 1 0 *jam 7-26-96
*
* area length vol theta phi elev rough hyd pvbfe
8400101 13.5335 12.4284 0. 0. -90.0 -12.4284 1.5e-4 0.0864 00100
*
* ebt press Uf Uv voidv
8400200 000 69.300 271.84 1099.9 0.99613
*
* from to juna kf kr fvcahs
*8401101 803000000 840000000 3.1416 23.4899 23.4899 000000 *jam 7-26-96
*8402101 840010000 841000000 13.5335 0. 0. 101000 *jam 7-26-96
8401101 840010000 841000000 13.5335 0. 0. 101000 *jam 7-26-96
*
```

```
* jun_Dh      flood  gas-int slope
*8401110 0.0      0.0  1.0  1.0          *jam 7-26-96
*8402110 0.0864    0.0  1.0  1.0          *jam 7-26-96
8401110 0.0864    0.0  1.0  1.0          *jam 7-26-96
*
* liq_vel  vap_vel      vel.int.
*8401201 7.7263   124.84     0.          *jam 7-26-96
*8402201 8.9171   19.266     0.          *jam 7-26-96
8401201 8.9171   19.266     0.          *jam 7-26-96
*
*
* component 841 - RFW Heater B3 drain junction volume
8410000 'HTRB3-s2' branch
*
* #juns vel/flow
8410001 1      0
*
* area length vol  theta phi elev  rough hyd  pvbfe
8410101 13.5335 11.1133 0.   0.  -90.0 -11.1133 1.5e-4 0.0864 00100
*
* ebt press Uf      Uv      voidv
8410200 000   69.309 271.88   1100.0   0.96083
*
* from      to      juna kf      kr      fvcahs
8411101 841010000   842000000 13.5335 0.   0.   101000
*
* jun_Dh      flood  gas-int slope
8411110 0.0864    0.0  1.0  1.0
*
* liq_vel  vap_vel      vel.int.
8411201 9.3922   5.8524     0.
*
*
* component 842 - RFW Heater B3 Shellside middle & lower volumes
8420000 'HTRB3-s3' pipe
*
* nv
8420001 4
*
* flowa      vn
8420101 13.5335    1
8420102 6.7667    4  *volumes 2-4 share space with subcooling zone
*
* flowl      vn
8420301 3.0000    2  *same as corresponding primary tube length
```

8420302 7.0534 4 \*same as corresponding primary tube length  
\*  
\* volume vn  
8420401 0.0 4  
\*  
\* incl vn  
8420601 -90.0 4  
\*  
\* roughness dhyd vn  
8420801 1.5e-4 0.0864 4  
\*  
\* kf kr jn  
8420901 0.0 0.0 3  
\*  
\* pvbfe vn  
8421001 00100 4  
\*  
\* fvcahs jn  
8421101 101000 3  
\*  
\* ebt press. Uf Uv voidv VN  
8421201 000 69.322 271.84 1100.0 0.98918 0. 1  
8421202 000 69.529 271.38 1099.9 0.16248 0. 2  
8421203 000 72.030 269.21 1100.5 2.68060e-06 0. 3  
8421204 000 74.835 267.04 1101.0 8.83757e-06 0. 4  
\*  
\* vel/flow  
8421300 0  
\*  
\* liq-flo vap-flo vel.int jn  
8421301 70.794 0.44862 0. 1  
8421302 0.75643 -0.90429 0. 2  
8421303 0.63162 0.77799 0. 3  
\*  
\* jun\_Dh flood gas-int slope jn  
8421401 0.0864 0.0 1.0 1.0 3  
\*  
\*  
\* component 843 - RFW Heater B3 Subcooling Zone  
8430000 'HTRB3-s4' pipe  
\*  
\* nv  
8430001 3  
\*  
\* flowa vn

8430101 6.7667 3  
\*  
\* flowl vn  
8430301 3.0000 1 \*same as corresponding primary tube length  
8430302 7.0534 3 \*same as corresponding primary tube length  
\*  
\* volume vn  
8430401 0.0 3  
\*  
\* incl vn  
8430601 -90.0 3  
\*  
\* roughness dhyd vn  
8430801 1.5e-4 0.0864 3  
\*  
\* kf kr jn  
8430901 0.0 0.0 2  
\*  
\* pvbfe vn  
8431001 00100 3  
\*  
\* fvcahs jn  
8431101 101000 2  
\*  
\* ebt press. Uf Uv voidv VN  
8431201 000 69.415 233.60 1100.1 8.99481e-02 0. 1  
8431202 000 71.404 226.39 1100.4 1.57683e-07 0. 2  
8431203 000 74.264 242.61 1100.9 3.17648e-06 0. 3  
\*  
\* vel/flow  
8431300 0  
\*  
\* liq-flo vap-flo vel.int jn  
8431301 3.53376e-02 -1.6814 0. 1  
8431302 3.03089e-02 3.099473e-02 0. 2  
\*  
\* jun\_Dh flood gas-int slope jn  
8431401 0.0864 0.0 1.0 1.0 2  
\*  
\* component 844 - RFW Heater B3 Drain Piping  
8440000 'HTRB3drn' branch  
\*  
\* #juns vel/flow  
8440001 1 1

```
*  
* area length vol theta phi elev rough hyd pvbfe  
8440101 0.5475 5.0 0. 0. 0. 0. 1.5e-4 0.0 00000  
*  
* ebt press. Uf Uv voidv  
8440200 000 199.30 338.19 1113.6 0.0  
*  
* from to juna kf kr fvcahs  
8441101 843010000 844000000 0.5475 0.0 0. 000100  
*  
* liq_vel vap_vel vel.int.  
8441201 228.5294 0.0 0.  
*  
*  
* component 845 - RFW HTRB3 Drain Valve  
8450000 'LCV6-23' valve  
*  
* from to juna kf kr fvcahs  
8450101 844010000 852000000 0.3491 7.4816 7.4816 000000  
*  
8450201 0 12.689 44.886 0. *2,468,117/3 lb/hr target  
*  
8450300 srvvlv  
*  
8450301 0472 * valve position demand based on htr B3 level error  
*  
8450400 1.0 950.0 * max Cv = 950.0 per BFN-VTD-K125-0060 for  
* 8" linear double-seated full-port  
8450401 0.0 0.0001 0.0001 * Assume linear Cv vs stroke for globe  
8450402 1.0 1.0 1.0 * valve  
*  
*  
8470000 'HTRB3jun' mtpljun  
8470001 2 0  
*  
* from to juna kf kr fvcahs incr1 incr2 jn  
8470011 842020004 843010003 .1 5. 5. 001000 1. 1. 1. 0 0 0 1  
8470021 842040004 843030003 1. 5. 5. 001000 1. 1. 1. 0 0 0 2  
*  
* liq-flo vap-flo jn  
8471011 4.0946 4.0946 1  
8471021 0.0 0.0 2  
*  
* component 813 - RFW Heater B4 steam supply vlv - jam 7-27-96  
8130000 b4stvlv1 valve *jam 7-27-96
```

```
* from to juna kf kr fvcahs
8130101 805000000 850000000 2.8229 6197.85 6197.85 000000 *jam 7-27-96
* liq_vel vap_vel vel.int.
8130201 0 0.83437 24.814 0.0 *jam 7-26-96
8130300 trpvlv *jam 7-26-96
8130301 633 *jam 7-26-96
*
*
* component 850 - RFW Heater A4 (top of shell nearest tubesheet)
8500000 'HTRB4-s1' branch
*
* #juns vel/flow
*8500001 2 0 *jam 7-26-96
8500001 1 0 *jam 7-26-96
*
* area length vol theta phi elev rough hyd pvbfe
8500101 0.0 2.9375 153.2704 0. -90.0 -2.9375 1.5e-4 0.1309 00100
*
* ebt press Uf Uv voidv
8500200 000 27.276 213.37 1086.4 0.99962
*
* from to juna kf kr fvcahs
*8501101 805000000 850000000 2.8229 6197.85 6197.85 000000 *jam 7-27-96
*8502101 850010000 851000000 9.7832 0. 0. 001003 *jam 7-27-96
8501101 850010000 851000000 9.7832 0. 0. 001003 *jam 7-27-96
*
* jun_Dh flood gas-int slope
*8501110 0.0 0.0 1.0 1.0 *jam 7-27-96
*8502110 0.1309 0.0 1.0 1.0 *jam 7-27-96
8501110 0.1309 0.0 1.0 1.0 *jam 7-27-96
*
* liq_vel vap_vel vel.int.
*8501201 0.83437 24.814 0. *jam 7-27-96
*8502201 9.1016 8.7249 0. *jam 7-27-96
8501201 9.1016 8.7249 0. *jam 7-27-96
*
* component 814 - RFW Heater B4 steam supply vlv - jam 7-27-96
8140000 b4stvlv2 valve *jam 7-27-96
* from to juna kf kr fvcahs
8140101 804000000 851000000 2.8229 4.4554 4.4554 000000 *jam 7-27-96
* liq_vel vap Vel vel.int.
8140201 0 41.854 271.59 0.0 *jam 7-26-96
8140300 trpvlv *jam 7-26-96
8140301 633 *jam 7-26-96
*
```

\*

\* component 851 - RFW Heater A4 (top of shell furthest from tubesheet)  
8510000 'HTRB4-s2' branch

\*

\* #juns vel/flow

\*8510001 2 0 \*jam 7-27-96  
8510001 1 0 \*jam 7-27-96

\*

\* area length vol theta phi elev rough hyd pvbfe  
8510101 0.0 2.9375 265.4972 0. -90.0 -2.9375 1.5e-4 0.1309 00100

\*

\* ebt press Uf Uv voidv  
8510200 000 27.276 213.38 1086.4 0.99996

\*

\* from to juna kf kr fvcahs  
\*8511101 804000000 851000000 2.8229 4.4554 4.4554 000000 \*jam 7-27-96  
\*8512101 851010000 852000000 153.4359 0. 0. 101000 \*jam 7-27-96  
8511101 851010000 852000000 153.4359 0. 0. 101000 \*jam 7-27-96

\*

\* jun\_Dh flood gas-int slope  
\*8511110 0.0 0.0 1.0 1.0 \*jam 7-27-96  
\*8512110 0.1309 0.0 1.0 1.0 \*jam 7-27-96  
8511110 0.1309 0.0 1.0 1.0 \*jam 7-27-96

\*

\* liq\_vel vap\_vel vel.int.  
\*8511201 41.854 271.59 0. \*jam 7-27-96  
\*8512201 38.784 4.5911 0. \*jam 7-27-96  
8511201 38.784 4.5911 0. \*jam 7-27-96

\*

\*

\* component 852 - RFW Heater B4 (bottom of shell furthest from tubesheet)  
8520000 'HTRB4-s3' branch

\*

\* #juns vel/flow  
8520001 0 0

\*

\* area length vol theta phi elev rough hyd pvbfe  
8520101 0.0 2.9375 265.4972 0. -90.0 -2.9375 1.5e-4 0.1309 00100

\*

\* ebt press Uf Uv voidv  
8520200 000 27.292 209.34 1086.4 0.52487

\*

\*

\* component 853 - RFW Heater B4 Subcooling Zone  
8530000 'HTRB4-s4' branch

```
*  
* #juns vel/flow  
8530001 1 0  
*  
* area length vol theta phi elev rough hyd pvbfe  
8530101 9.7832 15.6667 0.0 0. 0.0 0.0 1.5e-4 0.1309 00100  
*  
* ebt press Uf Uv voidv  
8530200 000 26.746 170.92 1086.2 2.46992e-02  
*  
* from to juna kf kr fvcahs  
8531101 852010000 853000000 1.7671 5.0 5.0 001000  
*  
* jun_Dh flood gas-int slope  
8531110 0.1309 0.0 1.0 1.0  
*  
* liq_vel vap_vel vel.int.  
8531201 6.4784 37.792 0.  
*  
*  
* component 854 - RFW Heater B4 Drain Piping  
8540000 'HTRB4drn' branch  
*  
* #juns vel/flow  
8540001 1 0  
*  
* area length vol theta phi elev rough hyd pvbfe  
8540101 1.6230 10.0 0. 0. 50.15 7.6771 1.5e-4 0.0 00000  
*  
* ebt press. Uf Uv voidv  
8540200 000 26.326 174.57 1085.9 7.05438e-04  
*  
* from to juna kf kr fvcahs  
8541101 853010000 854000000 1.6230 0.0 0. 000100  
*  
* liq_vel vap_vel vel.int.  
8541201 3.1304 4.5777 0.  
*  
*  
* component 855 - RFW HTRB4 Drain Valve  
8550000 'LCV6-29A' valve  
*  
* from to juna kf kr fvcahs  
8550101 854010000 860010003 0.7854 23.7848 23.7848 000000  
*
```

8550201 0 7.5514 7.5514 0. \*3,184,100/3 lb/hr target  
\*  
8550300 srvvlv  
\*  
8550301 0482 \* valve position demand based on htr B4 level error  
\*  
8550400 1.0 2180.0 \* max Cv = 2180.0 per BFN-VTD-K125-0060 for  
\* 12" linear double-seated full-port  
8550401 0.0 0.0001 0.0001 \* Assume linear Cv vs stroke for globe  
8550402 1.0 1.0 1.0 \* valve  
\*  
\*  
\* component 857 - RFW HTRB4 Bypass Valve \*prb 01-24-96  
10:22am  
8570000 'LCV6-29B' valve \*prb 01-24-96 10:22am  
\* \*prb 01-24-96 10:22am  
\* from to juna kf kr fvcahs \*prb 01-24-96 10:22am  
\*8570101 854010000 758000000 0.7854 0.0 0.0 000000 \*prb 01-24-96  
10:22am  
8570101 854010000 758000000 0.7854 23.7848 23.7848 000000 \*jam 7-26-96  
\* \*prb 01-24-96 10:22am  
8570201 1 0.0 0.0 0.0 \*prb 01-24-96 10:22am  
\* \*prb 01-24-96 10:22am  
\*prb 01-24-96 10:22am  
\*prb 01-24-96 10:22am  
8570300 srvvlv  
\* \*prb 01-24-96 10:22am  
\*prb 01-24-96 10:22am  
8570301 0460 \* valve position demand \*prb 01-24-96 10:22am  
\* \*prb 01-24-96 10:22am  
8570400 1.0 2180.0 \* max Cv = 2180.0 per BFN-VTD-K125-0060 for \*prb  
01-24-96 10:22am  
\* 12" linear double-seated full-port \*prb 01-24-96 10:22am  
8570401 0.0 0.0001 0.0001 \* Assume linear Cv vs stroke for globe \*prb 01-24-96  
10:22am  
8570402 1.0 1.0 1.0 \* valve \*prb 01-24-96 10:22am  
\*  
\*  
\* component 860 - RFW Heater B5 Flash Tank  
8600000 'FL-TankB' pipe  
\*  
\* nv  
8600001 4  
\*  
\* flowa vn  
8600101 16.4988 4  
\*  
\* flowl vn

```
8600301 1.4583      1
8600302 2.9583      2
8600303 2.500       3
8600304 5.2188      4
*
*      volume      vn
8600401 0.0          4
*
*      incl        vn
8600601 -90.0        4
*
*      roughness   dhyd  vn
8600801 0.0          0.0  4
*
*      kf         kr    jn
8600901 0.0          0.0  3
*
*      pvbfe      vn
8601001 00010        4
*
*      fvcahs     jn
8601101 101000       3
*
*      ebt  press. Uf      Uv      voidv      VN
8601201 000  9.6940 160.59  1071.8  0.98351  0.  1
8601202 000  9.6954 159.92  1071.8  0.99883  0.  2
8601203 000  9.9628 160.43  1072.2  0.53140  0.  3
8601204 000  12.394 159.48  1075.2  0.00000e+00  0.  4
*
*      vel/flow
8601300 0
*
*      liq-flo  vap-flo      vel.int     jn
8601301 19.581 0.27746    0.        1
8601302 282.58 0.63630    0.        2
8601303 0.63560 -4.2606   0.        3
*
*      jun_Dh      flood      gas-int      slope jn
8601401 0.0          0.0      1.0        1.0  3
*
*
* component 861 - RFW Heater B5 Drain Piping
8610000 'HTRB5drn' branch
*
*      #juns  vel/flow
```

```
8610001 1    0
*
*   area  length  vol  theta  phi  elev  rough  hyd  pvbfe
8610101 2.9483 10.0  0.  0.  0.0  0.0  1.5e-4 0.0  00000
*
*   ebt  press. Uf      Uv      voidv
8610200 000  13.552 159.14  1076.4  0.0
*
*   from      to      juna  kf  kr  fvcahs
8611101 860010000  861000000  2.9483 0.0  0.  000100
*
*   liq_vel  vap_vel      vel.int.
8611201 1.6705  1.9099      0.
*
* component 815 - RFW Heater B5 steam supply vlv - jam 7-27-96
8150000 b5stvlv1  valve *jam 7-27-96
*   from      to      juna  kf  kr  fvcahs
8150101 806000000  862000000  9.0164 6243.8 6243.8 000000 *jam 7-27-96
*   liq_vel  vap Vel      vel.int.
8150201 0  0.49198  22.264      0.0          *jam 7-26-96
8150300 trpvlv                                *jam 7-26-96
8150301 633                                    *jam 7-26-96
*
*
* component 862 - RFW Heater B5 (top of shell nearest tubesheet)
8620000 'HTRB5-s1'  branch
*
*   #juns  vel/flow
*8620001 3    0          *jam 7-27-96
8620001 2    0          *jam 7-27-96
*
*   area  length  vol  theta  phi  elev  rough  hyd  pvbfe
8620101 0.0  2.8333 170.5096 0.  -90.0 -2.8333 1.5e-4 0.1128 00100
*
*   ebt  press  Uf      Uv      voidv
8620200 000  9.4593 158.61  1071.3  0.99998
*
*   from      to      juna  kf  kr  fvcahs
*8621101 806000000  862000000  9.0164 6243.8 6243.8 001000
*jam 7-27-96
*8622101 862010000  863000000  8.7069 0.  0.  001003
*jam 7-27-96
8621101 862010000  863000000  8.7069 0.  0.  001003
*jam 7-27-96
```

```
*8623101 860000000 862000000 0.7530 1.50 1.50 001000
*jam 7-27-96
8622101 860000000 862000000 0.7530 1.50 1.50 001000
*jam 7-27-96
*
* jun_Dh    flood  gas-int slope
*8621110 2.3958      0.0  1.0  1.0                      *jam 7-27-96
*8622110 0.1128      0.0  1.0  1.0                      *jam 7-27-96
8621110 0.1128      0.0  1.0  1.0                      *jam 7-27-96
*8623110 0.0          0.0  1.0  1.0                      *jam 7-27-96
8622110 0.0          0.0  1.0  1.0                      *jam 7-27-96
*
* liq_vel  vap_vel    vel.int.
*8621201 0.49198     22.264   0.                         *jam 7-27-96
*8622201 -31.397     -26.477   0.                         *jam 7-27-96
8621201 -31.397     -26.477   0.                         *jam 7-27-96
*8623201 -30.730     237.56    0.                         *jam 7-27-96
8622201 -30.730     237.56    0.                         *jam 7-27-96
*
* component 816 - RFW Heater B5 steam supply vlv - jam 7-27-96
8160000 b5stv1v2    valve *jam 7-27-96
* from      to       juna kf kr fvcahs
8160101 807000000 863000000 9.0164 2.9489 2.9489 000000 *jam 7-27-96
* liq_vel  vap_vel    vel.int.
8160201 0 26.337    161.50   0.0                         *jam 7-26-96
8160300 trpv1v2
8160301 633
*
*
* component 863 - RFW Heater B5 (top of shell furthest from tubesheet)
8630000 'HTRB5-s2' branch
*
* #juns vel/flow
*8630001 2 0          *jam 7-27-96
8630001 1 0          *jam 7-27-96
*
* area length vol theta phi elev rough hyd pvbfe
8630101 0.0 2.8333 128.8119 0. -90.0 -2.8333 1.5e-4 0.1128 00100
*
* ebt press Uf      Uv      voidv
8630200 000 9.4589 158.60 1071.4 0.99992
*
* from      to       juna kf kr fvcahs
*8631101 807000000 863000000 9.0164 2.9489 2.9489 001000 *jam 9-27-96
*8632101 863010000 864000000 83.8342 0. 0. 001000 *jam 9-27-96
```

```
8631101 863010000    864000000    83.8342  0.   0.   001000    *jam 9-27-96
*
*   jun_Dh      flood  gas-int slope
*8631110 2.3958      0.0   1.0   1.0                      *jam 9-27-96
*8632110 0.1128      0.0   1.0   1.0                      *jam 9-27-96
8631110 0.1128      0.0   1.0   1.0                      *jam 9-27-96
*
*   liq_vel    vap_vel      vel.int.
*8631201 26.337     161.50      0.                      *jam 9-27-96
*8632201 34.542     8.5995      0.                      *jam 9-27-96
8631201 34.542     8.5995      0.                      *jam 9-27-96
*
*
* component 864 - RFW Heater B5 (bottom of shell furthest from tubesheet)
8640000 'HTRB5-s3' branch
*
*   #juns  vel/flow
8640001 2    0
*
*   area  length vol  theta phi elev  rough hyd  pvbfe
8640101 0.0  2.8333 128.8119 0.  -90.0 -2.8333 1.5e-4 0.1128 00100
*
*   ebt  press Uf      Uv      voidv
8640200 000  9.6340 148.68   1071.7  0.39598
*
*   from      to      juna kf   kr   fvcahs
8641101 864010004  865010003  8.7069 0.   0.   001000
8642101 864010000  866000000  0.8685 1.5  100.0 001001 * discourage reverse
flow
*
*   jun_Dh      flood  gas-int slope
8641110 0.1128      0.0   1.0   1.0
8642110 0.6651      0.0   1.0   1.0
*
*   liq_vel    vap_vel      vel.int.
8641201 3.4725   -8.5376      0.
8642201 0.47271   -9.3520      0.
*
*
* component 865 - RFW Heater B5 (bottom of shell nearest tubesheet)
8650000 'HTRB5-s4' branch
*
*   #juns  vel/flow
8650001 2    0
*
```

```
* area length vol theta phi elev rough hyd pvbfe
8650101 0.0 2.8333 170.5096 0. -90.0 -2.8333 1.5e-4 0.1128 00100
*
* ebt press Uf Uv voidv
8650200 000 9.4996 134.05 1071.5 0.44943
*
* from to juna kf kr fvcahs
8651101 862010000 865000000 110.9722 0.0 0.0 001000
8652101 865010000 866000000 0.8685 1.5 100.0 001001 * discourage reverse
flow
*
* jun_Dh flood gas-int slope
8651110 0.1128 0.0 1.0 1.0
8652110 0.6651 0.0 1.0 1.0
*
* liq_vel vap_vel vel.int.
8651201 37.265 5.8851 0.
8652201 -0.42722 -10.256 0.
*
*
* component 866 - RFW Heater B5 Collector
8660000 'Coll-B5' branch
*
* #juns vel/flow
8660001 1 0
*
* area length vol theta phi elev rough hyd pvbfe
8660101 4.9087 0.0 145.2255 0. 0.0 0.0 1.5e-4 0.0 00000
*
* ebt press Uf Uv voidv
8660200 000 9.9594 146.78 1072.2 0.10641
*
* from to juna kf kr fvcahs
8661101 866010002 860030003 4.9087 1.0 0.50 031000
*
* jun_Dh flood gas-int slope
8661110 2.5 0.0 1.0 1.0
*
* liq_vel vap_vel vel.int.
8661201 -0.18014 -1.3910 0.
*
*
* component 867 - RFW HTRB5 Drain Valve
*
8670000 'LCV6-32A' valve
```

\*  
\* from to juna kf kr fvcahs  
8670101 861010000 969000000 0.7854 5.6209 5.6209 001000  
\*  
8670201 0 9.4 9.4 0. \*3,184,100/3 lb/hr target  
\*  
8670300 srvv1v  
\*  
8670301 0493 \* valve position demand based on htr B5 level error  
\*  
8670400 1.0 2180.0 \* max Cv = 2180.0 per BFN-VTD-K125-0060 for  
\* 12" linear double-seated full-port  
8670401 0.0 0.0001 0.0001 \* Assume linear Cv vs stroke for globe  
8670402 1.0 1.0 1.0 \* valve  
\*  
\*  
\* component 868 - RFW HTRB5 Bypass Valve \*prb 01-24-96  
10:22am  
8680000 'LCV6-32B' valve \*prb 01-24-96 10:22am  
\* \*prb 01-24-96 10:22am  
\* from to juna kf kr fvcahs \*prb 01-24-96 10:22am  
\*8680101 861010000 969000000 0.7854 0.0 0.0 000000 \*prb 01-24-96  
10:22am  
8680101 861010000 969000000 0.7854 0.0 5.6209 001000 \*jam 7-26-96  
\* \*prb 01-24-96 10:22am  
8680201 1 0.0 0.0 0.0 \*prb 01-24-96 10:22am  
\* \*prb 01-24-96 10:22am  
8680300 srvv1v \*prb 01-24-96 10:22am  
\* \*prb 01-24-96 10:22am  
8680301 0495 \* valve position demand \*prb 01-24-96 10:22am  
\* \*prb 01-24-96 10:22am  
8680400 1.0 2180.0 \* max Cv = 2180.0 per BFN-VTD-K125-0060 for \*prb  
01-24-96 10:22am  
\* 12" linear double-seated full-port \*prb 01-24-96 10:22am  
8680401 0.0 0.0001 0.0001 \* Assume linear Cv vs stroke for globe \*prb 01-24-96  
10:22am  
8680402 1.0 1.0 1.0 \* valve \*prb 01-24-96 10:22am  
\*  
\*-----  
\* Train C Feedwater Heaters - Shellside  
\*-----  
\*-----  
\* component 901 - RFW HTR C1 Steam Supply

9010000 'STM-src1' tmdpvol  
\*  
\* area length vol azmth incl elev rough hyd fe  
9010101 5.0 10.0 0.0 0.0 90.0 10.0 0.0 0.0 10  
\*  
\* ebt trip variable  
9010200 002 0 cntrlvar 010 \*RX Power, % \*prb 01-25-96 11:25pm  
\*  
\* %pwr press qual.  
9010201 0.0 7.545 0.9107 \*extrapolated \*prb 01-26-96 10:38pm  
9010202 25.0 55.019 0.9022 \*prb 01-26-96 10:38pm  
9010203 50.0 110.02 0.8907 \*prb 01-26-96 10:38pm  
9010204 75.0 153.73 0.8837 \*prb 01-26-96 10:38pm  
9010205 90.0 186.86 0.8791 \*prb 01-26-96 10:38pm  
9010206 100.0 209.01 0.8765 \*prb 01-26-96 10:38pm  
\*  
\*  
\* component 902 - RFW HTR C2 Steam Supply  
9020000 'STM-src2' tmdpvol  
\*  
\* area length vol azmth incl elev rough hyd fe  
9020101 5.0 10.0 0.0 0.0 0.0 0.0 0.0 0.0 10  
\*  
\* ebt trip variable  
9020200 002 0 cntrlvar 010 \*RX Power, % \*prb 01-26-96 11:55pm  
\*  
\* %pwr press qual.  
9020201 0.0 3.43 0.9607 \*extrapolated \*prb 01-26-96 11:55pm  
9020202 25.0 31.30 0.9587 \*prb 01-26-96 11:55pm  
9020203 50.0 61.70 0.9533 \*prb 01-26-96 11:55pm  
9020204 75.0 88.31 0.9530 \*prb 01-26-96 11:55pm  
9020205 90.0 107.20 0.9508 \*prb 01-26-96 11:55pm  
9020206 100.0 119.81 0.9495 \*prb 01-26-96 11:55pm  
\*  
\*  
\* component 903 - RFW HTR C3 Steam Supply  
9030000 'STM-src3' tmdpvol  
\*  
\* area length vol azmth incl elev rough hyd fe  
9030101 5.0 10.0 0.0 0.0 0.0 0.0 0.0 0.0 10  
\*  
\* ebt trip variable  
9030200 002 0 cntrlvar 010 \*RX Power, % \*prb 01-26-96 11:55pm  
\*  
\* %pwr press qual. \*prb 01-26-96 11:55pm

9030201 0.0 1.99 0.9421 \*extrapolated \*prb 01-26-96 11:55pm  
9030202 25.0 19.80 0.9389 \*prb 01-26-96 11:55pm  
9030203 50.0 38.70 0.9316 \*prb 01-26-96 11:55pm  
9030204 75.0 55.97 0.9305 \*prb 01-26-96 11:55pm  
9030205 90.0 67.71 0.9276 \*prb 01-26-96 11:55pm  
9030206 100.0 75.51 0.9259 \*prb 01-26-96 11:55pm  
\*  
\*  
\* component 904 - RFW HTR C4 Steam Supply #1  
9040000 'STMsrc4A' tmdpvol  
\*  
\* area length vol azmth incl elev rough hyd fe  
9040101 2.8229 10.0 0.0 0.0 0.0 0.0 0.0 10  
\*  
\* ebt trip variable  
9040200 002 0 cntrlvar 010 \*RX Power, % \*prb 01-27-96 10:08am  
\* \*prb 01-27-96 10:08am  
\* %pwr press qual. \*prb 01-27-96 10:08am  
9040201 0.0 0.75 0.6576 \*extrapolated \*prb 01-27-96 10:08am  
9040202 25.0 7.66 0.7094 \*prb 01-27-96 10:08am  
9040203 50.0 14.80 0.8077 \*prb 01-27-96 10:08am  
9040204 75.0 21.59 0.8363 \*prb 01-27-96 10:08am  
9040205 90.0 26.05 0.8437 \*prb 01-27-96 10:08am  
9040206 100.0 29.00 0.8482 \*prb 01-27-96 10:08am  
\*  
\*  
\* component 905 - RFW HTR C4 Steam Supply #2  
9050000 'STMsrc4B' tmdpvol  
\*  
\* area length vol azmth incl elev rough hyd fe  
9050101 2.8229 10.0 0.0 0.0 0.0 0.0 0.0 10  
\*  
\* ebt trip variable  
9050200 002 0 cntrlvar 010 \*RX Power, % \*prb 01-27-96 10:08am  
\* \*prb 01-27-96 10:08am  
\* %pwr press qual. \*prb 01-27-96 10:08am  
9050201 0.0 1.127 0.3577 \*extrapolated \*prb 01-27-96 10:08am  
9050202 25.0 12.30 0.4394 \*prb 01-27-96 10:08am  
9050203 50.0 24.00 0.5701 \*prb 01-27-96 10:08am  
9050204 75.0 34.91 0.6273 \*prb 01-27-96 10:08am  
9050205 90.0 42.24 0.6434 \*prb 01-27-96 10:08am  
9050206 100.0 47.12 0.6485 \*prb 01-27-96 10:08am  
\*  
\*  
\* component 906 - RFW HTR C5 Steam Supply #1 (From "B" LP Turbine, point MR5)

9060000 'STMsrc5A' tmdpvol  
\*  
\* area length vol azmth incl elev rough hyd fe  
9060101 9.0164 10.0 0.0 0.0 0.0 0.0 0.0 0.0 10  
\*  
\* ebt trip variable  
9060200 002 0 cntrlvar 010 \*RX Power, % \*prb 01-27-96 12:31pm  
\* \*prb 01-27-96 12:31pm  
\* %pwr press qual. \*prb 01-27-96 12:31pm  
9060201 0.0 0.30 0.064 \*extrapolated \*prb 01-27-96 12:31pm  
9060202 25.0 4.59 0.1630 \*prb 01-27-96 12:31pm  
9060203 50.0 8.88 0.2620 \*prb 01-27-96 12:31pm  
9060204 75.0 13.01 0.5389 \*prb 01-27-96 12:31pm  
9060205 90.0 15.71 0.5008 \*prb 01-27-96 12:31pm  
9060206 100.0 17.49 0.4806 \*prb 01-27-96 12:31pm  
\*  
\*  
\* component 907 - RFW HTR C5 Steam Supply #2 (From "C" LP Turbine, point #5)  
9070000 'STMsrc5B' tmdpvol  
\*  
\* area length vol azmth incl elev rough hyd fe  
9070101 9.0164 10.0 0.0 0.0 0.0 0.0 0.0 0.0 10  
\*  
\* ebt trip variable  
9070200 002 0 cntrlvar 010 \*RX Power, % \*prb 01-27-96 12:31pm  
\* \*prb 01-27-96 12:31pm  
\* %pwr press qual. \*prb 01-27-96 12:31pm  
9070201 0.0 0.45 0.2807 \*extrapolated \*prb 01-27-96 12:31pm  
9070202 25.0 2.69 0.4153 \*prb 01-27-96 12:31pm  
9070203 50.0 5.05 0.5633 \*prb 01-27-96 12:31pm  
9070204 75.0 7.23 0.6912 \*prb 01-27-96 12:31pm  
9070205 90.0 8.66 0.7368 \*prb 01-27-96 12:31pm  
9070206 100.0 9.60 0.7545 \*prb 01-27-96 12:31pm  
\*  
\*  
\* component 908 - Moisture Separator  
9080000 'Mois-Sep' tmdpvol  
\*  
\* area length vol azmth incl elev rough hyd fe  
9080101 5.0 10.0 0.0 0.0 0.0 0.0 0.0 0.0 10  
\*  
\* ebt trip variable \*prb 01-26-96 11:47pm  
9080200 001 0 cntrlvar 010 \*RX Power, % \*prb 01-26-96 11:47pm  
\*  
\* %pwr temp qual. \*prb 01-26-96 11:47pm

---

9080201 0.0 253.12 0.0 \*extrapolated \*prb 01-26-96 11:47pm  
 9080202 25.0 286.00 0.0 \*prb 01-26-96 11:47pm  
 9080203 50.0 333.40 0.0 \*prb 01-26-96 11:47pm  
 9080204 75.0 359.02 0.0 \*prb 01-26-96 11:47pm  
 9080205 90.0 374.74 0.0 \*prb 01-26-96 11:47pm  
 9080206 100.0 384.07 0.0 \*prb 01-26-96 11:47pm  
 \*  
 \*  
 \* component 909: Moisture Separator Drain to HTR C2  
 9090000 'MS-drain' tmdpjun  
 9090101 908000000 931000000 1.3963  
 \*  
 \* trip variable \*prb 01-26-96 11:47pm  
 \*9090200 1 0 cntrlvar 010 \*RX Power, % \*prb 01-26-96 11:47pm  
 9090200 1 634 cntrlvar 010 \*RX Power, % \*jam 7-27-96  
 \*  
 \* %pwr liq.flow . \*prb 01-26-96 11:47pm  
 9090201 0.0 0.0 0.0 0.0 \*prb 01-26-96 11:47pm  
 9090202 25.0 22.4352 0.0 0.0 \*242,300/3 lb/hr \*prb 01-26-96 11:47pm  
 9090203 50.0 54.9444 0.0 0.0 \*593,400/3 lb/hr \*prb 01-26-96 11:47pm  
 9090204 75.0 82.8714 0.0 0.0 \*895,011/3 lb/hr \*prb 01-26-96 11:47pm  
 9090205 90.0 105.3094 0.0 0.0 \*1,137,342/3 lb/hr \*prb 01-26-96 11:47pm  
 9090206 100.0 120.7569 0.0 0.0 \*1,304,175/3 lb/hr \*prb 01-26-96 11:47pm  
 \*  
 \* component 910 - RFW Heater C1 steam supply vlv - jam 7-27-96  
 9100000 c1stmvlv valve \*jam 7-27-96  
 \* from to juna kf kr fvcahs  
 9100101 901000000 920000000 1.3417 15.7355 15.7355 000000 \*jam 7-27-96  
 \* liq\_vel vap\_vel vel.int.  
 9100201 0 60.166 118.13 0.0 \*jam 7-26-96  
 9100300 trpvlv \*jam 7-26-96  
 9100301 634 \*jam 7-26-96  
 \*  
 \* component 920 - RFW Heater C1 Steam Dome (top of vertical shell)  
 9200000 'HTRC1-s1' branch  
 \*  
 \* #juns vel/flow  
 \*9200001 2 0  
 9200001 1 0 \*jam 7-27-96  
 \*  
 \* area length vol theta phi elev rough hyd pvbfe  
 9200101 12.34 13.7904 0. 0. -90.0 -13.7904 1.5e-4 0.0772 00100  
 \*  
 \* ebt press Uf Uv voidv  
 9200200 000 198.29 354.09 1113.5 0.99410

\*  
\* from to juna kf kr fvcahs  
\*9201101 901000000 920000000 1.3417 15.7355 15.7355 000000 \*jam 7-27-96  
\*9202101 920010000 921000000 0. 0. 0. 101000 \*jam 7-27-96  
9201101 920010000 921000000 0. 0. 0. 101000 \*jam 7-27-96  
\*  
\* jun\_Dh flood gas-int slope  
\*9201110 0.0 0.0 1.0 1.0 \*jam 7-27-96  
\*9202110 0.0772 0.0 1.0 1.0 \*jam 7-27-96  
9201110 0.0772 0.0 1.0 1.0  
\*  
\* liq\_vel vap\_vel vel.int.  
\*9201201 60.166 118.13 0. \*jam 7-27-96  
\*9202201 7.3903 8.4137 0. \*jam 7-27-96  
9201201 7.3903 8.4137 0. \*jam 7-27-96  
\*  
\*  
\* component 921 - RFW Heater C1 Shellside middle volumes  
9210000 'HTRC1-s2' pipe  
\*  
\* nv  
9210001 3  
\*  
\* flowa vn  
9210101 12.34 3 \*Shell area (60.75" ID) minus tube area (5/8"OD)  
\* \*tube area = (2)(1906 tubes)(tube area)  
\*  
\* flowl vn  
9210301 10.4596 1  
9210302 2.6667 3 \*same as corresponding primary tube length  
\*  
\* volume vn  
9210401 0.0 3  
\*  
\* incl vn  
9210601 -90.0 3  
\*  
\* roughness dhyd vn  
9210801 1.5e-4 0.0772 3  
\*  
\* kf kr jn  
9210901 0.0 0.0 2  
\*  
\* pvbfe vn  
9211001 00100 3

```
*  
*   fvcahs      jn  
9211101 101000      2  
*  
*   ebt  press. Uf      Uv      voidv      VN  
9211201 0    198.33 354.09    1113.5  0.99189    0.  1  
9211202 0    198.36 354.05    1113.5  0.96348    0.  2  
9211203 0    198.89 336.85    1113.6  2.33801e-02  0.  3  
*  
*   vel/flow  
9211300 0  
*  
*   liq-flo  vap-flo  vel.int      jn  
9211301 11.168    2.4853  0.        1  
9211302 3.0088    5.32454e-02 0.        2  
*  
*   jun_Dh      flood      gas-int      slope jn  
9211401 0.0772    0.0        1.0        1.0  2  
*  
*  
* component 922 - RFW Heater C1 Tubesheet Shellside (bottom of vertical shell)  
9220000 'HTRC1-s3' branch  
*  
*   #juns vel/flow  
9220001 1    0  
*  
*   area  length vol  theta phi elev  rough hyd  pvbfe  
9220101 12.34  1.3307 0.  0.  -90.0 -1.3307 1.5e-4 0.0772 00100  
*  
*   ebt  press. Uf      Uv      voidv  
9220200 000    199.30 338.19    1113.6  0.0  
*  
*   from      to      juna  kf  kr  fvcahs  
9221101 921010000    922000000  0.  0.0  0.  101000  
*  
*   jun_Dh      flood  gas-int slope  
9221110 0.0772    0.0  1.0  1.0  
*  
*   liq_vel  vap_vel      vel.int.  
9221201 0.11251    -1.1900      0.  
*  
*  
* component 923 - RFW Heater C1 Drain Piping  
9230000 'HTRC1drn' branch  
*
```

```
* #juns vel/flow
9230001 1 0
*
* area length vol theta phi elev rough hyd pvbfe
9230101 0.3474 10.0 0. 0. 82.6 9.9167 1.5e-4 0.0 00000
*
* ebt press. Uf Uv voidv
9230200 000 199.30 338.19 1113.6 0.0
*
* from to juna kf kr fvcahs
9231101 922010000 923000000 0.3474 0.0 0. 000100
*
* liq_vel vap_vel vel.int.
9231201 3.7345 3.7345 0.
*
*
* component 925 - RFW HTRC1 Drain Valve
9250000 'LCV6-37' valve
*
* from to juna kf kr fvcahs
9250101 923010000 931000000 0.0873 39.0223 39.0223 000000
*
9250201 0 15.463 15.465 0. * 819,483/3 lb/hr
*
9250300 srvv1v
*
9250301 0950 * valve position demand from htr C1 level control system
*
9250400 1.0 288.0 * max Cv = 288.0 per BFN-VTD-K125-0060 for
* 4" linear double-seated full-port
9250401 0.0 0.0001 0.0001 * Assume linear Cv vs stroke for globe
9250402 1.0 1.0 1.0 * valve
*
* component 911 - RFW Heater C2 steam supply vlv - jam 7-27-96
9110000 c2stmvlv valve *jam 7-27-96
* from to juna kf kr fvcahs
9110101 902000000 930000000 0.7854 14.1087 14.1087 000000 *jam 7-27-96
* liq_vel vap_vel vel.int.
9110201 0 74.200 202.58 0.0 *jam 7-26-96
9110300 trpv1v *jam 7-26-96
9110301 634 *jam 7-26-96
*
* component 930 - RFW Heater C2 Steam Dome (top of vertical shell)
9300000 'HTRC2-s1' branch
*
```

---

```

* #juns vel/flow
*9300001 2    0                                *jam 9-27-96
9300001 1    0                                *jam 9-27-96
*
* area length vol theta phi elev rough hyd pvbfe
9300101 12.34 10.2904 0.   0.  -90.0 -10.2904 1.5e-4 0.0772 00100
*
* ebt press Uf      Uv      voidv
9300200 000  109.21 304.89   1106.3  0.99832
*
* from      to      juna kf      kr      fvcahs
*9301101 902000000 930000000 0.7854 14.1087 14.1087 000001      *jam 9-27-96
*9302101 930010000 931000000 12.34 0.   0.   101000      *jam 9-27-96
9301101 930010000 931000000 12.34 0.   0.   101000      *jam 9-27-96
*
* jun_Dh      flood gas-int slope
*9301110 0.0      0.0  1.0  1.0                  *jam 9-27-96
*9302110 0.0772    0.0  1.0  1.0                  *jam 9-27-96
9301110 0.0772    0.0  1.0  1.0                  *jam 9-27-96
*
* liq_vel      vap_vel      vel.int.
*9301201 74.200   202.58     0.                  *jam 9-27-96
*9302201 12.027   7.9267     0.                  *jam 9-27-96
9301201 12.027   7.9267     0.                  *jam 9-27-96
*
*
* component 931 - RFW Heater C2 drain junction volume
9310000 'HTRC2-s2' branch
*
* #juns vel/flow
9310001 1    0
*
* area length vol theta phi elev rough hyd pvbfe
9310101 12.34 8.8763 0.   0.  -90.0 -8.8763 1.5e-4 0.0772 00100
*
* ebt press Uf      Uv      voidv
9310200 000  109.23 305.04   1106.4  0.97393
*
* from      to      juna kf      kr      fvcahs
9311101 931010000 932000000 12.34 0.   0.   101000
*
* jun_Dh      flood gas-int slope
9311110 0.0772    0.0  1.0  1.0
*
* liq_vel      vap Vel      vel.int.

```

9311201 10.895 3.4280 0.  
\*  
\*  
\* component 932 - RFW Heater C2 Shellside middle volumes  
9320000 'HTRC2-s2' pipe  
\*  
\* nv  
9320001 2  
\*  
\* flowa vn  
9320101 12.34 2 \*Shell area (60.75" ID) minus tube area (5/8"OD)  
\* \*tube area = (2)(1906 tubes)(tube area)  
\*  
\* flowl vn  
9320301 3.0000 2 \*same as corresponding primary tube length  
\*  
\* volume vn  
9320401 0.0 2  
\*  
\* incl vn  
9320601 -90.0 2  
\*  
\* roughness dhyd vn  
9320801 1.5e-4 0.0772 2  
\*  
\* kf kr jn  
9320901 0.0 0.0 1  
\*  
\* pvbfe vn  
9321001 00100 2  
\*  
\* fvcahs jn  
9321101 101000 1  
\*  
\* ebt press. Uf Uv voidv VN  
9321201 000 109.25 304.86 1106.4 0.91724 0. 1  
9321202 000 109.87 298.86 1106.4 5.89169e-02 0. 2  
\*  
\* vel/flow  
9321300 0  
\*  
\* liq-flo vap-flo vel.int jn  
9321301 4.2183 0.30784 0. 1  
\*  
\* jun\_Dh flood gas-int slope jn

9321401 0.0772        0.0        1.0        1.0    1  
\*  
\*  
\* component 933 - RFW Heater C2 Tubesheet Shellside (bottom of vertical shell)  
9330000 'HTRC2-s3' branch  
\*  
\* #juns vel/flow  
9330001 1    0  
\*  
\* area length vol theta phi elev rough hyd pvbfe  
9330101 12.34 5.4974 0. 0. -90.0 -5.4974 1.5e-4 0.0772 00100  
\*  
\* ebt press. Uf        Uv        voidv  
9330200 000 111.52 291.80 1106.6 0.0  
\*  
\* from        to        juna kf kr fvcahs  
9331101 932010000 933000000 12.34 0.0 0. 101000  
\*  
\* jun\_Dh        flood gas-int slope  
9331110 0.0772        0.0 1.0 1.0  
\*  
\* liq\_vel        vap\_vel        vel.int.  
9331201 0.42029 -0.82167 0.  
\*  
\*  
\* component 934 - RFW Heater C2 Drain Piping  
9340000 'HTRC2drn' branch  
\*  
\* #juns vel/flow  
9340001 1    0  
\*  
\* area length vol theta phi elev rough hyd pvbfe  
9340101 0.5475 25.0 0. 0. 65.0 22.6667 1.5e-4 0.0 00000  
\*  
\* ebt press. Uf        Uv        voidv  
9340200 000 199.30 338.19 1113.6 0.0  
\*  
\* from        to        juna kf kr fvcahs  
9341101 933010000 934000000 0.5475 0.0 0. 000100  
\*  
\* liq\_vel        vap\_vel        vel.int.  
9341201 8.2628 7.7109 0.  
\*  
\*  
\* component 935 - RFW HTRC2 Drain Valve

9350000 'LCV6-40A' valve

\*

\* from to juna kf kr fvcahs

9350101 934010000 941000000 0.3491 22.8653 22.8653 000000

\*

9350201 1 228.5294 0.0 0. \*2,468,117/3 lb/hr

\*

9350300 srvv1v

\*

9350301 0958 \* valve position demand based from htr C2 level control

\*

9350400 1.0 950.0 \* max Cv = 950.0 per BFN-VTD-K125-0060 for

\* 8" linear double-seated full-port

9350401 0.0 0.0001 0.0001 \* Assume linear Cv vs stroke for globe

9350402 1.0 1.0 1.0 \* valve

\*

\*

\* component 937 - RFW HTRB2 Bypass Valve \*prb 01-23-96

01:05pm

9370000 'LCV6-4B' valve \*prb 01-23-96 01:05pm

\*

\*prb 01-23-96 01:05pm

\* from to juna kf kr fvcahs \*prb 01-23-96 01:05pm

\*9370101 934010000 738000000 0.3491 0.0 0.0 000000 \*prb 01-23-96

01:05pm

9370101 934010000 738000000 0.3491 22.8653 22.8653 000000 \*jam 7-26-96

\*

\*prb 01-23-96 01:05pm

9370201 1 0.0 0.0 0.0 \*prb 01-23-96 01:05pm

\*

\*prb 01-23-96 01:05pm

9370300 srvv1v \*prb 01-23-96 01:05pm

\*

\*prb 01-23-96 01:05pm

9370301 0960 \* valve position demand \*prb 01-23-96 01:05pm

\*

\*prb 01-23-96 01:05pm

9370400 1.0 950.0 \* max Cv = 950.0 per BFN-VTD-K125-0060 for \*prb

01-23-96 01:05pm

\* 8" linear double-seated full-port \*prb 01-23-96 01:05pm

9370401 0.0 0.0001 0.0001 \* Assume linear Cv vs stroke for globe \*prb 01-23-96  
01:05pm

9370402 1.0 1.0 1.0 \* valve \*prb 01-23-96 01:05pm

\*

\* component 912 - RFW Heater C3 steam supply vlv - jam 7-27-96

9120000 c3stmvlv valve \*jam 7-27-96

\* from to juna kf kr fvcahs

9120101 903000000 940000000 3.1416 23.4899 23.4899 000000 \*jam 7-27-96

\* liq\_vel vap Vel vel.int.

9120201 0 7.7263 124.84 0.0 \*jam 7-26-96

```
9120300 trpvlv *jam 7-26-96
9120301 634 *jam 7-26-96
*
* component 940 - RFW Heater C3 Steam Dome (top of vertical shell)
9400000 'HTRC3-s1' branch
*
* #juns vel/flow
*9400001 2 0 *jam 7-26-96
9400001 1 0 *jam 7-26-96
*
* area length vol theta phi elev rough hyd pvbfe
9400101 13.5335 12.4284 0. 0. -90.0 -12.4284 1.5e-4 0.0864 00100
*
* ebt press Uf Uv voidv
9400200 000 69.300 271.84 1099.9 0.99613
*
* from to juna kf kr fvcahs
*9401101 903000000 940000000 3.1416 23.4899 23.4899 000000 *jam 7-26-96
*9402101 940010000 941000000 13.5335 0. 0. 101000 *jam 7-26-96
9401101 940010000 941000000 13.5335 0. 0. 101000 *jam 7-26-96
*
* jun_Dh flood gas-int slope
*9401110 0.0 0.0 1.0 1.0 *jam 7-26-96
*9402110 0.0864 0.0 1.0 1.0 *jam 7-26-96
9401110 0.0864 0.0 1.0 1.0 *jam 7-26-96
*
* liq_vel vap_vel vel.int.
*9401201 7.7263 124.84 0. *jam 7-26-96
*9402201 8.9171 19.266 0. *jam 7-26-96
9401201 8.9171 19.266 0. *jam 7-26-96
*
*
* component 941 - RFW Heater C3 drain junction volume
9410000 'HTRC3-s2' branch
*
* #juns vel/flow
9410001 1 0
*
* area length vol theta phi elev rough hyd pvbfe
9410101 13.5335 11.1133 0. 0. -90.0 -11.1133 1.5e-4 0.0864 00100
*
* ebt press Uf Uv voidv
9410200 000 69.309 271.88 1100.0 0.96083
*
* from to juna kf kr fvcahs
```

9411101 941010000 942000000 13.5335 0. 0. 101000  
\*  
\* jun\_Dh flood gas-int slope  
9411110 0.0864 0.0 1.0 1.0  
\*  
\* liq\_vel vap\_vel vel.int.  
9411201 9.3922 5.8524 0.  
\*  
\*  
\* component 942 - RFW Heater C3 Shellside middle & lower volumes  
9420000 'HTRC3-s3' pipe  
\*  
\* nv  
9420001 4  
\*  
\* flowa vn  
9420101 13.5335 1  
9420102 6.7667 4 \*volumes 2-4 share space with subcooling zone  
\*  
\* flowl vn  
9420301 3.0000 2 \*same as corresponding primary tube length  
9420302 7.0534 4 \*same as corresponding primary tube length  
\*  
\* volume vn  
9420401 0.0 4  
\*  
\* incl vn  
9420601 -90.0 4  
\*  
\* roughness dhyd vn  
9420801 1.5e-4 0.0864 4  
\*  
\* kf kr jn  
9420901 0.0 0.0 3  
\*  
\* pvbfe vn  
9421001 00100 4  
\*  
\* fvcahs jn  
9421101 101000 3  
\*  
\* ebt press. Uf Uv voidv VN  
9421201 000 69.322 271.84 1100.0 0.98918 0. 1  
9421202 000 69.529 271.38 1099.9 0.16248 0. 2  
9421203 000 72.030 269.21 1100.5 2.68060e-06 0. 3

```
9421204 000  74.835 267.04    1101.0  8.83757e-06  0.   4
*
*   vel/flow
9421300 0
*
*   liq-flo  vap-flo      vel.int    jn
9421301 70.794  0.44862     0.        1
9421302 0.75643 -0.90429     0.        2
9421303 0.63162  0.77799     0.        3
*
*   jun_Dh      flood      gas-int    slope jn
9421401 0.0864    0.0       1.0       1.0   3
*
*
* component 943 - RFW Heater C3 Subcooling Zone
9430000 'HTRC3-s4'  pipe
*
*   nv
9430001 3
*
*   flowa      vn
9430101 6.7667    3
*
*   flowl      vn
9430301 3.0000    1      *same as corresponding primary tube length
9430302 7.0534    3      *same as corresponding primary tube length
*
*   volume      vn
9430401 0.0       3
*
*   incl       vn
9430601 -90.0     3
*
*   roughness   dhyd  vn
9430801 1.5e-4    0.0864 3
*
*   kf   kr   jn
9430901 0.0   0.0   2
*
*   pvbfe      vn
9431001 00100     3
*
*   fvcahs     jn
9431101 101000    2
*
```

```
* ebt press. Uf      Uv      voidv          VN
9431201 000  69.415 233.60   1100.1  8.99481e-02  0.   1
9431202 000  71.404 226.39   1100.4  1.57683e-07  0.   2
9431203 000  74.264 242.61   1100.9  3.17648e-06  0.   3
*
* vel/flow
9431300 0
*
* liq-flo vap-flo    vel.int    jn
9431301 3.53376e-02 -1.6814     0.       1
9431302 3.03089e-02 3.099473e-02   0.       2
*
* jun_Dh      flood      gas-int      slope jn
9431401 0.0864      0.0        1.0        1.0   2
*
*
* component 944 - RFW Heater C3 Drain Piping
9440000 'HTRC3drn' branch
*
* #juns vel/flow
9440001 1      1
*
* area length vol  theta phi elev  rough hyd pvbfe
9440101 0.5475 5.0  0.   0.   0.   0.   1.5e-4 0.0  00000
*
* ebt press. Uf      Uv      voidv
9440200 000  199.30 338.19   1113.6  0.0
*
* from      to      juna kf      kr      fvcahs
9441101 943010000 944000000 0.5475 0.0  0.   000100
*
* liq_vel vap_vel    vel.int.
9441201 228.5294 0.0        0.
*
*
* component 945 - RFW HTRC3 Drain Valve
9450000 'LCV6-43' valve
*
* from      to      juna kf      kr      fvcahs
9450101 944010000 952000000 0.3491  7.4816  7.4816  000000
*
9450201 0      12.689   44.886  0.   *2,468,117/3 lb/hr target
*
9450300 srvvlv
*
```

9450301 0972 \* valve position demand based on htr C3 level error  
\*  
9450400 1.0 950.0 \* max Cv = 950.0 per BFN-VTD-K125-0060 for  
\* 8" linear double-seated full-port  
9450401 0.0 0.0001 0.0001 \* Assume linear Cv vs stroke for globe  
9450402 1.0 1.0 1.0 \* valve  
\*  
\*  
9470000 'HTRC3jun' mtpljun  
9470001 2 0  
\*  
\* from to juna kf kr fvcahs incr1 incr2 jn  
9470011 942020004 943010003 .1 5. 5. 001000 1. 1. 1. 0 0 0 1  
9470021 942040004 943030003 1. 5. 5. 001000 1. 1. 1. 0 0 0 2  
\*  
\* liq-flo vap-flo jn  
9471011 4.0946 4.0946 1  
9471021 0.0 0.0 2  
\*  
\* component 913 - RFW Heater C4 steam supply vlv - jam 7-27-96  
9130000 c4stvlv1 valve \*jam 7-27-96  
\* from to juna kf kr fvcahs  
9130101 905000000 950000000 2.8229 6197.85 6197.85 000000 \*jam 7-27-96  
\* liq\_vel vap\_vel vel.int.  
9130201 0 0.83437 24.814 0.0 \*jam 7-26-96  
9130300 trpvlv \*jam 7-26-96  
9130301 634 \*jam 7-26-96  
\*  
\*  
\* component 950 - RFW Heater C4 (top of shell nearest tubesheet)  
9500000 'HTRC4-s1' branch  
\*  
\* #juns vel/flow  
\*9500001 2 0 \*jam 7-26-96  
9500001 1 0 \*jam 7-26-96  
\*  
\* area length vol theta phi elev rough hyd pvbfe  
9500101 0.0 2.9375 153.2704 0. -90.0 -2.9375 1.5e-4 0.1309 00100  
\*  
\* ebt press Uf Uv voidv  
9500200 000 27.276 213.37 1086.4 0.99962  
\*  
\* from to juna kf kr fvcahs  
\*9501101 905000000 950000000 2.8229 6197.85 6197.85 000000 \*jam 7-27-96  
\*9502101 950010000 951000000 9.7832 0. 0. 001003 \*jam 7-27-96

```
9501101 950010000    951000000    9.7832 0.  0.  001003      *jam 7-27-96
*
*   jun_Dh      flood  gas-int slope
*9501110 0.0        0.0  1.0  1.0                      *jam 7-27-96
*9502110 0.1309    0.0  1.0  1.0                      *jam 7-27-96
9501110 0.1309    0.0  1.0  1.0                      *jam 7-27-96
*
*   liq_vel  vap_vel      vel.int.
*9501201 0.83437   24.814     0.                      *jam 7-27-96
*9502201 9.1016    8.7249    0.                      *jam 7-27-96
9501201 9.1016    8.7249    0.                      *jam 7-27-96
*
* component 914 - RFW Heater C4 steam supply vlv - jam 7-27-96
9140000 c4stvlv2    valve  *jam 7-27-96
*   from      to      juna  kf   kr   fvcahs
9140101 904000000  951000000  2.8229 4.4554 4.4554 000000      *jam 7-27-96
*   liq_vel  vap_vel      vel.int.
9140201 0  41.854   271.59     0.0                     *jam 7-26-96
9140300 trpvlv                                *jam 7-26-96
9140301 634                                *jam 7-26-96
*
*
* component 951 - RFW Heater C4 (top of shell furthest from tubesheet)
9510000 'HTRC4-s2'  branch
*
*   #juns  vel/flow
*9510001 2  0                           *jam 7-27-96
9510001 1  0                           *jam 7-27-96
*
*   area  length vol  theta phi elev  rough hyd  pvbfe
9510101 0.0  2.9375 265.4972 0.  -90.0 -2.9375 1.5e-4 0.1309 00100
*
*   ebt  press Uf      Uv      voidv
9510200 000  27.276 213.38    1086.4  0.99996
*
*   from      to      juna  kf   kr   fvcahs
*9511101 904000000  951000000  2.8229 4.4554 4.4554 000000      *jam 7-27-96
*9512101 951010000  952000000  153.4359 0.  0.  101000      *jam 7-27-96
9511101 951010000  952000000  153.4359 0.  0.  101000      *jam 7-27-96
*
*   jun_Dh      flood  gas-int slope
*9511110 0.0        0.0  1.0  1.0                      *jam 7-27-96
*9512110 0.1309    0.0  1.0  1.0                      *jam 7-27-96
9511110 0.1309    0.0  1.0  1.0                      *jam 7-27-96
*
```

```
* liq_vel vap_vel vel.int.
*9511201 41.854   271.59    0.                      *jam 7-27-96
*9512201 38.784   4.5911    0.                      *jam 7-27-96
9511201 38.784   4.5911    0.                      *jam 7-27-96
*
*
* component 952 - RFW Heater C4 (bottom of shell furthest from tubesheet)
9520000 'HTRC4-s3' branch
*
* #juns vel/flow
9520001 0   0
*
* area length vol theta phi elev rough hyd pvbfe
9520101 0.0  2.9375 265.4972 0. -90.0 -2.9375 1.5e-4 0.1309 00100
*
* ebt press Uf      Uv      voidv
9520200 000  27.292 209.34   1086.4  0.52487
*
*
* component 953 - RFW Heater C4 Subcooling Zone
9530000 'HTRC4-s4' branch
*
* #juns vel/flow
9530001 1   0
*
* area length vol theta phi elev rough hyd pvbfe
9530101 9.7832 15.6667 0.0   0.  0.0  0.0   1.5e-4 0.1309 00100
*
* ebt press Uf      Uv      voidv
9530200 000  26.746 170.92   1086.2  2.46992e-02
*
* from      to      juna kf   kr   fvcahs
9531101 952010000 953000000 1.7671 5.0  5.0  001000
*
* jun_Dh    flood  gas-int slope
9531110 0.1309   0.0   1.0  1.0
*
* liq_vel vap_vel vel.int.
9531201 6.4784   37.792    0.
*
*
* component 954 - RFW Heater C4 Drain Piping
9540000 'HTRC4drn' branch
*
* #juns vel/flow
```

9540001 1 0  
\*  
\* area length vol theta phi elev rough hyd pvbfe  
9540101 1.6230 10.0 0. 0. 50.15 7.6771 1.5e-4 0.0 00000  
\*  
\* ebt press. Uf Uv voidv  
9540200 000 26.326 174.57 1085.9 7.05438e-04  
\*  
\* from to juna kf kr fvcahs  
9541101 953010000 954000000 1.6230 0.0 0. 000100  
\*  
\* liq\_vel vap\_vel vel.int.  
9541201 3.1304 4.5777 0.  
\*  
\*  
\* component 955 - RFW HTRC4 Drain Valve  
9550000 'LCV6-47A' valve  
\*  
\* from to juna kf kr fvcahs  
9550101 954010000 960010003 0.7854 23.7848 23.7848 000000  
\*  
9550201 0 7.5514 7.5514 0. \*3,184,100/3 lb/hr target  
\*  
9550300 srvv1v  
\*  
9550301 0982 \* valve position demand based on htr C4 level error  
\*  
9550400 1.0 2180.0 \* max Cv = 2180.0 per BFN-VTD-K125-0060 for  
\* 12" linear double-seated full-port  
9550401 0.0 0.0001 0.0001 \* Assume linear Cv vs stroke for globe  
9550402 1.0 1.0 1.0 \* valve  
\*  
\*  
\* component 957 - RFW HTRC4 Bypass Valve \*prb 01-24-96  
10:22am  
9570000 'LCV6-47B' valve \*prb 01-24-96 10:22am  
\* \*prb 01-24-96 10:22am  
\* from to juna kf kr fvcahs \*prb 01-24-96 10:22am  
\*9570101 954010000 758000000 0.7854 0.0 0.0 000000 \*prb 01-24-96  
10:22am  
9570101 954010000 758000000 0.7854 23.7848 23.7848 000000 \*jam 7-26-96  
\* \*prb 01-24-96 10:22am  
9570201 1 0.0 0.0 0.0 \*prb 01-24-96 10:22am  
\* \*prb 01-24-96 10:22am  
9570300 srvv1v \*prb 01-24-96 10:22am

\* \*prb 01-24-96 10:22am  
9570301 0984 \* valve position demand \*prb 01-24-96 10:22am  
\* \*prb 01-24-96 10:22am  
9570400 1.0 2180.0 \* max Cv = 2180.0 per BFN-VTD-K125-0060 for \*prb  
01-24-96 10:22am  
\* 12" linear double-seated full-port \*prb 01-24-96 10:22am  
9570401 0.0 0.0001 0.0001 \* Assume linear Cv vs stroke for globe \*prb 01-24-96  
10:22am  
9570402 1.0 1.0 1.0 \* valve \*prb 01-24-96 10:22am  
\*  
\*  
\* component 960 - RFW Heater C5 Flash Tank  
9600000 'FL-TankC' pipe  
\*  
\* nv  
9600001 4  
\*  
\* flowa vn  
9600101 16.4988 4  
\*  
\* flowl vn  
9600301 1.4583 1  
9600302 2.9583 2  
9600303 2.500 3  
9600304 5.2188 4  
\*  
\* volume vn  
9600401 0.0 4  
\*  
\* incl vn  
9600601 -90.0 4  
\*  
\* roughness dhyd vn  
9600801 0.0 0.0 4  
\*  
\* kf kr jn  
9600901 0.0 0.0 3  
\*  
\* pvbfe vn  
9601001 00010 4  
\*  
\* fvcahs jn  
9601101 101000 3  
\*  
\* ebt press. Uf Uv voidv VN

```
9601201 000  9.6940 160.59    1071.8  0.98351    0.   1
9601202 000  9.6954 159.92    1071.8  0.99883    0.   2
9601203 000  9.9628 160.43    1072.2  0.53140    0.   3
9601204 000  12.394 159.48    1075.2  0.00000e+00  0.   4
*
*      vel/flow
9601300 0
*
*      liq-flo  vap-flo      vel.int     jn
9601301 19.581  0.27746      0.       1
9601302 282.58   0.63630      0.       2
9601303 0.63560 -4.2606      0.       3
*
*      jun_Dh      flood      gas-int      slope jn
9601401 0.0      0.0        1.0        1.0   3
*
*
* component 961 - RFW Heater C5 Drain Piping
9610000 'HTRC5drn' branch
*
*      #juns  vel/flow
9610001 1      0
*
*      area  length vol  theta phi elev  rough hyd  pvbfe
9610101 2.9483 10.0  0.   0.   0.0  0.0   1.5e-4 0.0  00000
*
*      ebt  press. Uf      Uv      voidv
9610200 000  13.552 159.14    1076.4  0.0
*
*      from      to      juna  kf  kr  fvcahs
9611101 960010000  961000000  2.9483 0.0  0.   000100
*
*      liq_vel  vap_vel      vel.int.
9611201 1.6705  1.9099      0.
*
* component 915 - RFW Heater C5 steam supply vlv - jam 7-27-96
9150000 c5stvlv1 valve *jam 7-27-96
*      from      to      juna  kf  kr  fvcahs
9150101 906000000  962000000  9.0164 6243.8 6243.8 000000      *jam 7-27-96
*      liq_vel  vap_vel      vel.int.
9150201 0  0.49198 22.264      0.0          *jam 7-26-96
9150300 trpvlv                                *jam 7-26-96
9150301 634                                    *jam 7-26-96
*
```

\* component 962 - RFW Heater C5 (top of shell nearest tubesheet)  
9620000 'HTRC5-s1' branch  
\*  
\* #juns vel/flow  
\*9620001 3 0 \*jam 7-27-96  
9620001 2 0 \*jam 7-27-96  
\*  
\* area length vol theta phi elev rough hyd pvbfe  
9620101 0.0 2.8333 170.5096 0. -90.0 -2.8333 1.5e-4 0.1128 00100  
\*  
\* ebt press Uf Uv voidv  
9620200 000 9.4593 158.61 1071.3 0.99998  
\*  
\* from to juna kf kr fvcahs  
\*9621101 906000000 962000000 9.0164 6243.8 6243.8 001000  
\*jam 7-27-96  
\*9622101 962010000 963000000 8.7069 0. 0. 001003  
\*jam 7-27-96  
9621101 962010000 963000000 8.7069 0. 0. 001003  
\*jam 7-27-96  
\*9623101 960000000 962000000 0.7530 1.50 1.50 001000  
\*jam 7-27-96  
9622101 960000000 962000000 0.7530 1.50 1.50 001000  
\*jam 7-27-96  
\*  
\* jun\_Dh flood gas-int slope  
\*9621110 2.3958 0.0 1.0 1.0 \*jam 7-27-96  
\*9622110 0.1128 0.0 1.0 1.0 \*jam 7-27-96  
9621110 0.1128 0.0 1.0 1.0 \*jam 7-27-96  
\*9623110 0.0 0.0 1.0 1.0 \*jam 7-27-96  
9622110 0.0 0.0 1.0 1.0 \*jam 7-27-96  
\*  
\* liq\_vel vap\_vel vel.int.  
\*9621201 0.49198 22.264 0. \*jam 7-27-96  
\*9622201 -31.397 -26.477 0. \*jam 7-27-96  
9621201 -31.397 -26.477 0. \*jam 7-27-96  
\*9623201 -30.730 237.56 0. \*jam 7-27-96  
9622201 -30.730 237.56 0. \*jam 7-27-96  
\*  
\* component 916 - RFW Heater C5 steam supply vlv - jam 7-27-96  
9160000 c5stvlv2 valve \*jam 7-27-96  
\* from to juna kf kr fvcahs  
9160101 907000000 963000000 9.0164 2.9489 2.9489 000000 \*jam 7-27-96  
\* liq\_vel vap\_vel vel.int.  
9160201 0 26.337 161.50 0.0 \*jam 7-26-96

9160300 trpvlv \*jam 7-26-96  
9160301 634 \*jam 7-26-96  
\*  
\*  
\* component 963 - RFW Heater C5 (top of shell furthest from tubesheet)  
9630000 'HTRC5-s2' branch  
\*  
\* #juns vel/flow  
\*9630001 2 0 \*jam 7-27-96  
9630001 1 0 \*jam 7-27-96  
\*  
\* area length vol theta phi elev rough hyd pvbfe  
9630101 0.0 2.8333 128.8119 0. -90.0 -2.8333 1.5e-4 0.1128 00100  
\*  
\* ebt press Uf Uv voidv  
9630200 000 9.4589 158.60 1071.4 0.99992  
\*  
\* from to juna kf kr fvcahs  
\*9631101 907000000 963000000 9.0164 2.9489 2.9489 001000 \*jam 9-27-96  
\*9632101 963010000 964000000 83.8342 0. 0. 001000 \*jam 9-27-96  
9631101 963010000 964000000 83.8342 0. 0. 001000 \*jam 9-27-96  
\*  
\* jun\_Dh flood gas-int slope  
\*9631110 2.3958 0.0 1.0 1.0 \*jam 9-27-96  
\*9632110 0.1128 0.0 1.0 1.0 \*jam 9-27-96  
9631110 0.1128 0.0 1.0 1.0 \*jam 9-27-96  
\*  
\* liq\_vel vap\_vel vel.int.  
\*9631201 26.337 161.50 0. \*jam 9-27-96  
\*9632201 34.542 8.5995 0. \*jam 9-27-96  
9631201 34.542 8.5995 0. \*jam 9-27-96  
\*  
\*  
\* component 964 - RFW Heater C5 (bottom of shell furthest from tubesheet)  
9640000 'HTRC5-s3' branch  
\*  
\* #juns vel/flow  
9640001 2 0  
\*  
\* area length vol theta phi elev rough hyd pvbfe  
9640101 0.0 2.8333 128.8119 0. -90.0 -2.8333 1.5e-4 0.1128 00100  
\*  
\* ebt press Uf Uv voidv  
9640200 000 9.6340 148.68 1071.7 0.39598  
\*

```
* from to juna kf kr fvcahs
9641101 964010004 965010003 8.7069 0. 0. 001000
9642101 964010000 966000000 0.8685 1.5 100.0 001001 * discourage reverse
flow
*
* jun_Dh flood gas-int slope
9641110 0.1128 0.0 1.0 1.0
9642110 0.6651 0.0 1.0 1.0
*
* liq_vel vap_vel vel.int.
9641201 3.4725 -8.5376 0.
9642201 0.47271 -9.3520 0.
*
*
* component 965 - RFW Heater C5 (bottom of shell nearest tubesheet)
9650000 'HTRC5-s4' branch
*
* #juns vel/flow
9650001 2 0
*
* area length vol theta phi elev rough hyd pvbfe
9650101 0.0 2.8333 170.5096 0. -90.0 -2.8333 1.5e-4 0.1128 00100
*
* ebt press Uf Uv voidv
9650200 000 9.4996 134.05 1071.5 0.44943
*
* from to juna kf kr fvcahs
9651101 962010000 965000000 110.9722 0.0 0.0 001000
9652101 965010000 966000000 0.8685 1.5 100.0 001001 * discourage reverse
flow
*
* jun_Dh flood gas-int slope
9651110 0.1128 0.0 1.0 1.0
9652110 0.6651 0.0 1.0 1.0
*
* liq_vel vap_vel vel.int.
9651201 37.265 5.8851 0.
9652201 -0.42722 -10.256 0.
*
*
* component 966 - RFW Heater C5 Collector
9660000 'Coll-C5' branch
*
* #juns vel/flow
9660001 1 0
```

```
*  
* area length vol theta phi elev rough hyd pvbfe  
9660101 4.9087 0.0 145.2255 0. 0.0 0.0 1.5e-4 0.0 00000  
*  
* ebt press Uf Uv voidv  
9660200 000 9.9594 146.78 1072.2 0.10641  
*  
* from to juna kf kr fvcahs  
9661101 966010002 960030003 4.9087 1.0 0.50 031000  
*  
* jun_Dh flood gas-int slope  
9661110 2.5 0.0 1.0 1.0  
*  
* liq_vel vap_vel vel.int.  
9661201 -0.18014 -1.3910 0.  
*  
*  
* component 967 - RFW HTR C5 Drain Valve  
*  
9670000 'LCV6-50A' valve  
*  
* from to juna kf kr fvcahs  
9670101 961010000 969000000 0.7854 5.6209 5.6209 001000  
*  
9670201 0 9.4 9.4 0. *3,184,100/3 lb/hr target  
*  
9670300 srvvlv  
*  
9670301 0993 * valve position demand based on htr C5 level error  
*  
9670400 1.0 2180.0 * max Cv = 2180.0 per BFN-VTD-K125-0060 for  
* 12" linear double-seated full-port  
9670401 0.0 0.0001 0.0001 * Assume linear Cv vs stroke for globe  
9670402 1.0 1.0 1.0 * valve  
*  
*  
* component 968 - RFW HTRC5 Bypass Valve *prb 01-25-96  
09:19pm  
9680000 'LCV6-50B' valve *prb 01-25-96 09:19pm  
* *prb 01-25-96 09:19pm  
* from to juna kf kr fvcahs *prb 01-25-96 09:19pm  
*9680101 961010000 969000000 0.7854 0.0 0.0 000000 *prb 01-25-96  
09:19pm  
9680101 961010000 969000000 0.7854 0.0 5.6209 001000 *jam 7-26-96  
* *prb 01-25-96 09:19pm
```

9680201 1 0.0 0.0 0.0 \*prb 01-25-96 09:19pm  
9680300 srvv lv \*prb 01-25-96 09:19pm  
9680301 0995 \* valve position demand \*prb 01-25-96 09:19pm  
\*prb 01-25-96 09:19pm  
9680400 1.0 2180.0 \* max Cv = 2180.0 per BFN-VTD-K125-0060 for \*prb  
01-25-96 09:19pm  
\*prb 01-25-96 09:19pm  
12" linear double-seated full-port \*prb 01-25-96 09:19pm  
9680401 0.0 0.0001 0.0001 \* Assume linear Cv vs stroke for globe \*prb 01-25-96  
09:19pm  
9680402 1.0 1.0 1.0 \* valve \*prb 01-25-96 09:19pm  
\*  
\*  
\* component 969 - RFW Heater sump header  
9690000 'HTR-sump' branch  
\*  
\* #juns vel/flow  
9690001 1 1  
\*  
\* area length vol theta phi elev rough hyd pvbfe  
\*9690101 5.0 10.0 0.0 0. 0.0 0.0 1.5e-4 0.0 00000  
9690101 8.0 50.0 0.0 0. 0.0 0.0 1.5e-4 0.0 00000 \*jam 7-28-96  
\*  
\* ebt press temp  
9690200 003 1.0 101.14  
\*  
\* from to juna kf kr fvcahs  
9691101 969010000 970000000 0.0 1.0 0.50 001000  
\*  
\* liq\_vel vap\_vel vel.int.  
9691201 884.4722 0.0 0.  
\*  
\*  
\* component 970 - HTR sump / condenser  
\*-----  
9700000 'HTR-cond' tm dpvol  
\*  
\* area length vol azmth incl elev rough hyd fe  
\*9700101 5.0 10.0 0.0 0.0 0.0 0.0 0.0 10  
9700101 8.0 50.0 0.0 0.0 0.0 0.0 0.0 10 \*jam 7-28-96  
\*  
\* ebt trip variable  
9700200 003  
\*

```
* time press temp.  
9700201 0.0 0.9823 101.14  
*  
* component 971 - HTR sump / condenser *jam 7-28-96  
* ----- *jam 7-28-96  
9710000 'HTR2cond' tmdpvol *jam 7-28-96  
* *jam 7-28-96  
* area length vol azmth incl elev rough hyd fe *jam 7-28-96  
9710101 1.0 50.0 0.0 0.0 0.0 0.0 0.0 10 *jam 7-28-96  
* *jam 7-28-96  
* ebt trip variable *jam 7-28-96  
9710200 003 *jam 7-28-96  
* *jam 7-28-96  
* time press temp. *jam 7-28-96  
9710201 0.0 0.9823 101.14 *jam 7-28-96  
*  
*  
*-----  
* feedwater train heat structures  
*-----  
*  
* heat structure geometry per vendor spec shts. included with app. d  
*  
*** drain cooler A tubes ***  
15201000 1 2 2 0 2.84000e-02  
15201100 0 1  
15201101 1 0.0313  
15201201 4 1  
15201301 1. 1  
15201400 -1  
15201401 1.3759e+02 1.3950e+02  
15201501 520010000 0 1 1 6.66e4 1  
15201601 0 0 0 1 6.66e4 1  
15201701 10816 1. 0. 0. 1  
15201801 0. 10. 10. 0. 0. 0. 1. 1  
15201901 0. 10. 10. 0. 0. 0. 0. 1. 1  
*  
*** drain cooler B tubes ***  
15211000 1 2 2 0 2.84000e-02  
15211100 0 1  
15211101 1 0.0313  
15211201 4 1  
15211301 1. 1  
15211400 -1
```

15211401 1.3759e+02 1.3950e+02  
15211501 521010000 0 1 1 6.66e4 1  
15211601 0 0 0 1 6.66e4 1  
15211701 10816 1. 0. 0. 1  
15211801 0. 10. 10. 0. 0. 0. 1. 1  
15211901 0. 10. 10. 0. 0. 0. 0. 1. 1  
\*  
\*\*\* drain cooler C tubes \*\*\*  
15221000 1 2 2 0 2.84000e-02  
15221100 0 1  
15221101 1 0.0313  
15221201 4 1  
15221301 1. 1  
15221400 -1  
15221401 1.3759e+02 1.3950e+02  
15221501 522010000 0 1 1 6.66e4 1  
15221601 0 0 0 1 6.66e4 1  
15221701 10816 1. 0. 0. 1  
15221801 0. 10. 10. 0. 0. 0. 0. 1. 1  
15221901 0. 10. 10. 0. 0. 0. 0. 1. 1  
\*  
\*  
\* heat structure 530-1 RFW Heater A5 Tubes  
\* nh np geom init lt.coord  
15301000 8 3 2 1 0.0231  
\*  
\* mesh loc'n format  
15301100 0 1  
\*  
\* # intervals rt.coord  
15301101 2 0.0260  
\*  
\* comp # inter#(in)  
15301201 004 2  
\*  
\* rel. source interval  
15301301 1. 2  
\*  
15301400 -1  
\*  
\* mesh point temperatures  
15301401 148.87 158.13 172.26  
15301402 161.67 165.87 172.99  
15301403 170.81 171.20 171.81

15301404 175.92 172.87 171.76  
15301405 181.78 186.13 189.06  
15301406 185.58 187.62 189.36  
15301407 187.29 188.05 189.65  
15301408 188.65 188.95 189.53  
\*  
\* lt.boundary incr bdry code factor hs#  
15301501 530010000 0 1 1 12556.8 1 \*(0.7) 17938.3  
15301502 530020000 0 1 1 12556.8 2 \*(0.7) 17938.3  
15301503 530030000 0 1 1 12556.8 3 \*(0.7) 17938.3  
15301504 530040000 0 1 1 12556.8 4 \*(0.7) 17938.3  
15301505 530050000 0 1 1 12556.8 5 \*(0.7) 17938.3  
15301506 530060000 0 1 1 12556.8 6 \*(0.7) 17938.3  
15301507 530070000 0 1 1 12556.8 7 \*(0.7) 17938.3  
15301508 530080000 0 1 1 12556.8 8 \*(0.7) 17938.3  
\*  
\* rt.boundary incr bdry code factor hs#  
15301601 765010000 0 1 1 12556.8 1 \*(0.7) 17938.3  
15301602 765010000 0 1 1 12556.8 2 \*(0.7) 17938.3  
15301603 764010000 0 1 1 12556.8 3 \*(0.7) 17938.3  
15301604 764010000 0 1 1 12556.8 4 \*(0.7) 17938.3  
15301605 763010000 0 1 1 12556.8 5 \*(0.7) 17938.3  
15301606 763010000 0 1 1 12556.8 6 \*(0.7) 17938.3  
15301607 762010000 0 1 1 12556.8 7 \*(0.7) 17938.3  
15301608 762010000 0 1 1 12556.8 8 \*(0.7) 17938.3  
\*  
\* src.type s.mult dh-lt dh-rt hs#  
15301701 0 0.0 0.0 0.0 8  
\*  
\* hed hlf hlr gslf gslr gkf gkr lbf hs#  
15301801 0.0 5.4844 100.0 100.0 100.0 0.0 0.0 1.0 1  
15301802 0.0 100.0 100.0 100.0 100.0 0.0 0.0 1.0 7  
15301803 0.0 100.0 5.4844 100.0 100.0 0.0 0.0 1.0 8  
\*  
15301901 0.0 100.0 100.0 100.0 100.0 0.0 0.0 1.0 8  
\*  
\*  
\* heat structure 531-1 RFW Heater B5 Tubes  
\* nh np geom init lt.coord  
15311000 8 3 2 1 0.0231  
\*  
\* mesh loc'n format  
15311100 0 1  
\*

```
*      # intervals  rt.coord
15311101 2        0.0260
*
*      comp #    inter#(in)
15311201 004      2
*
*      rel. source  interval
15311301 1.       2
*
15311400 -1
*
*      mesh point temperatures
15311401 152.71   158.09   163.24
15311402 153.75   159.06   164.11
15311403 162.74   168.34   173.74
15311404 168.95   173.40   177.69
15311405 176.29   179.73   182.98
15311406 181.27   183.49   185.58
15311407 184.14   185.46   186.70
15311408 185.89   186.61   187.28
*
*      lt.boundary  incr  bdry  code  factor hs#
15311501 531010000 0     1     1     12556.8 1 *(0.7) 17938.3
15311502 531020000 0     1     1     12556.8 2 *(0.7) 17938.3
15311503 531030000 0     1     1     12556.8 3 *(0.7) 17938.3
15311504 531040000 0     1     1     12556.8 4 *(0.7) 17938.3
15311505 531050000 0     1     1     12556.8 5 *(0.7) 17938.3
15311506 531060000 0     1     1     12556.8 6 *(0.7) 17938.3
15311507 531070000 0     1     1     12556.8 7 *(0.7) 17938.3
15311508 531080000 0     1     1     12556.8 8 *(0.7) 17938.3
*
*
*      rt.boundary  incr  bdry  code  factor hs#
15311601 865010000 0     1     1     12556.8 1 *(0.7) 17938.3
15311602 865010000 0     1     1     12556.8 2 *(0.7) 17938.3
15311603 864010000 0     1     1     12556.8 3 *(0.7) 17938.3
15311604 864010000 0     1     1     12556.8 4 *(0.7) 17938.3
15311605 863010000 0     1     1     12556.8 5 *(0.7) 17938.3
15311606 863010000 0     1     1     12556.8 6 *(0.7) 17938.3
15311607 862010000 0     1     1     12556.8 7 *(0.7) 17938.3
15311608 862010000 0     1     1     12556.8 8 *(0.7) 17938.3
*
*      src.type    s.mult dh-lt dh-rt hs#
15311701 0          0.0   0.0   0.0   8
*
```

```
* hed hlf hlr gslf gslr gkf gkr lbf hs#
15311801 0.0  5.4844 100.0 100.0 100.0 0.0 0.0 1.0 1
15311802 0.0  100.0 100.0 100.0 100.0 0.0 0.0 1.0 7
15311803 0.0  100.0 5.4844 100.0 100.0 0.0 0.0 1.0 8
*
15311901 0.0  100.0 100.0 100.0 100.0 0.0 0.0 1.0 8
*
*
* heat structure 532-1 RFW Heater C5 Tubes
* nh np geom init lt.coord
15321000 8   3   2   1   0.0231
*
* mesh loc'n format
15321100 0     1
*
* # intervals rt.coord
15321101 2     0.0260
*
* comp # inter#(in)
15321201 004    2
*
* rel. source interval
15321301 1.     2
*
15321400 -1
*
* mesh point temperatures
15321401 136.71 137.95 139.07
15321402 136.55 137.75 138.87
15321403 138.78 139.81 140.79
15321404 140.92 141.87 142.77
15321405 159.80 167.15 174.08
15321406 170.62 175.64 180.38
15321407 176.32 179.08 181.68
15321408 180.69 182.69 184.57
*
* lt.boundary incr bdry code factor hs#
15321501 532010000 0   1   1   12556.8 1 *(0.7) 17938.3
15321502 532020000 0   1   1   12556.8 2 *(0.7) 17938.3
15321503 532030000 0   1   1   12556.8 3 *(0.7) 17938.3
15321504 532040000 0   1   1   12556.8 4 *(0.7) 17938.3
15321505 532050000 0   1   1   12556.8 5 *(0.7) 17938.3
15321506 532060000 0   1   1   12556.8 6 *(0.7) 17938.3
15321507 532070000 0   1   1   12556.8 7 *(0.7) 17938.3
15321508 532080000 0   1   1   12556.8 8 *(0.7) 17938.3
```

```
*  
*  
*      rt.boundary  incr  bdry   code  factor hs#  
15321601 965010000  0     1     1    12556.8 1 *(0.7) 17938.3  
15321602 965010000  0     1     1    12556.8 2 *(0.7) 17938.3  
15321603 964010000  0     1     1    12556.8 3 *(0.7) 17938.3  
15321604 964010000  0     1     1    12556.8 4 *(0.7) 17938.3  
15321605 963010000  0     1     1    12556.8 5 *(0.7) 17938.3  
15321606 963010000  0     1     1    12556.8 6 *(0.7) 17938.3  
15321607 962010000  0     1     1    12556.8 7 *(0.7) 17938.3  
15321608 962010000  0     1     1    12556.8 8 *(0.7) 17938.3  
*  
*      src.type    s.mult dh-lt dh-rt hs#  
15321701 0          0.0   0.0   0.0   8  
*  
*      hed    hlf    hlr    gslf   gslr   gkf   gkr   lbf   hs#  
15321801 0.0    5.4844 100.0 100.0 100.0 0.0 0.0 1.0 1  
15321802 0.0    100.0 100.0 100.0 100.0 0.0 0.0 1.0 7  
15321803 0.0    100.0 5.4844 100.0 100.0 0.0 0.0 1.0 8  
*  
15321901 0.0    100.0 100.0 100.0 100.0 0.0 0.0 1.0 8  
*  
*  
* heat structure 540-1 RFW Heater A4 Tubes  
*      nh    np    geom  init  lt.coord  
15401000 10    3     2     1    0.0231  
*  
*      mesh loc'n  format  
15401100 0      1  
*  
*      # intervals rt.coord  
15401101 2      0.0260  
*  
*      comp #    inter#(in)  
15401201 004    2  
*  
*      rel. source interval  
15401301 1.      2  
*  
15401400 -1  
*  
*      mesh point temperatures  
15401401 196.10  198.57  200.90  
15401402 196.69  198.94  201.05  
15401403 214.70  221.16  227.25
```

<b>15401404</b>	<b>225.70</b>	<b>230.12</b>	<b>234.28</b>
<b>15401405</b>	<b>232.97</b>	<b>235.92</b>	<b>238.70</b>
<b>15401406</b>	<b>238.11</b>	<b>240.19</b>	<b>242.15</b>
<b>15401407</b>	<b>240.94</b>	<b>242.10</b>	<b>243.09</b>
<b>15401408</b>	<b>242.41</b>	<b>243.03</b>	<b>243.55</b>
<b>15401409</b>	<b>243.10</b>	<b>243.41</b>	<b>243.71</b>
<b>15401410</b>	<b>243.58</b>	<b>243.77</b>	<b>243.95</b>

\*

*	<b>lt.boundary</b>	<b>incr</b>	<b>bdry</b>	<b>code</b>	<b>factor</b>	<b>hs#</b>
15401501	540010000	0	1	1	14906.7	1 *(1.5) 14906.7
15401502	540020000	0	1	1	13865.0	2 *(1.5) 13865.0
15401503	540030000	0	1	1	13865.0	3 *(1.0) 13865.0
15401504	540040000	0	1	1	13865.0	4 *(1.0) 13865.0
15401505	540050000	0	1	1	13865.0	5 *(1.0) 13865.0
15401506	540060000	0	1	1	13865.0	6 *(1.0) 13865.0
15401507	540070000	0	1	1	13865.0	7 *(1.0) 13865.0
15401508	540080000	0	1	1	13865.0	8 *(1.0) 13865.0
15401509	540090000	0	1	1	13865.0	9 *(1.0) 13865.0
15401510	540100000	0	1	1	14906.7	10 *(1.0) 13865.0

\*

\*

*	<b>rt.boundary</b>	<b>incr</b>	<b>bdry</b>	<b>code</b>	<b>factor</b>	<b>hs#</b>
15401601	753010000	0	1	1	14906.7	1 *(1.5) 14906.7
15401602	753010000	0	1	1	13865.0	2 *(1.5) 13865.0
15401603	752010000	0	1	1	13865.0	3 *(1.0) 13865.0
15401604	752010000	0	1	1	13865.0	4 *(1.0) 13865.0
15401605	752010000	0	1	1	13865.0	5 *(1.0) 13865.0
15401606	751010000	0	1	1	13865.0	6 *(1.0) 13865.0
15401607	751010000	0	1	1	13865.0	7 *(1.0) 13865.0
15401608	751010000	0	1	1	13865.0	8 *(1.0) 13865.0
15401609	750010000	0	1	1	13865.0	9 *(1.0) 13865.0
15401610	750010000	0	1	1	14906.7	10 *(1.0) 14906.7

\*

\*

*	<b>src.type</b>	<b>s.mult</b>	<b>dh-lt</b>	<b>dh-rt</b>	<b>hs#</b>
15401701	0	0.0	0.0	0.0	10

\*

\*

*	<b>hed</b>	<b>hlf</b>	<b>hlr</b>	<b>gslf</b>	<b>gslr</b>	<b>gkf</b>	<b>gkr</b>	<b>lbf</b>	<b>hs#</b>
15401801	0.0	4.5052	100.0	100.0	100.0	0.0	0.0	1.0	01
15401802	0.0	100.0	100.0	100.0	100.0	0.0	0.0	1.0	09
15401803	0.0	100.0	4.5052	100.0	100.0	0.0	0.0	1.0	10

\*

15401901 0.0 100.0 100.0 5.0 5.0 0.1 0.1 1.0 10

\*

\*

\* heat structure 541-1 RFW Heater B4 Tubes

```
* nh np geom init lt.coord
15411000 10 3 2 1 0.0231
*
* mesh loc'n format
15411100 0 1
*
* # intervals rt.coord
15411101 2 0.0260
*
* comp # inter#(in)
15411201 004 2
*
* rel. source interval
15411301 1. 2
*
15411400 -1
*
* mesh point temperatures
15411401 196.10 198.57 200.90
15411402 196.69 198.94 201.05
15411403 214.70 221.16 227.25
15411404 225.70 230.12 234.28
15411405 232.97 235.92 238.70
15411406 238.11 240.19 242.15
15411407 240.94 242.10 243.09
15411408 242.41 243.03 243.55
15411409 243.10 243.41 243.71
15411410 243.58 243.77 243.95
*
* lt.boundary incr bdry code factor hs#
15411501 541010000 0 1 1 14906.7 1 *(1.5) 14906.7
15411502 541020000 0 1 1 13865.0 2 *(1.5) 13865.0
15411503 541030000 0 1 1 13865.0 3 *(1.0) 13865.0
15411504 541040000 0 1 1 13865.0 4 *(1.0) 13865.0
15411505 541050000 0 1 1 13865.0 5 *(1.0) 13865.0
15411506 541060000 0 1 1 13865.0 6 *(1.0) 13865.0
15411507 541070000 0 1 1 13865.0 7 *(1.0) 13865.0
15411508 541080000 0 1 1 13865.0 8 *(1.0) 13865.0
15411509 541090000 0 1 1 13865.0 9 *(1.0) 13865.0
15411510 541100000 0 1 1 14906.7 10 *(1.0) 13865.0
*
*
* rt.boundary incr bdry code factor hs#
15411601 853010000 0 1 1 14906.7 1 *(1.5) 14906.7
15411602 853010000 0 1 1 13865.0 2 *(1.5) 13865.0
```

```
15411603 852010000  0   1   1   13865.0 3 *(1.0) 13865.0
15411604 852010000  0   1   1   13865.0 4 *(1.0) 13865.0
15411605 852010000  0   1   1   13865.0 5 *(1.0) 13865.0
15411606 851010000  0   1   1   13865.0 6 *(1.0) 13865.0
15411607 851010000  0   1   1   13865.0 7 *(1.0) 13865.0
15411608 851010000  0   1   1   13865.0 8 *(1.0) 13865.0
15411609 850010000  0   1   1   13865.0 9 *(1.0) 13865.0
15411610 850010000  0   1   1   14906.7 10 *(1.0) 14906.7
*
*      src.type    s.mult dh-lt dh-rt hs#
15411701 0          0.0  0.0  0.0  10
*
*      hed    hlf    hlr    gslf   gslr   gkf   gkr   lbf   hs#
15411801 0.0    4.5052 100.0 100.0 100.0 0.0 0.0 1.0 01
15411802 0.0    100.0 100.0 100.0 100.0 0.0 0.0 1.0 09
15411803 0.0    100.0 4.5052 100.0 100.0 0.0 0.0 1.0 10
*
15411901 0.0    100.0 100.0 5.0   5.0   0.1  0.1  1.0 10
*
*
* heat structure 542-1 RFW Heater C4 Tubes
*      nh    np    geom   init   lt.coord
15421000 10   3   2   1   0.0231
*
*      mesh loc'n  format
15421100 0       1
*
*      # intervals rt.coord
15421101 2       0.0260
*
*      comp #    inter#(in)
15421201 004     2
*
*      rel. source interval
15421301 1.       2
*
15421400 -1
*
*      mesh point temperatures
15421401 196.10  198.57  200.90
15421402 196.69  198.94  201.05
15421403 214.70  221.16  227.25
15421404 225.70  230.12  234.28
15421405 232.97  235.92  238.70
15421406 238.11  240.19  242.15
```

---

```

15421407 240.94  242.10  243.09
15421408 242.41  243.03  243.55
15421409 243.10  243.41  243.71
15421410 243.58  243.77  243.95
*
*   lt.boundary  incr  bdry  code  factor hs#
15421501 542010000  0    1    1    14906.7 1  *(1.5) 14906.7
15421502 542020000  0    1    1    13865.0 2  *(1.5) 13865.0
15421503 542030000  0    1    1    13865.0 3  *(1.0) 13865.0
15421504 542040000  0    1    1    13865.0 4  *(1.0) 13865.0
15421505 542050000  0    1    1    13865.0 5  *(1.0) 13865.0
15421506 542060000  0    1    1    13865.0 6  *(1.0) 13865.0
15421507 542070000  0    1    1    13865.0 7  *(1.0) 13865.0
15421508 542080000  0    1    1    13865.0 8  *(1.0) 13865.0
15421509 542090000  0    1    1    13865.0 9  *(1.0) 13865.0
15421510 542100000  0    1    1    14906.7 10 *(1.0) 13865.0
*
*
*   rt.boundary  incr  bdry  code  factor hs#
15421601 953010000  0    1    1    14906.7 1  *(1.5) 14906.7
15421602 953010000  0    1    1    13865.0 2  *(1.5) 13865.0
15421603 952010000  0    1    1    13865.0 3  *(1.0) 13865.0
15421604 952010000  0    1    1    13865.0 4  *(1.0) 13865.0
15421605 952010000  0    1    1    13865.0 5  *(1.0) 13865.0
15421606 951010000  0    1    1    13865.0 6  *(1.0) 13865.0
15421607 951010000  0    1    1    13865.0 7  *(1.0) 13865.0
15421608 951010000  0    1    1    13865.0 8  *(1.0) 13865.0
15421609 950010000  0    1    1    13865.0 9  *(1.0) 13865.0
15421610 950010000  0    1    1    14906.7 10 *(1.0) 14906.7
*
*   src.type    s.mult dh-lt dh-rt hs#
15421701 0        0.0  0.0  0.0  10
*
*   hed    hlf    hlr    gslf   gslr   gkf   gkr   lbf   hs#
15421801 0.0    4.5052 100.0 100.0 100.0 0.0  0.0  1.0  01
15421802 0.0    100.0 100.0 100.0 100.0 0.0  0.0  1.0  09
15421803 0.0    100.0 4.5052 100.0 100.0 0.0  0.0  1.0  10
*
15421901 0.0    100.0 100.0 5.0   5.0   0.1  0.1  1.0  10
*
*
* heat structure 550-1 RFW Heater A3 Tubes
*   nh    np    geom  init  lt.coord
15501000 12    3     2     1     0.0231
*
```

```
*      mesh loc'n  format
15501100 0      1
*
*      # intervals  rt.coord
15501101 2      0.026
*
*      comp #    inter#(in)
15501201 004      2
*
*      rel. source  interval
15501301 1.      2
*
15501400 -1
*
*      mesh point temperatures
15501401 246.43  247.53  248.56
15501402 246.17  246.52  246.83
15501403 247.68  248.25  248.78
15501404 269.73  276.87  283.59
15501405 281.70  286.31  290.65
15501406 289.69  292.67  295.49
15501407 294.81  296.72  298.52
15501408 297.99  299.19  300.32
15501409 298.66  299.68  300.63
15501410 298.35  298.90  299.40
15501411 297.82  297.95  298.06
15501412 297.58  297.58  297.58
*
*      lt.boundary  incr  bdry  code  factor hs#
15501501 550010000  0   1   1   21221.2 1 *(1.5) 14147.5
15501502 550020000  0   1   1   19721.3 2 *(1.5) 13147.5
15501503 550030000  0   1   1   8388.0 3 *(1.0) 5592.0
15501504 550040000  0   1   1   5592.0 4 *(1.0) 5592.0
15501505 550050000  0   1   1   20715.2 5 *(1.0) 20715.2
15501506 550060000  0   1   1   20715.2 6 *(1.0) 20715.2
15501507 550070000  0   1   1   20715.2 7 *(1.0) 20715.2
15501508 550080000  0   1   1   20715.2 8 *(1.0) 20715.2
15501509 550090000  0   1   1   5592.0 9 *(1.0) 5592.0
15501510 550100000  0   1   1   5592.0 10 *(1.0) 5592.0
15501511 550110000  0   1   1   13147.5 11 *(1.0) 13147.5
15501512 550120000  0   1   1   14147.5 12 *(1.0) 14147.5
*
*
*      rt.boundary  incr  bdry  code  factor hs#
15501601 743030000  0   1   1   21221.2 1 *(1.5) 14147.5
```

15501602 743020000 0 1 1 19721.3 2 \*(1.5) 13147.5  
15501603 743010000 0 1 1 8388.0 3 \*(1.0) 5592.0  
15501604 742010000 0 1 1 5592.0 4 \*(1.0) 5592.0  
15501605 741010000 0 1 1 20715.2 5 \*(1.0) 20715.2  
15501606 740010000 0 1 1 20715.2 6 \*(1.0) 20715.2  
15501607 740010000 0 1 1 20715.2 7 \*(1.0) 20715.2  
15501608 741010000 0 1 1 20715.2 8 \*(1.0) 20715.2  
15501609 742010000 0 1 1 5592.0 9 \*(1.0) 5592.0  
15501610 742020000 0 1 1 5592.0 10 \*(1.0) 5592.0  
15501611 742030000 0 1 1 13147.5 11 \*(1.0) 13147.5  
15501612 742040000 0 1 1 14147.5 12 \*(1.0) 14147.5  
\*  
\* src.type s.mult dh-lt dh-rt hs#  
15501701 0 0.0 0.0 0.0 12  
\*  
\* hed hlf hlr gslf gslr gkf gkr lbf hs#  
15501801 0.0 4.0632 100.0 100.0 100.0 0.0 0.0 1.0 01  
15501802 0.0 100.0 100.0 100.0 100.0 0.0 0.0 1.0 11  
15501803 0.0 100.0 4.0632 100.0 100.0 0.0 0.0 1.0 12  
\*  
15501901 0.0 100.0 100.0 5.0 5.0 0.1 0.1 1.0 12  
\*  
\*  
\* heat structure 551-1 RFW Heater B3 Tubes  
\* nh np geom init lt.coord  
15511000 12 3 2 1 0.0231  
\*  
\* mesh loc'n format  
15511100 0 1  
\*  
\* # intervals rt.coord  
15511101 2 0.026  
\*  
\* comp # inter#(in)  
15511201 004 2  
\*  
\* rel. source interval  
15511301 1. 2  
\*  
15511400 -1  
\*  
\* mesh point temperatures  
15511401 246.43 247.53 248.56  
15511402 246.17 246.52 246.83  
15511403 247.68 248.25 248.78

15511404	269.73	276.87	283.59						
15511405	281.70	286.31	290.65						
15511406	289.69	292.67	295.49						
15511407	294.81	296.72	298.52						
15511408	297.99	299.19	300.32						
15511409	298.66	299.68	300.63						
15511410	298.35	298.90	299.40						
15511411	297.82	297.95	298.06						
15511412	297.58	297.58	297.58						
*									
*	lt.boundary	incr	bdry	code	factor	hs#			
15511501	551010000	0	1	1	21221.2	1 *(1.5)	14147.5		
15511502	551020000	0	1	1	19721.3	2 *(1.5)	13147.5		
15511503	551030000	0	1	1	8388.0	3 *(1.0)	5592.0		
15511504	551040000	0	1	1	5592.0	4 *(1.0)	5592.0		
15511505	551050000	0	1	1	20715.2	5 *(1.0)	20715.2		
15511506	551060000	0	1	1	20715.2	6 *(1.0)	20715.2		
15511507	551070000	0	1	1	20715.2	7 *(1.0)	20715.2		
15511508	551080000	0	1	1	20715.2	8 *(1.0)	20715.2		
15511509	551090000	0	1	1	5592.0	9 *(1.0)	5592.0		
15511510	551100000	0	1	1	5592.0	10 *(1.0)	5592.0		
15511511	551110000	0	1	1	13147.5	11 *(1.0)	13147.5		
15511512	551120000	0	1	1	14147.5	12 *(1.0)	14147.5		
*									
*									
*	rt.boundary	incr	bdry	code	factor	hs#			
15511601	843030000	0	1	1	21221.2	1 *(1.5)	14147.5		
15511602	843020000	0	1	1	19721.3	2 *(1.5)	13147.5		
15511603	843010000	0	1	1	8388.0	3 *(1.0)	5592.0		
15511604	842010000	0	1	1	5592.0	4 *(1.0)	5592.0		
15511605	841010000	0	1	1	20715.2	5 *(1.0)	20715.2		
15511606	840010000	0	1	1	20715.2	6 *(1.0)	20715.2		
15511607	840010000	0	1	1	20715.2	7 *(1.0)	20715.2		
15511608	841010000	0	1	1	20715.2	8 *(1.0)	20715.2		
15511609	842010000	0	1	1	5592.0	9 *(1.0)	5592.0		
15511610	842020000	0	1	1	5592.0	10 *(1.0)	5592.0		
15511611	842030000	0	1	1	13147.5	11 *(1.0)	13147.5		
15511612	842040000	0	1	1	14147.5	12 *(1.0)	14147.5		
*									
*	src.type	s.mult	dh-lt	dh-rt	hs#				
15511701	0	0.0	0.0	0.0	12				
*									
*	hed	hlf	hlr	gslf	gslr	gkf	gkr	lbf	hs#
15511801	0.0	4.0632	100.0	100.0	100.0	0.0	0.0	1.0	01
15511802	0.0	100.0	100.0	100.0	100.0	0.0	0.0	1.0	11

```
15511803 0.0   100.0 4.0632 100.0 100.0 0.0 0.0 1.0 12
*
15511901 0.0   100.0 100.0 5.0  5.0  0.1 0.1 1.0 12
*
*
* heat structure 552-1 RFW Heater C3 Tubes
* nh np geom init lt.coord
15521000 12  3   2   1   0.0231
*
* mesh loc'n format
15521100 0      1
*
* # intervals rt.coord
15521101 2      0.026
*
* comp # inter#(in)
15521201 004    2
*
* rel. source interval
15521301 1.     2
*
15521400 -1
*
* mesh point temperatures
15521401 246.43  247.53  248.56
15521402 246.17  246.52  246.83
15521403 247.68  248.25  248.78
15521404 269.73  276.87  283.59
15521405 281.70  286.31  290.65
15521406 289.69  292.67  295.49
15521407 294.81  296.72  298.52
15521408 297.99  299.19  300.32
15521409 298.66  299.68  300.63
15521410 298.35  298.90  299.40
15521411 297.82  297.95  298.06
15521412 297.58  297.58  297.58
*
* lt.boundary incr bdry code factor hs#
15521501 552010000  0   1   1   21221.2 1 *(1.5) 14147.5
15521502 552020000  0   1   1   19721.3 2 *(1.5) 13147.5
15521503 552030000  0   1   1   8388.0 3 *(1.0) 5592.0
15521504 552040000  0   1   1   5592.0 4 *(1.0) 5592.0
15521505 552050000  0   1   1   20715.2 5 *(1.0) 20715.2
15521506 552060000  0   1   1   20715.2 6 *(1.0) 20715.2
15521507 552070000  0   1   1   20715.2 7 *(1.0) 20715.2
```

```
15521508 552080000  0   1   1   20715.2 8 *(1.0) 20715.2
15521509 552090000  0   1   1   5592.0 9 *(1.0) 5592.0
15521510 552100000  0   1   1   5592.0 10 *(1.0) 5592.0
15521511 552110000  0   1   1   13147.5 11 *(1.0) 13147.5
15521512 552120000  0   1   1   14147.5 12 *(1.0) 14147.5
*
*
*   rt.boundary  incr  bdry  code  factor hs#
15521601 943030000  0   1   1   21221.2 1 *(1.5) 14147.5
15521602 943020000  0   1   1   19721.3 2 *(1.5) 13147.5
15521603 943010000  0   1   1   8388.0 3 *(1.0) 5592.0
15521604 942010000  0   1   1   5592.0 4 *(1.0) 5592.0
15521605 941010000  0   1   1   20715.2 5 *(1.0) 20715.2
15521606 940010000  0   1   1   20715.2 6 *(1.0) 20715.2
15521607 940010000  0   1   1   20715.2 7 *(1.0) 20715.2
15521608 941010000  0   1   1   20715.2 8 *(1.0) 20715.2
15521609 942010000  0   1   1   5592.0 9 *(1.0) 5592.0
15521610 942020000  0   1   1   5592.0 10 *(1.0) 5592.0
15521611 942030000  0   1   1   13147.5 11 *(1.0) 13147.5
15521612 942040000  0   1   1   14147.5 12 *(1.0) 14147.5
*
*   src.type    s.mult dh-lt dh-rt hs#
15521701 0       0.0  0.0  0.0  12
*
*   hed    hlf    hlr    gslf   gslr   gkf   gkr   lbf   hs#
15521801 0.0    4.0632 100.0 100.0 100.0 0.0  0.0  1.0  01
15521802 0.0    100.0 100.0 100.0 100.0 0.0  0.0  1.0  11
15521803 0.0    100.0 4.0632 100.0 100.0 0.0  0.0  1.0  12
*
15521901 0.0    100.0 100.0 5.0   5.0   0.1  0.1  1.0  12
*
*
* heat structure 590-1 RFW Heater A2 Tubes
*   nh   np   geom  init  lt.coord
15901000 10   3   2   1   0.022
*
*   mesh loc'n  format
15901100 0       1
*
*   # intervals  rt.coord
15901101 2       0.026
*
*   comp #     inter#(in)
15901201 004      2
*
```

```
*      rel. source  interval
15901301 1.      2
*
15901400 -1
*
*      mesh point temperatures
15901401 303.62   304.79   305.86
15901402 306.11   307.75   309.25
15901403 318.82   324.86   330.41
15901404 328.06   331.84   335.32
15901405 333.40   335.65   337.72
15901406 336.33   337.62   338.81
15901407 337.88   338.59   339.25
15901408 338.29   338.84   339.35
15901409 337.26   337.13   337.02
15901410 335.67   335.19   334.76
*
*      lt.boundary  incr  bdry  code  factor hs#
15901501 590010000  0    1    1    14896.8 1 *(1.5) 11917.5
15901502 590020000  0    1    1    7147.5  2 *(1.5) 5718.0
15901503 590030000  0    1    1    7147.5  3 *(1.5) 5718.0
15901504 590040000  0    1    1    21147.8 4 *(1.5) 16918.2
15901505 590050000  0    1    1    21147.8 5 *(1.5) 16918.2
15901506 590060000  0    1    1    21147.8 6 *(1.5) 16918.2
15901507 590070000  0    1    1    21147.8 7 *(1.5) 16918.2
15901508 590080000  0    1    1    7147.5  8 *(1.5) 5718.0
15901509 590090000  0    1    1    7147.5  9 *(1.5) 5718.0
15901510 590100000  0    1    1    14896.8 10 *(1.5) 11917.5
*
*
*      rt.boundary  incr  bdry  code  factor hs#
15901601 733010000  0    1    1    14896.8 1 *(1.5) 11917.5
15901602 732020000  0    1    1    7147.5  2 *(1.5) 5718.0
15901603 732010000  0    1    1    7147.5  3 *(1.5) 5718.0
15901604 731010000  0    1    1    21147.8 4 *(1.5) 16918.2
15901605 730010000  0    1    1    21147.8 5 *(1.5) 16918.2
15901606 730010000  0    1    1    21147.8 6 *(1.5) 16918.2
15901607 731010000  0    1    1    21147.8 7 *(1.5) 16918.2
15901608 732010000  0    1    1    7147.5  8 *(1.5) 5718.0
15901609 732020000  0    1    1    7147.5  9 *(1.5) 5718.0
15901610 733010000  0    1    1    14896.8 10 *(1.5) 11917.5
*
*      src.type    s.mult dh-lt dh-rt hs#
15901701 0          0.0   0.0   0.0   10
*
```

```
* hed hlf hlr gslf gslr gkf gkr lbf hs#
15901801 0.0  3.5039 100.0 100.0 100.0 0.0 0.0 1.0 01
15901802 0.0  100.0 100.0 100.0 100.0 0.0 0.0 1.0 09
15901803 0.0  100.0 3.5039 100.0 100.0 0.0 0.0 1.0 10
*
15901901 0.0  100.0 100.0 5.0  5.0  0.1 0.1 1.0 10
*
*
* heat structure 591-1 RFW Heater B2 Tubes
* nh np geom init lt.coord
15911000 10  3   2   1   0.022
*
* mesh loc'n format
15911100 0    1
*
* # intervals rt.coord
15911101 2    0.026
*
* comp # inter#(in)
15911201 004  2
*
* rel. source interval
15911301 1.   2
*
15911400 -1
*
* mesh point temperatures
15911401 303.62 304.79 305.86
15911402 306.11 307.75 309.25
15911403 318.82 324.86 330.41
15911404 328.06 331.84 335.32
15911405 333.40 335.65 337.72
15911406 336.33 337.62 338.81
15911407 337.88 338.59 339.25
15911408 338.29 338.84 339.35
15911409 337.26 337.13 337.02
15911410 335.67 335.19 334.76
*
* lt.boundary incr bdry code factor hs#
15911501 591010000 0  1   1   14896.8 1 *(1.5) 11917.5
15911502 591020000 0  1   1   7147.5 2 *(1.5) 5718.0
15911503 591030000 0  1   1   7147.5 3 *(1.5) 5718.0
15911504 591040000 0  1   1   21147.8 4 *(1.5) 16918.2
15911505 591050000 0  1   1   21147.8 5 *(1.5) 16918.2
15911506 591060000 0  1   1   21147.8 6 *(1.5) 16918.2
```

```
15911507 591070000  0   1   1   21147.8 7 *(1.5) 16918.2
15911508 591080000  0   1   1   7147.5 8 *(1.5) 5718.0
15911509 591090000  0   1   1   7147.5 9 *(1.5) 5718.0
15911510 591100000  0   1   1   14896.8 10 *(1.5) 11917.5
*
*
*      rt.boundary  incr  bdry  code  factor hs#
15911601 833010000  0   1   1   14896.8 1 *(1.5) 11917.5
15911602 832020000  0   1   1   7147.5 2 *(1.5) 5718.0
15911603 832010000  0   1   1   7147.5 3 *(1.5) 5718.0
15911604 831010000  0   1   1   21147.8 4 *(1.5) 16918.2
15911605 830010000  0   1   1   21147.8 5 *(1.5) 16918.2
15911606 830010000  0   1   1   21147.8 6 *(1.5) 16918.2
15911607 831010000  0   1   1   21147.8 7 *(1.5) 16918.2
15911608 832010000  0   1   1   7147.5 8 *(1.5) 5718.0
15911609 832020000  0   1   1   7147.5 9 *(1.5) 5718.0
15911610 833010000  0   1   1   14896.8 10 *(1.5) 11917.5
*
*      src.type    s.mult dh-lt dh-rt hs#
15911701 0        0.0  0.0  0.0  10
*
*      hed    hlf    hlr    gslf   gslr   gkf   gkr   lbf   hs#
15911801 0.0    3.5039 100.0 100.0 100.0 0.0 0.0 1.0 01
15911802 0.0    100.0 100.0 100.0 100.0 0.0 0.0 1.0 09
15911803 0.0    100.0 3.5039 100.0 100.0 0.0 0.0 1.0 10
*
15911901 0.0    100.0 100.0 5.0   5.0   0.1  0.1  1.0  10
*
*
* heat structure 592-1 RFW Heater C2 Tubes
*      nh    np    geom  init  lt.coord
15921000 10   3   2   1   0.022
*
*      mesh loc'n  format
15921100 0        1
*
*      # intervals  rt.coord
15921101 2        0.026
*
*      comp #    inter#(in)
15921201 004      2
*
*      rel. source  interval
15921301 1.        2
*
```

**15921400 -1**

\*

\* mesh point temperatures

15921401	303.62	304.79	305.86
15921402	306.11	307.75	309.25
15921403	318.82	324.86	330.41
15921404	328.06	331.84	335.32
15921405	333.40	335.65	337.72
15921406	336.33	337.62	338.81
15921407	337.88	338.59	339.25
15921408	338.29	338.84	339.35
15921409	337.26	337.13	337.02
15921410	335.67	335.19	334.76

\*

\* lt.boundary incr bdry code factor hs#

15921501	592010000	0	1	1	14896.8	1 *(1.5) 11917.5
15921502	592020000	0	1	1	7147.5	2 *(1.5) 5718.0
15921503	592030000	0	1	1	7147.5	3 *(1.5) 5718.0
15921504	592040000	0	1	1	21147.8	4 *(1.5) 16918.2
15921505	592050000	0	1	1	21147.8	5 *(1.5) 16918.2
15921506	592060000	0	1	1	21147.8	6 *(1.5) 16918.2
15921507	592070000	0	1	1	21147.8	7 *(1.5) 16918.2
15921508	592080000	0	1	1	7147.5	8 *(1.5) 5718.0
15921509	592090000	0	1	1	7147.5	9 *(1.5) 5718.0
15921510	592100000	0	1	1	14896.8	10 *(1.5) 11917.5

\*

\*

\* rt.boundary incr bdry code factor hs#

15921601	933010000	0	1	1	14896.8	1 *(1.5) 11917.5
15921602	932020000	0	1	1	7147.5	2 *(1.5) 5718.0
15921603	932010000	0	1	1	7147.5	3 *(1.5) 5718.0
15921604	931010000	0	1	1	21147.8	4 *(1.5) 16918.2
15921605	930010000	0	1	1	21147.8	5 *(1.5) 16918.2
15921606	930010000	0	1	1	21147.8	6 *(1.5) 16918.2
15921607	931010000	0	1	1	21147.8	7 *(1.5) 16918.2
15921608	932010000	0	1	1	7147.5	8 *(1.5) 5718.0
15921609	932020000	0	1	1	7147.5	9 *(1.5) 5718.0
15921610	933010000	0	1	1	14896.8	10 *(1.5) 11917.5

\*

\* src.type s.mult dh-lt dh-rt hs#

15921701	0	0.0	0.0	0.0	10
----------	---	-----	-----	-----	----

\*

\* hed hlf hlr gslf gslr gkf gkr lbf hs#

15921801	0.0	3.5039	100.0	100.0	100.0	0.0	0.0	1.0	01
----------	-----	--------	-------	-------	-------	-----	-----	-----	----

15921802	0.0	100.0	100.0	100.0	100.0	0.0	0.0	1.0	09
----------	-----	-------	-------	-------	-------	-----	-----	-----	----

```
15921803 0.0   100.0 3.5039 100.0 100.0 0.0 0.0 1.0 10
*
15921901 0.0   100.0 100.0 5.0  5.0  0.1 0.1 1.0 10
*
*
* heat structure 600-1 RFW Heater A1 Tubes
* nh np geom init lt.coord
16001000 10  3  2  1   0.022
*
* mesh loc'n format
16001100 0      1
*
* # intervals rt.coord
16001101 2      0.026
*
* comp # inter#(in)
16001201 004    2
*
* rel. source interval
16001301 1.     2
*
16001400 -1
*
* mesh point temperatures
16001401 334.73 337.01 339.10
16001402 342.92 348.65 353.94
16001403 350.65 358.47 365.67
16001404 361.40 366.91 372.00
16001405 370.28 374.50 378.38
16001406 375.68 378.54 381.17
16001407 378.82 380.63 382.30
16001408 379.67 381.32 382.84
16001409 377.60 377.59 377.59
16001410 374.79 373.19 371.71
*
* lt.boundary incr bdry code factor hs#
16001501 600010000 0  1  1   5963.7 1 *(1.5) 3975.8
16001502 600020000 0  1  1   7624.0 2 *(1.5) 5082.7
16001503 600030000 0  1  1   7624.0 3 *(1.5) 5082.7
16001504 600040000 0  1  1   29904.1 4 *(1.5) 19936.1
16001505 600050000 0  1  1   29904.1 5 *(1.5) 19936.1
16001506 600060000 0  1  1   29904.1 6 *(1.5) 19936.1
16001507 600070000 0  1  1   29904.1 7 *(1.5) 19936.1
16001508 600080000 0  1  1   7624.0 8 *(1.5) 5082.7
16001509 600090000 0  1  1   7624.0 9 *(1.5) 5082.7
```

```
16001510 600100000 0 1 1 5963.7 10 *(1.5) 3975.8
*
*
*      rt.boundary  incr  bdry  code  factor hs#
16001601 722010000 0 1 1 5963.7 1 *(1.5) 3975.8
16001602 721030000 0 1 1 7624.0 2 *(1.5) 5082.7
16001603 721020000 0 1 1 7624.0 3 *(1.5) 5082.7
16001604 721010000 0 1 1 29904.1 4 *(1.5) 19936.1
16001605 720010000 0 1 1 29904.1 5 *(1.5) 19936.1
16001606 720010000 0 1 1 29904.1 6 *(1.5) 19936.1
16001607 721010000 0 1 1 29904.1 7 *(1.5) 19936.1
16001608 721020000 0 1 1 7624.0 8 *(1.5) 5082.7
16001609 721030000 0 1 1 7624.0 9 *(1.5) 5082.7
16001610 722010000 0 1 1 5963.7 10 *(1.5) 3975.8
*
*      src.type    s.mult dh-lt dh-rt hs#
16001701 0       0.0 0.0 0.0 10
*
*      hed    hlf    hlr    gslf   gslr   gkf   gkr   lbf   hs#
16001801 0.0    1.4206 100.0 100.0 100.0 0.0 0.0 1.0 01
16001802 0.0    100.0 100.0 100.0 100.0 0.0 0.0 1.0 09
16001803 0.0    100.0 1.4206 100.0 100.0 0.0 0.0 1.0 10
*
16001901 0.0    100.0 100.0 5.0 5.0 0.1 0.1 1.0 10
*
*
* heat structure 601-1 RFW Heater B1 Tubes
*      nh    np    geom  init  lt.coord
16011000 10 3 2 1 0.022
*
*      mesh loc'n  format
16011100 0       1
*
*      # intervals  rt.coord
16011101 2       0.026
*
*      comp #    inter#(in)
16011201 004     2
*
*      rel. source  interval
16011301 1.       2
*
16011400 -1
*
*      mesh point temperatures
```

---

16011401	334.73	337.01	339.10		
16011402	342.92	348.65	353.94		
16011403	350.65	358.47	365.67		
16011404	361.40	366.91	372.00		
16011405	370.28	374.50	378.38		
16011406	375.68	378.54	381.17		
16011407	378.82	380.63	382.30		
16011408	379.67	381.32	382.84		
16011409	377.60	377.59	377.59		
16011410	374.79	373.19	371.71		
*					
* lt.boundary incr bdry code factor hs#					
16011501	601010000	0	1	1	5963.7 1 *(1.5) 3975.8
16011502	601020000	0	1	1	7624.0 2 *(1.5) 5082.7
16011503	601030000	0	1	1	7624.0 3 *(1.5) 5082.7
16011504	601040000	0	1	1	29904.1 4 *(1.5) 19936.1
16011505	601050000	0	1	1	29904.1 5 *(1.5) 19936.1
16011506	601060000	0	1	1	29904.1 6 *(1.5) 19936.1
16011507	601070000	0	1	1	29904.1 7 *(1.5) 19936.1
16011508	601080000	0	1	1	7624.0 8 *(1.5) 5082.7
16011509	601090000	0	1	1	7624.0 9 *(1.5) 5082.7
16011510	601100000	0	1	1	5963.7 10 *(1.5) 3975.8
*					
*					
* rt.boundary incr bdry code factor hs#					
16011601	822010000	0	1	1	5963.7 1 *(1.5) 3975.8
16011602	821030000	0	1	1	7624.0 2 *(1.5) 5082.7
16011603	821020000	0	1	1	7624.0 3 *(1.5) 5082.7
16011604	821010000	0	1	1	29904.1 4 *(1.5) 19936.1
16011605	820010000	0	1	1	29904.1 5 *(1.5) 19936.1
16011606	820010000	0	1	1	29904.1 6 *(1.5) 19936.1
16011607	821010000	0	1	1	29904.1 7 *(1.5) 19936.1
16011608	821020000	0	1	1	7624.0 8 *(1.5) 5082.7
16011609	821030000	0	1	1	7624.0 9 *(1.5) 5082.7
16011610	822010000	0	1	1	5963.7 10 *(1.5) 3975.8
*					
* src.type s.mult dh-lt dh-rt hs#					
16011701	0	0.0	0.0	0.0	10
*					
* hed hlf hlr gslf gslr gkf gkr lbf hs#					
16011801	0.0	1.4206	100.0	100.0	100.0 0.0 0.0 1.0 01
16011802	0.0	100.0	100.0	100.0	100.0 0.0 0.0 1.0 09
16011803	0.0	100.0	1.4206	100.0	100.0 0.0 0.0 1.0 10
*					
16011901	0.0	100.0	100.0	5.0	5.0 0.1 0.1 1.0 10

```
*  
*  
* heat structure 602-1 RFW Heater C1 Tubes  
* nh np geom init lt.coord  
16021000 10 3 2 1 0.022  
*  
* mesh loc'n format  
16021100 0 1  
*  
* # intervals rt.coord  
16021101 2 0.026  
*  
* comp # inter#(in)  
16021201 004 2  
*  
* rel. source interval  
16021301 1. 2  
*  
16021400 -1  
*  
* mesh point temperatures  
16021401 334.73 337.01 339.10  
16021402 342.92 348.65 353.94  
16021403 350.65 358.47 365.67  
16021404 361.40 366.91 372.00  
16021405 370.28 374.50 378.38  
16021406 375.68 378.54 381.17  
16021407 378.82 380.63 382.30  
16021408 379.67 381.32 382.84  
16021409 377.60 377.59 377.59  
16021410 374.79 373.19 371.71  
*  
* lt.boundary incr bdry code factor hs#  
16021501 602010000 0 1 1 5963.7 1 *(1.5) 3975.8  
16021502 602020000 0 1 1 7624.0 2 *(1.5) 5082.7  
16021503 602030000 0 1 1 7624.0 3 *(1.5) 5082.7  
16021504 602040000 0 1 1 29904.1 4 *(1.5) 19936.1  
16021505 602050000 0 1 1 29904.1 5 *(1.5) 19936.1  
16021506 602060000 0 1 1 29904.1 6 *(1.5) 19936.1  
16021507 602070000 0 1 1 29904.1 7 *(1.5) 19936.1  
16021508 602080000 0 1 1 7624.0 8 *(1.5) 5082.7  
16021509 602090000 0 1 1 7624.0 9 *(1.5) 5082.7  
16021510 602100000 0 1 1 5963.7 10 *(1.5) 3975.8  
*  
*
```

```
* rt.boundary incr bdry code factor hs#
16021601 922010000 0 1 1 5963.7 1 *(1.5) 3975.8
16021602 921030000 0 1 1 7624.0 2 *(1.5) 5082.7
16021603 921020000 0 1 1 7624.0 3 *(1.5) 5082.7
16021604 921010000 0 1 1 29904.1 4 *(1.5) 19936.1
16021605 920010000 0 1 1 29904.1 5 *(1.5) 19936.1
16021606 920010000 0 1 1 29904.1 6 *(1.5) 19936.1
16021607 921010000 0 1 1 29904.1 7 *(1.5) 19936.1
16021608 921020000 0 1 1 7624.0 8 *(1.5) 5082.7
16021609 921030000 0 1 1 7624.0 9 *(1.5) 5082.7
16021610 922010000 0 1 1 5963.7 10 *(1.5) 3975.8
*
* src.type s.mult dh-lt dh-rt hs#
16021701 0 0.0 0.0 0.0 10
*
* hed hlf hlr gslf gslr gkf gkr lbf hs#
16021801 0.0 1.4206 100.0 100.0 100.0 0.0 0.0 1.0 01
16021802 0.0 100.0 100.0 100.0 100.0 0.0 0.0 1.0 09
16021803 0.0 100.0 1.4206 100.0 100.0 0.0 0.0 1.0 10
*
16021901 0.0 100.0 100.0 5.0 5.0 0.1 0.1 1.0 10
*
*
* heater tube thermal properties (type 304 stainless steel)
*-----
*
20100400 tbl/fctn 1 1
* thermal conductivity (btu/s-ft-degf)
20100401 2.26e-3
*
* volumetric heat capacity (btu/ft**3-degf)
20100451 53.7
*
*
* tables of heater-tube heat flux [w/m**2] vs rx power [w]
*-----
*
* tables derived from refs. [188 - 193, 204, & 205] as per calcs. of app. d
*
* drain coolers
20258000 reac-t
20258009 3.293e9 31374. * jam
20258008 3.1284e9 29002. * jam
20258007 2.9637e9 26666. * jam
```

20258006 2.7991e9 24368. \* jam  
20258005 2.6344e9 21872. \* jam  
20258004 2.4698e9 19382. \* jam  
20258003 1.8384e9 9524. \* jam  
20258002 9.775e8 2047. \* jam  
20258001 0. 0.  
\*

\*

\* heater related control variables (tube powers [w])

\*-----

\*

\* tube power = surface area \* heat flux

\*

\* reactor power [w] = % rated power \* rated power [w]

20580100 rxpower mult 3.293e+07 3.3125499e+09 0

20580101 cntrlvar 010

\*

\* drain cooler (single)

20581600 pwrdc\_s function 1.217e+03 3.8182160e+07 0

20581601 cntrlvar 801 580

\*

\* cntrlvar 0815: HTRA5 power (BTU/HR)

20581500 'HTR5-PWR' sum 3.414426 250700000. 0

20581501 0.0 1.0 q 530010000 1.0 q 530050000

20581502 1.0 q 530020000 1.0 q 530060000

20581503 1.0 q 530030000 1.0 q 530070000

20581504 1.0 q 530040000 1.0 q 530080000

\*

\* cntrlvar 0814: HTRA4 power (BTU/HR)

20581400 'HTR4-PWR' sum 3.414426 266000000. 0

20581401 0.0 1.0 q 540010000 1.0 q 540060000

20581402 1.0 q 540020000 1.0 q 540070000

20581403 1.0 q 540030000 1.0 q 540080000

20581404 1.0 q 540040000 1.0 q 540090000

20581405 1.0 q 540050000 1.0 q 540100000

\*

\* cntrlvar 0813: HTRA3 power (BTU/HR)

20581300 'HTR3-PWR' sum 3.414426 283000000. 0

20581301 0.0 1.0 q 550010000 1.0 q 550070000

20581302 1.0 q 550020000 1.0 q 550080000

20581303 1.0 q 550030000 1.0 q 550090000

20581304 1.0 q 550040000 1.0 q 550100000

20581305 1.0 q 550050000 1.0 q 550110000

20581306        1.0 q 550060000    1.0 q 550120000

\*

\* cntrlvar 0812: HTRA2 power (BTU/HR)

20581200 'HTR2-PWR' sum 3.414426 150800000. 0

20581201 0.0 1.0 q 590010000 1.0 q 590060000

20581202 1.0 q 590020000 1.0 q 590070000

20581203 1.0 q 590030000 1.0 q 590080000

20581204 1.0 q 590040000 1.0 q 590090000

20581205 1.0 q 590050000 1.0 q 590100000

\*

\* cntrlvar 811: HTRA1 power (BTU/HR)

20581100 'HTR1-PWR' sum 3.414426 227800000. 0

20581101 0.0 1.0 q 600010000 1.0 q 600060000

20581102 1.0 q 600020000 1.0 q 600070000

20581103 1.0 q 600030000 1.0 q 600080000

20581104 1.0 q 600040000 1.0 q 600090000

20581105 1.0 q 600050000 1.0 q 600100000

\*

# B

## RELAP5 MODEL INPUT DECK WITH NEW RECIRCULATION CONTROLS

---

```
= brown's ferry relap5 plant model
* Full implementation of 3-train FW heaters
*
*card prob type transnt/stdy-st
*0000100 new stdy-st
0000100 new transnt
*0000100 restart transnt
*
*card inp-chk/run
0000101 run *prb 01-24-96 10:13am
*
*card input units output units
0000102 british british
*103 24012
*
* restart file
*0000104 none *remove asterisk at beginning
*
*card reference elev fluid name
0000120 100010000 8.750 h2o primary
0000121 960030000 597.020833 h2o 'FW-HTRS'
*
*
*-----
* time step control cards
*-----
*card end min max cntrl minor major restrt
0000201 1.00 1.e-6 0.025 00003 1000 2000 5000
0000201 200. 1.e-6 1.25e-2 00003 9000 14000 14000
*
*-----
* minor edits
*-----
*
```

```
*0000301 cntrlvar 675      *stand alone
*0000301 cntrlvar 646      *labview
*0000302 cntrlvar 650
*0000303 cntrlvar 689
*0000305 mflowj  610012200  *HTR-A1 Feedwater flow (lb/sec)
*0000306 tempf   605010000  *HTR-A1 RFW outlet temperature
*0000310 cntrlvar 0306      *HTR-A1 level
*0000311 cntrlvar 0324      *HTR-A1 drain valve position
*0000312 cntrlvar 0811      *HTR-A1 power
*
*0000320 mflowj  588010000  *HTR-A2 Feedwater flow (lb/sec)
*0000321 tempf   595010000  *HTR-A2 RFW outlet temperature
*0000322 cntrlvar 0331      *HTR-A2 level
*0000323 cntrlvar 0349      *HTR-A2 drain valve position
*0000324 cntrlvar 0812      *HTR-A2 power
*
*0000330 mflowj  550010000  *HTR-A3 Feedwater flow (lb/sec)
*0000331 tempf   555010000  *HTR-A3 RFW outlet temperature
*0000332 cntrlvar 0361      *HTR-A3 level
*0000333 cntrlvar 0379      *HTR-A3 drain valve position
*0000334 cntrlvar 0813      *HTR-A3 power
*
*0000335 mflowj  540010000  *HTR-A4 Feedwater flow (lb/sec)
*0000336 tempf   545010000  *HTR-A4 RFW outlet temperature
*0000337 cntrlvar 0381      *HTR-A4 level
*0000338 cntrlvar 0399      *HTR-A4 drain valve position
*0000339 cntrlvar 0814      *HTR-A4 power
*
*0000340 mflowj  530010000  *HTR-A5 Feedwater flow (lb/sec)
*0000341 tempf   535010000  *HTR-A5 RFW outlet temperature
*0000342 cntrlvar 0410      *HTR-A5 level
*0000343 cntrlvar 0411      *HTR-A5 level lagged
*0000344 cntrlvar 0429      *HTR-A5 drain valve position
*0000345 cntrlvar 0815      *HTR-A5 power
*
* core flow [lbm/hr]
*20591500 coreflw  sum 7.930e+03 9.8994448e+07 0
*20591501 0. 1. mflowj 110010000 1. mflowj 110020000
*
*-----
* variable trip cards
*-----
*
* vessel level trips
```

0000401 cntrlvar 2 le null 0 -1.2200e+02 n -1.0  
0000402 cntrlvar 2 le null 0 -4.5000e+01 n -1.0  
0000403 cntrlvar 6 le null 0 1.1200e+01 n -1.0  
0000404 cntrlvar 7 le null 0 2.7000e+01 n -1.0  
0000405 cntrlvar 6 ge null 0 5.1000e+01 n -1.0  
0000406 cntrlvar 6 ge null 0 5.5000e+01 l -1.0  
\* ref. 55  
\*  
\* main turbine trips  
0000407 cntrlvar 115 ge null 0 1.0000e-01 l -1.0  
\*  
\* always true trip for tmdpjuns  
0000408 time 0 ge null 0 .0000e+00 l .0  
\*  
\* always false for msiv open trip  
0000409 time 0 ge null 0 1.0000e+06 l -1.0  
\*  
\* msiv fast closure trips (all valves)  
0000411 cntrlvar 500 le null 0 8.5770e+02 l -1.0  
\* ref. 351, 358  
\*  
\* msiv single valve fast closure  
0000415 cntrlvar 116 ge null 0 1.0000e-01 l -1.0  
\*  
\* msiv single valve fast closure for dual msiv trip  
0000416 cntrlvar 117 ge null 0 1.0000e-01 l -1.0  
\*  
\* 30% permissive  
0000417 mflowj 430000000 ge null 0 1.1151e+03 n .0  
\* ref. 349  
\*  
\* recirc pump trips (both)  
0000420 time 0 ge timeof 402 1.7500e-01 l -1.0  
0000421 cntrlvar 90 ge null 0 1.1327e+03 n -1.0  
0000422 time 0 ge timeof 421 1.3500e-01 l -1.0  
0000423 cntrlvar 114 ge null 0 1.0000e-01 l -1.0  
0000424 time 0 ge timeof 640 1.6500e-01 l -1.0  
\* time for trip 424 based on 0.03 sec to tsv close setpt and 0.135 sec delay  
\* for recirc pump trip  
\*  
\* recirc pump a trip (single)  
0000425 cntrlvar 113 ge null 0 1.0000e-01 l -1.0  
\*  
\* 28% recirc pump runbacks (both)

0000427 mflowj 605040000 lt null 0 7.4340e+02 n -1.0  
0000430 time 0 ge timeof 427 1.5000e+01 n -1.0  
\*  
\* RRP a 28% runback  
0000431 cntrlvar 118 ge null 0 1.0000e-01 n -1.0  
\*  
\* RRP b 28% runback  
0000432 cntrlvar 119 ge null 0 1.0000e-01 n -1.0  
\*  
\* RRP a seizure  
0000433 cntrlvar 120 ge null 0 1.0000e-01 l -1.0  
\*  
\* 75% recirc runback conditions  
0000434 mflowj 570020000 lt null 0 2.4780e+02 n -1.0  
0000435 mflowj 571020000 lt null 0 2.4780e+02 n -1.0  
0000436 mflowj 572020000 lt null 0 2.4780e+02 n -1.0  
\*  
\* feedwater single pump manual trips  
0000437 cntrlvar 104 le null 0 1.0000e-01 n -1.0  
0000438 cntrlvar 105 le null 0 1.0000e-01 n -1.0  
0000439 cntrlvar 106 le null 0 1.0000e-01 n -1.0  
\*  
\* manual hpci initiation  
0000440 cntrlvar 121 ge null 0 1.0000e-01 l -1.0  
\*  
\*manual RCIC initiation  
0000442 cntrlvar 122 ge null 0 1.0000e-01 l -1.0  
\*  
\* scram variable trips  
0000445 time 0 ge timeof 403 7.0000e-02 l -1.0  
0000446 cntrlvar 90 ge null 0 1.0577e+03 n -1.0  
0000447 time 0 ge timeof 605 4.5000e-01 l -1.0  
\* trip 447 assumes 4 sec msiv closure on trip, ref. 351 states 3 - 5 seconds  
0000448 cntrlvar 123 ge null 0 1.0000e-01 l -1.0  
0000449 time 0 ge timeof 640 8.0000e-02 l -1.0  
0000450 cntrlvar 14 ge null 0 1.1800e+02 l -1.0  
0000451 time 0 ge timeof 450 9.0000e-02 l -1.0  
0000452 time 0 ge timeof 446 7.0000e-02 l -1.0  
\* time delays on scram, except manual scram, include 0.05 sec time delay for  
\* scram solenoid deenergization per ref. 349  
\*  
\* srv setpoints  
0000455 p 400010000 ge null 0 1.1197e+03 n -1.0  
0000456 p 400010000 ge null 0 1.1297e+03 n -1.0

0000457 p 400010000 le null 0 1.0860e+03 n .0  
0000458 p 400010000 le null 0 1.0960e+03 n .0  
\*  
\* condensate pump trips  
0000460 cntrlvar 100 le null 0 1.0000e-01 n -1.0  
0000461 cntrlvar 101 le null 0 1.0000e-01 n -1.0  
\*  
\* condensate booster pump trips  
0000465 cntrlvar 102 le null 0 1.0000e-01 n -1.0  
0000466 cntrlvar 103 le null 0 1.0000e-01 n -1.0  
\*  
\* small loca  
0000468 cntrlvar 124 ge null 0 1.0000e-01 l -1.0  
\*  
\* single element, feedwater pump control trips  
0000470 cntrlvar 646 ge null 0 9.0000e-01 n -1.0  
\* use 1st line with Labview, next line without Labview  
\*0000471 cntrlvar 631 lt null 0 2.6762e+00 n -1.0 \* steam flow lt 20%  
0000471 cntrlvar 630 lt null 0 2.6762e+00 n -1.0 \* steam flow lt 20%  
\*  
\* trips to open minimum recirc valves in rfp trains  
0000475 mflowj 570020000 le null 0 1.6667e+02 n -1.0 \* ref. 55  
0000476 mflowj 571020000 le null 0 1.6667e+02 n -1.0 \* ref. 55  
0000477 mflowj 572020000 le null 0 1.6667e+02 n -1.0 \* ref. 55  
\*  
\* trips to close minimum recirc valves in rfp trains  
0000478 mflowj 570020000 ge null 0 3.4444e+02 n .0 \* ref. 55  
0000479 mflowj 571020000 ge null 0 3.4444e+02 n .0 \* ref. 55  
0000480 mflowj 572020000 ge null 0 3.4444e+02 n .0 \* ref. 55  
\*  
\* runback reset trip  
0000490 cntrlvar 125 ge null 0 .9000e+00 n -1.0 \* when true, resets  
\*  
\* additional pump trips  
0000501 time 0 le timeof 614 .0000e+00 n .0  
0000502 time 0 le timeof 612 .0000e+00 n .0  
0000506 time 0 le timeof 460 .0000e+00 n .0  
0000507 time 0 le timeof 461 .0000e+00 n .0  
0000508 time 0 le timeof 465 .0000e+00 n .0  
0000509 time 0 le timeof 466 .0000e+00 n .0  
\*  
\* feed pump speed trips  
0000510 pmpvel 570 lt null 0 500. n  
0000511 pmpvel 571 lt null 0 500. n

0000512 pmpvel 572 lt null 0 500. n  
\*  
\* scram pump selection criteria  
0000515 cntrlvar 7 le null 0 1.1000e+01 n -1.0 \* set scram response  
0000516 time 0 le timeof 649 6.0000e+01 n -1.0 \* set scram response  
0000517 cntrlvar 7 gt cntrlvar 108 0.8 n -1.0 \* reset scram response  
0000518 time 0 gt timeof 675 300. 1 -1.0 \* reset scram response  
\*  
0000520 cntrlvar 675 gt null 0 63. n -1.0 \*scram resp.  
\*  
\*-----  
\* logic trip cards  
\*-----  
\*  
\* main turbine trip  
0000601 407 or 406 1 -1.0  
\*  
\* msiv fast closure (all vlvs)  
0000605 401 or 411 1 -1.0  
\*  
\* recirc pumps trip (both)  
0000610 420 or 422 1 -1.0  
0000611 424 or 423 1 -1.0  
0000612 610 or 611 1 -1.0  
\*  
\* recirc pump a trip  
0000614 612 or 425 1 -1.0  
\*  
\* fw pump trips  
0000618 437 or 406 n -1.0  
0000619 438 or 406 n -1.0  
0000620 439 or 406 n -1.0  
\*  
\* 28% recirc pump runback, pump a  
0000621 431 or 430 n -1.0  
\*  
\* 28% recirc pump runback, pump b  
0000622 432 or 430 n -1.0  
\*  
\* 75% recirc pump runback  
0000623 435 or 434 n -1.0  
0000624 623 or 436 n -1.0  
0000625 624 and 404 n -1.0  
\*

\* hpci initiation

0000629 440 or 402 n -1.0

0000630 631 or 629 n -1.0

0000631 630 and -405 n -1.0

\*

\* inverse fwp trips for shell side ms tmdpjn's

632 -618 or -618 n -1.0 \*jam 7-27-96

633 -619 or -619 n -1.0 \*jam 7-27-96

634 -620 or -620 n -1.0 \*jam 7-27-96

\*

\* rcic initiation

0000635 402 or 442 n -1.0

0000636 637 or 635 n -1.0

0000637 636 and -405 n -1.0

\*

\* turbine stop valve closure and ge 30% flow

0000640 601 and 417 l -1.0

\*

\* reactor scram

0000645 445 or 447 l -1.0

0000646 448 or 449 l -1.0

0000647 451 or 452 l -1.0

0000648 645 or 646 l -1.0

0000649 647 or 648 l -1.0

\*

\* srv grp 1 lifted

0000655 656 or 455 n -1.0

0000656 655 and -457 n -1.0

\*

\* srv grp 2 lifted

0000660 661 or 456 n -1.0

0000661 660 and -458 n -1.0

\*

\* msiv single closure indication

0000665 415 or 605 l -1.0 \* single closure, ok

\*

\* msiv single closure for dual msiv trip w/ trip 665

0000666 416 or 605 l -1.0 \* single closure for dual trip, ok

\*

\* single element feed pump control

0000671 470 or 471 n -1.0

\*

\* feed pump scram response

0000675 515 and 516 l -1.0 \* starts scram response

0000676 517 or 518 n -1.0 \* resets response, allowing pump restoration  
0000677 675 and -676 n -1.0 \* initially sets max pump speeds, all pumps  
0000678 675 and 676 l -1.0 \* reset response in past  
0000679 677 and -678 n -1.0 \* imposes max pump speeds  
\*

\* pump b response to scram

0000681 675 and -512 l -1.0 \* initially drive b to 600 rpm  
\*

\* pump a response to scram

0000682 -512 or -511 n 0.0 \* true if pmp b or c >500 rpm  
0000684 682 and 675 l -1.0 \* initially drives pmp a to 600 rpm  
\*

\* additional runback trips to incorporate new reset button

\* 28% runback trips, pump a

0000685 621 or 686 n 0.0 \* used to init runback

0000686 685 and -490 n -1.0

\* 28% runback trips, pump b

0000687 622 or 688 n 0.0 \* used to init runback

0000688 687 and -490 n -1.0

\*\* 75 % runback trips

0000689 625 or 690 n 0.0 \* used to init runback

0000690 689 and -490 n -1.0

\*

0000691 510 or 684 n -1.0

0000692 511 or 681 n -1.0

\*

-----

\* control system general tables

-----

\*

\* recirc pmp speed controller function gen output (%) vs. spd controller outpt

----- ref. 349

20222000 reac-t

20222001 0. 0.

20222002 58.3 25.

20222003 84.2 50.

20222004 91.8367 69.64874

20222005 95.46 100.

20222006 97.04 160.

\*

\* recirc coupler torque first term vs. coupler slip, ref. 349

-----

20224200 reac-t

20224201 0. 0.

20224202 4.1667e-2 2.0e-4  
20224203 8.3333e-2 4.0046e-4  
20224204 1.25e-1 6.0234e-4  
20224205 2.0833e-1 1.0181e-3  
20224206 2.5e-1 1.2375e-3  
20224207 3.3333e-1 1.7185e-3  
20224208 0.5 3.0e-3  
20224209 0.75 6.6375e-3  
20224210 .97982 1.3551e-2  
\*

\* "normalized" recirc pump motor torque vs. % synchronous speed, ref. 349

-----  
20225400 reac-t

20225401 0. 0.8  
20225402 40. 0.9  
20225403 80. 1.6  
20225404 95.6 2.2  
20225405 98.0 1.0  
20225406 100. 0.  
20225407 102. -1.  
20225408 104.4 -2.2  
20225409 120. -1.6  
20225410 160. -0.9  
20225411 200. -0.8  
\*

\* recirc pump motor torque multiplier vs generator rpm

-----  
20225800 reac-t

20225801 0. 0.  
20225802 501.83 0.4015  
20225803 607.11 0.5554  
20225804 825. 1.0  
\*

\* normalized load torque vs. % main turbine speed, ref. 349

-----  
20230000 reac-t

20230001 1. -3.  
20230002 94. -2.  
20230003 96. -1.  
20230004 98. 0.  
20230005 100. 1.  
20230006 102. 2.  
20230007 199. 3.  
\*

\* turbine control vlv linearization (function generator), ref. 349 and 17

\*-----

20252000 reac-t

20252001 0.0 0.0

20252002 51. 20.

20252003 91. 40.

20252004 100. 52.2

20252005 102. 60.

20252006 111. 100.

\*

\* turbine control valve position multiplier vs. time since turbine trip

\*-----

20252700 reac-t

20252701 0.0 1.0

20252702 0.1 0.0

\*

\* turbine normalized steam flow vs tcv position in %, ref. 349

\*-----

20253500 reac-t

20253501 0.0 0.0

20253502 20. 0.51

20253503 40. 0.91

20253504 52.2 1.0

20253505 60. 1.02

20253506 100. 1.11

\*

\* single element controller gain based on # pumps and stm flow

\*-----

20261700 reac-t

20261701 100.0 0.36364

20261702 101.338 0.36364

20261703 104.04 0.83333

20261704 116.0 0.83333

20261705 200.0 0.5

20261706 204.014 0.5

20261707 206.69 0.66667

20261708 210.04 0.74074

20261709 216.0 0.74074

20261710 300.0 0.57143

20261711 306.69 0.57143

20261712 310.04 0.74074

20261713 313.38 0.86957

\*

\* three element level controller gain based on steam flow in Mlbm/hr

\*-----  
20261800 reac-t  
20261801 4.014 0.83333  
20261802 6.690 0.74074  
20261803 10.04 0.74074  
20261804 13.38 0.86957  
\*  
\* three element steam/feed flow controller gain based on # pumps  
\*-----  
20261900 reac-t  
20261901 100.0 0.16667  
20261902 216.0 0.16667  
20261903 300.0 0.20  
20261904 316.0 0.20  
\*  
\* lp delta enthalpy in turbine vs inlet pressure  
\*-----  
20266300 reac-t  
20266301 1.25 0.0  
20266302 40.0 154.0  
20266303 70.0 179.5  
20266304 100. 199.0  
20266305 130. 212.0  
20266306 160. 220.0  
20266307 180. 225.0  
20266308 200.0 228.0  
20266309 214.0 230.0  
20266310 917. 222.  
20266311 967. 264.5  
\*  
\*  
\*-----  
\* control variables  
\*-----  
\*20500000 999  
\*  
\* wide range level  
\*-----  
\*  
\* instantaneous wide range level  
20500100 instwr sum 1.000e+00 3.3058701e+01 0  
20500101 -528.00 380.638 voidf 140010000  
20500102 152.868 voidf 150010000 \* inst zero @ 528 inches per ref 195  
20500103 74.004 voidf 160010000

```
20500104      1.0  cntrlvar 866
*
*
20586600 addlevel  sum 2.678e+02  0.0 1 .000e+00
20586601 -0.05  1.0  voidf 190010000
*
* lagged yarway wide range level
* this level detector also used for yarway narrow range control functions
20500200 wrlevel  lag 1.000e+00 3.3052502e+01 0 3 -1.550e+02 6.000e+01
20500201 1.0  cntrlvar 001 * ref. 349
*
* narrow range level
*-----
*
* lagged narrow range level
20500600 nrlevel  lag 1.00    33.0      0 3 -10. 70.
20500601 0.5  cntrlvar 001 *lag time const. per ref. 349
*
* dummy return control variable for labview to return level signal in
* stand alone mode
20500700 levelret constant 3.3000000e+01
*
* aprm scram setpoint
*-----
*
* total reactor power (lagged) in %, sensed rx power
20501000 rxpwr   lag 3.037e-08 1.0059400e+02 0
20501001 0.03  rktpow  0 * 100% = 3293mw, ref. 349
*
* combined recirc pump mass flows (lb/sec)
20501100 rcrcflow  sum 2.205e+00 9.7047197e+03 0
20501101 0.0   1.0  mflowj 230010000 * ref. 349
20501102      1.0  mflowj 280010000
*
* sensed percentage recirc flow
20501200 perrecrc  lag 1.053e-02 1.0219100e+02 0
20501201 0.5  cntrlvar 011 * ref. 349
*
* flow bias in percent
20501300 flobias  sum 1.000e+00 0.0 3 .000e+00 5.800e+01
20501301 58.  -.58  cntrlvar 012 * aprm scram setpt per ref. 359, per
* bob stegl?
*
* aprm in percent including flow bias
```

```
20501400 aprmflo    sum 1.000e+00 1.0059400e+02 0
20501401 0.0    1.0    cntrlvar 010 * ref. 349, 359
20501402      1.0    cntrlvar 013
*
* reactor steam dome pressure (lagged)
*-----
20509000 rxpress    lag 1.450e-04 1.0233800e+03 0
20509001 0.5    p 190010000 * ref. 349
*
* dummy return control variable for labview to return pressure signal in
* stand alone mode
20509100 pressret constant 1.0233300e+03
*
*
* problem control inputs
*-----
* note: some of these will not activate trips within the trip section
* until the deck is altered for use with labview in the testing mode.
*
* condensate pump a control
20510000 condacnt constant 1.0000000e+00 * 1.0 equals "run", 0.0 equals "tripped"
*
* condensate pump b/c control
20510100 condcbcnt constant 1.0000000e+00 * 1.0 equals "run", 0.0 equals "tripped"
*
* condensate booster pump a control
20510200 cndbacnt constant 1.0000000e+00 * 1.0 equals "run", 0.0 equals "tripped"
*
* condensate booster pump b/c control
20510300 cndbbcnt constant 1.0000000e+00 * 1.0 equals "run", 0.0 equals "tripped"
*
* feedwater pump a control
20510400 rfpacont constant 1.0000000e+00 * 1.0 equals "run", 0.0 equals "tripped"
*
* feedwater pump b control
20510500 rfpbcont constant 1.0000000e+00 * 1.0 equals "run", 0.0 equals "tripped"
*
* feedwater pump c control
20510600 rfpcccont constant 1.0000000e+00 * 1.0 equals "run", 0.0 equals "tripped"
*
* manual speed setpoint, both recirc pumps
20510700 rrpmansp constant 9.7659264e+01
*
* level setpoint
```

20510800 lvlsetpt constant 3.300000e+01 \* ref. 348  
\*  
\* rod reactivity insertion rate (positive or negative)  
20510900 reactrat constant 0.  
\*  
\* single rrp trip  
20511300 sirrptrp constant 0. \* 0. equals ok, 1.0 equals trip  
\*  
\* dual rrp trip  
20511400 durrptrp constant 0. \* 0. equals ok, 1.0 equals trip  
\*  
\* main turbine trip  
20511500 mturbtrp constant 0. \* 0. equals ok, 1.0 equals trip  
\*  
\* single msiv trip  
20511600 msiv1trp constant 0. \* 0. equals ok, 1.0 equals trip  
\*  
\* single msiv trip  
20511700 msiv2trp constant 0. \* 0. equals ok, 1.0 equals trip  
\*  
\* rrp a runback trip  
20511800 rrpaptrp constant 0. \* 0. equals ok, 1.0 equals trip  
\*  
\* rrp b runback trip  
20511900 rrpbrtrp constant 0. \* 0. equals ok, 1.0 equals trip  
\*  
\* rrp seizure trip  
20512000 rrpseize constant 0. \* 0. equals ok, 1.0 equals trip  
\*  
\* hpci trip  
20512100 hpci\_trp constant 0. \* 0. equals ok, 1.0 equals trip  
\*  
\* rcic trip  
20512200 rcic\_trp constant 0. \* 0. equals ok, 1.0 equals trip  
\*  
\* scram trip  
20512300 scramtrp constant 0. \* 0. equals ok, 1.0 equals trip  
\*  
\* loca trip  
20512400 loca\_trp constant 0. \* 0. equals ok, 1.0 equals trip  
\*  
\* runback reset  
20512500 runbkrst constant 0. \* 0. equals no reset action  
\*

\*  
\* inverse scram response tripunit  
20520000 negscrtr tripunit 1.0 1. 0  
20520001 -679  
\*  
\* recirc pump speeds, all ref. 349 uno  
\*-----  
\*  
\* tripunit for large torque during pump a seizure  
20520200 seizurea tripunit 1.500e+05 0. 0 \* s is adjustable  
20520201 433  
\*  
\*  
\* recirc pumps speed demand limiters  
\*  
\* 28% runback trip unit, pump a  
20520800 trip28a tripunit 1.000e+00 0. 0  
20520801 685  
\*  
\* 28% runback trip unit, pump b  
20520900 trip28b tripunit 1.000e+00 0. 0  
20520901 687  
\*  
\* 28% limiter, pump a  
20521000 lim28a sum 1.000e+00 1.2800000e+02 0  
20521001 128.0 -100. cntrlvar 208 \*=128 for no runback, 28 @ runback  
\*  
\* 28% limiter, pump b  
20521100 lim28b sum 1.000e+00 1.2800000e+02 0  
20521101 128.0 -100. cntrlvar 209 \*=128 for no runback, 28 @ runback  
\*  
\* 75% runback trip unit  
20521200 trip75 tripunit 1.000e+00 0. 0  
20521201 689  
\*  
\* 75% limiter, both pumps  
20521300 lim75 sum 1.000e+00 1.7500000e+02 0  
20521301 175. -100. cntrlvar 212 \* 175 for no runback, 75 @ runback  
\*  
\* recirc pump a demand limiter (in %)  
20521400 admdlim stdfnctn 1.000e+00 9.7659302e+01 0  
20521401 min cntrlvar 213  
20521402 cntrlvar 210  
20521403 cntrlvar 107

\*

\* recirc pump b demand limiter (in %)

20521500 bdmdlim stdfnctn 1.000e+00 9.7659302e+01 0

20521501 min cntrlvar 213

20521502 cntrlvar 211

20521503 cntrlvar 107

\*

\* recirc pumps speed controllers

\*

\* recirc pump a speed error

20521600 rrpaspde sum 1.000e+00 3.6342631e-04 0 3 -1.000e+01 1.000e+01

20521601 0.0 1.0 cntrlvar 214

20521602 -.0906924 cntrlvar 252

\*

\* recirc pump b speed error

20521700 rrpbspde sum 1.000e+00 3.6342631e-04 0 3 -1.000e+01 1.000e+01

20521701 0.0 1.0 cntrlvar 215

20521702 -.0906924 cntrlvar 253

\*

\* recirc pump a speed controller integral term

20521800 rpascint integral 2.712e-02 8.9533699e+01 0 3 0.0 100.0

20521801 cntrlvar 216

\*

\* recirc pump b speed controller integral term

20521900 rpbscint integral 2.712e-02 8.9533699e+01 0 3 0.0 100.0

20521901 cntrlvar 217

\*

\* recirc pump a speed controller

20522000 rpascont sum 1.000e+00 8.9533798e+01 0 3 0.0 100.0

20522001 0.0 0.3 cntrlvar 216 \* jam

20522002 1.0 cntrlvar 218

\*

\* recirc pump b speed controller

20522100 rpbscont sum 1.000e+00 8.9533798e+01 0 3 0.0 100.0

20522101 0.0 0.3 cntrlvar 217 \* jam

20522102 1.0 cntrlvar 219

\*

\*

\* recirc pump a generator speed in rpm

\* s=conversion from 0-100% controller output to 0-1800 rpm generator speed

20525200 rpagensp lag 18.0 1.0768101e+03 0

20525201 1.0 cntrlvar 220 \* 1.0 sec lag assumed prb/jam

\*

\* recirc pump b generator speed in rpm

\* s=conversion from 0-100% controller output to 0-1800 rpm generator speed  
20525300 rpbgensp lag 18.0 1.0768101e+03 0  
20525301 1.0 cntrlvar 221 \* 1.0 sec lag assumed prb/jam  
\*  
\* recirc pump motor torques  
\*  
\* recirc pump a percent of synchronous speed  
\*  $s = (\text{gen synch speed @ no load}) / (\text{mtr synch speed at no load}) * 100 * (60/2\pi)$   
\* generator no load speed is 1200 rpm, mtr no load synch speed is 1800 rpm,  
\* 100 converts to percent and  $(60/2\pi)$  converts pmpvel from rad/s to rpm.  
20525400 rpasynch div 6.366e+02 9.7945000e+01 0  
20525401 cntrlvar 252 pmpvel 230  
\*  
\* recirc pump b percent of synchronous speed  
\*  $s = (\text{gen synch speed @ no load}) / (\text{mtr synch speed at no load}) * 100 * (60/2\pi)$   
\* generator no load speed is 1200 rpm, mtr no load synch speed is 1800 rpm,  
\* 100 converts to percent and  $(60/2\pi)$  converts pmpvel from rad/s to rpm.  
20525500 rpbsynch div 6.366e+02 9.7945000e+01 0  
20525501 cntrlvar 253 pmpvel 280  
\*  
\* recirc pump a motor torque in lbf\*ft at 100% speed  
\*  $s = 0.5$  (value from ref. 349) since single pump instead of double pump  
20525600 rpamtrtq function 2.245e+04 2.3067900e+04 0  
20525601 cntrlvar 254 254  
\*  
\* recirc pump b motor torque in lbf\*ft at 100% speed  
\*  $s = 0.5$  (value from ref. 349) since single pump instead of double pump  
20525700 rpbmtrtq function 2.245e+04 2.3067900e+04 0  
20525701 cntrlvar 255 254  
\*  
\* recirc pump a motor torque multiplier for speed  
20525800 ratrqlmul function 1.000e+00 1.0000000e+00 0  
20525801 cntrlvar 252 258  
\*  
\* recirc pump b motor torque multiplier for speed  
20525900 rbtrqlmul function 1.000e+00 1.0000000e+00 0  
20525901 cntrlvar 253 258  
\*  
\* recirc pump a motor torque  
20526000 rpamtrtq mult 1.000e+00 2.3067900e+04 0  
20526001 cntrlvar 256 cntrlvar 258  
\*  
\* recirc pump b motor torque  
20526100 rpbmtrtq mult 1.000e+00 2.3067900e+04 0

20526101 cntrlvar 257 cntrlvar 259  
\*  
\*  
\* recirc pump speeds (with no trip)  
\*  
\* recirc pump a torque difference in lbf\*ft  
20526200 rpadlttq sum 1.000e+00 -4.8878230e-03 0  
20526201 0.0 1.0 cntrlvar 260  
20526202 0.7376 pmptrq 230 \* conversion factor is n\*m to lbf\*ft  
20526203 -1.0 cntrlvar 202 \* applies large stopping torque for  
\* seizure of pump a  
\*  
\* recirc pump b torque difference in lbf\*ft  
20526300 rpbdllttq sum 1.000e+00 -4.8878230e-03 0  
20526301 0.0 1.0 cntrlvar 261  
20526302 0.7376 pmptrq 280 \* conversion factor is n\*m to lbf\*ft  
\*  
\* recirc pump a speed with no pump trip  
\*  $s = \{(60/2\pi)(32.174)[(19,175 \text{ lb*ft}^{**2})^{**(-1)}]\}$ , pump and motor i is assumed  
\* to be 17,044 lb\*ft\*\*2 based on 1/2 of ref. 349 value, which lists 2 values  
20526400 rpaspeed integral 1.602e-02 1.5820800e+03 0  
20526401 cntrlvar 262  
\*  
\* recirc pump b speed with no pump trip  
\*  $s = \{(60/2\pi)(32.174)[(17,044 \text{ lb*ft}^{**2})^{**(-1)}]\}$ , pump and motor i is assumed  
\* to be 17,044 lb\*ft\*\*2 based on 1/2 of ref. 349 value, which lists 2 values  
20526500 rpbspeed integral 1.602e-02 1.5820800e+03 0  
20526501 cntrlvar 263  
\*  
\*  
\* rod reactivity, cumulative  
\*-----  
\*  
20530000 rodrctdm integral 5.000e-02 0.0 3 -2.300e+01 3.000e+00  
20530001 cntrlvar 109  
\*  
\* normalized scram curve  
\* s is the inverse of 28.9308, the scram shutdown reactivity margin  
20530100 normsfrm function 3.457e-02 0.0  
20530101 time 0 200  
\*  
\* scram multiplier  
\* this term will remove the rod reactivity added by cntrlvar 300 at the same  
\* rate as scram reactivity is inserted.

```
20530200 scrmmult    sum 1.000e+00 1.0000000e+00 0
20530201 1.0      1.0      cntrlvar 301
*
* rod reactivity, including provision to disable following a scram
20530300 rodreact   mult 1.000e+00 0.0
20530301 cntrlvar 302      cntrlvar 300
*
*
* feedwater heater level controls
*-----
*
* cntrlvar 305: RFW HTRA1 collapsed liquid level (inches above lower tap)
20530500 'HTRA1LVL'  sum 12. 16.0  1
20530501 -2.6641    1.3307 voidf 722010000
20530502      2.6667 voidf 721030000
20530503      2.6667 voidf 721020000
*20530504      10.4596 voidf 721010000
*20530505      13.7904 voidf 720010000
*
* heater A1 level out to LabVIEW
20530600 a1lvlout   lag 1.00    16.0     0 3 0. 32. *prb
20530601 0.05      cntrlvar 305 *lag time const.
*
* instant drain vlv position in %, A1
20532300 a1drinst   constant    32.0
*
* drain vlv position, heater a1, normalized to 1.0
20532400 a1drnpos   lag 0.01    0.32     0
20532401 0.05      cntrlvar 323
*
* cntrlvar 0330: RFW HTRA2 collapsed liquid level (inches above lower tap)
20533000 'HTRA2LVL'  sum 12. 18.0  1
20533001 -6.9974    5.4974 voidf 733010000
20533002      3.0000 voidf 732020000
20533003      3.0000 voidf 732010000
*20533004      8.8763 voidf 731010000
*20533005      10.2904 voidf 730010000
*
* heater A2 level out to LabVIEW
20533100 a2lvlout   lag 1.00    18.0     0 3 0. 36. *prb
20533101 0.05      cntrlvar 330 *lag time const.
*
* instant drain vlv position in %, A2
20534800 a2drinst   constant    44.0
```

\*

\* drain vlv position, heater a2  
20534900 a2drnpos lag 0.01 0.44 0  
20534901 0.05 cntrlvar 348

\*

\* instant A2 bypass vlv position, in %  
20535400 a2byinst constant 0.0 \*prb 01-18-96 10:09am

\*

\* bypass vlv position, heater a2, normalized to 1.0  
20535500 a2byppos lag 0.01 0.0 0 \*prb 01-18-96 10:10am  
20535501 0.05 cntrlvar 354

\*

\* cntrlvar 0360: RFW HTA3 collapsed liquid level (inches above lower tap)  
20536000 'HTA3LVL' sum 12. 18.0 1  
20536001 -15.6068 7.0534 voidf 742040000  
20536002 7.0534 voidf 742030000  
20536003 3.0000 voidf 742020000  
20536004 3.0000 voidf 742010000  
\*20536005 11.1133 voidf 741010000  
\*20536006 12.4284 voidf 740010000

\*

\* heater A3 level out to LabVIEW  
20536100 a3lvlout lag 1.00 18.0 0 3 0. 36. \*prb  
20536101 0.05 cntrlvar 360 \*lag time const.

\*

\* instant drain vlv position, A3 in %  
20537800 a3drinst constant 34.0

\*

\* drain vlv position, heater a3  
20537900 a3drnpos lag 0.01 0.34 0  
20537901 0.05 cntrlvar 378

\*

\* cntrlvar 0380: RFW HTA4 collapsed liquid level (inches above shell bottom)  
20538000 'HTA4LVL' sum 12. 16.9375 1  
20538001 0.0 0.1667 voidf 751010000 \* upper tap 2" above centerline  
20538002 2.9375 voidf 752010000 \* shell radius

\*

\* heater A4 level out to LabVIEW  
20538100 a4lvlout lag 1.00 16.9375 0 3 0. 37.25 \*prb  
20538101 0.05 cntrlvar 380 \*lag time const.

\*

\* instant drain vlv position, A4 in %  
20539800 a4drinst constant 40.0

\*

\* drain vlv position, heater a4  
20539900 a4drnpos lag 0.01 0.40 0  
20539901 0.05 cntrlvar 398  
\*  
\* instant bypass vlv position, A4 in %  
20540400 a4byinst constant 0.0 \*prb 01-24-96 10:34am  
\*  
\* bypass vlv position, heater a4, normalized to 1.0  
20540500 a4byppos lag 0.01 0.0 0 \*prb 01-24-96 10:35am  
20540501 0.05 cntrlvar 404  
\*  
\* cntrlvar 0410: RFW HTRA5 collapsed liquid level (inches above shell bottom)  
20541000 'HTRA5LVL' sum 12. 15.0 0  
20541001 -5.2188 2.500 voidf 760030000 \* level taps are at top  
20541002 5.2188 voidf 760040000 \* & bottom of collector tank  
\*  
\* heater A5 level out to LabVIEW  
20541100 a5lvlout lag 1.00 15.0 0 3 0. 30. \*prb  
20541101 0.05 cntrlvar 410 \*lag time const.  
\*  
\* instant drain vlv position, A5 in %  
20542800 a5drinst constant 40.0  
\*  
\* drain vlv position, heater a5, normalized to 1.0  
20542900 a5drnpos lag 0.01 0.40 0  
20542901 0.05 cntrlvar 428  
\*  
\* instant bypass vlv position, A5 in %  
20543400 a5byinst constant 0.0 \*prb 01-25-96 09:08pm  
\*  
\* bypass vlv position, heater a5, normalized to 1.0  
20543500 a4byppos lag 0.01 0.0 0 \*prb 01-25-96 09:09pm  
20543501 0.05 cntrlvar 434  
\*  
\* cntrlvar 440: RFW HTRB1 collapsed liquid level (inches above lower tap)  
20544000 'HTRB1LVL' sum 12. 16.0 1  
20544001 -2.6641 1.3307 voidf 822010000  
20544002 2.6667 voidf 821030000  
20544003 2.6667 voidf 821020000  
\*20544004 10.4596 voidf 821010000  
\*20544005 13.7904 voidf 820010000  
\*  
\* heater b1 level out to LabVIEW  
20544100 b1lvlout lag 1.00 33.0 0 3 0. 44.

20544101 0.05 cntrlvar 440 \*lag time const.  
\*  
\* auto vlv position demand, b1 drain vlv  
20544900 b1draut constant 32.0  
\*  
\* drain vlv position, heater b1, normalized to 1.0  
20545000 b1drnpos lag 0.01 0.32 0  
20545001 0.05 cntrlvar 449  
\*  
\* cntrlvar 0451: RFW HTRB2 collapsed liquid level (inches above lower tap)  
20545100 'HTRB2LVL' sum 12. 18.0 1  
20545101 -6.9974 5.4974 voidf 833010000  
20545102 3.0000 voidf 832020000  
20545103 3.0000 voidf 832010000  
\*205045104 8.8763 voidf 831010000  
\*205045105 10.2904 voidf 830010000  
\*  
\* heater b2 level out to LabVIEW  
\*205045200 b2lvlout lag 1.00 33.0 0 3 0. 36. \*prb  
20545200 b2lvlout lag 1.00 18.0 0 3 0. 36. \*prb  
20545201 0.05 cntrlvar 451 \*lag time const.  
\*  
\* auto vlv position demand, b2 drain vlv  
20545700 b2draut constant 44.0  
\*  
\* drain vlv position, heater b2, normalized to 1.0  
20545800 b2drnpos lag 0.01 0.44 0  
20545801 0.05 cntrlvar 457  
\*  
\* auto vlv position demand, b2 bypass vlv  
20545900 b2byaut constant 0.0  
\*  
\* bypass vlv position, heater b2, normalized to 1.0  
20546000 b2byppos lag 0.01 0.0 0 \*prb 01-23-96 01:10pm  
20546001 0.05 cntrlvar 459  
\*  
\* cntrlvar 0465: RFW HTRB3 collapsed liquid level (inches above lower tap)  
20546500 'HTRB3LVL' sum 12. 18.0 0  
20546501 -15.6068 7.0534 voidf 842040000  
20546502 7.0534 voidf 842030000  
20546503 3.0000 voidf 842020000  
20546504 3.0000 voidf 842010000  
\*20504655 11.1133 voidf 841010000  
\*20504656 12.4284 voidf 840010000

\*  
\* heater b3 level out to LabVIEW  
20546600 b3lvlout lag 1.00 18.0 0 3 0. 36.  
20546601 0.05 cntrlvar 465 \*lag time const.  
\*  
\* auto vlv position demand, b3 drain vlv, in %  
20547100 b3draut constant 34.  
\*  
\* drain vlv position, heater b3  
20547200 b3drnpos lag 0.01 0.34 0  
20547201 0.05 cntrlvar 471  
\*  
\* cntrlvar 0475: RFW HTRB4 collapsed liquid level (inches above shell bottom)  
20547500 'HTRB4LVL' sum 12. 16.9375 0  
20547501 0.0 0.1667 voidf 851010000 \* upper tap 2" above centerline  
20547502 2.9375 voidf 852010000 \* shell radius  
\*  
\* heater b4 level out to LabVIEW  
20547600 b4lvlout lag 1.00 16.9375 0 3 0. 37.25 \*prb  
20547601 0.05 cntrlvar 475 \*lag time const.  
\*  
\* auto vlv position demand, b4 drain vlv, in %  
20548100 b4draut constant 40.  
\*  
\* drain vlv position, heater b4, normalized to 1.0  
20548200 b4drnpos lag 0.01 0.40 0  
20548201 0.05 cntrlvar 481  
\*  
\* auto vlv position demand, b4 bypass vlv, in %  
20548300 b4byaut constant 0.0  
\*  
\* bypass vlv position, heater b4, normalized to 1.0  
20548400 b4byppos lag 0.01 0.5 0  
20548401 0.05 cntrlvar 483  
\*  
\* cntrlvar 0486: RFW HTRB5 collapsed liquid level (inches above shell bottom)  
20548600 'HTRB5LVL' sum 12. 15.0 0  
20548601 -5.2188 2.500 voidf 860030000 \* level taps are at top  
20548602 5.2188 voidf 860040000 \* & bottom of collector tank  
\*  
\* heater b5 level out to LabVIEW  
20548700 b5lvlout lag 1.00 15.0 0 3 0. 30. \*prb  
20548701 0.05 cntrlvar 486 \*lag time const.  
\*

\* auto vlv position demand, b5 drain vlv, in %  
20549200 b5draut constant 40.  
\*  
\* drain vlv position, heater b5, normalized to 1.0  
20549300 b5drnpos lag 0.01 0.40 0  
20549301 0.05 cntrlvar 492  
\*  
\* auto vlv position demand, b5 bypass vlv, in %  
20549400 b5byaut constant 0.0  
\*  
\* bypass vlv position, heater b5, normalized to 1.0  
20549500 b5byppos lag 0.01 0.0 0 \*prb 01-25-96 09:13pm  
20549501 0.05 cntrlvar 494  
\*  
\*  
\* turbine control valve flow  
\*-----  
\*  
\* pressure control unit (other units not modelled since pressure control is  
\* sufficient for transients of interest)  
\*  
\* steam line pressure (psia)  
20550000 slpress lag 1.450e-04 9.7806598e+02 0  
20550001 0.5 p 420030000 \* ref. 349 for time constant, ref. 13  
\*  
\* pressure error signal (psid)  
20550100 presserr sum 1.000e+00 3.0066700e+01 0  
20550101 -947.99951 1.0 cntrlvar 500 \* pressure setpoint from ref. 349  
\* also ref. 361, 13, 14  
\*  
\* lead-lag press error signal  
20550200 ldlgpres lead-lag 3.333e+00 1.0019800e+02 0  
20550201 2.0 5.0 cntrlvar 501 \* ref. 14, 349, 361  
\*  
\* inverse turbine trip, load limiter & max combined flow limiter  
\* assumed that load limiter is set to 110. & max combined flow = 125.  
20550400 invtrip tripunit 1.100e+02 1.1000000e+02 0  
20550401 -601 \* ref. 15, 349, 361  
\*  
\* pressure control unit signal (lvg output)  
20550600 pcusignl stdfnctn 1.000e+00 1.0019800e+02 0  
20550601 min cntrlvar 502  
20550602 cntrlvar 504 \* ref. 15, 349, 361  
\*

\* turbine control valves (tcv) relay  
20550800 tcvrelay lag 1.000e+00 1.0019800e+02 0  
20550801 0.02 cntrlvar 506 \* ref. 349  
\*  
\* tcv delay function  
20551000 tcvdelay delay 1.000e+00 1.0019800e+02 0  
20551001 cntrlvar 508 0.1 2 \* ref. 349  
\*  
\* turbine control valve linearization (dfg board output)  
20551200 tcvliner function 1.000e+00 5.2970501e+01 0  
20551201 cntrlvar 510 520 \* ref. 17, 349  
\* normalized shape of the curve from ref. 349 is the same as the dfg board  
\* output voltage vs. input voltage signal shown on ref. 17; values from ref.  
\* 349 are used in the table.  
\*  
\* lagged tcv servo position demand in % open  
20551400 tcvsrvpd lag 1.000e+00 5.2970299e+01 0 3 .000e+00 1.000e+02  
20551401 0.1 cntrlvar 512 \* ref. 16, 349  
\*  
\* max tcv positive position change in % open in this time step  
20551600 tcvcghmx mult 1.000e+01 5.0000000e-01 0  
20551601 dt 0 \* ref. 349  
\*  
\* tcv position max value in this time step  
20551800 tcnposmx sum 1.000e+00 5.3470299e+01 0  
20551801 0.0 1.0 cntrlvar 516  
20551802 1.0 cntrlvar 524 \* ref. 349  
\*  
\* minimum of tcv position demand & max posit  
20552000 tcvmn1 stdfnctn 1.000e+00 5.2970299e+01 0  
20552001 min cntrlvar 514  
20552002 cntrlvar 518  
\*  
\* tcv position minimum value in % open in this time step  
20552200 tcnposmn sum 1.000e+00 5.2260300e+01 0  
20552201 0.0 -1.42 cntrlvar 516 \* max closure rate is 14.2% per second  
20552202 1.0 cntrlvar 524 \* ref. 349  
\*  
\* tcv current position with no turbine trip  
20552400 postcvnt stdfnctn 1.000e+00 5.2970299e+01 0 3 .000e+00 1.000e+02  
20552401 max cntrlvar 520  
20552402 cntrlvar 522  
\*  
\* turbine trip

20552500 turbtrip tripunit 1.000e+00 0.0  
20552501 601  
\*  
\* time since turbine trip  
20552600 turbtrpt integral 1.000e+00 0.0  
20552601 cntrlvar 525  
\*  
\* tcv position multiplier with turbine trip  
20552700 trbtmult function 1.000e+00 1.0000000e+00 0  
20552701 cntrlvar 526 527 \* tcv closure on trip in 0.1 sec, ref. 349  
\*  
\* tcv position in current time step  
20552800 tcnposit mult 1.000e+00 5.2970299e+01 0  
20552801 cntrlvar 524 cntrlvar 527  
\*  
\* steam flow in lb/sec for 978.00 psia (100% turbine inlet pressure)  
20553200 untbflow function 3.717e+03 3.7243401e+03 0 \* s= 100% flow in lb/s  
20553201 cntrlvar 528 535 \* ref. 349 for table  
\*  
\* steam flow through tcv in lb/sec  
\* multiplicative constant s= 1.45038e-4 \* 1/978psia, or conversion factor for  
\* pa to psia divided by 978 psia. this gives tcv steam flow at any pressure.  
20553600 tcflow mult 1.483e-07 3.7255500e+03 0  
20553601 cntrlvar 532 \* ref. 349  
20553602 p 420030000  
\*  
\* convert tcv mass flow to velocity  
\*  
20553700 tcvrhoa mult 6.720e-01 2.4019800e+01 0  
20553701 rho 420030000 avol 420030000  
\*  
20553800 tcvel div 1.000e+00 1.5510300e+02 0  
20553801 cntrlvar 537 cntrlvar 536  
\*  
\*  
\* turbine bypass valve steam flow in lb/sec  
\*-----  
\*  
\* pressure regulator and low value gate signal difference in %  
20554000 ploaddif sum 1.000e+00 -2.5000000e+00 0  
20554001 -2.5 1.0 cntrlvar 502 \* ref. 15, 349, 361  
20554002 -1.0 cntrlvar 506 \* -2.5 is small closing bias  
\*  
\* combined maximum flow limiter in %

```
20554200 maxfolum sum 1.000e+00 2.4802401e+01 0
20554201 125. -1.0 cntrlvar 506 * ref. 16, 349, 361
*
* bypass valve control signal, lvg output
20554400 bpvsig stdfnctn 1.000e+00 0.0 3 .000e+00 2.620e+01
20554401 min cntrlvar 540 * ref. 16, 349, 361
20554402 cntrlvar 542
*
* delayed bypass valve control signal
20554600 bpvsgdel delay 1.000e+00 0.0
20554601 cntrlvar 544 0.1 5 * ref. 349
*
* bpv position error signal
20554700 bpverror sum 2.000e+01 0.0 3 -1.050e+02 1.050e+02
20554701 0.0 1.0 cntrlvar 546 * ref. 16, 349, 361
20554702 -1.0 cntrlvar 548
*
* bpv servo position
20554800 bpvposit integral 1.000e+00 0.0 3 .000e+00 2.620e+01
20554801 cntrlvar 547
*
* bpv steam flow in lb/sec
* multiplicative factor is equal to conversion factor from pa to psia times
* (1/978 psia) times 0.01 to convert from percentage flow at 978 psia. s =
* (1.45038e-4)*(1/978)* 0.01.
20555000 tbpvmflo mult 5.512e-06 0.0
20555001 p 420030000 * ref. 349
20555002 cntrlvar 548
*
* convert tbpv mdot to velocity
*
20555200 tbpvvel div 1.000e+00 0.0
20555201 cntrlvar 537 cntrlvar 550
*
*
* feedwater flow controller
*-----
*
* feedpumps above min speed (in auto)
*
* rfp a above min speed tripunit
20558000 rfpauto tripunit 1.0 1.0 0
20558001 -691
*
```

\* rfp b above min speed tripunit  
20558100 rfpbauto tripunit 1.0 1.0 0  
20558101 -692  
\*  
\* rfp c above min speed tripunit  
20558200 rfpcauto tripunit 1.0 1.0 0  
20558201 -512  
\*  
\* terms used in Woodward governors  
\*  
\* error multiplier term 1  
20558300 err1mult sum 1.0 0.1125 1  
20558301 0.1 1.0 dt 0  
20558301 0.07 1.0 dt 0  
\*  
\* error multiplier term  
20558400 err\_mult div 1.0 0.1 1  
20558401 cntrlvar 583 dt 0  
\*  
\* sum mult term  
20558500 sum\_mult div 0.07 0.9 1  
20558501 cntrlvar 583  
\*  
\* woodward governor a error term  
\* (in percent or error/100)  
20558600 woodaerr sum 0.02 0.0 0  
20558601 0.0 1.0 cntrlvar 689  
20558602 -9.549 pmpvel 570  
\*  
\* woodward governor b error term  
20558700 woodberr sum 0.02 0.0 0  
20558701 0.0 1.0 cntrlvar 686  
20558702 -9.549 pmpvel 571  
\*  
\* woodward governor c error term  
20558800 woodcerr sum 0.02 0.0 0  
20558801 0.0 1.0 cntrlvar 683  
20558802 -9.549 pmpvel 572  
\*  
\* fsubn a  
20559500 fsubn\_a lag 1.0 0.0 0  
20559501 0.1 cntrlvar 586  
\*  
\* fsubn b

```
20559600 fsubn_b    lag 1.0    0.0      0
20559601 0.1  cntrlvar 587
*
* fsubn c
20559700 fsubn_c    lag 1.0    0.0      0
20559701 0.1  cntrlvar 588
*
*
* level signal, level error
*
* level error in inches
20560200 lvlerror   sum 1.000e+00 -5.6445029e-02 0
20560201 0.0    1.0  cntrlvar 108
20560202     -1.0  cntrlvar 007  * use with labview
*20560202     -1.0  cntrlvar 006  * use without labview
*
* bypass valve control
*
* bypass vlv control multiplier
20560400 byponoff constant 0. * equal 1.0 in bypass vlv auto control
*
* bypass proportional error
20560600 bypprope   mult 1.000e+00 0.0
20560601 cntrlvar 602    cntrlvar 604 * s = tuning parameter
*
* bypass integral term
20560800 bypinter integral 1.667e-02 0.0 3 0. 100. * s=tuning parameter in 1/sec
20560801 cntrlvar 606
*
* bypass valve controller lc-3-53 output
20560900 lc-3-53   sum 1.000e-02 0.0 * s converts 100% demand to 1.0 position dmd
20560901 0.0    1.0  cntrlvar 606
20560902     1.0  cntrlvar 608 * ref. 104, 363
*
* bypass valve controller lc-3-53 switch
20561000 lc353swh  mult 1.0    0.0      0
20561001 cntrlvar 604    cntrlvar 609 * used to simulate manual closing when not in
use
*
* bypass valve position (normalized)
20561100 bypposit   lag 1.000e+00 0.0 3 .000e+00 1.000e+00
20561101 2.0  cntrlvar 610 * time constant is a guess
*
* variable feedwater pump controller gains
```

\*

\* tripunit for feedpump a  
20561300 rfpatrip tripunit 1. 1. 0  
20561301 -618

\*

\* tripunit for feedpump b  
20561400 rfpbtrip tripunit 1. 1. 0  
20561401 -619

\*

\* tripunit for feedpump c  
20561500 rfpctrip tripunit 1. 1. 0  
20561501 -620

\*

\* dependent variable for single element gain  
20561600 e1vargnx sum 1. 313.405 0  
20561601 0.0 100. cntrlvar 580  
20561602 100. cntrlvar 581  
20561603 100. cntrlvar 582  
20561604 1. cntrlvar 631 \* use with Labview  
\*20561604 1. cntrlvar 630 \* use without Labview

\*

\* single element gain  
20561700 e1vargny function 1. 0.86957 0 \* tuning parameter  
20561701 cntrlvar 616 617

\*

\* three element gain, level controller  
20561800 e3vargny function 1. 0.86957 0 \* tuning parameter  
20561801 cntrlvar 631 618 \* use with Labview  
\*20561801 cntrlvar 630 618 \* use without Labview

\*

\* three element gain, sf/fw mismatch controller  
20561900 e3misgan function 1. 0.86957 0 \* tuning parameter  
20561901 cntrlvar 616 619

\*

\* feedwater flow signal

\*

\* lagged feedwater mass flow in Mlbm/hr  
\* s= conversion factor from kg/sec to Mlb/hr; flow is sum of lagged flows  
\* through feedwater lines a and b. lag time constant is from ref. 349.  
20562200 lmflowfw lag 7.938e-03 1.3405000e+01 0  
20562201 0.5 mflowj 605040000

\*

\* return feedwater mass flow from LabVIEW  
20562300 labfwflo constant 1.3405000e+01

\*  
\* steam flow signal  
\*  
\* steam mass flow for use without LabVIEW  
20563000 stmflow sum 1.000e+00 1.3400000e+01 0  
20563001 0.0 1.0 cntrlvar 900  
20563002 1.0 cntrlvar 901  
20563003 1.0 cntrlvar 902  
\*  
\* return steam mass flow from LabVIEW  
20563100 labstflo constant 1.34050000e+01  
\*  
\*  
\* single or three element control selection  
\*  
\* bypass valve not being controlled multiplier  
\* = 1 when bypass valve is not used to control level, 0 when in use.  
20563400 bypasnot sum 1.000e+00 1.0000000e+00 0  
20563401 1.0 -1.0 cntrlvar 604  
\*  
\* operator selected single element feed pump control  
\* = 1 when selected, 0 otherwise  
20564600 e1selctd constant 0.  
\*  
\* single element feed pump control multiplier  
\* = 1 when operator selected or tripped, 0 otherwise  
20564800 sngelmlt tripunit 1.000e+00 0.0  
20564801 671  
\*  
\* operator selected three element feed pump control  
\* = 1 when operator selected, 0 otherwise  
20565000 elem3sel constant 1.0000000e+00  
\*  
\* single element inverse tripunit  
\* = 1 when single element feed pump control is not selected or tripped  
20565200 notsingle tripunit 1.000e+00 1.0000000e+00 0  
20565201 -671  
\*  
\* three element level controller  
\*  
\* level pi zeroing error for 1e operation  
20563200 e3lvlzer mult -1.0 0.0 0  
20563201 cntrlvar 655 cntrlvar 648  
\*

\* level error term for three element control  
20565300 e3lvlerr mult 1.0 0.0 0  
20565301 cntrlvar 602 cntrlvar 652  
20565302 cntrlvar 634  
\*  
\* proportional error term for three element control  
20565400 e3proper mult 1.0 0.0 0  
20565401 cntrlvar 653 cntrlvar 618  
\*  
\* three element level error signal (1e or 3e)  
20565500 e3lvler1 sum 1.0 0.0 0  
20565501 0.0 1.0 cntrlvar 632  
20565502 1.0 cntrlvar 653  
\*  
\* three element level integrand  
20565600 e3integd integral 9.5238e-03 0.0 0 3 0. 16.  
20565601 cntrlvar 655  
\*  
\* steam flow in 3e, 0 otherwise  
20565700 e3stmflo mult 1.0 13.407 0  
20565701 cntrlvar 631 cntrlvar 650 cntrlvar 652 \* use with Labview  
\*20565701 cntrlvar 630 cntrlvar 650 cntrlvar 652 \* use without Labview  
\*  
\* feed flow in 1e, 0 otherwise  
20565800 e1fdflo mult 1.0 0. 0  
20565801 cntrlvar 648 cntrlvar 623 \* use with labview  
\*20565801 cntrlvar 648 cntrlvar 622 \* use without labview  
\*  
\* three element controller when in 3e or tracking in 1e  
20565900 e3-e3cnt sum 1.0 13.407 0 3 0. 16.  
20565901 0.0 1.0 cntrlvar 654  
20565902 1.0 cntrlvar 656  
20565903 1.0 cntrlvar 657  
20565904 1.0 cntrlvar 658  
\*  
\*  
\* steam flow feedwater flow mismatch  
\*  
\* level controller + steam flow minus feed flow  
20566000 fwstmdel sum 1.000e+00 0.000 0 \* equals 0 when not in 3e  
20566001 0.0 1.0 cntrlvar 659 \* level pi + stm flow, ff in 1e  
20566002 -1.0 cntrlvar 623 \* feedflow (with Labview)  
\*20566002 -1.0 cntrlvar 622 \* feedflow (without labview)  
\*

\* feed flow proportional error  
20566100 ffproerr mult 1.000e+00 0.0 0  
20566101 cntrlvar 660 cntrlvar 619  
\*  
\* track 1e error  
20566200 e1errtr sum 1.0 0.0 0  
20566201 0.0 1.0 cntrlvar 682  
20566202 -1.0 cntrlvar 665  
\*  
\* track 1e error times 1e multiplier  
20566300 e1ertrp mult 1.0 0.0 0  
20566301 cntrlvar 662 cntrlvar 648  
\*  
\* total error for sf\_fw integral  
20566400 sffwerr sum 1.0 0.0 0  
20566401 0.0 1.0 cntrlvar 663  
20566402 1.0 cntrlvar 660  
\*  
\* three element sf\_fw integrand  
20566500 sffwintg integral 2.3813-01 84.324 0 3 0. 100.  
20566501 cntrlvar 664  
\*  
\* three element sf\_fw controller output  
20566600 sffwout sum 1.0 84.324 0 3 0. 100.  
20566601 0.0 1.0 cntrlvar 665  
20566602 1.0 cntrlvar 661  
\*  
\*  
\* single element controller  
\*  
\* level error term for single element control  
20566700 e1vlerr mult 1.0 0.0 0  
20566701 cntrlvar 602 cntrlvar 648  
20566702 cntrlvar 634 cntrlvar 200  
\*  
\* proportional error term for single element control  
20566800 e1proper mult 1.0 0.0 0  
20566801 cntrlvar 667 cntrlvar 617  
\*  
\* three element tracking error  
20566900 e3trerr sum 1.0 0.0 0  
20566901 0.0 1.0 cntrlvar 666  
20566902 -1.0 cntrlvar 675  
\*

\* three element tracking error when in 3e  
20567000 e3trerrt mult 1.0 0.0 0  
20567001 cntrlvar 669 cntrlvar 650 cntrlvar 652  
\*  
\* single element integral error term  
20567100 e1err sum 1.0 0.0 0  
20567101 0.0 1.0 cntrlvar 670  
20567102 1.0 cntrlvar 667  
20567103 1.0 cntrlvar 804  
\*  
\* single element integrand  
20567400 e1integd integral 1.667e-2 84.324 0 3 0. 100.  
20567401 cntrlvar 671  
\*  
\* single element controller  
20567500 e1-e1cnt sum 1.0 84.324 0 3 0. 100.  
20567501 0.0 1.0 cntrlvar 668  
20567502 1.0 cntrlvar 674  
\*  
\* track 3E selection  
20567600 track3el mult 1.0 84.324 1  
20567601 cntrlvar 652 cntrlvar 666  
\*  
\* track 1E selection  
20567700 track1el mult 1.0 0. 0  
20567701 cntrlvar 648 cntrlvar 675  
\*  
\* controller output in 1e or 3e  
20567800 e1-e1e3o sum 1.0 84.324 0 3 0. 100.  
20567801 0.0 1.0 cntrlvar 677  
20567802 1.0 cntrlvar 676  
\*  
\* scram response tripunit  
20567900 scrrespt tripunit 37.0 0. 0  
20567901 679 \* = 37 when scram respnse in, 0 otherwise  
\*  
\* max controller output following a scram response  
20568000 scrrspmx sum 1.0 100. 0  
20568001 100. -1.0 cntrlvar 679 \* 63. when response in  
\*  
\* single element controller out in 1e/3e w/ scram response  
20568100 e1scram stdfnctn 1.0 84.324 0  
20568101 min cntrlvar 680 cntrlvar 678  
\*

\* controller output with bypass zero feature  
20568200 i\_apiout mult 1.0 84.324 0  
20568201 cntrlvar 681 cntrlvar 634  
\*  
\* conversion of demand signal to speed demand  
20568300 spddmd sum 1.0 4816.2 0  
20568301 600. 50. cntrlvar 682  
\*  
\* individual pump responses  
\*  
\* pump b speed limiter tripunit  
20568400 b600rpm tripunit 9400. 0.0 0  
20568401 681 \* s = amt subtracted from large # to give limit  
\*  
\* pump b speed limit following scram response  
20568500 b600limt sum 1.0 10000. 0  
20568501 10000. -1.0 cntrlvar 684  
\*  
\* pump b speed controller output  
20568600 bcontout stdfnctn 1.0 4816.2 0  
20568601 min cntrlvar 685 cntrlvar 683 \* controller output to pump b  
\*  
\* pump a speed limiter tripunit  
20568700 a600rpm tripunit 9400. 0.0 0  
20568701 684 \* s = amt subtracted from large # to give limit  
\*  
\* pump a speed limit following scram response  
20568800 a600limt sum 1.0 10000. 0  
20568801 10000. -1.0 cntrlvar 687  
\*  
\* pump a speed controller output  
20568900 acontout stdfnctn 1.0 4816.2 0  
20568901 min cntrlvar 688 cntrlvar 683 \* controller output to pump a  
\*  
\*  
\* mathematical models of governors  
\*  
\* woodward a governor differential term  
20569000 woodadif diffreni 3.5 0.0 0  
20569000 woodadif diffreni .35 0.0 0  
20569001 cntrlvar 595  
\*  
\* woodward b governor differential term  
20569100 woodbdif diffreni .35 0.0 0

20569101 cntrlvar 596

\*

\* woodward c governor differential term

20569200 woodcdif diffreni .35 0.0 0

20569201 cntrlvar 597

\*

\* woodward a governor integral term

20569600 woodaint integral 2.8e+00 37.983 0 3 0. 100.

20569601 cntrlvar 595

\*

\* woodward b governor integral term

20569700 woodbint integral 2.8e+00 37.983 0 3 0. 100.

20569701 cntrlvar 596

\*

\* woodward c governor integral term

20569800 woodcint integral 2.8e+00 37.983 0 3 0. 100.

20569801 cntrlvar 597

\*

\* woodward a output in valve poppet dmd (sec op cyl pos)

\* s= (6.37"/100%)

20569900 woodaout sum 6.370e-02 2.4195099e+00 0 3 .000e+00 6.370e+00

20569901 0.0 7.00 cntrlvar 595

20569902 1.0 cntrlvar 690

20569903 1.0 cntrlvar 696

\*

\* woodward b output in valve poppet dmd (sec op cyl pos)

\* s= (6.37"/100%)

20570000 woodbout sum 6.370e-02 2.4195099e+00 0 3 .000e+00 6.370e+00

20570001 0.0 7.00 cntrlvar 596

20570002 1.0 cntrlvar 697

20570003 1.0 cntrlvar 691

\*

\* woodward c output in valve poppet dmd (sec op cyl pos)

\* s= (6.37"/100%)

20570100 woodcout sum 6.370e-02 2.4195099e+00 0 3 .000e+00 6.370e+00

20570101 0.0 7.00 cntrlvar 597

20570102 1.0 cntrlvar 698

20570103 1.0 cntrlvar 692

\*

\* woodward a output w/ pump tripunit

20570500 rfpasctr mult 1.0 2.4195700e+00 0

20570501 cntrlvar 613 cntrlvar 699

\*

\* woodward b output w/ pump tripunit

```
20570600 rfpbsctr mult 1.0 2.4195700e+00 0
20570601 cntrlvar 614 cntrlvar 700
*
* woodward c output w/ pump tripunit
20570700 rfpclsctr mult 1.0 2.4195700e+00 0
20570701 cntrlvar 615 cntrlvar 701
*
* rfpt a secondary operating cylinder position (valve position)
20570800 secopaps lag 1.000e+00 2.4195700e+00 0
20570801 0.1 cntrlvar 705 * lag time constant is a guess to acct for
* valve response to sec op cyl position
*
* rfpt b secondary operating cylinder position (valve position)
20570900 secopbps lag 1.000e+00 2.4187300e+00 0
20570901 0.2 cntrlvar 706 * lag time constant is from governor tuning
*
* rfpt c secondary operating cylinder position (valve position)
20571000 secopcps lag 1.000e+00 2.4187300e+00 0
20571001 0.2 cntrlvar 707 * lag time constant is from governor tuning
*
* steam inlet valve and turbine math models
*
* rfp a instantaneous lp steam mass flow in klbm/hr at 198.6 psia inlet p
* flow at fully open lp poppets from ref. 378; secondary cylinder travel
* from ref. 74
20571100 rfpamdot sum 2.911e+01 6.6794998e+01 0 3 .000e+00 8.020e+01
20571101 -.125 1.0 cntrlvar 708 * cntrlvar 708 is sec cyl travel
*
* rfp b instantaneous lp steam mass flow in klbm/hr at 198.6 psia inlet p
* flow at fully open lp poppets from ref. 378; secondary cylinder travel
* from ref. 74
20571200 rfpbmdot sum 2.911e+01 6.6770401e+01 0 3 .000e+00 8.020e+01
20571201 -.125 1.0 cntrlvar 709 * cntrlvar 709 is sec cyl travel
*
* rfp c instantaneous lp steam mass flow in klbm/hr at 198.6 psia inlet p
* flow at fully open lp poppets from ref. 378; secondary cylinder travel
* from ref. 74
20571300 rfpclmdot sum 2.911e+01 6.6770500e+01 0 3 .000e+00 8.020e+01
20571301 -.125 1.0 cntrlvar 710 * cntrlvar 710 is sec cyl travel
*
* rfp a instantaneous hp steam mass flow in klbm/hr at 965.0 psia inlet p
* flow at fully open hp poppets from ref. 378; secondary cylinder travel
* from ref. 74
20571400 rfpahpfl sum 2.381e+01 0.0 1 .000e+00
```

20571401 -2.88 1.0 cntrlvar 708 \* cntrlvar 708 is sec cyl travel  
\*  
\* rfp b instantaneous hp steam mass flow in klbm/hr at 965.0 psia inlet p  
\* flow at fully open hp poppets from ref. 378; secondary cylinder travel  
\* from ref. 74  
20571500 rfpbhpfl sum 2.381e+01 0.0 1 .000e+00  
20571501 -2.88 1.0 cntrlvar 709 \* cntrlvar 709 is sec cyl travel  
\*  
\* rfp c instantaneous hp steam mass flow in klbm/hr at 965.0 psia inlet p  
\* flow at fully open hp poppets from ref. 378; secondary cylinder travel  
\* from ref. 74  
20571600 rfpchpfl sum 2.381e+01 0.0 1 .000e+00  
20571601 -2.88 1.0 cntrlvar 710 \* cntrlvar 710 is sec cyl travel  
\*  
\* lp poppet inlet pressure, based on steam flow, see curves developed by saic  
\* from heat balance information  
20571700 lppopptp sum 1.427e+01 1.9357700e+02 0 1 1.470e+01  
20571701 0.1510 1.0 cntrlvar 900  
20571702 1.0 cntrlvar 901  
20571703 1.0 cntrlvar 902  
\*  
\* multiplicative factor for low press flow based on inlet pressure  
\* assumed linear with p-inlet  
20571800 flowmult mult 5.035e-03 9.7465998e-01 0  
20571801 cntrlvar 717  
\*  
\* multiplicative factor for high press flow based on inlet pressure  
\* assumed linear with p-inlet  
20571900 hflomult mult 1.503e-07 1.0138201e+00 0  
20571901 p 420030000 \* s = (1/965psia)(1.450383-4 psi/pa)  
\*  
\* lp delta enthalpy across rfpt in btu/lbm vs. inlet pressure  
20572000 rfptenth function 1.000e+00 2.2703700e+02 0  
20572001 cntrlvar 717 663  
\*  
\* hp delta enthalpy across rfpt in btu/lbm vs. inlet pressure  
20572100 hpdlength function 1.000e+00 2.6450000e+02 0  
20572101 p 420030000 663  
\*  
\* rfp a instantaneous turbine power output in hp from lp valves  
20572200 talpipwr mult 3.930e-01 5.8087798e+03 0  
20572201 cntrlvar 720 cntrlvar 718  
20572202 cntrlvar 711  
\*

\* rfp b instantaneous turbine power output in hp from lp valves  
20572300 tblpipwr mult 3.930e-01 5.8066401e+03 0  
20572301 cntrlvar 720 cntrlvar 718  
20572302 cntrlvar 712  
\*  
\* rfp c instantaneous turbine power output in hp from lp valves  
20572400 tclpipwr mult 3.930e-01 5.8066499e+03 0  
20572401 cntrlvar 720 cntrlvar 718  
20572402 cntrlvar 713  
\*  
\* rfp a instantaneous turbine power output in hp from hp valves  
20572500 tahpipwr mult 3.930e-01 0.0  
20572501 cntrlvar 721 cntrlvar 719  
20572502 cntrlvar 714  
\*  
\* rfp b instantaneous turbine power output in hp from hp valves  
20572600 tbhpipwr mult 3.930e-01 0.0  
20572601 cntrlvar 721 cntrlvar 719  
20572602 cntrlvar 715  
\*  
\* rfp c instantaneous turbine power output in hp from hp valves  
20572700 tchpipwr mult 3.930e-01 0.0  
20572701 cntrlvar 721 cntrlvar 719  
20572702 cntrlvar 716  
\*  
\* rfp a instantaneous turbine power output in hp  
20573000 rfptaipw sum 1.000e+00 5.8087798e+03 0  
20573001 0.0 1.0 cntrlvar 725  
20573002 1.0 cntrlvar 722  
\*  
\* rfp b instantaneous turbine power output in hp  
20573100 rfptbipw sum 1.000e+00 5.8066401e+03 0  
20573101 0.0 1.0 cntrlvar 726  
20573102 1.0 cntrlvar 723  
\*  
\* rfp c instantaneous turbine power output in hp  
20573200 rfptcipw sum 1.000e+00 5.8066499e+03 0  
20573201 0.0 1.0 cntrlvar 727  
20573202 1.0 cntrlvar 724  
\*  
\* rfp a turbine power output in hp  
20573500 rfptapwr lag 1.000e+00 5.8088701e+03 0  
20573501 0.05 cntrlvar 730  
\*

\* rfp b turbine power output in hp  
20573600 rfptbpwr lag 1.000e+00 5.8067700e+03 0  
20573601 0.05 cntrlvar 731  
\*  
\* rfp c turbine power output in hp  
20573700 rfptcpwr lag 1.000e+00 5.8067798e+03 0  
20573701 0.05 cntrlvar 732  
\*  
\* rfp a load power,pl, in hp  
20574000 rfpalpwr mult 1.341e-03 -5.8111099e+03 0  
20574001 pmpvel 570 pmptrq 570  
\*  
\* rfpb load power,pl, in hp  
20574100 rfpblpwr mult 1.341e-03 -5.8104702e+03 0  
20574101 pmpvel 571 pmptrq 571  
\*  
\* rfp c load power,pl, in hp  
20574200 rfpclpwr mult 1.341e-03 -5.8104800e+03 0  
20574201 pmpvel 572 pmptrq 572  
\*  
\* rfp a differential power  
20574500 rfpadpwr sum 1.000e+00 -2.2463901e+00 0  
20574501 0.0 1.0 cntrlvar 735  
20574502 1.0 cntrlvar 740  
\*  
\* rfp b differential power  
20574600 rfpbdpwr sum 1.000e+00 -3.7010801e+00 0  
20574601 0.0 1.0 cntrlvar 736  
20574602 1.0 cntrlvar 741  
\*  
\* rfp c differential power  
20574700 rfpcdpwr sum 1.000e+00 -3.7016301e+00 0  
20574701 0.0 1.0 cntrlvar 737  
20574702 1.0 cntrlvar 742  
\*  
\* rfp a net angular acceleration, in rpm/sec  
20575000 rfpalpha div 3.806e+02 -1.7738999e-01 0 \* (550lbf-ft/hp-sec)(32.17lbm-ft\*\*2/  
20575001 cntrlvar 756 cntrlvar 745 \* sec\*\*2)(60sec/min)\*\*2  
\* /{(4239lbm-ft\*\*2)(2pi)\*\*2} = s  
\*  
\* rfp b net angular acceleration, in rpm/sec  
20575100 rfpbalpha div 3.806e+02 -2.9226699e-01 0  
20575101 cntrlvar 757 cntrlvar 746  
\*

```
* rfp c net angular acceleration, in rpm/sec
20575200 rfpccalfa    div 3.806e+02 -2.9231101e-01 0
20575201 cntrlvar 758    cntrlvar 747
*
* rfp a delta rpm
20575300 rfpadrpm    mult 1.000e+00 -8.8695129e-03 0
20575301 cntrlvar 750    dt      0
*
* rfp b delta rpm
20575400 rfpbdrpm    mult 1.000e+00 -1.4613370e-02 0
20575401 cntrlvar 751    dt      0
*
* rfp c delta rpm
20575500 rfp cdrpm    mult 1.000e+00 -1.4615540e-02 0
20575501 cntrlvar 752    dt      0
*
* rfp a current rpm
20575600 rfp parpm   sum 1.000e+00 4.8197402e+03 0
20575601 0.0    1.0    cntrlvar 753
20575602      1.0    cntrlvar 756
*
* rfp b current rpm
20575700 rfp brpm    sum 1.000e+00 4.8196499e+03 0
20575701 0.0    1.0    cntrlvar 754
20575702      1.0    cntrlvar 757
*
* rfp c current rpm
20575800 rfp crpm    sum 1.000e+00 4.8196499e+03 0
20575801 0.0    1.0    cntrlvar 755
20575802      1.0    cntrlvar 758
*
20580200 output01 tripunit 1.0      0.      0
20580201 520
*
20580300 scramerr   sum 7.5      0.      0
20580301 63.    -1.0    cntrlvar 675
*
20580400 scramer1   mult .027027  0.      0
20580401 cntrlvar 679  cntrlvar 802 cntrlvar 803
*
*
*-----*
* additional rfwcs output control variables *
*-----*
```

\* mass flow rate, steam line a, in mlbm/hr  
20590000 stmfloa mult 7.938e-03 3.3373001e+00 0  
20590001 mflowj 412000000 \* constant = (2.205 lbm/kg)(3600sec/hr)(1.e-6)  
\*  
\* mass flow rate, steam line b, in mlbm/hr  
20590100 stmflob mult 7.938e-03 3.3373001e+00 0  
20590101 mflowj 411000000 \* constant = (2.205 lbm/kg)(3600sec/hr)(1.e-6)  
\*  
\* mass flow rate, steam line c/d, in mlbm/hr  
20590200 stmflocd mult 7.938e-03 6.7396998e+00 0  
20590201 mflowj 410000000 \* constant = (2.205 lbm/kg)(3600sec/hr)(1.e-6)  
\*  
\* reactor scram signal  
20590600 scarmsig tripunit 1.000e+00 0.0  
20590601 649  
\*  
\* level 8 signal (trips all rfps)  
20590700 lvl8\_sig tripunit 1.000e+00 0.0  
20590701 406  
\*  
\* problem time  
20590800 proftime mult 1.000e+00 1.0000000e+03 0  
20590801 time 0  
\*  
\*  
20591000 rfparsm mult 9.549e+00 4.8196001e+03 0  
20591001 pmpvel 570  
\*  
20591100 rfparsm mult 9.549e+00 4.8195098e+03 0  
20591101 pmpvel 571  
\*  
20591200 rfparsm mult 9.549e+00 4.8195098e+03 0  
20591201 pmpvel 572  
\*  
\* cntrlvar 940: RFW HTRC1 collapsed liquid level (inches above lower tap)  
20594000 'HTRC1LVL' sum 12. 16.0 1  
20594001 -2.6641 1.3307 voidf 922010000  
20594002 2.6667 voidf 921030000  
20594003 2.6667 voidf 921020000  
\*2059404 10.4596 voidf 921010000  
\*2059405 13.7904 voidf 920010000  
\*  
\* heater c1 level out to LabVIEW  
20594100 c1lvlout lag 1.00 33.0 0 3 0. 44.

20594101 0.5 cntrlvar 940 \*lag time const.  
\*  
\* auto vlv position demand, c1 drain vlv, in %  
20594900 c1draut constant 32.  
\*  
\* drain vlv position, heater c1  
20595000 c1drnpos lag 0.01 0.32 0  
20595001 0.05 cntrlvar 949  
\*  
\* cntrlvar 0951: RFW HTRC2 collapsed liquid level (inches above lower tap)  
20595100 'HTRC2LVL' sum 12. 18.0 1  
20595101 -6.9974 5.4974 voidf 933010000  
20595102 3.0000 voidf 932020000  
20595103 3.0000 voidf 932010000  
\*20509514 8.8763 voidf 931010000  
\*20509515 10.2904 voidf 930010000  
\*  
\* heater c2 level out to LabVIEW  
20595200 c2lvlout lag 1.00 18.0 0 3 0. 36. \*prb  
20595201 0.5 cntrlvar 951 \*lag time const.  
\*  
\* auto vlv position demand, c2 drain vlv, in %  
20595700 c2draut constant 44.  
\*  
\* drain vlv position, heater c2  
20595800 c2drnpos lag 0.01 0.44 0  
20595801 0.05 cntrlvar 957  
\*  
\* auto vlv position demand, c2 bypass vlv, in %  
20595900 c2byaut constant 0.0  
\*  
\* bypass vlv position, heater c2, normalized to 1.0  
20596000 c2byppos lag 0.01 0.0 0  
20596001 0.05 cntrlvar 959  
\*  
\* cntrlvar 0965: RFW HTRC3 collapsed liquid level (inches above lower tap)  
20596500 'HTRC3LVL' sum 12. 18.0 0  
20596501 -15.6068 7.0534 voidf 942040000  
20596502 7.0534 voidf 942030000  
20596503 3.0000 voidf 942020000  
20596504 3.0000 voidf 942010000  
\*20509655 11.1133 voidf 941010000  
\*20509656 12.4284 voidf 940010000  
\*

\* heater c3 level out to LabVIEW  
20596600 c3lvlout lag 1.00 18.0 0 3 0. 36. \*prb  
20596601 0.5 cntrlvar 965 \*lag time const.  
\*  
\* auto vlv position demand, c3 drain vlv, in %  
20597100 c3draut constant 34.  
\*  
\* drain vlv position, heater c3  
20597200 c3drnpos lag 0.01 0.34 0  
20597201 0.05 cntrlvar 971  
\*  
\* cntrlvar 0975: RFW HTRC4 collapsed liquid level (inches above shell bottom)  
20597500 'HTRC4LVL' sum 12. 16.9375 0  
20597501 0.0 0.1667 voidf 951010000 \* upper tap 2" above centerline  
20597502 2.9375 voidf 952010000 \* shell radius  
\*  
\* heater c4 level out to LabVIEW  
20597600 c4lvlout lag 1.00 16.9375 0 3 0. 37.25 \*prb  
20597601 0.05 cntrlvar 975 \*lag time const.  
\*  
\* auto vlv position demand, c4 drain vlv, in %  
20598100 c4draut constant 40.  
\*  
\* drain vlv position, heater c4, normalized to 1.0  
20598200 c4drnpos lag 0.01 0.40 0  
20598201 0.05 cntrlvar 981  
\*  
\* auto vlv position demand, c4 bypass vlv, in %  
20598300 c4byaut constant 0.0  
\*  
\* bypass vlv position, heater c4, normalized to 1.0  
20598400 c4byppos lag 0.01 0.0 0 \*prb 01-24-96 10:46am  
20598401 0.05 cntrlvar 983  
\*  
\* cntrlvar 0986: RFW HTRC5 collapsed liquid level (inches above shell bottom)  
20598600 'HTRC5LVL' sum 12. 15.0 0  
20598601 -5.2188 2.500 voidf 960030000 \* level taps are at top  
20598602 5.2188 voidf 960040000 \* & bottom of collector tank  
\*  
\* heater c5 level out to LabVIEW  
20598700 c5lvlout lag 1.00 15.0 0 3 0. 30. \*prb  
20598701 0.05 cntrlvar 986 \*lag time const.  
\*  
\* auto vlv position demand, c5 drain vlv, in %

20599200 c5draut constant 40.  
\*  
\* drain vlv position, heater c5, normalized to 1.0  
20599300 c5drnpos lag 0.01 0.40 0  
20599301 0.05 cntrlvar 992  
\*  
\* auto vlv position demand, c5 bypass vlv, in %  
20599400 c5byaut constant 0.0  
\*  
\* bypass vlv position, heater c5, normalized to 1.0  
20599500 c5byppos lag 0.01 0.0 0 \*prb 01-25-96 09:22pm  
20599501 0.05 cntrlvar 994  
\*  
\*  
\*-----  
\* hydrodynamic components  
\*-----  
\*-----  
\* reactor vessel  
\*-----  
\* note: initial conditions are taken from the output  
\* of a steady state calculation run for 1000 sec.  
\*  
\* the brown's ferry retran input deck is  
\* reference [349]  
\*-----  
\* (100) entrance volume to core  
\*-----  
1000000 lplenum branch  
\*card jun vel/flow  
1000001 1 0  
\*  
\*card vol flow area vol length vol of vol az angle  
1000101 0.0 17.534 2230.000 0.  
\*card inc angle elev change roughness hyd dia pvbfe  
1000102 90. 17.534 5.e-6 .8628 00000  
\*-----  
\* volume length, volume, elev change, hyd dia are from ref. [349].  
\*-----  
\*card ebt press ul ug alpha  
1000200 0 1.0450000e+03 5.1590997e+02 1.1091000e+03 0.  
\*  
\* jun (100-01) lower plenum to core inlet  
\*-----

---

*RELAP5 Model INPUT DECK WITH NEW RECIRCULATION CONTROLS*

```
*card from to area kf kr fvcahs
1001101 100010000 110000000 37.503 0.0000 9.1510 001000
*-----
* junction area is from ref. [349]
* kf: modelling assumption
* kr: ref. [349]
*-----
*card int. liq flow int. vap flow int vel
1001201 1.5436000e+01 1.7542999e+01 0.
*
*-----
* (110) core inlet
*-----
*card name type
1100000 corein branch
*
*card jun vel/flow
1100001 2 0
*
*card vol flow area vol length vol of vol az angle
1100101 0.0 0.492 37.710 0.
*card inc angle elev change roughness hyd dia pvbfe
1100102 90. 0.492 5.e-6 0.04461 00000
*
* volume length, volume, elev change, hyd dia are from ref. [349].
*-----
*card ebt press ul ug alpha
1100200 0 1.0417000e+03 5.1590997e+02 1.1092000e+03 0.
*
* jun (110-01) core inlet to reactor core
*-----
*card from to area kf kr fvcahs
1101101 110010000 120000000 83.9636 0.615385 0.07692 001000
*-----
* junction area, kf, and kr are from ref. [349].
*-----
*card int. liq flow int. vap flow inter. vel
1101201 6.0906000e+00 9.3687000e+00 0.
1102201 1.0246000e+02 1.0581000e+02 0.
*
* jun (110-02) core inlet to core bypass
*-----
*card from to area kf kr fvcahs
1102101 110010000 130000000 0.6590 0.084 0.648 001000
```

```
*-----
* junction area is from ref. [349].
* kf: modelling assumption used to achieve a 0.119 bypass ratio
* kr: ref. [349]
*-----
*
* -----
* (111) loca time dependent junction
* -----
*card component name type
1110000 locajun tmdpjun
1110101 100000000 113000000 0.
1110200 1 468
1110201 -1.0 0.0 0.0 0.0
1110202 0.0 40.0 0.0 0.0
*
* -----
* (112) single junction: core region (120) - core exit (170)
* -----
*card component name type
1120000 singjun sngljun
*
*card from vol to vol jun area f loss r loss fvcahs
1120101 120010000 170000000 84.9744 0.10000 7.11200 001000
*-----
* junction area, kf, and kr are from ref. [349].
* -----
* -----
*card vel/flow int liq flow int vapor flow interface vel
1120201 0 1.6455999e+01 2.8388000e+01 0.
*
* -----
* (113) loca time dependent volume
* -----
*card component name type
1130000 locavol tmdpvol
1130101 0. 1. 1. 0. 0. 0. 0. 0. 00000
1130200 001
1130201 0.0 526. 0.
*
* -----
* (120) core region (pipe)
* -----
```

```
*card component type
1200000 core pipe
*
*card num vol
1200001 5
*card vol flow area vol
1200101 0.0 5
*card jun flow area jun
1200201 0.0 4
*card vol length vol
1200301 2.7386 5
*card vol of vol vol
1200401 232.7108 5
*card azimuthal angle vol
1200501 0.0 5
*card inclination angle vol
1200601 90.0 5
*card elevation change vol
1200701 2.7386 5
*card wall roughness hyd dia vol
1200801 5.e-6 0.0446 5
*-----
* vol length, vol, elev change are calculated in
* appendix a. hyd dia from ref. [349].
*-----
*card f loss coeff r loss coeff jun
1200901 2.0000 0.2500 4
*-----
* kf and kr are calculated in appendix a
*-----
*card pvbfe vol
1201001 11100 5
*
*card fvcahs jun
1201101 001000 4
*
*card ebt press ul ug alpha w5 vol
1201201 0 1.041000e+03 5.3301001e+02 1.1092000e+03 1.1264000e-01 .0 1
1201202 0 1.0395000e+03 5.4077002e+02 1.1093000e+03 3.7233001e-01 .0 2
1201203 0 1.0377000e+03 5.4346002e+02 1.1093000e+03 4.7633001e-01 .0 3
1201204 0 1.0356000e+03 5.4379999e+02 1.1094000e+03 5.1504999e-01 .0 4
1201205 0 1.0334000e+03 5.4351001e+02 1.1095000e+03 6.8190002e-01 .0 5
*
*card vel/flow
```

1201300 0  
\*  
\*card int liq flow int vap flow inter vel jun  
1201301 6.8456001e+00 1.0574000e+01 0. 1  
1201302 9.4076996e+00 1.5172000e+01 0. 2  
1201303 1.0775000e+01 2.3551001e+01 0. 3  
1201304 1.1115000e+01 3.1582001e+01 0. 4  
\*  
\*-----  
\* (130) core bypass (branch)  
\*-----  
\*card component name type  
1300000 coreby branch  
\*  
\*card num jun vel/flow  
1300001 1 0  
\*  
\*card vol flow area vol length vol of vol az angle  
1300101 0.0 13.693 952.140 0.0  
\*card inc angle elev change roughness hyd dia pvbfe  
1300102 90.0 13.693 5.0e-6 0.1867 00000  
\*-----  
\* vol length, vol, elev change, hyd dia are from ref. [349].  
\*-----  
\*card ebt press ul ug alpha  
1300200 0 1.0351000e+03 5.1590997e+02 1.1094000e+03 0.  
\*  
\* jun (130-01) core bypass - core exit  
\*-----  
\*card from vol to vol jun area f loss r loss fvcahs  
1301101 130010000 170000000 46.5040 0.747 0.374 001000  
\*-----  
\* junction area, kf, kr are from the ref. [349].  
\*-----  
\*card int liq flow int vap flow inter vel  
1301201 1.4520000e+00 6.1647000e+00 0.  
\*  
\*-----  
\* (140) lower downcomer (branch)  
\*-----  
\*card component name type  
1400000 lowerdc branch  
\*card num jun vel/flow  
1400001 2 0

\*

\*card vol flow area vol length vol of vol az angle  
1400101 0.0 21.330 2004.467 0.0  
\*card inc angle elev change rough hyd dia pvbfe  
1400102 -90.0 -21.330 5.e-6 1.9452 00000

\*

\* vol length, vol, elev change are calculated in app a  
\* hyd dia from ref. [349]

\*

\*card ebt press ul ug alpha  
1400200 0 1.0323000e+03 5.1578003e+02 1.1095000e+03 0.

\*

\* jun (140-01) lower downcomer to recirculation pump suction(a)

\*

\*card from vol to vol jun area f loss r loss fvcahs  
1401101 140010000 220000000 3.5410 0.005 1.00 001000

\*

\* junction area from ref. [349], kf modelling assumption,  
\* kr from ref. [349]

\*

\*card int liquid flow int vapor flow inter vel  
1401201 2.8816000e+01 3.0966000e+01 0.  
1402201 2.8816000e+01 3.0966000e+01 0.

\*

\* jun (140-02) lower downcomer to recirculation pump suction(b)

\*

\*card from vol to vol jun area f loss r loss fvcahs  
1402101 140010000 270000000 3.5410 0.005 1.00 001000

\*

\* junction area from ref. [349], kf modelling assumption,  
\* kr from ref. [349]

\*

\*

\*

\* (150) middle downcomer (branch)

\*

\*card component name type

1500000 middledc branch

\*card num jun vel/flow

1500001 1 0

\*

\*card vol flow area vol length vol of vol az angle

1500101 0.0 12.739 1411.466 0.0

\*card inc angle elev change roughness hyd dia pvbfe

```
1500102 -90.0 -12.739 5.e-6 2.716 00000
*-----
* see note with card 1400101
*-----
*card ebt press ul ug alpha
1500200 0 1.0266000e+03 5.1595001e+02 1.1097000e+03 0.
*
* jun (150-01) middle downcomer to lower downcomer
*-----
*card from vol to vol jun area f loss r loss fvcahs
1501101 150010000 140000000 87.0380 0.00 0.00 001000
*
* junction area, kf, kr from ref. [349]
*-----
*card int liquid flow int vapor flow inter vel
1501201 2.3452001e+00 2.9754000e+00 0.
*
*-----
* (160) upper downcomer
*-----
*card name type
1600000 uppdc branch
*
*card jun vel/flow
1600001 1 0
*
*card area length of vol vol of vol az angle
1600101 0. 6.167 965.359 0.0
*card inc angle elev change roughness hyd dia pvbfe
1600102 -90. -6.167 5.e-6 0.8132 00000
*-----
* see note with card 1400101
*-----
*card ebt press ul ug alpha
1600200 0 1.0242000e+03 5.2938000e+02 1.1099000e+03 6.2769002e-01
*
* jun (160-01) upper downcomer to middle downcomer
*-----
*card from to area kf kr fvcahs
1601101 160010000 150000000 156.536 0.00 0.00 001000
*-----
* junction area, kf, kr from ref. [349]
*-----
*card int liq flow int vap flow inter. vel.
```

```
1601201 -1.8235701e-04 -1.7219000e+00 0.  
*  
*-----  
*(170) core exit (branch)  
*-----  
*card component name type  
1700000 uplenum branch  
*card num jun vel/flow  
1700001 0 0  
*  
*card vol flow area vol length vol of vol az angle  
1700101 0.0 12.739 1330.250 0.0  
*card inc angle elev change roughness hyd dia pvbfe  
1700102 90.0 12.739 5.e-6 0.5054 10000  
*-----  
* vol length, vol, elev change, hyd dia from ref. [349]  
*-----  
*card ebt press ul ug alpha  
1700200 0 1.0315000e+03 5.4301001e+02 1.1095000e+03 5.4667002e-01  
*  
*-----  
*(180) steam separator (branch:separator)  
*-----  
*card component name type  
1800000 seprt separatr  
*  
*card num jun vel/flow  
1800001 3 0  
*  
*card vol flow area vol length vol of vol az angle  
1800101 0.0 6.167 461.676 0.0  
*card inc angle elev change roughness hyd dia pvbfe  
1800102 90.0 6.167 5.e-6 0.7658 00010  
*-----  
* vol length, vol, elev change, hyd dia from ref. [349]  
*-----  
*card ebt pres ul ug vapor void fraction  
1800200 0 1.0251000e+03 5.4235999e+02 1.1096000e+03 6.9423002e-01  
*  
* jun (180-01) separator - steam dome  
*-----  
*card from vol to vol jun area f loss r loss fvcahs void  
1801101 180010000 190000000 280.478 150. 150. 001000 0.5 * kwr  
*-----
```

\* junction area is set equal to the volume flow area of the steam dome  
\* kf, kr from ref. [349]

\*

\*card int liq flow int vap flow inter vel

1801201 3.4347999e-01 5.7609000e+00 0.

1802201 8.6007996e+00 8.6309996e+00 0.

1803201 1.0917000e+01 2.7964001e+01 0.

\*

\* jun (180-02) separator to middle downcomer

\*

\*card from vol to vol jun area f loss r loss fvcahs void

1802101 180000000 150000000 60.0000 3. 3. 001000 0.15 \* kwr

\*

\* junction area from ref. [349] (50.6358) was too small and restricted

\* flow to the middle downcomer, so a new value was used that would allow

\* the required mass flow to the middle downcomer. kf and kr from ref.

\* [349]

\*

\* jun (180-03) core exit to steam separator

\*

\*card from vol to vol jun area f loss r loss fvcahs

1803101 170010000 180000000 104.423 13.4 13.4 001000 \* kwr

\*

\* junction area from ref. [349]. kf and kr: modelling assumption

\* used to achieve the required flow

\*

\*

\* (190) steam dome (branch)

\*

\*card component name type

1900000 stdome branch

\*

\*card num jun vel/flow

1900001 2 0

\*1900001 3 0

\*

\*card vol flow area vol length vol of vol az angle

1900101 0.0 22.318 6259.714 0.0

\*card inc angle elev change roughness hyd dia pvbfe

1900102 90.0 22.318 5.e-6 17.932 11000

\*

\* vol length, vol, elev change, hyd dia from the retran input deck

```
*-----
*card ebt press ul ug alpha
1900200 0 1.0236000e+03 5.4206000e+02 1.1097000e+03 9.9997002e-01
*
* jun (190-01) steam dome to main steimeline
*-----
*card from to area kf kr fvcahs
1901101 190010000 400000000 12.6713 1.6937 1.6937 001000
*1901101 190010000 400000000 12.6713 1.2000 1.0000 001000
*-----
* junction area from retran input deck. kf and kr: modelling
* assumption used to achieve the required flow
*-----
*card int. liq flow int vap flow inter. vel
1901201 1.2182000e+02 1.2764000e+02 0.
1902201 2.6910000e+00 -2.8625701e-04 0.
*1903201 3.4839001e+00 -3.3684799e-05 0.0000000e+00
*
* jun (190-02) steam dome to upper downcomer
*-----
*card from to area kf kr fvcahs
1902101 190000000 160000000 136.0630 0.00 0.00 001000
*-----
* junction area, kf, kr from ref. [349]
*-----
*
*-----
* jet pumps and recirculation loops
*-----
* loop a
*-----
*-----
*****(200) jet pump (a) (branch:*****jetmixer)
*-----
*card component name type
2000000 jetpa jetmixer
*card num jun vel/flow
2000001 3 0
*
*card vol flow area vol length vol of vol az angle
2000101 0.0 7.0000 27.840 0.0
*card inc angle elev change roughness hyd dia pvbfe
2000102 -90.0 -7.0000 5.e-6 5.0 00000
*
```

\* see calculations in appendix c for vol length, vol, elev change.

\* hyd dia from ref. [349]

\*

\*card ebt press ul ug alpha

2000200 0 1.0118000e+03 5.1594000e+02 1.1101000e+03 0.

\*

\* jun (200-01) recirculation discharge (a) to jetpump (a)

\*

\*card from vol to vol jun area f loss r loss fvcahs

2001101 240010000 200000000 0.8226 1.1 1.100 001000

\*

\* junction area, kf and kr used to achieve required flow.

\*

\*card int liq flow int vapor flow inter vel

2001201 1.2392000e+02 1.2392000e+02 0.

2002201 6.7608002e+01 7.0873001e+01 0.

2003201 7.8358002e+01 8.2028000e+01 0.

\*

\* jun (200-02) middle downcomer to jet pump (a)

\*

\*card from vol to vol jun area f loss r loss fvcahs

2002101 150010000 200000000 2.7724 0.24 5.000 001000

\*

\* junction area, kf and kr used to achieve required flow.

\*

\* jun (200-03) jet pump (a) to jet pump diffuser

\*

\*card from vol to vol jun area f loss r loss fvcahs

2003101 200010000 210000000 3.6950 0.0 0.0 001000

\*

\* junction area from ref. [349], kf and kr used to achieve required flow.

\*

\*

\* (210) jet pump diffuser (a)

\*

\*card name type

2100000 diffa branch

\*

\*card jun vel/flow

2100001 1 0

\*card area length volume az angle

2100101 0.0 7.1851 83.520 0.0

\*card incl angle dz rough dh pvbfe

```
2100102 -90.0 -7.1851 5.e-6 0.0 00000
*-----
* see calculations in appendix c
*-----
*card ebt press ul ug alpha
2100200 0 1.0379000e+03 5.1594000e+02 1.1093000e+03 0.
*
* jun (210-01) jet pump diffuser (a) to lower plenum
*-----
*card from to area kf kr fvcahs
2101101 210010000 100010000 19.689 0.15 0.15 001000
*
* junction area from ref. [349]. kf and kr: modelling
* assumption used to achieve the required pressure and flow.
*-----
*card init liq flow init vap flow inter vel
2101201 1.4702000e+01 1.6590000e+01 0.
*
*-----
* (220) recirculation suction (a)
*-----
*card component type
2200000 recira snglvol
*
*card vol flow area vol length vol of vol az angle
2200101 0.0 47.427 167.939 0.0
*card inc angle elev change roughness hyd dia pvbfe
2200102 -28.95 -41.499 5.e-6 1.0617 01000
*
* see calculations in appendix c.
*-----
*card ebt press ul ug alpha
2200200 0 1.0375000e+03 5.1578998e+02 1.1093000e+03 0. 0.
*
*-----
* (230) recirculation pump (a)
*-----
*card component type
2300000 pumpa pump
*
*card vol flow area vol length vol of vol az angle
2300101 0.0 28.235 76.344 0.0
*card inc angle elev change pvbfe
2300102 13.22 6.457 00000
```

\*-----  
\* see calculations in appendix c.  
\*-----  
\*  
\*pump junction geometry cards:  
\*card from vol jun area f loss cof r loss cof vcahs  
2300108 220010000 0.0 1.000 1.000 00000  
\*card to vol jun area f loss cof r loss cof vcahs  
2300109 240000000 0.0 10.00 10.00 00000  
\*-----  
\* kf and kr from ref. [349]  
\*-----  
\*pump initial condition cards:  
\*card ebt press ul ug alpha  
2300200 0 1.1499000e+03 5.1589001e+02 1.1059000e+03 0. 0.  
\*card vel/flow int liquid flow int vapor flow inter  
2300201 0 3.7737000e+01 3.7737000e+01 0.  
2300202 0 3.9660000e+01 3.9660000e+01 0.  
\*  
\*pump index and option card  
\*card indic 2p 2pd motor pump torq tdp vel pump trip rev  
2300301 280 -1 -3 -1 0 408 0  
\*  
\*pump description card (from ref. [1] pg 6i)  
\*card pump vel ratio flow head torque inertia  
2300302 1.6200000e+03 9.7660494e-01 4.5200000e+04 7.6325000e+02 2.1326699e+04  
2300303 1.9174500e+04  
\*card density motor torw w1 w2 w3 w4  
2300304 47.167 0.0 1122.5 0.0 0.0 0.0  
\*-----  
\* since this model has two loops the flow, torque, and inertia values  
\* from ref. [349] were divided in half.  
\*-----  
\*  
\* speed table  
2306100 501 cntrlvar 264  
2306101 0. 0.  
2306102 1.e4 1.e4  
\*  
\*-----  
\* (240) recirculation discharge (a)  
\*-----  
\*card component type

```
2400000      discha      snglvol
*
*card    vol flow area  vol length  vol of vol  az angle
2400101      0.0      115.912     297.963     0.0
*card    inc angle  elev change  roughness  hyd dia  pvbfe
2400102      29.10     56.372      5.e-6      0.949     01000
*
*-----*
* see calculations in appendix c.
*-----
*card ebt press      ul      ug      alpha
2400200  0 1.1711000e+03 5.1591998e+02 1.1053000e+03 0.0.
*
*-----
* !jet pumps and recirculation loops
*-----
* loop b
*-----
*-----
* (250) jet pump (b) (branch:jet mixer)
*-----
* see card 200 for reference.
*-----
*card component name   type
2500000  jetpb       jetmixer
*card num jun   vel/flow
2500001      3      0
*
*card    vol flow area  vol length  vol of vol  az angle
2500101      0.0      7.0000     27.840     0.0
*card    inc angle  elev change  roughness  hyd dia  pvbfe
2500102     -90.0     -7.0000     5.0e-6     5.0     00000
*
*card    ebt    press      ul      ug      alpha
2500200  0 1.0118000e+03 5.1594000e+02 1.1101000e+03 0.
*
* jun (250-01) recirculation discharge (b) to jetpump (b)
*-----
*card from vol  to vol  jun area  f loss  r loss  fvcahs
2501101 290010000 250000000  0.8226  1.1     1.100  001000
*
*card int liquid flow  int vapor flow  inter vel
2501201  1.2392000e+02 1.2392000e+02 0.
2502201  6.7608002e+01 7.0873001e+01 0.
2503201  7.8358002e+01 8.2028000e+01 0.
```

\*  
\* jun (250-02) middle downcomer to jet pump (b)  
\*-----  
\*card from vol to vol jun area f loss r loss fvcahs  
2502101 150010000 250000000 2.7724 0.24 5.000 001000  
\*-----  
\*  
\* jun (250-03) jet pump (b) to jet pump diffuser  
\*-----  
\*card from vol to vol jun area f loss r loss fvcahs  
2503101 250010000 260000000 3.695 0.0 0.0 001000  
\*  
\*-----  
\* (260) jet pump diffuser (b)  
\*-----  
\* see card 210 for references.  
\*-----  
\*card name type  
2600000 diffb branch  
\*  
\*card jun vel/flow  
2600001 1 0  
\* card area length volume az angle  
2600101 0.0 7.1851 83.520 0.0  
\*card incl angle dz rough dh pvbfe  
2600102 -90.0 -7.1851 5.e-6 0.0 00000  
\*  
\*card ebt press ul ug alpha  
2600200 0 1.0379000e+03 5.1594000e+02 1.1093000e+03 0.  
\*  
\* jun (260-01) jet pump diffuser (b) to lower plenum  
\*-----  
\*card from to area kf kr fvcahs  
2601101 260010000 100010000 19.689 0.15 0.15 001000  
\*  
\*card init liq flow init vap flow inter vel  
2601201 1.4702000e+01 1.6590000e+01 0.  
\*  
\*-----  
\* (270) recirculation suction (b)  
\*-----  
\* see card 220 for references.  
\*-----  
\*card component type

```
2700000      recirb      snglvol
*
*card    vol flow area  vol length  vol of vol  az angle
2700101      0.0        47.427     167.939    0.0
*card    inc angle  elev change  roughness  hyd dia  pvbfe
2700102      -28.95    -41.499     5.0e-6     1.0617   01000
*card    ebt      press      ul      ug      alpha
2700200  0 1.0375000e+03 5.1578998e+02 1.1093000e+03 0. 0.
*
*-----  
* (280) recirculation pump (b) (pump)
*-----  
*see card 230 for references, unless otherwise noted.
*-----  
*card    component    type
2800000      pumpb      pump
*
*card    vol flow area  vol length  vol of vol  az angle
2800101      0.0        28.235     76.344    0.0
*card    inc angle  elev change  pvbfe
2800102      13.22     6.457      00000
*
*pump junction geometry cards:
*card    from vol    jun area  f loss cof  r loss cof  vcahs
2800108  270010000    0.0        1.000      1.000    00000
*card    to vol     jun area  f loss cof  r loss cof  vcahs
2800109  290000000    0.0        10.00     10.00    00000
*
*pump initial condition cards:
*card    ebt      press      ul      ug      alpha
2800200  0 1.1499000e+03 5.1589001e+02 1.1059000e+03 0. 0.
*
*card    vel/flow   int liquid flow  int vapor flow  inter vel
2800201  0 3.7737000e+01 3.7737000e+01 0.
2800202  0 3.9660000e+01 3.9660000e+01 0.
*
*pump index and option card
*card    indic 2p  2pd  m pump torq  tdp vel  pump trip  rev
2800301  0  -1  -3    -1     0    408    0
*
*pump description card
*card    pump vel  ratio  flow   head torque  iner
2800302  1.6200000e+03 9.7660494e-01 4.5200000e+04 7.6325000e+02 2.1326699e+04
2800303  1.9174500e+04
```

```
*card density motor torw w1      w2   w3   w4
2800304 47.167    0.0    1122.5   0.0  0.0  0.0
*
* single phase homologous curves (from ref. [349])
*
* pump head curves
*card type regime phead1 phead2 phead1 phead2
2801100 1   1     0.0    1.41   0.25  1.365
2801101          0.33  1.345   0.50  1.280
2801102          0.67  1.195   0.75  1.150
2801103          1.00  1.00
*
2801200 1   2     0.2    -0.32  0.25  -0.290
2801201          0.33  -0.230  0.40  -0.170
2801202          0.50  -0.05   0.60  0.100
2801203          0.67  0.230   0.75  0.390
2801204          0.80  0.500   1.00  1.000
*
2801300 1   3     -1.    1.920  -0.80  1.725
2801301          -0.67  1.625  -0.50  1.540
2801302          -0.33  1.480  -0.25  1.465
2801303          -0.01  1.420  0.00  1.410
*
2801400 1   4     -1.00  2.24   -0.66  1.180
2801401          -0.50  0.800  -0.24  0.64
*
2801500 1   5     0.00  0.926   0.25  0.882
2801501          0.33  0.884   0.50  0.908
2801502          0.67  0.948   0.75  0.960
2801503          1.00  1.00
*
2801600 1   6     0.20  -0.314  0.25  -0.250
2801601          0.33  -0.140  0.40  -0.051
2801602          0.50  0.100   0.60  0.275
2801603          0.67  0.387   0.75  0.530
2801604          0.80  0.627   1.00  1.00
*
2801700 1   7     -1.00  -1.880  -0.67  1.450
2801701          -0.50  1.270   -0.33  1.140
2801702          -0.25  1.070   -0.01  0.930
2801703          0.00  0.926
*
2801800 1   8     -1.00  1.760   0.66  1.080
2801801          -0.50  0.920   -0.24  0.720
```

\*

\* pump torque curves

\*card type regime ptork1 ptork2 ptork1 ptork2

2801900	2	1	0.0	0.930	0.25	0.870
2801901			0.33	0.890	0.50	0.900
2801902			0.67	0.960	0.75	0.950
2801903			1.00	1.000		

\*

2802000	2	2	0.20	-7.84	0.25	-4.000
2802001			0.33	-1.16	0.40	-0.320
2802002			0.50	0.40	0.60	0.820
2802003			0.67	0.87	0.75	1.000
2802004			0.80	0.98	0.99	0.999

\*

2802100	2	3	-1.00	1.88	-0.67	1.450
2802101			-0.50	1.27	-0.33	1.140
2802102			-0.25	1.07	-0.01	0.930

\*

2802200	2	4	-0.99	1.760	-0.66	2.400
2802201			-0.50	3.840	-0.24	12.500

\*

2802300	2	5	0.00	-0.720	0.30	-0.600
2802301			0.42	-0.400	0.50	-0.050
2802302			0.75	0.250	1.00	0.57

\*

2802400	2	6	0.00	1.44	0.10	1.400
2802401			0.22	1.20	0.33	1.100
2802402			0.55	1.00	0.80	0.80
2802403			1.00	0.57		

\*

2802500	2	7	-1.00	-2.00	-0.30	-1.500
2802501			-0.18	-1.35	-0.07	-1.000
2802502			0.00	-0.92		

\*

2802600	2	8	-1.00	-2.00	-0.25	-1.800
2802601			-0.12	-1.50	-0.08	-1.400
2802602			0.00	-1.00		

\*

\* speed table

2806100 502 cntrlvar 265

2806101 0. 0.

2806102 1.e4 1.e4

\*

\* tmp - use simple target-core-flow controller

```
*2806100 408 cntrlvar 831
*
* tmp - ramp pump speed from somewhere to somewhere else and hold
*2806100 408
*2806101 0. 1581.48 60. 982.
*
*-----
* (290) recirculation discharge piping (b)
*-----
* see card 240 for references.
*-----
*card component type
2900000 dischb snglvol
*card vol flow area vol length vol of vol az angle
2900101 0.00 115.912 297.963 0.0
*card inc angle elev change roughness hyd dia pvbfe
2900102 29.10 56.372 5.0e-6 0.949 01000
*
*card ebt press ul ug alpha
2900200 0 1.1711000e+03 5.1591998e+02 1.1053000e+03 0. 0.
*
*-----
* hpci and rcic systems
*-----
*-----
*(300) hpci and rcic supply
*-----
*card name type
3000000 rcicvola tmdpvol
*
*card flow area length of vol vol of vol az angle
3000101 5.0 10.0 0.0 0.0
*card incl. angle elev change roughness hyd dia pvbfe
3000102 90. 10.0 0.00015 1.0 00010
*
* length, vol, elev change, hyd dia values are assumed.
*-----
*card ebt trip no.
3000200 001 408
*card search variable temp quality
3000201 0. 99.99 0.0
*
*-----  
* the thermodynamic values are based on nominal pool temperature
*-----
```

```
*  
*-----  
*(301) hpci and rcic supply  
*-----  
*card name type  
3010000 rcicvolb tmdpvol  
*  
*card flow area length of vol vol of vol az angle  
3010101 5.0 10.0 0.0 0.0  
*card incl. angle elev change roughness hyd dia pvbfe  
3010102 90. 10.0 0.00015 1.0 00010  
*-----  
* length, vol, elev change, hyd dia values are assumed.  
*-----  
*card ebt trip no.  
3010200 001 408  
*card search variable temp quality  
3010201 0. 99.99 0.0  
*-----  
* the thermodynamic values are based on nominal pool temperature  
*-----  
*  
*  
*-----  
*(310) hpci supply valve  
*-----  
*card name type  
3100000 hpcijun tmdpjun  
*  
*card from to jun area  
3100101 301000000 150000000 1.  
*card control word table trip  
3100200 1 631  
*card search var. liq vel/flow vap vel/flow inter. vel  
3100201 -1. 0. 0. 0.  
3100202 0. 0. 0. 0.  
3100203 20. 694. 0. 0.  
*  
*-----  
*(320) rcic supply valve  
*-----  
*card name type  
3200000 rcicjun tmdpjun  
*
```

```
*card from to jun area
3200101 300000000 150000000 1.
*card control word table trip
3200200 1 637
*card search var. liq vel/flow vap vel/flow inter. vel
3200201 -1. 0. 0. 0.
3200202 0. 0. 0. 0.
3200203 20. 82.4 0. 0.
*
*-----
*(350) hpci and rcic exhaust
*-----
*card name type
3500000 exhausta tmdpvol
*
*card flow area length of vol vol of vol az angle
3500101 5.0 10.0 0.0 0.0
*card incl. angle elev change roughness hyd dia pvbfe
3500102 90. 10.0 0.00015 1.0 00010
*
* length, vol, elev change, hyd dia values are assumed.
*-----
*card ebt trip no.
3500200 001 408
*card search variable temp quality
3500201 0. 212.0 1.0
*
* the thermodynamic values are for steam at atmospheric conditions
*-----
*
*-----
*(351) hpci and rcic exhaust
*-----
*card name type
3510000 exhaustb tmdpvol
*
*card flow area length of vol vol of vol az angle
3510101 5.0 10.0 0.0 0.0
*card incl. angle elev change roughness hyd dia pvbfe
3510102 90. 10.0 0.00015 1.0 00010
*
* length, vol, elev change, hyd dia values are assumed.
*-----
*card ebt trip no.
```

```
3510200 001      408
*card  search variable  temp  quality
3510201  0.       212.0  1.0
*
*-----
* the thermodynamic values are for steam at atmospheric conditions
*-----
*
*-----
*(360) hpci turbine supply
*-----
*card    name      type
3600000  hpciturb  tmdpjun
*
*card    from      to      jun area
3600101 190000000 351000000 1.
*card    control word  table trip
3600200  1       631
*card    search var. liq vel/flow vap vel/flow inter. vel
3600201  -1.     0.      0.      0.
3600202  0.      0.      58.3    0.
*
*-----
*(370) rcic turbine supply
*-----
*card    name      type
3700000  rcicturb  tmdpjun
*
*card    from      to      jun area
3700101 190000000 350000000 1.
*card    control word  table trip
3700200  1       636
*card    search var. liq vel/flow vap vel/flow inter. vel
3700201  -1.     0.      0.      0.
3700202  0.      0.      9.17    0.
*
*-----
* main steam system
*-----
*
* (400) main steam line
*-----
*card    component   type
4000000  steamln   snglvol
*
```

```
*card    vol flow area  length  vol of vol  az angle
4000101      0.0     116.770   1507.501   0.0
*card    incl angle  elev change  roughness  hyd dia  pvbfe
4000102      33.777    64.720     5.e-6     8.108   11000
*-----
* see calculations in appendix c.
*-----
*card    ebt  press  ul  ug  alpha
4000200  0 1.0120000e+03 5.4041998e+02 1.1095000e+03 9.9992001e-01 0.
*
*-----
* main steam valve double (representative of 2 msivs)
*-----
* 
4100000  msiv_d  valve
*
*card  from vol  to vol  jun area  f loss  r loss  fvcahs
4100101 400010000 420000000  6.4550   4.0    4.5  001020
*-----
* junction flow area is representative of 2 msiv's.  see calculations
* in appendix c. kf and kr are assumed.
*-----
*card  flag  int liq flow  int vap flow  inter vel
4100201  0 1.2715000e+02 1.2715000e+02 0.
*
*card  valve type
4100300  mtrvlv
*
*card  open trip  close trip  vel change rate  init pos  table
4100301  409      666      0.25          1.    545
* valve closes in 4 sec. -- initial position = 1.0; fully open
*
* table defined to give negligible form loss
4100401 0. 1.e6 1.e6
4100402 1. 1.e6 1.e6
*
*-----
* main steam valve single 1 (representative of 1 msiv)
*-----
*
4110000  msiv_s1  valve
*
*card  from vol  to vol  jun area  f loss  r loss  fvcahs
4110101 400010000 420000000  3.227   4.10   4.5  001020
```

\*-----  
\* junction flow area is representative of 1 msiv. see calculations  
\* in appendix c. kf and kr are assumed.  
\*-----  
\*  
\*card flag int liq flow int vap flow inter vel  
4110201 0 1.2594000e+02 1.2594000e+02 0.  
\*  
\*card valve type  
4110300 mtrvlv  
\*  
\*card open trip close trip vel change rate init pos table  
4110301 409 665 0.25 1. 545  
\* valve closes in 4 sec. -- initial position = 1.0; fully open  
\*  
\* table defined to give negligible form loss  
4110401 0. 1.e6 1.e6  
4110402 1. 1.e6 1.e6  
\*  
\*-----  
\* main steam valve single 2 (representative of 1 msiv)  
\*-----  
\*  
4120000 msiv\_s2 valve  
\*  
\*card from vol to vol jun area f loss r loss fvcahs  
4120101 400010000 420000000 3.227 4.10 4.5 001020  
\*-----  
\* junction flow area is representative of 1 msiv. see calculations  
\* in appendix c. kf and kr are assumed.  
\*-----  
\*  
\*card flag int liq flow int vap flow inter vel  
4120201 0 1.2594000e+02 1.2594000e+02 0.  
\*  
\*card valve type  
4120300 mtrvlv  
\*  
\*card open trip close trip vel change rate init pos table  
4120301 409 605 0.25 1. 545  
\* valve closes in 4 sec. -- initial position = 1.0; fully open  
\*  
\* table defined to give negligible form loss  
4120401 0. 1.e6 1.e6

```
4120402 1. 1.e6 1.e6
*
*-----
* (420) main steam header to turbine -- 4 line
*-----
*      name      type
4200000  turbine      pipe
*
*card  number of vols
4200001    3
*
*card  vol area   vol number
4200101    0.0      3
*
*card  init jun flow area  jun number
4200201    10.875    2
*
*card  pipe vol length  vol number
4200301    58.271    1
4200302    35.670    2
4200303    12.000    3
*
*card  vol of vol    vol number
4200401    633.529    1
4200402    387.911    2
4200403    130.494    3
*
*card  az angle     vol number
4200501    0.0      3
*
*card  incl. angle  vol number
4200601    0.0      1
4200602    90.00     3
*
*card  elev change  vol number
4200701    0.0      1
4200702    35.670    2
4200703    12.000    3
*
*card  roughness   hyd dia  vol number
4200801    5.0e-6    7.442    3
*-----
```

\* see calculations in appendix c for vol length, vol, elev change  
\* and hyd dia.

```
*-----
*card kf kr jun number
4200901 2.500 2.500 1
4200902 0.000 1.710 2
*-----
* kf and kr values were used that would maintain the pressure in
* volume 420-03 equal to 970 psi.
*-----
*card pvbfe vol number
4201001 11000 3
*card fvcahs jun number
4201101 001020 2
*card ebt press ul ug alpha
4201201 0 9.9373999e+02 5.3834998e+02 1.1090000e+03 9.9984998e-01 .0 1
4201202 0 9.7894000e+02 5.3546997e+02 1.1101000e+03 9.9967003e-01 .0 2
4201203 0 9.7832001e+02 5.3535999e+02 1.1103000e+03 9.9963999e-01 .0 3
*
*card pipe vol control word
4201300 0
*card init liq flow init vap flow inter vel jun number
4201301 1.5260001e+02 1.5260001e+02 0. 1
4201302 1.5496001e+02 1.5496001e+02 0. 2
*
*
*-----
*(430) turbine control and stop valve
*-----
*card name type
4300000 tcs-valv tmdpjun
*card from to area
4300101 420010000 450000000 10.875
*
* area set equal to area of volume 420-03.
*-----
*card vel/flow table trip # var req num var req
4300200 0 408 cntrlvar 538
*card search var init liq vel init vap vel inter vel
4300201 -1. 152.99 152.99 0.
4300203 0. 0. 0. 0.
4300204 1.e+4 1.e+4 1.e+4 0.
*
*-----
*(440) turbine bypass valve
*-----
```

```
4400000 bypsvlv tmdpjun
4400101 420010000 451000000 0.
4400200 0 408 cntrlvar 552
*
4400201 -1. 0. 0. 0.
4400202 0. 0. 0. 0.
4400203 1.e+4 1.e+4 1.e+4 0.
*
*-----
* (450) main condenser (steam exhaust)
*-----
*card name type
4500000 condns1a tmdpvol
*card vol flow area length vol of vol az angle
4500101 1.0+6      0.0    1.0+6    0.0
*card incl angle elev change roughness hyd dia pvbfe
4500102  0.0       0.0     0.0     0.0   00010
*
*-----  
* vol flow area, vol, elev change, hyd dia are assumed.
*-----
*card ebt trip #
4500200 003      401
*card search var press temp
4500201 0.0      916.0  544.
*
*-----  
* thermodynamic values are assumed.
*-----  
*-----  
*-----  
* (451) main condenser (steam exhaust)
*-----
*card name type
4510000 condns1b tmdpvol
*card vol flow area length vol of vol az angle
4510101 1.0+6      0.0    1.0+6    0.0
*card incl angle elev change roughness hyd dia pvbfe
4510102  0.0       0.0     0.0     0.0   00010
*
*-----  
* vol flow area, vol, elev change, hyd dia are assumed.
*-----
*card ebt trip #
4510200 003      408
*card search var press temp
```

4510201 0.0 14.7 212.

\*-----

\* thermodynamic values are for steam at atmospheric conditions.

\*-----

\*

\*-----

\* (460) suppression pool

\*-----

\*card name type

4600000 spool1a tmdpvol

\*card area length vol of vol az angle

4600101 1.0e+6 0.0 1.0e+6 0.0

\*card incl angle elev change roughness hyd dia pvbfe

4600102 0.0 0.0 0.0 0.0 00010

\*-----

\* vol flow area, vol, elev change, hyd dia are assumed.

\*-----

\*card ebt trip #

4600200 003 408

\*card search var. press temp

4600201 0.0 14.7 212.

\*-----

\* thermodynamic values are for steam at atmospheric conditions.

\*-----

\*

\*

\*-----

\* (461) suppression pool

\*-----

\*card name type

4610000 spool1b tmdpvol

\*card area length vol of vol az angle

4610101 1.0e+6 0.0 1.0e+6 0.0

\*card incl angle elev change roughness hyd dia pvbfe

4610102 0.0 0.0 0.0 0.0 00010

\*-----

\* vol flow area, vol, elev change, hyd dia are assumed.

\*-----

\*card ebt trip #

4610200 003 408

\*card search var. press temp

4610201 0.0 14.7 212.

\*-----

\* thermodynamic values are for steam at atmospheric conditions.

```
*-----  
*  
*-----  
* s/rv valves  
*-----  
*-----  
* (470) safety relief valve #1  
*-----  
4700000 srv1 valve  
4700101 400000000 460000000 0.4300 1.0 1.0 000100  
* valve area required to achieve correct mass flow through  
* each valve. valves max flow = 950,000 lb/hr each.  
* mass flow through bank #1 should be equal to 1056 lb/s.  
4700201 0 0. 0. 0.  
4700300 trpvlv  
4700301 656  
*-----  
*-----  
* (480) safety relief valve #2  
*-----  
4800000 srv2 valve  
4800101 400000000 461000000 0.9800 1.0 1.0 000100  
4800201 0 0. 0. 0.  
* valve area required to achieve correct mass flow through  
* each valve. valves max flow = 950,000 lb/hr each.  
* mass flow through bank #2 should be equal to 2375 lb/s.  
4800300 trpvlv  
4800301 661  
*-----  
*-----|  
* heat structures |  
*-----|  
*-----  
* (1) nuclear heat structures (core region)  
*-----  
*card num hs mesh pts geom type int flag left coord  
11201000 5 4 2 0 .00000e+00  
*  
*card loc flag format flag  
11201100 0 1  
*  
*card num intervals right coordinate
```

---

*RELAP5 Model INPUT DECK WITH NEW RECIRCULATION CONTROLS*

11201101 1 .01708 \* uo-2 pellet  
11201102 1 .01745 \* he-gap  
11201103 1 .020117 \* zircaloy-2 clad

\*

\* coordinates from ref. [349]

\*

\*card comp num interval num

11201201 1 1  
11201202 -2 2 \* neg sign added - kwr  
11201203 -3 3 \* neg sign added - kwr

\*

\*card source value interval num (ref [1] pg 18)

11201301 1.00 1  
11201302 0.00 3

\*

11201400 -1

11201401 1.8951e+03 1.1451e+03 6.1207e+02 5.6766e+02  
11201402 2.4940e+03 1.3402e+03 6.3223e+02 5.7362e+02  
11201403 2.5437e+03 1.3544e+03 6.3439e+02 5.7483e+02  
11201404 2.1243e+03 1.2240e+03 6.2057e+02 5.7044e+02  
11201405 1.3737e+03 9.4812e+02 5.9176e+02 5.6189e+02

\*

\*

\*

\*card temperature mesh pt num

\*

\* initial temperatures taken from the output of the steady state

\* calculation after 1000 seconds.

\*

\*

\*card left vol incr b.cond sa code area/factor hs

11201501 0 0 0 0 0.0 5

\*

\*card right vol incr b.cond sa code area/factor hs

11201601 120010000 10000 1 0 14974.10 5

\*

\* see calculations in appendix c for area/factor.

\*

\*card source type mult heat left heat right hs

11201701 1000 .1825 0.0 0.0 1  
11201702 1000 .2424 0.0 0.0 2  
11201703 1000 .2465 0.0 0.0 3  
11201704 1000 .2066 0.0 0.0 4  
11201705 1000 .1220 0.0 0.0 5

```
*-----
* see calculations in appendix c for axial mult.
*
* note -- 1000 in card 701-703 specifies total reactor power from
* the reactor kinetics calculation
*-----
*
*card    source type  mult   heat left  heat right hs
*11201701 10099    .1825   0.0     0.0     1
*11201702 10099    .2424   0.0     0.0     2
*11201703 10099    .2465   0.0     0.0     3
*11201704 10099    .2066   0.0     0.0     4
*11201705 10099    .1220   0.0     0.0     5
*
* card  eqv dia    length hlr gslf gslr glcf glcr lbf hs
11201801 0.0      10.0   10.0  0.0  0.0  0.0  0.0  1.0  5
11201901 0.0      10.0   10.0  0.0  0.0  0.0  0.0  1.0  5
*
*-----
* additional reactor vessel heat structures
* see calculations in appendix c
*-----
*
* (1001) vessel bottom head
*-----
*card    num hs  mesh pts  geom type  int flag  left coord
11001000 1  2  2  0  1.04583e+01
*
*card    loc flag  format flag
11001100 0      1
*
*card    num intervals  right coordinate
11001101    1      10.9948
*
*card    comp num  interval num
11001201    5      1
*
*card    source value  interval num
11001301    0.00    1
*
11001400 -1
11001401 5.2595e+02 5.2293e+02
*
```

```
*card left vol incr b.cond sa code area/factor hs
11001501 100010000 0 1 1 687.23 1
*
*card right vol incr b.cond sa code area/factor hs
11001601 -100 0 3101 1 687.23 1
*
*card source type
11001701 0 0 0 0 1
*
*card qv dia length hlr gslf gslr glcf glcr lbf hs
11001801 0.0 10.0 10.0 0.0 0.0 0.0 0.0 1.0 1
11001901 0.0 10.0 10.0 0.0 0.0 0.0 0.0 1.0 1
*
*
*-----
*(1401) lower downcomer
*-----
*card num hs mesh pts geom type int flag left coord
11401000 1 2 2 0 1.04583e+01
*
*card loc flag format flag
11401100 0 1
*
*card num intervals right coordinate
11401101 1 10.9948
*
*card comp num interval num
11401201 5 1
*
*card source value interval num
11401301 0.00 1
*
11401400 -1
11401401 5.2640e+02 5.2322e+02
*
*
*card left vol incr b.cond sa code area/factor hs
11401501 140010000 0 1 1 1401.625 1
*
*card right vol incr b.cond sa code area/factor hs
11401601 -100 0 3101 1 1401.625 1
*
*card source type
11401701 0 0 0 0 1
```

```
*  
* card eqv dia length hlr gslf gslr glcf glcr lbf hs  
11401801 0.0    10.0 10.0 0.0 0.0 0.0 0.0 1.0 1  
11401901 0.0    10.0 10.0 0.0 0.0 0.0 0.0 0.0 1.0 1  
*  
*-----  
*(1501) middle downcomer vessel barrel  
*-----  
*card num hs mesh pts geom type int flag left coord  
11501000 1 2 2 0 1.04583e+01  
*  
*card loc flag format flag  
11501100 0      1  
*  
*card num intervals right coordinate  
11501101     1      10.9948  
*  
*card comp num interval num  
11501201 5      1  
*  
*card source value interval num  
11501301 0.00    1  
*  
11501400 -1  
11501401 5.2655e+02 5.2330e+02  
*  
*  
*card left vol incr b.cond sa code area/factor hs  
11501501 150010000 0   1   1      837.098  1  
*  
*card right vol incr b.cond sa code area/factor hs  
11501601 -100    0   3101 1      837.098  1  
*  
*card source type  
11501701 0 0 0 0 1  
*  
* card eqv dia length hlr gslf gslr glcf glcr lbf hs  
11501801 0.0    10.0 10.0 0.0 0.0 0.0 0.0 1.0 1  
11501901 0.0    10.0 10.0 0.0 0.0 0.0 0.0 0.0 1.0 1  
*  
*-----  
*(1601) upper downcomer vessel barrel  
*-----  
*card num hs mesh pts geom type int flag left coord
```

```
11601000 1 2 2 0 1.04583e+01
*
*card loc flag format flag
11601100 0 1
*
*card num intervals right coordinate
11601101 1 10.9948
*
*card comp num interval num
11601201 5 1
*
*card source value interval num
11601301 0.00 1
*
11601400 -1
11601401 5.3686e+02 5.3481e+02
*
*
*card left vol incr b.cond sa code area/factor hs
11601501 160010000 0 1 1 405.242 1
*
*card right vol incr b.cond sa code area/factor hs
11601601 -100 0 3101 1 405.242 1
*
*card source type
11601701 0 0 0 0 1
*
* card eqv dia length hlr gslf gslr glcf glcr lbf hs
11601801 0.0 10.0 10.0 0.0 0.0 0.0 0.0 1.0 1
11601901 0.0 10.0 10.0 0.0 0.0 0.0 0.0 1.0 1
*
*-----
* (1901) steam dome
*-----
*card num hs mesh pts geom type int flag left coord
11901000 1 2 2 0 1.04583e+01
*
*card loc flag format flag
11901100 0 1
*
*card num intervals right coordinate
11901101 1 10.9948
*
*card comp num interval num
```

```
11901201      5      1
*
*card  source value  interval num
11901301    0.00      1
*
11901400 -1
11901401 5.4718e+02 5.4300e+02
*
*
*card  left vol incr b.cond sa code area/factor hs
11901501 190010000 0  1   1     687.230  1
*
*card  right vol incr b.cond sa code area/factor hs
11901601 -100    0  3101 1     687.230  1
*
*card  source type
11901701  0  0  0  0  1
*
* card  eqv dia  length hlr gslf gslr glcf glcr lbf hs
11901801 0.0    10.0 10.0 0.0 0.0 0.0 0.0 1.0 1
11901901 0.0    10.0 10.0 0.0 0.0 0.0 0.0 1.0 1
*
* temperature
*-----
20210000 temp
20210001 0. 135.
*-----
* from section 4.2.4.9 of the fsar (bfnp-7)
* outside air temperature
*-----
*
* heat transfer coefficient
*-----
20210100 htc-t
20210101 -1.0  5.3458e-5
20210102  0.0  5.3458e-5
20210103  1.0e6 5.3458e-5
*-----
* see calculations in app. c
* from section 4.2.4.9 of the fsar (bfnp-7)
*-----
*
*-----
* point kinetics
```

```
*-----
30000000      point      separabl
*
*          total    init.   delay/   f.p.   u238
*          power    react.   prompt   yield   yield
30000001      gamma    3293.e+6  0.    165.000  1.    1.
*-----
* above values are from ref. [349]
*-----
*
* scram
30000011 200
*
* rod insertion
30000012 10300 *jam steady-state
*
* density reactivity feedback
*   density reactivity
*   (lb/ft3) (dollars)
*30000501  0.    -6.
*30000502  47.2   0.
*-----
* see calculations in app. c
*-----
30000501  0.    -9.
30000502  47.2   0.
*30000501  0.    0.    *steady-state prb
*30000502  47.2   0.    *steady-state prb
* density feedback adjusted to give good power response to changes
* in core flow
*
* doppler reactivity feedback
*   temperature reactivity
*   (deg f)   (dollars)
30000601  500.  0.
*30000602  4172. -2.6321
30000602  4172. -1.6
*30000601  500.  0.        *steady-state prb
*30000602  4172. -0.0     *steady-state prb
*-----
* see calculations in app. c
*-----
* doppler feedback adjusted to give good power response to changes
* in core flow
```

\*

\* volume weighting factors

*30000701	120010000	0 .1583	0.
*30000702	120020000	0 .2795	0.
*30000703	120030000	0 .2887	0.
*30000704	120040000	0 .2028	0.
*30000705	120050000	0 .0707	0.
30000701	120020000	0 1.	0.

\*

\* heat structure weighting factors

*30000801	1201001	0 .1583	0.
*30000802	1201002	0 .2795	0.
*30000803	1201003	0 .2887	0.
*30000804	1201004	0 .2028	0.
*30000805	1201005	0 .0707	0.
30000801	1201002	0 1.	0.

\*

---

\* see calculations in appendix c for vol weighting factors and

\* heat structure weighting factors.

\*

---

\* weighting tied to the most dynamic hydro cell and fuel segment

\* to give good power response to changes in core flow

\*

\* reactor scram curve

\*

\*card table type trip no.

20220000	reac-t	649
----------	--------	-----

\*

\*card argument function

20220001	-1.0	0.
20220002	.270	0.
20220003	.620	-0.7859
20220004	.970	-1.3479
20220005	1.337	-2.2928
20220006	1.703	-4.0022
20220007	2.070	-6.7163
20220008	2.445	-10.7728
20220009	2.820	-17.0824
20220010	3.195	-24.6860
20220011	3.570	-28.4429
20220012	3.945	-28.9308
20220013	1.0e+6	-28.9308

\*

---

\* scram curve is from fig 3.6-13 of the fsar (bfnp-7).

## *RELAP5 Model INPUT DECK WITH NEW RECIRCULATION CONTROLS*

```

*
*
*
*
*
*-----*
*-----*
* heat structure thermal property data
*-----*
*-----*
* u0-2 fuel table (1)
*-----*
* card      material type    format flag    vol heat cap flag
20100100    tbl/fctn        1                  1
*
* thermal conductivity data
*-----*
*card      temp   thermal cond      temp   thermal cond
20100101  500.0  9.281e-4       650.0  8.253e-4
20100102  800.0  7.436e-4       950.0  6.775e-4
20100103 1100.0  6.228e-4      1250.0  5.772e-4
20100104 1400.0  5.389e-4      1550.0  5.064e-4
20100105 1700.0  4.789e-4      1850.0  4.553e-4
20100106 2000.0  4.272e-4      2150.0  4.186e-4
20100107 2300.0  4.047e-4      2450.0  3.931e-4
20100108 2600.0  3.839e-4      3100.0  3.675e-4
20100109 3600.0  3.703e-4      4100.0  3.906e-4
20100110 4600.0  4.272e-4      5100.0  4.806e-4
20100111 1.0e+6  4.806e-4
*
*-----*
* data from ref. [349]
*-----*
*
*volumetric heat capacity data
*-----*
*card      temp   vol heat cap      temp   vol heat cap
20100151  32.0   34.45          122.0  38.35
20100152  212.0  40.95         392.0  43.55
20100153  752.0  46.80         2012.0 51.35
20100154 2732.0  52.65         3092.0 56.55
20100155 3452.0  63.05         3812.0 72.80
20100156 4352.0  89.70         4532.0 94.25
20100157 4532.1  98.15         4892.0 100.10
20100158 5144.0 101.40         1.0e+6 101.40
*
```

```
* data from ref. [349]
*-----
*
*
*
* he-gap    table (2)
* -----
* card      material type   format flag    vol heat cap flag
20100200    tbl/fctn        1              1
*
* thermal conductivity data
* -----
*card      thermal cond
20100201    3.09410e-5
*
* data from ref. [349]
*-----
*
* volumetric heat capacity data
* -----
*card      vol heat cap
20100251    0.010
*
* data from ref. [349]
*-----
*
*
* zircaloy  table (3)
* -----
* card      material type   format flag    vol heat cap flag
20100300    tbl/fctn        1              1
*
* thermal conductivity data
* -----
*card      temp   thermal cond     temp   thermal cond
20100301    32.0   2.170e-3     212.0  2.220e-3
20100302    392.0  2.280e-3     572.0  2.440e-3
20100303    752.0  2.650e-3     932.0  2.889e-3
20100304   1112.0  3.119e-3    1292.0 3.469e-3
20100305   1472.0  3.661e-3    1652.0 3.881e-3
20100306   1832.0  4.111e-3    2012.0  4.481e-3
20100307   2192.0  4.939e-3    2372.0  5.461e-3
20100308   2552.0  6.050e-3    2732.0  6.681e-3
20100309   3092.0  8.031e-3    3360.0  9.200e-3
```

```
20100310  1.0e+6  9.200e-3
*-----
* data from ref. [349]
*-----
*
*volumetric heat capacity data
*-----
*card      temp    vol heat cap      temp    vol heat cap
20100351   0.0    28.39        1480.3   34.48
20100352  1675.0   85.18        1787.5   34.48
20100353  1.0e+6   34.48
*-----
* data from ref. [349]
*-----
*
* steel table (5)
* -----
* card      material type  format flag    vol heat cap flag
20100500    tbl/fctn       1                  1
*
* thermal conductivity data
* -----
*card      temp    thermal cond    temp    thermal cond
20100501   0.0    2.500e-3     200.0   2.500e-3
20100502  1600.0   4.167e-3    1.0e+6   4.167e-3
*-----
* data from ref. [349]
*-----
*
*volumetric heat capacity data
*-----
*card      temp    vol heat cap      temp    vol heat cap
20100551  200.0   60.00        2200.0   80.00
20100552  1.0e+6   80.00
*-----
* data from ref. [349]
*-----
*
*****
* table for normal valve area vs. stem position
*****
*
* the following table gives valve flow area vs stem position
```

\* valve area = ( stem position )\*\*3.

\*

20254500 normarea

20254501 .0 .0

20254502 .16675 .059

20254503 .3334 .089

20254504 .43339 .098

20254505 .5 .457

20254506 .583375 .667

20254507 .6666 .819

20254508 .79435 1.

20254509 1. 1.

\*

\*

\*-----

\* feedwater train

\*-----

\*

\* feedwater train hydro components

\*-----

\*

\*\*\* condensate supply (at the base of the condensers) \*\*\*

\* press. and temp. per refs. [368] and [188], respectively

\*

5000000 condensr tmdpvol

5000101 0. 100. 1.e6 0. 0. 0.

5000102 0. 0. 0.0010

5000200 003

5000201 0. 0.9824 101.1

\*

\*\*\* piping from condensers to condensate pumps \*\*\*

\* 3 36" dia. sch. 40 pipes 100' long are represented here. see app. d

\* for reasoning elev. change per ref. [285 & 368].

\*

5020000 cnd\_pmp branch

5020001 1 0

5020101 19.4754 100. 0. 0. -5.3 -9.20 0.00015 2.8750 01000

5020200 0 2.8822999e+00 6.9094002e+01 1.0562000e+03 0.

5021101 500000000 502000000 0. 0. 0. 001000

5021201 3.0864000e+00 3.0864000e+00 0.

\*

\*\*\* condensate pump (single) \*\*\*

\* geometry and performance from ref. [90] as per calculations of app. d.

\*

5050000 cndpmp\_s pump  
5050101 0. 50.2 277. 0. 0. 0. 0. 00000  
5050108 502010000 7.069 0. 0. 001000  
5050109 508000000 3.142 262. 1.e99 001000  
5050200 0 7.2176003e+01 6.9154999e+01 1.1005000e+03 0. 0.  
5050201 0 2.8364000e+00 2.8364000e+00 0.  
5050202 0 6.3801999e+00 6.3801999e+00 0.  
5050301 0 -1 -3 -1 0 460 0  
5050302 1.1700000e+03 1.0000000e+00 1.0830000e+04 2.8400000e+02  
\* need correct inertia  
5050303 3983. 1355. 62.4 0.  
5050304 0. 0. 0. 0.  
\* han  
5051100 1 1  
5051101 0. 1.276421  
5051102 0.05 1.270980  
5051103 0.1 1.262995  
5051104 0.15 1.253315  
5051105 0.2 1.242654  
5051106 0.25 1.231591  
5051107 0.3 1.220570  
5051108 0.35 1.209902  
5051109 0.4 1.199759  
5051110 0.45 1.190182  
5051111 0.5 1.181074  
5051112 0.55 1.172205  
5051113 0.6 1.163208  
5051114 0.65 1.153582  
5051115 0.7 1.142693  
5051116 0.75 1.129767  
5051117 0.8 1.113900  
5051118 0.85 1.094051  
5051119 0.9 1.069043  
5051120 0.95 1.037564  
5051121 1. 1.  
\* hvn  
5051200 1 2  
5051201 0.52 0. \*jam  
5051202 0.75 0.434464  
5051203 0.775 0.489052  
5051204 0.8 0.541027  
5051205 0.825 0.592472  
5051206 0.85 0.644935  
5051207 0.875 0.699426

5051208 0.9 0.756421

5051209 0.925 0.815858

5051210 0.95 0.877137

5051211 0.975 0.939126

5051212 1. 1.

\* had and hvd (incomplete but sufficient - only normal modes of pump

\* operation are of concern)

5051300 1 3 0. 1.276421

5051400 1 4 0. 1.276421

\* ban

5051500 2 1

5051501 0. 0.658983

5051502 0.05 0.657930

5051503 0.1 0.660392

5051504 0.15 0.666062

5051505 0.2 0.674639

5051506 0.25 0.685835

5051507 0.3 0.699368

5051508 0.35 0.714969

5051509 0.4 0.732377

5051510 0.45 0.751340

5051511 0.5 0.771615

5051512 0.55 0.792970

5051513 0.6 0.815183

5051514 0.65 0.838039

5051515 0.7 0.861334

5051516 0.75 0.884874

5051517 0.8 0.908474

5051518 0.85 0.931959

5051519 0.9 0.955161

5051520 0.95 0.977925

5051521 1. 1.

\* bvn

5051600 2 2

5051601 0.35 0. \* extrapolated value

5051602 0.75 0.617190

5051603 0.775 0.659431

5051604 0.8 0.697266

5051605 0.825 0.733179

5051606 0.85 0.768990

5051607 0.875 0.805856

5051608 0.9 0.844273

5051609 0.925 0.884074

5051610 0.95 0.924429

5051611 0.975 0.963845

5051612 1. 1.

\* bad and bvd (incomplete but sufficient - only normal modes of pump

\* operation are of concern)

5051700 2 3 0. 0.658983

5051800 2 4 0. 0.658983

\*

\* velocity table

5056100 506

5056101 0. 1170.

\*

\*\*\* condensate pump (double) \*\*\*

\* geometry and performance from ref. [90] as per calculations of app. d.

\*

5060000 cndpmp\_d pump

5060101 0. 50.2 554. 0. 0. 0. 00000

5060108 502010000 14.138 0. 0. 001000

5060109 508000000 6.284 262. 1.e99 001000

5060200 0 7.2193001e+01 6.9154999e+01 1.1005000e+03 0. 0.

5060201 0 2.8334000e+00 2.8334000e+00 0.

5060202 0 6.3734002e+00 6.3734002e+00 0.

5060301 505 -1 -3 -1 0 461 0

5060302 1.1700000e+03 1.0000000e+00 2.1660000e+04 2.8400000e+02

\* need correct inertia

5060303 7966. 2710. 62.4 0.

5060304 0. 0. 0. 0.

\*

\* velocity table

5066100 507

5066101 0. 1170.

\*

\*\*\* piping from condensate pumps to condensate booster pumps \*\*\*

\* 3 18" dia. sch. 40 pipes 100' long are represented here. see app. d

\* for explanation. elev. change per ref. [285 & 327].

\*

5080000 pmp\_pmp branch

5080001 0 0

5080101 4.6599 100. 0. 0. 3.3 5.75 0.00015 1.4063 01000

5080200 0 6.5344002e+01 6.9155998e+01 1.0992000e+03 0.

\*

\*\*\* condensate booster pump (single) \*\*\*

\* pump performance from "turbine cycle performance monitoring instruction

\* unit 2", 2-ti-266 rev. 0004 as per calculations of app. d.

\*

5100000 bstpmp\_s pump  
\* need true length/volume  
5100101 1.5533 0. 20. 0. 0. 0. 00000  
5100108 508010000 1.5533 0. 0. 001000  
5100109 515000000 1.5533 0. 1.e99 001000  
5100200 0 1.8571001e+02 6.9267998e+01 1.1128000e+03 0. 0.  
5100201 0 1.2955000e+01 1.2955000e+01 0.  
5100202 0 1.2951000e+01 1.2951000e+01 0.  
5100301 0 -1 -3 -1 0 465 0  
\* need true inertia  
5100302 1.7800000e+03 1.0000000e+00 1.0800000e+04 5.3500000e+02 4.8920000e+03  
5100303 9.0000000e+02 6.2099998e+01  
5100304 0. 0. 0. 0. 0.  
\* han  
5101100 1 1  
5101101 0. 1.192908  
5101102 0.05 1.186873  
5101103 0.1 1.181114  
5101104 0.15 1.175519  
5101105 0.2 1.169975  
5101106 0.25 1.164371  
5101107 0.3 1.158596  
5101108 0.35 1.152542  
5101109 0.4 1.146100  
5101110 0.45 1.139163  
5101111 0.5 1.131625  
5101112 0.55 1.123380  
5101113 0.6 1.114325  
5101114 0.65 1.104356  
5101115 0.7 1.093370  
5101116 0.75 1.081268  
5101117 0.8 1.067948  
5101118 0.85 1.053312  
5101119 0.9 1.037261  
5101120 0.95 1.019698  
5101121 1. 1.  
\* hvn  
5101200 1 2  
5101201 0.60 0. \*jam  
5101202 0.75 0.432022  
5101203 0.775 0.496009  
5101204 0.8 0.555960  
5101205 0.825 0.612788  
5101206 0.85 0.667405

5101207 0.875 0.720723

5101208 0.9 0.773656

5101209 0.925 0.827115

5101210 0.95 0.882014

5101211 0.975 0.939264

5101212 1. 1.

\* had and hvd (incomplete but sufficient - only normal modes of pump

\* operation are of concern)

5101300 1 3 0. 1.192908

5101400 1 4 0. 1.192908

\* ban

5101500 2 1

5101501 0. 0.557646

5101502 0.05 0.572111

5101503 0.1 0.586739

5101504 0.15 0.601668

5101505 0.2 0.617028

5101506 0.25 0.632941

5101507 0.3 0.649524

5101508 0.35 0.666885

5101509 0.4 0.685126

5101510 0.45 0.704341

5101511 0.5 0.724618

5101512 0.55 0.746038

5101513 0.6 0.768675

5101514 0.65 0.792593

5101515 0.7 0.817854

5101516 0.75 0.844509

5101517 0.8 0.872603

5101518 0.85 0.902176

5101519 0.9 0.933257

5101520 0.95 0.965871

5101521 1. 1.

\* bvn

5101600 2 2

5101601 0.05 0. \*jam

5101602 0.85 0.833692

5101603 0.875 0.858738

5101604 0.9 0.883908

5101605 0.925 0.909902

5101606 0.95 0.937417

5101607 0.975 0.967152

5101608 1. 1.

\* bad and bvd (incomplete but sufficient - only normal modes of pump

\* operation are of concern)

5101700 2 3 0. 0.557646

5101800 2 4 0. 0.557646

\*

\* velocity table

5106100 508

5106101 0. 1780.

\*

\*\*\* condensate booster pump (double) \*\*\*

\* pump performance from "turbine cycle performance monitoring instruction

\* unit 2", 2-ti-266 rev. 0004 as per calculations of app. d.

\*

5110000 bstmp\_d pump

\* need true length/volume

5110101 3.1066 0. 40. 0. 0. 0. 0.0000

5110108 508010000 3.1066 0. 0. 001000

5110109 515000000 3.1066 0. 1.e99 001000

5110200 0 1.8573000e+02 6.9268997e+01 1.1128000e+03 0. 0.

5110201 0 1.2868000e+01 1.2868000e+01 0.

5110202 0 1.2864000e+01 1.2864000e+01 0.

5110301 510 -1 -3 -1 0 466 0

\* need true inertia

5110302 1.7800000e+03 1.0000000e+00 2.1600000e+04 5.3500000e+02 9.7840000e+03

5110303 1.8000000e+03 6.2099998e+01

5110304 0. 0. 0. 0. 0.

\*

\* velocity table

5116100 509

5116101 0. 1780.

\*

\*\*\* piping from condensate booster pumps to drain coolers \*\*\*

\* 3 18" dia. sch. 40 pipes 100' long are represented here. see app. d

\* for explanation. elev. change per ref. [327].

\*

5150000 pmp\_dc branch

5150001 3 0

5150101 4.6599 100. 0. 0. 0.3 30. 0.00015 1.4063 01000

5150200 0 3.0087000e+02 6.9268997e+01 1.1172000e+03 0.

5151101 515010000 520000000 0. 0. 0. 0.001000

5152101 515010000 521000000 0. 0. 0. 0.001000

5153101 515010000 522000000 0. 0. 0. 0.001000

5151201 5.5050998e+00 5.5050998e+00 0.

5152201 5.5050998e+00 5.5050998e+00 0.

5153201 5.5050998e+00 5.5050998e+00 0.

\*

\*\*\* drain cooler A \*\*\*

\* geometry per vendor spec shts. included with app. d  
5200000 'drcool-A' snglvol  
5200101 3.65 92. 0. 0. 0.  
5200102 0. 5.e-6 0.0567 01000  
5200200 0 2.9114999e+02 9.8335999e+01 1.1170000e+03 0. 0.

\*

\*\*\* drain cooler B \*\*\*

\* geometry per vendor spec shts. included with app. d  
5210000 'drcool-B' snglvol  
5210101 3.65 92. 0. 0. 0.  
5210102 0. 5.e-6 0.0567 01000  
5210200 0 2.9114999e+02 9.8335999e+01 1.1170000e+03 0. 0.

\*

\*\*\* drain cooler C \*\*\*

\* geometry per vendor spec shts. included with app. d  
5220000 'drcool-C' snglvol  
5220101 3.65 92. 0. 0. 0.  
5220102 0. 5.e-6 0.0567 01000  
5220200 0 2.9114999e+02 9.8335999e+01 1.1170000e+03 0. 0.

\*

\*\*\* piping from drain cooler A to heater A5 \*\*\*

\* geometry per refs. [324, 326, 327, & 328]  
5250000 'DC-HTRA5' pipe  
5250001 1  
5250101 1.5533 1  
5250301 14. 1  
5250401 0. 1  
5250501 0. 1  
5250601 42.7 1  
5250701 9.5 1  
5250801 0.00015 1.4063 1  
5251001 01000 1  
5251201 0 2.8410001e+02 9.8336998e+01 1.1168000e+03 0. .0 1

\*

\*\*\* piping from drain cooler B to heater B5 \*\*\*

\* geometry per refs. [324, 326, 327, & 328]  
5260000 'DC-HTRB5' pipe  
5260001 1  
5260101 1.5533 1  
5260301 14. 1  
5260401 0. 1  
5260501 0. 1

5260601 42.7 1  
5260701 9.5 1  
5260801 0.00015 1.4063 1  
5261001 01000 1  
5261201 0 2.8410001e+02 9.8336998e+01 1.1168000e+03 0. .0 1  
\*  
\*\*\* piping from drain cooler C to heater C5 \*\*\*  
\* geometry per refs. [324, 326, 327, & 328]  
5270000 'DC-HTRC5' pipe  
5270001 1  
5270101 1.5533 1  
5270301 14. 1  
5270401 0. 1  
5270501 0. 1  
5270601 42.7 1  
5270701 9.5 1  
5270801 0.00015 1.4063 1  
5271001 01000 1  
5271201 0 2.8410001e+02 9.8336998e+01 1.1168000e+03 0. .0 1  
\*  
\*  
\* component 530 - RFW Heater A5 Tubes  
5300000 'HTRA5-p' pipe  
\*  
\* nv  
5300001 8  
\*  
\* varea vn  
5300101 3.0778 8 \*1832 tubes, 5/8" OD, .035" wall, 20BWG  
\*  
\* jarea jn  
5300201 3.0778 7  
\*  
\* vlength vn  
5300301 9.7917 8 \* total tube length = (2)(39' 2")  
\*  
\* volume vn  
5300401 0.0 8  
\*  
\* incl vn  
5300601 0.0 8  
\*  
\* roughness dhyd vn  
5300801 1.5e-4 0.0462 8

\*

\* kf kr jn  
5300901 0.0 0.0 7

\*

\* pvbfe vn  
5301001 00000 8

\*

\* fvcahs jn  
5301101 001000 7

\*

\* ebt press. temp. vn  
5301201 3 281.31 147.046 0. 0. 0. 1  
5301202 3 279.96 160.125 0. 0. 0. 2  
5301203 3 278.61 169.237 0. 0. 0. 3  
5301204 3 277.26 174.520 0. 0. 0. 4  
5301205 3 275.92 180.835 0. 0. 0. 5  
5301206 3 274.57 184.710 0. 0. 0. 6  
5301207 3 273.22 186.605 0. 0. 0. 7  
5301208 3 271.87 187.884 0. 0. 0. 8

\*

\* vel/flow  
5301300 0

\*

\* liq-flo vap-flo int jn  
5301301 6.5111 6.5111 0. 1  
5301302 6.5184 6.5184 0. 2  
5301303 6.5268 6.5268 0. 3  
5301304 6.5343 6.5343 0. 4  
5301305 6.5723 6.5723 0. 5  
5301306 6.5960 6.5960 0. 6  
5301307 6.6071 6.6071 0. 7

\*

\*

\* component 531 - RFW Heater B5 Tubes  
5310000 'HTRB5-p' pipe

\*

\* nv  
5310001 8

\*

\* varea vn  
5310101 3.0778 8 \*1832 tubes, 5/8" OD, .035" wall, 20BWG

\*

\* jarea jn  
5310201 3.0778 7

---

```

*
*      vlength      vn
5310301 9.7917      8      * total tube length = (2)(39' 2")
*
*      volume       vn
5310401 0.0        8
*
*      incl         vn
5310601 0.0        8
*
*      roughness    dhyd  vn
5310801 1.5e-4     0.0462 8
*
*      kf   kr   jn
5310901 0.0   0.0   7
*
*      pvbfe      vn
5311001 00000      8
*
*      fvcahs     jn
5311101 001000     7
*
*      ebt  press. temp.          vn
5311201 3   281.31 147.046 0.  0.  0.  1
5311202 3   279.96 160.125 0.  0.  0.  2
5311203 3   278.61 169.237 0.  0.  0.  3
5311204 3   277.26 174.520 0.  0.  0.  4
5311205 3   275.92 180.835 0.  0.  0.  5
5311206 3   274.57 184.710 0.  0.  0.  6
5311207 3   273.22 186.605 0.  0.  0.  7
5311208 3   271.87 187.884 0.  0.  0.  8
*
*      vel/flow
5311300 0
*
*      liq-flo    vap-flo    int  jn
5311301 6.5111    6.5111    0.   1
5311302 6.5184    6.5184    0.   2
5311303 6.5268    6.5268    0.   3
5311304 6.5343    6.5343    0.   4
5311305 6.5723    6.5723    0.   5
5311306 6.5960    6.5960    0.   6
5311307 6.6071    6.6071    0.   7
*
```

\*

\* component 532 - RFW Heater C5 Tubes  
5320000 'HTRC5-p' pipe

\*

\* nv  
5320001 8

\*

\* varea vn  
5320101 3.0778 8 \*1832 tubes, 5/8" OD, .035" wall, 20BWG

\*

\* jarea jn  
5320201 3.0778 7

\*

\* vlength vn  
5320301 9.7917 8 \* total tube length = (2)(39' 2")

\*

\* volume vn  
5320401 0.0 8

\*

\* incl vn  
5320601 0.0 8

\*

\* roughness dhyd vn  
5320801 1.5e-4 0.0462 8

\*

\* kf kr jn  
5320901 0.0 0.0 7

\*

\* pvbfe vn  
5321001 00000 8

\*

\* fvcahs jn  
5321101 001000 7

\*

\* ebt press. temp. vn  
5321201 3 281.31 147.046 0. 0. 0. 1  
5321202 3 279.96 160.125 0. 0. 0. 2  
5321203 3 278.61 169.237 0. 0. 0. 3  
5321204 3 277.26 174.520 0. 0. 0. 4  
5321205 3 275.92 180.835 0. 0. 0. 5  
5321206 3 274.57 184.710 0. 0. 0. 6  
5321207 3 273.22 186.605 0. 0. 0. 7  
5321208 3 271.87 187.884 0. 0. 0. 8

\*

```
*      vel/flow
5321300 0
*
*      liq-flo      vap-flo      int   jn
5321301 6.5111    6.5111      0.    1
5321302 6.5184    6.5184      0.    2
5321303 6.5268    6.5268      0.    3
5321304 6.5343    6.5343      0.    4
5321305 6.5723    6.5723      0.    5
5321306 6.5960    6.5960      0.    6
5321307 6.6071    6.6071      0.    7
*
*** piping from heater A5 to heater A4 ***
* geometry per refs. [324, 326, 327, & 328]
5350000 'htrA5_4'    pipe
5350001 1
5350101 1.5533 1
5350301 21. 1
5350401 0. 1
5350501 0. 1
5350601 0. 1
5350701 0. 1
5350801 0.00015 1.4063 1
5351001 01000 1
5351201 0 2.7210001e+02 1.5058000e+02 1.1165000e+03 0. .0 1
*
*** piping from heater B5 to heater B4 ***
* geometry per refs. [324, 326, 327, & 328]
5360000 'htrB5_4'    pipe
5360001 1
5360101 1.5533 1
5360301 21. 1
5360401 0. 1
5360501 0. 1
5360601 0. 1
5360701 0. 1
5360801 0.00015 1.4063 1
5361001 01000 1
5361201 0 2.7210001e+02 1.5058000e+02 1.1165000e+03 0. .0 1
*
*** piping from heater C5 to heater C4 ***
* geometry per refs. [324, 326, 327, & 328]
5370000 'htrC5_4'    pipe
5370001 1
```

---

*RELAP5 Model INPUT DECK WITH NEW RECIRCULATION CONTROLS*

5370101 1.5533 1  
5370301 21. 1  
5370401 0. 1  
5370501 0. 1  
5370601 0. 1  
5370701 0. 1  
5370801 0.00015 1.4063 1  
5371001 01000 1  
5371201 0 2.7210001e+02 1.5058000e+02 1.1165000e+03 0. .0 1  
\*  
\*  
\* component 540 - RFW Heater A4 Tubes  
\*  
5400000 'HTRA4-p' pipe  
\*  
\* nv  
5400001 10  
\*  
\* varea vn  
5400101 2.9736 10 \*1770 tubes, 5/8" OD, .035" wall, 20BWG  
\*  
\* jarea jn  
5400201 2.9736 9  
\*  
\* vlength vn  
5400301 7.8333 10 \* total tube length = (2)(39' 2")  
\*  
\* volume vn  
5400401 0.0 10  
\*  
\* incl vn  
5400601 0.0 10  
\*  
\* roughness dhyd vn  
5400801 1.5e-4 0.0462 10  
\*  
\* kf kr jn  
5400901 0.0 0.0 9  
\*  
\* pvbfe vn  
5401001 00000 10  
\*  
\* fvcahs jn  
5401101 001000 9

\*  
\* ebt press. temp. vn  
5401201 3 273.96 189.940 0. 0. 0. 1  
5401202 3 272.49 195.815 0. 0. 0. 2  
5401203 3 271.03 212.726 0. 0. 0. 3  
5401204 3 269.56 224.282 0. 0. 0. 4  
5401205 3 268.09 231.955 0. 0. 0. 5  
5401206 3 266.61 237.355 0. 0. 0. 6  
5401207 3 265.13 240.458 0. 0. 0. 7  
5401208 3 263.66 242.113 0. 0. 0. 8  
5401209 3 262.18 242.934 0. 0. 0. 9  
5401210 3 260.70 243.473 0. 0. 0. 10  
\*  
\* vel/flow  
5401300 1  
\*  
\* liq-flo vap-flo int jn  
5401301 1232.9 0.0 0. 9  
\*  
\*  
\* component 541 - RFW Heater B4 Tubes  
\*  
5410000 'HTRB4-p' pipe  
\*  
\* nv  
5410001 10  
\*  
\* varea vn  
5410101 2.9736 10 \*1770 tubes, 5/8" OD, .035" wall, 20BWG  
\*  
\* jarea jn  
5410201 2.9736 9  
\*  
\* vlength vn  
5410301 7.8333 10 \* total tube length = (2)(39' 2")  
\*  
\* volume vn  
5410401 0.0 10  
\*  
\* incl vn  
5410601 0.0 10  
\*  
\* roughness dhyd vn  
5410801 1.5e-4 0.0462 10

---

*RELAP5 Model INPUT DECK WITH NEW RECIRCULATION CONTROLS*

\*  
\* kf kr jn  
5410901 0.0 0.0 9  
\*  
\* pvbfe vn  
5411001 00000 10  
\*  
\* fvcahs jn  
5411101 001000 9  
\*  
\* ebt press. temp. vn  
5411201 3 273.96 189.940 0. 0. 0. 1  
5411202 3 272.49 195.815 0. 0. 0. 2  
5411203 3 271.03 212.726 0. 0. 0. 3  
5411204 3 269.56 224.282 0. 0. 0. 4  
5411205 3 268.09 231.955 0. 0. 0. 5  
5411206 3 266.61 237.355 0. 0. 0. 6  
5411207 3 265.13 240.458 0. 0. 0. 7  
5411208 3 263.66 242.113 0. 0. 0. 8  
5411209 3 262.18 242.934 0. 0. 0. 9  
5411210 3 260.70 243.473 0. 0. 0. 10  
\*  
\* vel/flow  
5411300 1  
\*  
\* liq-flo vap-flo int jn  
5411301 1232.9 0.0 0. 9  
\*  
\*  
\* component 542 - RFW Heater C4 Tubes  
\*  
5420000 'HTRC4-p' pipe  
\*  
\* nv  
5420001 10  
\*  
\* varea vn  
5420101 2.9736 10 \*1770 tubes, 5/8" OD, .035" wall, 20BWG  
\*  
\* jarea jn  
5420201 2.9736 9  
\*  
\* vlength vn  
5420301 7.8333 10 \* total tube length = (2)(39' 2")

\*  
\* volume vn  
5420401 0.0 10  
\*  
\* incl vn  
5420601 0.0 10  
\*  
\* roughness dhyd vn  
5420801 1.5e-4 0.0462 10  
\*  
\* kf kr jn  
5420901 0.0 0.0 9  
\*  
\* pvbfe vn  
5421001 00000 10  
\*  
\* fvcahs jn  
5421101 001000 9  
\*  
\* ebt press. temp. vn  
5421201 3 273.96 189.940 0. 0. 0. 1  
5421202 3 272.49 195.815 0. 0. 0. 2  
5421203 3 271.03 212.726 0. 0. 0. 3  
5421204 3 269.56 224.282 0. 0. 0. 4  
5421205 3 268.09 231.955 0. 0. 0. 5  
5421206 3 266.61 237.355 0. 0. 0. 6  
5421207 3 265.13 240.458 0. 0. 0. 7  
5421208 3 263.66 242.113 0. 0. 0. 8  
5421209 3 262.18 242.934 0. 0. 0. 9  
5421210 3 260.70 243.473 0. 0. 0. 10  
\*  
\* vel/flow  
5421300 1  
\*  
\* liq-flo vap-flo int jn  
5421301 1232.9 0.0 0. 9  
\*  
\*  
\*\*\* piping from heater A4 to heater A3 \*\*\*  
\* geometry per refs. [324, 326, 327, & 328]  
5450000 'htrA4\_3' pipe  
5450001 1  
5450101 1.5533 1  
5450301 116. 1

5450401 0. 1  
5450501 0. 1  
5450601 -3.6 1  
5450701 -7.25 1  
5450801 0.00015 1.4063 1  
5451001 01000 1  
5451201 0 2.6126001e+02 2.0678999e+02 1.1162000e+03 0. .0 1  
\*  
\*\*\* piping from heater B4 to heater B3 \*\*\*  
\* geometry per refs. [324, 326, 327, & 328]  
5460000 'htrB4\_3' pipe  
5460001 1  
5460101 1.5533 1  
5460301 116. 1  
5460401 0. 1  
5460501 0. 1  
5460601 -3.6 1  
5460701 -7.25 1  
5460801 0.00015 1.4063 1  
5461001 01000 1  
5461201 0 2.6126001e+02 2.0678999e+02 1.1162000e+03 0. .0 1  
\*  
\*\*\* piping from heater C4 to heater C3 \*\*\*  
\* geometry per refs. [324, 326, 327, & 328]  
5470000 'htrC4\_3' pipe  
5470001 1  
5470101 1.5533 1  
5470301 116. 1  
5470401 0. 1  
5470501 0. 1  
5470601 -3.6 1  
5470701 -7.25 1  
5470801 0.00015 1.4063 1  
5471001 01000 1  
5471201 0 2.6126001e+02 2.0678999e+02 1.1162000e+03 0. .0 1  
\*  
\*  
\* component 550 - RFW Heater A3 Tubes  
5500000 'HTRA3-p' pipe  
\*  
\* nv  
5500001 12  
\*  
\* varea vn

5500101 3.1315 12 \*1864 tubes, 5/8" OD, .035" wall, 20BWG  
\*  
\* jarea jn  
5500201 3.1315 11  
\*  
\* vlength vn  
5500301 7.0534 1 \*  
5500302 7.0534 2 \*  
5500303 3.0000 3 \*volume center = lower level tap  
5500304 3.0000 4 \*volume center = upper level tap  
5500305 11.1133 5 \*remaining 35.5' total tube length  
5500306 11.1133 6 \*remaining 35.5' total tube length  
5500307 11.1133 7 \*remaining 35.5' total tube length  
5500308 11.1133 8 \*remaining 35.5' total tube length  
5500309 3.0000 9 \*volume center = lower level tap  
5500310 3.0000 10 \*volume center = upper level tap  
5500311 7.0534 11 \*  
5500312 7.0534 12 \*  
\*  
\* volume vn  
5500401 0.0 12  
\*  
\* incl vn  
5500601 90.0 6  
5500602 -90.0 12  
\*  
\* roughness dhyd vn  
5500801 1.5e-4 0.0462 12  
\*  
\* kf kr jn  
5500901 0.0 0.0 11  
\*  
\* pvbfe vn  
5501001 00000 12  
\*  
\* fvcahs jn  
5501101 001000 11  
\*  
\* ebt press. temp. vn  
5501201 3 259.34 244.415 0. 0. 0. 1  
5501202 3 255.25 246.066 0. 0. 0. 2  
5501203 3 252.33 247.155 0. 0. 0. 3  
5501204 3 250.59 254.653 0. 0. 0. 4  
5501205 3 246.53 272.296 0. 0. 0. 5

---

*RELAP5 Model INPUT DECK WITH NEW RECIRCULATION CONTROLS*

5501206 3 240.14 283.712 0. 0. 0. 6  
5501207 3 238.21 291.042 0. 0. 0. 7  
5501208 3 240.73 295.669 0. 0. 0. 8  
5501209 3 242.32 296.721 0. 0. 0. 9  
5501210 3 242.99 297.405 0. 0. 0. 10  
5501211 3 244.12 297.600 0. 0. 0. 11  
5501212 3 245.70 297.363 0. 0. 0. 12  
\*  
\* vel/flow  
5501300 1  
\*  
\* liq-flo vap-flo int jn  
5501301 1232.9 0.0 0. 11  
\*  
\*  
\* component 551 - RFW Heater B3 Tubes  
5510000 'HTRB3-p' pipe  
\*  
\* nv  
5510001 12  
\*  
\* varea vn  
5510101 3.1315 12 \*1864 tubes, 5/8" OD, .035" wall, 20BWG  
\*  
\* jarea jn  
5510201 3.1315 11  
\*  
\* vlength vn  
5510301 7.0534 1 \*  
5510302 7.0534 2 \*  
5510303 3.0000 3 \*volume center = lower level tap  
5510304 3.0000 4 \*volume center = upper level tap  
5510305 11.1133 5 \*remaining 35.5' total tube length  
5510306 11.1133 6 \*remaining 35.5' total tube length  
5510307 11.1133 7 \*remaining 35.5' total tube length  
5510308 11.1133 8 \*remaining 35.5' total tube length  
5510309 3.0000 9 \*volume center = lower level tap  
5510310 3.0000 10 \*volume center = upper level tap  
5510311 7.0534 11 \*  
5510312 7.0534 12 \*  
\*  
\* volume vn  
5510401 0.0 12  
\*

```
*      incl      vn
5510601 90.0      6
5510602 -90.0     12
*
*      roughness   dhyd  vn
5510801 1.5e-4    0.0462 12
*
*      kf  kr  jn
5510901 0.0  0.0  11
*
*      pvbfe      vn
5511001 00000     12
*
*      fvcahs      jn
5511101 001000    11
*
*      ebt press. temp.          vn
5511201 3  259.34 244.415 0.  0.  0.  1
5511202 3  255.25 246.066 0.  0.  0.  2
5511203 3  252.33 247.155 0.  0.  0.  3
5511204 3  250.59 254.653 0.  0.  0.  4
5511205 3  246.53 272.296 0.  0.  0.  5
5511206 3  240.14 283.712 0.  0.  0.  6
5511207 3  238.21 291.042 0.  0.  0.  7
5511208 3  240.73 295.669 0.  0.  0.  8
5511209 3  242.32 296.721 0.  0.  0.  9
5511210 3  242.99 297.405 0.  0.  0.  10
5511211 3  244.12 297.600 0.  0.  0.  11
5511212 3  245.70 297.363 0.  0.  0.  12
*
*      vel/flow
5511300 1
*
*      liq-flo    vap-flo    int   jn
5511301 1232.9    0.0      0.  11
*
*
* component 552 - RFW Heater C3 Tubes
5520000 'HTRC3-p'  pipe
*
*      nv
5520001 12
*
*      varea      vn
```

5520101 3.1315 12 \*1864 tubes, 5/8" OD, .035" wall, 20BWG  
\*  
\* jarea jn  
5520201 3.1315 11  
\*  
\* vlength vn  
5520301 7.0534 1 \*  
5520302 7.0534 2 \*  
5520303 3.0000 3 \*volume center = lower level tap  
5520304 3.0000 4 \*volume center = upper level tap  
5520305 11.1133 5 \*remaining 35.5' total tube length  
5520306 11.1133 6 \*remaining 35.5' total tube length  
5520307 11.1133 7 \*remaining 35.5' total tube length  
5520308 11.1133 8 \*remaining 35.5' total tube length  
5520309 3.0000 9 \*volume center = lower level tap  
5520310 3.0000 10 \*volume center = upper level tap  
5520311 7.0534 11 \*  
5520312 7.0534 12 \*  
\*  
\* volume vn  
5520401 0.0 12  
\*  
\* incl vn  
5520601 90.0 6  
5520602 -90.0 12  
\*  
\* roughness dhyd vn  
5520801 1.5e-4 0.0462 12  
\*  
\* kf kr jn  
5520901 0.0 0.0 11  
\*  
\* pvbfe vn  
5521001 00000 12  
\*  
\* fvcahs jn  
5521101 001000 11  
\*  
\* ebt press. temp. vn  
5521201 3 259.34 244.415 0. 0. 0. 1  
5521202 3 255.25 246.066 0. 0. 0. 2  
5521203 3 252.33 247.155 0. 0. 0. 3  
5521204 3 250.59 254.653 0. 0. 0. 4  
5521205 3 246.53 272.296 0. 0. 0. 5

5521206 3 240.14 283.712 0. 0. 0. 6  
5521207 3 238.21 291.042 0. 0. 0. 7  
5521208 3 240.73 295.669 0. 0. 0. 8  
5521209 3 242.32 296.721 0. 0. 0. 9  
5521210 3 242.99 297.405 0. 0. 0. 10  
5521211 3 244.12 297.600 0. 0. 0. 11  
5521212 3 245.70 297.363 0. 0. 0. 12  
\*  
\* vel/flow  
5521300 1  
\*  
\* liq-flo vap-flo int jn  
5521301 1232.9 0.0 0. 11  
\*  
\*  
\*\*\* piping from heaters 3 to feed pumps \*\*\*  
\* geometry per refs. [216, 324, 326, 327, 328]  
5550000 htr3\_pmp branch  
5550001 4 0  
5550101 4.6599 12. 0. 0. 0. 0. 0.00015 1.4063 01000  
5550200 0 2.5089999e+02 2.6672000e+02 1.1158000e+03 0.  
5551101 550010000 555000000 0. 0. 0. 0. 001000  
5552101 551010000 555000000 0. 0. 0. 0. 001000  
5553101 552010000 555000000 0. 0. 0. 0. 001000  
5554101 555010000 557000000 0.3491 7.301 7.417 001000  
5551201 6.9323001e+00 6.9323001e+00 0.  
5552201 6.9323001e+00 6.9323001e+00 0.  
5553201 6.9323001e+00 6.9323001e+00 0.  
5554201 6.0248899e-06 6.0249299e-06 0.  
\*  
\* feedwater bypass valve inlet  
5570000 bypinlet snglvol  
5570101 0.3491 40. 0. 0. 20.55 14.04 .00015 0. 01000  
5570200 0 2.4930000e+02 2.6673999e+02 1.1158000e+03 0. 0.  
\*  
\* feedwater bypass valve  
5580000 bypvalve valve  
5580101 557010000 559000000 0.3491 4.76 9.99e+99 000100  
5580201 0 0. 0. 0.  
5580300 srvvlv  
5580301 611  
\*  
\* feedwater bypass valve outlet  
5590000 bypotlet snglvol

5590101 0.3491 40. 0. 0. 20.55 14.04 .00015 0. 01000  
5590200 0 1.0997000e+03 2.6729001e+02 1.1074000e+03 0. 0.  
\*

\*\*\* feed pump (a) inlet volume

5600000 apmpin branch

5600001 1 0  
5600101 1.5533 67. 0. 0. 24.78 28.08 0.00015 1.4063 01000  
5600200 0 2.4492000e+02 2.6673001e+02 1.1156000e+03 0.  
5601101 555010000 560000000 1.5533 0. 0. 001000  
5601201 1.3924000e+01 1.3924000e+01 0.

\*

\*\*\* feed pump (b) inlet volume

5610000 bpmpin branch

5610001 1 0  
5610101 1.5533 67. 0. 0. 24.78 28.08 0.00015 1.4063 01000  
5610200 0 2.4492000e+02 2.6673001e+02 1.1156000e+03 0.  
5611101 555010000 561000000 1.5533 0. 0. 001000  
5611201 1.3923000e+01 1.3923000e+01 0.

\*

\*\*\* feed pump (c) inlet volume

5620000 cpmpin branch

5620001 1 0  
5620101 1.5533 67. 0. 0. 24.78 28.08 0.00015 1.4063 01000  
5620200 0 2.4492000e+02 2.6673001e+02 1.1156000e+03 0.  
5621101 555010000 562000000 1.5533 0. 0. 001000  
5621201 1.3923000e+01 1.3923000e+01 0.

\*

\*\*\* reactor feed pump (a) \*\*\*

\* performance from ref. [bfm-vtd-p025-0050] as per calcs. of app. d.

5700000 fdpmp\_a pump

\* need true volume

5700101 1.5533 0. 30. 0. 0. 0. 00000  
5700108 560010000 1.5533 0. 0. 001000  
5700109 575000000 1.5533 4. 0. 001000  
5700200 0 6.7017999e+02 2.6726001e+02 1.1173000e+03 0. 0.  
5700201 0 1.3924000e+01 1.3924000e+01 0.  
5700202 0 1.3907000e+01 1.3907000e+01 0.  
5700301 0 -1 -3 -1 0 408 0  
5700302 5.5000000e+03 8.7630910e-01 1.1200000e+04 2.8000000e+03  
5700303 8279. 4239. 57.2 0.

5700304 0. 0. 0. 0.

\* han

5701100 1 1

5701101 0. 1.197067

5701102 0.05 1.184067  
5701103 0.1 1.173948  
5701104 0.15 1.166099  
5701105 0.2 1.159951  
5701106 0.25 1.154979  
5701107 0.3 1.150703  
5701108 0.35 1.146687  
5701109 0.4 1.142538  
5701110 0.45 1.137910  
5701111 0.5 1.132499  
5701112 0.55 1.126046  
5701113 0.6 1.118334  
5701114 0.65 1.109195  
5701115 0.7 1.098501  
5701116 0.75 1.086169  
5701117 0.8 1.072161  
5701118 0.85 1.056483  
5701119 0.9 1.039186  
5701120 0.95 1.020363  
5701121 1. 1.

\* hvn

5701200 1 2

5701201 0.618 0. \* extrapolated value

5701202 0.725 0.384958  
5701203 0.75 0.447154  
5701204 0.775 0.504118  
5701205 0.8 0.557846  
5701206 0.825 0.609998  
5701207 0.85 0.661900  
5701208 0.875 0.714540  
5701209 0.9 0.768575  
5701210 0.925 0.824324  
5701211 0.95 0.881772  
5701212 0.975 0.940568  
5701213 1. 1.

\* had and hvd (incomplete but sufficient - only normal modes of pump

\* operation are of concern)

5701300 1 3 0. 1.197067

5701400 1 4 0. 0.7 \* jam

\* ban

5701500 2 1

5701501 0. 0.482838

5701502 0.05 0.500041

5701503 0.1 0.520557

5701504 0.15 0.543522  
5701505 0.2 0.568180  
5701506 0.25 0.593886  
5701507 0.3 0.620100  
5701508 0.35 0.646396  
5701509 0.4 0.672452  
5701510 0.45 0.698057  
5701511 0.5 0.723108  
5701512 0.55 0.747612  
5701513 0.6 0.771684  
5701514 0.65 0.795547  
5701515 0.7 0.819534  
5701516 0.75 0.844086  
5701517 0.8 0.869753  
5701518 0.85 0.897194  
5701519 0.9 0.927177  
5701520 0.95 0.960578  
5701521 1. 1.

\* bvn

5701600 2 2  
5701601 0.27 0. \*jam  
5701602 0.725 0.579497  
5701603 0.75 0.613313  
5701604 0.775 0.646402  
5701605 0.8 0.679301  
5701606 0.825 0.712545  
5701607 0.85 0.746670  
5701608 0.875 0.782212  
5701609 0.9 0.819708  
5701610 0.925 0.859692  
5701611 0.95 0.902700  
5701612 0.975 0.949269  
5701613 1. 1.

\* bad and bvd (incomplete but sufficient - only normal modes of pump

\* operation are of concern)

5701700 2 3 0. 0.482838

5701800 2 4 0. 0.8 \* jam

\*

\* velocity table

5706100 408 cntrlvar 756

5706101 0. 0. 10000. 10000.

\*

\*\*\* reactor feed pump (b) \*\*\*

\* performance from ref. [bfm-vtd-p025-0050] as per calcs. of app. d.

5710000 fdpmp\_b pump  
\* need true volume  
5710101 1.5533 0. 30. 0. 0. 0. 00000  
5710108 561010000 1.5533 0. 0. 001000  
5710109 576000000 1.5533 4. 0. 001000  
5710200 0 6.7017999e+02 2.6726001e+02 1.1173000e+03 0. 0.  
5710201 0 1.3923000e+01 1.3923000e+01 0.  
5710202 0 1.3906000e+01 1.3906000e+01 0.  
5710301 570 -1 -3 -1 0 408 0  
5710302 5.5000000e+03 8.7630910e-01 1.1200000e+04 2.8000000e+03  
5710303 8279. 4239. 57.2 0.  
5710304 0. 0. 0. 0.  
\*  
\* velocity table  
5716100 408 cntrlvar 757  
5716101 0. 0. 10000. 10000.  
\*  
\*\*\* reactor feed pump (c) \*\*\*  
\* performance from ref. [bfm-vtd-p025-0050] as per calcs. of app. d.  
5720000 fdpmp\_c pump  
\* need true flow area and length  
5720101 1.5533 0. 30. 0. 0. 0. 00000  
5720108 562010000 1.5533 0. 0. 001000  
5720109 577000000 1.5533 4. 0. 001000  
5720200 0 6.7017999e+02 2.6726001e+02 1.1173000e+03 0. 0.  
5720201 0 1.3923000e+01 1.3923000e+01 0.  
5720202 0 1.3906000e+01 1.3906000e+01 0.  
5720301 570 -1 -3 -1 0 408 0  
5720302 5.5000000e+03 8.7630910e-01 1.1200000e+04 2.8000000e+03  
\* moment of inertia per Bill Babb, GE  
5720303 8279. 4239. 57.2 0.  
5720304 0. 0. 0. 0.  
\*  
\* velocity table  
5726100 408 cntrlvar 758  
5726101 0. 0. 10000. 10000.  
\*  
\*\*\* feed pump (a) outlet volume (with check valve function) \*\*\*  
\* large loss coef. in reverse direction serves check valve function  
5750000 apmpout branch  
5750001 1 0  
5750101 1.5533 5. 0. 0. 0. 0. 0.00015 1.4063 01000  
5750200 0 1.0966000e+03 2.6726999e+02 1.1075000e+03 0.  
5751101 575010000 588000000 1.5533 0. 1.e99 001000

5751201 1.3886000e+01 1.3886000e+01 0.  
\*  
\*\*\* feed pump (b) outlet volume (with check valve function) \*\*\*  
\* large loss coef. in reverse direction serves check valve function  
5760000 bpmpout branch  
5760001 1 0  
5760101 1.5533 5. 0. 0. 0. 0.00015 1.4063 01000  
5760200 0 1.0966000e+03 2.6726999e+02 1.1075000e+03 0.  
5761101 576010000 588000000 1.5533 0. 1.e99 001000  
5761201 1.3885000e+01 1.3885000e+01 0.  
\*  
\*\*\* feed pump (c) outlet volume (with check valve function) \*\*\*  
\* large loss coef. in reverse direction serves check valve function  
5770000 cpmpout branch  
5770001 1 0  
5770101 1.5533 5. 0. 0. 0. 0.00015 1.4063 01000  
5770200 0 1.0966000e+03 2.6726999e+02 1.1075000e+03 0.  
5771101 577010000 588000000 1.5533 0. 1.e99 001000  
5771201 1.3885000e+01 1.3885000e+01 0.  
\*  
\*\*\* min. recirc. valve (a) \*\*\*  
\* this is a trip type valve with choked flow logic enabled, and  
\* abrupt area change logic invoked. the area of this valve is  
\* best defined as the area of the orifice placed in min. recirc.  
\* piping. this area has been estimated from consideration of  
\* ref. [178]. it corresponds to a diameter of 2".  
5800000 recirc\_a valve  
5800101 575010000 581000000 0.0014 6.4764 6.4764 000100  
5800201 0 0. 0. 0.  
5800300 mtrvlv \*jam  
5800301 475 478 1. 0. \*jam  
\*  
\*\*\* min. recirc. (a) sink \*\*\*  
\* fluid conditions of condensers (see comp. 500)  
5810000 sink\_a tmdpvol  
5810101 0. 100. 1.e6 0. 0. 0.  
5810102 0. 0. 00010  
5810200 003  
5810201 0. 0.9824 101.1  
\*  
\*\*\* min. recirc. valve (b) \*\*\*  
\* (see note of component 580)  
5820000 recirc\_b valve  
5820101 576010000 583000000 0.0014 6.4764 6.4764 000100

5820201 0 0. 0. 0.  
5820300 mtrvlv \*jam  
5820301 476 479 1. 0. \*jam  
\*  
\*\*\* min. recirc. (b) sink \*\*\*  
\* fluid conditions of condensers (see comp. 500)  
5830000 sink\_b tmdpvol  
5830101 0. 100. 1.e6 0. 0. 0.  
5830102 0. 0. 00010  
5830200 003  
5830201 0. 0.9824 101.1  
\*  
\*\*\* min. recirc. valve (c) \*\*\*  
\* (see note of component 580)  
5840000 recirc\_c valve  
5840101 577010000 585000000 0.0014 6.4764 6.4764 000100  
5840201 0 0. 0. 0.  
5840300 mtrvlv \*jam  
5840301 477 480 1. 0. \*jam  
\*  
\*  
\*\*\* min. recirc. (c) sink \*\*\*  
\* fluid conditions of condensers (see comp. 500)  
5850000 sink\_c tmdpvol  
5850101 0. 100. 1.e6 0. 0. 0.  
5850102 0. 0. 00010  
5850200 003  
5850201 0. 0.9824 101.1  
\*  
\*\*\* piping from feed pumps to heaters 2 \*\*\*  
\* geometry per ref. [216]  
\*  
5880000 pmp\_htr2 branch  
5880001 4 0  
5880101 4.6599 220.14 0. 0. -7.2 -27.75 0.00015 1.4063 01000  
5880200 0 1.1017000e+03 2.6726999e+02 1.1074000e+03 0.  
5881101 588010000 590000000 0. 0. 0. 001000  
5882101 588010000 591000000 0. 0. 0. 001000  
5883101 588010000 592000000 0. 0. 0. 001000  
5884101 559010000 588000000 0.3491 8.229 1.e+99 001000  
5881201 7.5832000e+00 7.5832000e+00 0.  
5882201 7.5832000e+00 7.5832000e+00 0.  
5883201 7.5832000e+00 7.5832000e+00 0.  
5884201 0. 0. 0.

```
*  
*  
* component 590 - RFW Heater A2 Tubes  
5900000 'HTRA2-p' pipe  
*  
* nv  
5900001 10  
*  
* varea vn  
5900101 2.8872 10 *1906 tubes, 5/8" OD, .049" wall, 18BWG  
*  
* jarea jn  
5900201 2.8872 9  
*  
* vlength vn  
5900301 5.4974 1 *  
5900302 3.0000 2 *volume center = lower level tap  
5900303 3.0000 3 *volume center = upper level tap  
5900304 8.8763 7 *remaining 35.5' total tube length  
5900305 3.0000 8 *volume center = lower level tap  
5900306 3.0000 9 *volume center = upper level tap  
5900307 5.4974 10 *  
*  
* volume vn  
5900401 0.0 10  
*  
* incl vn  
5900601 90.0 5  
5900602 -90.0 10  
*  
* roughness dhyd vn  
5900801 1.5e-4 0.0439 10 *.527" ID  
*  
* kf kr jn  
5900901 0.0 0.0 9  
*  
* pvbfe vn  
5901001 00000 10  
*  
* fvcahs jn  
5901101 001000 9  
*  
* ebt press. temp. vn  
5901201 3 1110.0 301.969 0. 0. 0. 1
```

5901202 3 1107.4 303.527 0. 0. 0. 2  
5901203 3 1105.5 309.131 0. 0. 0. 3  
5901204 3 1101.9 319.624 0. 0. 0. 4  
5901205 3 1096.4 325.800 0. 0. 0. 5  
5901206 3 1094.5 329.305 0. 0. 0. 6  
5901207 3 1096.0 331.281 0. 0. 0. 7  
5901208 3 1097.0 331.801 0. 0. 0. 8  
5901209 3 1097.5 331.601 0. 0. 0. 9  
5901210 3 1098.3 330.416 0. 0. 0. 10  
\*  
\* vel/flow  
5901300 1  
\*  
\* liq-flo vap-flo int jn  
5901301 1232.9 0.0 0. 9  
\*  
\*  
\* component 591 - RFW Heater B2 Tubes  
5910000 'HTRB2-p' pipe  
\*  
\* nv  
5910001 10  
\*  
\* varea vn  
5910101 2.8872 10 \*1906 tubes, 5/8" OD, .049" wall, 18BWG  
\*  
\* jarea jn  
5910201 2.8872 9  
\*  
\* vlength vn  
5910301 5.4974 1 \*  
5910302 3.0000 2 \*volume center = lower level tap  
5910303 3.0000 3 \*volume center = upper level tap  
5910304 8.8763 7 \*remaining 35.5' total tube length  
5910305 3.0000 8 \*volume center = lower level tap  
5910306 3.0000 9 \*volume center = upper level tap  
5910307 5.4974 10 \*  
\*  
\* volume vn  
5910401 0.0 10  
\*  
\* incl vn  
5910601 90.0 5  
5910602 -90.0 10

\*

\* roughness dhyd vn  
5910801 1.5e-4 0.0439 10 \*.527" ID

\*

\* kf kr jn  
5910901 0.0 0.0 9

\*

\* pvbfe vn  
5911001 00000 10

\*

\* fvcahs jn  
5911101 001000 9

\*

\* ebt press. temp. vn  
5911201 3 1110.0 301.969 0. 0. 0. 1  
5911202 3 1107.4 303.527 0. 0. 0. 2  
5911203 3 1105.5 309.131 0. 0. 0. 3  
5911204 3 1101.9 319.624 0. 0. 0. 4  
5911205 3 1096.4 325.800 0. 0. 0. 5  
5911206 3 1094.5 329.305 0. 0. 0. 6  
5911207 3 1096.0 331.281 0. 0. 0. 7  
5911208 3 1097.0 331.801 0. 0. 0. 8  
5911209 3 1097.5 331.601 0. 0. 0. 9  
5911210 3 1098.3 330.416 0. 0. 0. 10

\*

\* vel/flow  
5911300 1

\*

\* liq-flo vap-flo int jn  
5911301 1232.9 0.0 0. 9

\*

\*

\* component 592 - RFW Heater C2 Tubes

\*

5920000 'HTRC2-p' pipe

\*

\* nv  
5920001 10

\*

\* varea vn  
5920101 2.8872 10 \*1906 tubes, 5/8" OD, .049" wall, 18BWG

\*

\* jarea jn  
5920201 2.8872 9

---

```

*
*      vlength    vn
5920301 5.4974    1    *
5920302 3.0000    2    *volume center = lower level tap
5920303 3.0000    3    *volume center = upper level tap
5920304 8.8763    7    *remaining 35.5' total tube length
5920305 3.0000    8    *volume center = lower level tap
5920306 3.0000    9    *volume center = upper level tap
5920307 5.4974   10    *
*
*      volume     vn
5920401 0.0       10
*
*      incl       vn
5920601 90.0      5
5920602 -90.0     10
*
*      roughness  dhyd  vn
5920801 1.5e-4    0.0439 10  *.527" ID
*
*      kf   kr   jn
5920901 0.0  0.0  9
*
*      pvbfe     vn
5921001 00000    10
*
*      fvcahs    jn
5921101 001000   9
*
*      ebt press. temp.          vn
5921201 3   1110.0 301.969 0.  0.  0.  1
5921202 3   1107.4 303.527 0.  0.  0.  2
5921203 3   1105.5 309.131 0.  0.  0.  3
5921204 3   1101.9 319.624 0.  0.  0.  4
5921205 3   1096.4 325.800 0.  0.  0.  5
5921206 3   1094.5 329.305 0.  0.  0.  6
5921207 3   1096.0 331.281 0.  0.  0.  7
5921208 3   1097.0 331.801 0.  0.  0.  8
5921209 3   1097.5 331.601 0.  0.  0.  9
5921210 3   1098.3 330.416 0.  0.  0.  10
*
*      vel/flow
5921300 1
*
```

```
*      liq-flo      vap-flo      int   jn
5921301 1232.9      0.0       0.    9
*
*
*** piping from heater A2 to heater A1 ***
* geometry per ref. [215 & 216]
5950000 'htrA2_1' pipe
5950001 1
5950101 1.755 1
5950301 2. 1
5950401 0. 1
5950501 0. 1
5950601 0. 1
5950701 0. 1
5950801 0.00015 1.4948 1
5951001 01000 1
5951201 0 1.0973000e+03 2.9884000e+02 1.1075000e+03 0. .0 1
*
*** piping from heater B2 to heater B1 ***
* geometry per ref. [215 & 216]
5960000 'htrB2_1' pipe
5960001 1
5960101 1.755 1
5960301 2. 1
5960401 0. 1
5960501 0. 1
5960601 0. 1
5960701 0. 1
5960801 0.00015 1.4948 1
5961001 01000 1
5961201 0 1.0973000e+03 2.9884000e+02 1.1075000e+03 0. .0 1
*
*** piping from heater C2 to heater C1 ***
* geometry per ref. [215 & 216]
5970000 'htrC2_1' pipe
5970001 1
5970101 1.755 1
5970301 2. 1
5970401 0. 1
5970501 0. 1
5970601 0. 1
5970701 0. 1
5970801 0.00015 1.4948 1
5971001 01000 1
```

5971201 0 1.0973000e+03 2.9884000e+02 1.1075000e+03 0. .0 1  
\*  
\*  
\* component 600 - RFW Heater A1 Tubes  
6000000 'HTRA1-p' pipe  
\*  
\* nv  
6000001 10  
\*  
\* varea vn  
6000101 2.8872 10 \*1906 tubes, 5/8" OD, .049" wall, 18BWG  
\*  
\* jarea jn  
6000201 2.8872 9  
\*  
\* vlength vn  
6000301 1.3307 1 \*  
6000302 2.6667 2 \*volume center = lower level tap  
6000303 2.6667 3 \*volume center = upper level tap  
6000304 10.4596 7 \*remaining 41.8' total tube length  
6000305 2.6667 8 \*volume center = lower level tap  
6000306 2.6667 9 \*volume center = upper level tap  
6000307 1.3307 10 \*  
\*  
\* volume vn  
6000401 0.0 10  
\*  
\* incl vn  
6000601 90.0 5  
6000602 -90.0 10  
\*  
\* roughness dhyd vn  
6000801 1.0e-7 0.0439 10 \*.527" ID  
\*  
\* kf kr jn  
6000901 0.0 0.0 9  
\*  
\* pvbfe vn  
6001001 00000 10  
\*  
\* fvcahs jn  
6001101 001000 9  
\*  
\* ebt press. temp. vn

---

*RELAP5 Model INPUT DECK WITH NEW RECIRCULATION CONTROLS*

6001201 3 1089.5 331.600 0. 0. 0. 1  
6001202 3 1088.5 335.810 0. 0. 0. 2  
6001203 3 1087.1 340.290 0. 0. 0. 3  
6001204 3 1083.6 352.648 0. 0. 0. 4  
6001205 3 1078.1 362.143 0. 0. 0. 5  
6001206 3 1076.6 368.635 0. 0. 0. 6  
6001207 3 1079.1 372.725 0. 0. 0. 7  
6001208 3 1080.7 373.688 0. 0. 0. 8  
6001209 3 1081.4 373.683 0. 0. 0. 9  
6001210 3 1081.9 373.013 0. 0. 0. 10  
\*  
\* vel/flow  
6001300 1  
\*  
\* liq-flo vap-flo int jn  
6001301 1232.9 0.0 0. 9  
\*  
\*  
\* component 601 - RFW Heater B1 Tubes  
6010000 'HTRB1-p' pipe  
\*  
\* nv  
6010001 10  
\*  
\* varea vn  
6010101 2.8872 10 \*1906 tubes, 5/8" OD, .049" wall, 18BWG  
\*  
\* jarea jn  
6010201 2.8872 9  
\*  
\* vlength vn  
6010301 1.3307 1 \*  
6010302 2.6667 2 \*volume center = lower level tap  
6010303 2.6667 3 \*volume center = upper level tap  
6010304 10.4596 7 \*remaining 41.8' total tube length  
6010305 2.6667 8 \*volume center = lower level tap  
6010306 2.6667 9 \*volume center = upper level tap  
6010307 1.3307 10 \*  
\*  
\* volume vn  
6010401 0.0 10  
\*  
\* incl vn  
6010601 90.0 5

6010602 -90.0 10  
\*  
\* roughness dhyd vn  
6010801 1.0e-7 0.0439 10 \*.527" ID  
\*  
\* kf kr jn  
6010901 0.0 0.0 9  
\*  
\* pvbfe vn  
6011001 00000 10  
\*  
\* fvcahs jn  
6011101 001000 9  
\*  
\* ebt press. temp. vn  
6011201 3 1089.5 331.600 0. 0. 0. 1  
6011202 3 1088.5 335.815 0. 0. 0. 2  
6011203 3 1087.1 340.290 0. 0. 0. 3  
6011204 3 1083.6 352.648 0. 0. 0. 4  
6011205 3 1078.1 362.143 0. 0. 0. 5  
6011206 3 1076.6 368.635 0. 0. 0. 6  
6011207 3 1079.1 372.725 0. 0. 0. 7  
6011208 3 1080.7 373.688 0. 0. 0. 8  
6011209 3 1081.4 373.683 0. 0. 0. 9  
6011210 3 1081.9 373.013 0. 0. 0. 10  
\*  
\* vel/flow  
6011300 1  
\*  
\* liq-flo vap-flo int jn  
6011301 1232.9 0.0 0. 9  
\*  
\*  
\* component 602 - RFW Heater C1 Tubes  
6020000 'HTRC1-p' pipe  
\*  
\* nv  
6020001 10  
\*  
\* varea vn  
6020101 2.8872 10 \*1906 tubes, 5/8" OD, .049" wall, 18BWG  
\*  
\* jarea jn  
6020201 2.8872 9

\*  
\* vlength vn  
6020301 1.3307 1 \*  
6020302 2.6667 2 \*volume center = lower level tap  
6020303 2.6667 3 \*volume center = upper level tap  
6020304 10.4596 7 \*remaining 41.8' total tube length  
6020305 2.6667 8 \*volume center = lower level tap  
6020306 2.6667 9 \*volume center = upper level tap  
6020307 1.3307 10 \*  
\*  
\* volume vn  
6020401 0.0 10  
\*  
\* incl vn  
6020601 90.0 5  
6020602 -90.0 10  
\*  
\* roughness dhyd vn  
6020801 1.0e-7 0.0439 10 \*.527" ID  
\*  
\* kf kr jn  
6020901 0.0 0.0 9  
\*  
\* pvbfe vn  
6021001 00000 10  
\*  
\* fvcahs jn  
6021101 001000 9  
\*  
\* ebt press. temp. vn  
6021201 3 1089.5 331.600 0. 0. 0. 1  
6021202 3 1088.5 335.815 0. 0. 0. 2  
6021203 3 1087.1 340.290 0. 0. 0. 3  
6021204 3 1083.6 352.648 0. 0. 0. 4  
6021205 3 1078.1 362.143 0. 0. 0. 5  
6021206 3 1076.6 368.635 0. 0. 0. 6  
6021207 3 1079.1 372.725 0. 0. 0. 7  
6021208 3 1080.7 373.688 0. 0. 0. 8  
6021209 3 1081.4 373.683 0. 0. 0. 9  
6021210 3 1081.9 373.013 0. 0. 0. 10  
\*  
\* vel/flow  
6021300 1  
\*

---

```

*      liq-flo    vap-flo    int   jn
6021301 1232.9      0.0      0.    9
*
*
*** piping from heaters 1 to reactor ***
* geometry per ref. [215]
6050000 htr1_rx branch
6050001 4      0
6050101 5.0724 255.58 0. 0. 6.1 27.21 0.00015 1.7970 01000
6050200 0 1.0818000e+03 3.4728000e+02 1.1080000e+03 0.
6051101 600010000 605000000 0. 0. 0. 001000
6052101 601010000 605000000 0. 0. 0. 001000
6053101 602010000 605000000 0. 0. 0. 001000
6054101 605010000 150000000 5.0724 49. 0. 001000
*           / \
*      loss coef. specified to effect the flow losses attributable to
*      the feedwater sparger - see calc. of app. d.
*
6051201 7.9503999e+00 7.9503999e+00 0.
6052201 7.9503999e+00 7.9503999e+00 0.
6053201 7.9503999e+00 7.9503999e+00 0.
6054201 1.3383000e+01 1.3383000e+01 0.
*
*** miscellaneous junctures ***
* no flow losses or area restrictions
6100000 misc_jun mtpljun
6100001 24 1
*
*      from    to    juna kf kr fvcahs      incr1  incr2   jn
6100011 520010000 525000000 0. 0. 0. 001000 1. 1. 1. 0    0    0 1
6100021 521010000 526000000 0. 0. 0. 001000 1. 1. 1. 0    0    0 2
6100031 522010000 527000000 0. 0. 0. 001000 1. 1. 1. 0    0    0 3
6100041 525010000 530000000 0. 0. 0. 001000 1. 1. 1. 0    0    0 4
6100051 526010000 531000000 0. 0. 0. 001000 1. 1. 1. 0    0    0 5
6100061 527010000 532000000 0. 0. 0. 001000 1. 1. 1. 0    0    0 6
6100071 530010000 535000000 0. 0. 0. 001000 1. 1. 1. 0    0    0 7
6100081 531010000 536000000 0. 0. 0. 001000 1. 1. 1. 0    0    0 8
6100091 532010000 537000000 0. 0. 0. 001000 1. 1. 1. 0    0    0 9
6100101 535010000 540000000 0. 0. 0. 001000 1. 1. 1. 0    0    0 10
6100111 536010000 541000000 0. 0. 0. 001000 1. 1. 1. 0   0    0 11
6100121 537010000 542000000 0. 0. 0. 001000 1. 1. 1. 0   0    0 12
6100131 540010000 545000000 0. 0. 0. 001000 1. 1. 1. 0   0    0 13
6100141 541010000 546000000 0. 0. 0. 001000 1. 1. 1. 0   0    0 14
6100151 542010000 547000000 0. 0. 0. 001000 1. 1. 1. 0   0    0 15

```

---

*RELAP5 Model INPUT DECK WITH NEW RECIRCULATION CONTROLS*

6100161	545010000	550000000	0.	0.	001000	1. 1. 1. 0	0	0 16
6100171	546010000	551000000	0.	0.	001000	1. 1. 1. 0	0	0 17
6100181	547010000	552000000	0.	0.	001000	1. 1. 1. 0	0	0 18
6100191	590010000	595000000	0.	0.	001000	1. 1. 1. 0	0	0 19
6100201	591010000	596000000	0.	0.	001000	1. 1. 1. 0	0	0 20
6100211	592010000	597000000	0.	0.	001000	1. 1. 1. 0	0	0 21
6100221	595010000	600000000	0.	0.	001000	1. 1. 1. 0	0	0 22
6100231	596010000	601000000	0.	0.	001000	1. 1. 1. 0	0	0 23
6100241	597010000	602000000	0.	0.	001000	1. 1. 1. 0	0	0 24

\*

\* liq-flo vap-flo jn

6101011	1244.8	0.	1
6101021	1244.8	0.	2
6101031	1244.8	0.	3
6101041	1244.8	0.	4
6101051	1244.8	0.	5
6101061	1244.8	0.	6
6101071	1244.8	0.	7
6101081	1244.8	0.	8
6101091	1244.8	0.	9
6101101	1244.8	0.	10
6101111	1244.8	0.	11
6101121	1244.8	0.	12
6101131	1244.8	0.	13
6101141	1244.8	0.	14
6101151	1244.8	0.	15
6101161	1244.8	0.	16
6101171	1244.8	0.	17
6101181	1244.8	0.	18
6101191	1244.8	0.	19
6101201	1244.8	0.	20
6101211	1244.8	0.	21
6101221	1244.8	0.	22
6101231	1244.8	0.	23
6101241	1244.8	0.	24

\*

\*

\*

---

\* Train A Feedwater Heaters - Shellside

\*

---

\*

\* component 701 - RFW HTR A1 Steam Supply

7010000 'STM-src1' tmdpvol

\*

---

```

* area length vol azmth incl elev rough hyd fe
7010101 5.0 10.0 0.0 0.0 90.0 10.0 0.0 0.0 10
*
* ebt trip variable
7010200 002 0 cntrlvar 010 *RX Power, % *prb 01-26-96 11:55pm
*
* %pwr press qual.
7010201 0.0 7.545 0.9107 *extrapolated *prb 01-26-96 10:38pm
7010202 25.0 55.019 0.9022 *prb 01-26-96 10:38pm
7010203 50.0 110.02 0.8907 *prb 01-26-96 10:38pm
7010204 75.0 153.73 0.8837 *prb 01-26-96 10:38pm
7010205 90.0 186.86 0.8791 *prb 01-26-96 10:38pm
7010206 100.0 209.01 0.8765 *prb 01-26-96 10:38pm
*
*
* component 702 - RFW HTR A2 Steam Supply
7020000 'STM-src2' tmdpvol
*
* area length vol azmth incl elev rough hyd fe
7020101 5.0 10.0 0.0 0.0 0.0 0.0 0.0 0.0 10
*
* ebt trip variable
7020200 002 0 cntrlvar 010 *RX Power, % *prb 01-26-96 11:55pm
*
* %pwr press qual.
7020201 0.0 3.43 0.9607 *extrapolated *prb 01-26-96 11:55pm
7020202 25.0 31.30 0.9587 *prb 01-26-96 11:55pm
7020203 50.0 61.70 0.9533 *prb 01-26-96 11:55pm
7020204 75.0 88.31 0.9530 *prb 01-26-96 11:55pm
7020205 90.0 107.20 0.9508 *prb 01-26-96 11:55pm
7020206 100.0 119.81 0.9495 *prb 01-26-96 11:55pm
*
*
* component 703 - RFW HTR A3 Steam Supply
7030000 'STM-src3' tmdpvol
*
* area length vol azmth incl elev rough hyd fe
7030101 5.0 10.0 0.0 0.0 0.0 0.0 0.0 0.0 10
*
* ebt trip variable
7030200 002 0 cntrlvar 010 *RX Power, % *prb 01-26-96 11:55pm
*
* %pwr press qual.
7030201 0.0 1.99 0.9421 *extrapolated *prb 01-26-96 11:55pm
*prb 01-26-96 11:55pm

```

7030202 25.0 19.80 0.9389 \*prb 01-26-96 11:55pm  
7030203 50.0 38.70 0.9316 \*prb 01-26-96 11:55pm  
7030204 75.0 55.97 0.9305 \*prb 01-26-96 11:55pm  
7030205 90.0 67.71 0.9276 \*prb 01-26-96 11:55pm  
7030206 100.0 75.51 0.9259 \*prb 01-26-96 11:55pm  
\*  
\*  
\* component 704 - RFW HTR A4 Steam Supply #1  
7040000 'STMsrc4A' tmdpvol  
\*  
\* area length vol azmth incl elev rough hyd fe  
7040101 2.8229 10.0 0.0 0.0 0.0 0.0 0.0 10  
\*  
\* ebt trip variable  
7040200 002 0 cntrlvar 010 \*RX Power, % \*prb 01-27-96 10:08am  
\* \*prb 01-27-96 10:08am  
\* %pwr press qual. \*prb 01-27-96 10:08am  
7040201 0.0 0.75 0.6576 \*extrapolated \*prb 01-27-96 10:08am  
7040202 25.0 7.66 0.7094 \*prb 01-27-96 10:08am  
7040203 50.0 14.80 0.8077 \*prb 01-27-96 10:08am  
7040204 75.0 21.59 0.8363 \*prb 01-27-96 10:08am  
7040205 90.0 26.05 0.8437 \*prb 01-27-96 10:08am  
7040206 100.0 29.00 0.8482 \*prb 01-27-96 10:08am  
\*  
\*  
\* component 705 - RFW HTR A4 Steam Supply #2  
7050000 'STMsrc4B' tmdpvol  
\*  
\* area length vol azmth incl elev rough hyd fe  
7050101 2.8229 10.0 0.0 0.0 0.0 0.0 0.0 10  
\*  
\* ebt trip variable  
7050200 002 0 cntrlvar 010 \*RX Power, % \*prb 01-27-96 10:08am  
\* \*prb 01-27-96 10:08am  
\* %pwr press qual. \*prb 01-27-96 10:08am  
7050201 0.0 1.127 0.3577 \*extrapolated \*prb 01-27-96 10:08am  
7050202 25.0 12.30 0.4394 \*prb 01-27-96 10:08am  
7050203 50.0 24.00 0.5701 \*prb 01-27-96 10:08am  
7050204 75.0 34.91 0.6273 \*prb 01-27-96 10:08am  
7050205 90.0 42.24 0.6434 \*prb 01-27-96 10:08am  
7050206 100.0 47.12 0.6485 \*prb 01-27-96 10:08am  
\*  
\*  
\* component 706 - RFW HTR A5 Steam Supply #1 (From "B" LP Turbine, point MR5)

---

7060000 'STMsric5A' tmdpvol

\*

\* area length vol azmth incl elev rough hyd fe

7060101 9.0164 10.0 0.0 0.0 0.0 0.0 0.0 0.0 10

\*

\* ebt trip variable

7060200 002 0 cntrlvar 010 \*RX Power, % \*prb 01-27-96 12:31pm

\* \*prb 01-27-96 12:31pm

\* %pwr press qual. \*prb 01-27-96 12:31pm

7060201 0.0 0.30 0.064 \*extrapolated \*prb 01-27-96 12:31pm

7060202 25.0 4.59 0.1630 \*prb 01-27-96 12:31pm

7060203 50.0 8.88 0.2620 \*prb 01-27-96 12:31pm

7060204 75.0 13.01 0.5389 \*prb 01-27-96 12:31pm

7060205 90.0 15.71 0.5008 \*prb 01-27-96 12:31pm

7060206 100.0 17.49 0.4806 \*prb 01-27-96 12:31pm

\*

\*

\* component 707 - RFW HTR A5 Steam Supply #2 (From "C" LP Turbine, point #5)

7070000 'STMsric5B' tmdpvol

\*

\* area length vol azmth incl elev rough hyd fe

7070101 9.0164 10.0 0.0 0.0 0.0 0.0 0.0 0.0 10

\*

\* ebt trip variable

7070200 002 0 cntrlvar 010 \*RX Power, % \*prb 01-27-96 12:31pm

\* \*prb 01-27-96 12:31pm

\* %pwr press qual. \*prb 01-27-96 12:31pm

7070201 0.0 0.45 0.2807 \*extrapolated \*prb 01-27-96 12:31pm

7070202 25.0 2.69 0.4153 \*prb 01-27-96 12:31pm

7070203 50.0 5.05 0.5633 \*prb 01-27-96 12:31pm

7070204 75.0 7.23 0.6912 \*prb 01-27-96 12:31pm

7070205 90.0 8.66 0.7368 \*prb 01-27-96 12:31pm

7070206 100.0 9.60 0.7545 \*prb 01-27-96 12:31pm

\*

\*

\* component 708 - Moisture Separator

7080000 'Mois-Sep' tmdpvol

\*

\* area length vol azmth incl elev rough hyd fe

7080101 5.0 10.0 0.0 0.0 0.0 0.0 0.0 0.0 10

\*

\* ebt trip variable \*prb 01-26-96 11:47pm

7080200 001 0 cntrlvar 010 \*RX Power, % \*prb 01-26-96 11:47pm

\*

\* %pwr temp qual. \*prb 01-26-96 11:47pm  
7080201 0.0 253.12 0.0 \*extrapolated \*prb 01-26-96 11:47pm  
7080202 25.0 286.00 0.0 \*prb 01-26-96 11:47pm  
7080203 50.0 333.40 0.0 \*prb 01-26-96 11:47pm  
7080204 75.0 359.02 0.0 \*prb 01-26-96 11:47pm  
7080205 90.0 374.74 0.0 \*prb 01-26-96 11:47pm  
7080206 100.0 384.07 0.0 \*prb 01-26-96 11:47pm  
\*  
\*  
\* component 709: Moisture Separator Drain to HTR A2  
7090000 'MS-drain' tmdpjn  
7090101 708000000 731000000 1.3963  
\*  
\* trip variable \*prb 01-26-96 11:47pm  
\*7090200 1 0 cntrlvar 010 \*RX Power, % \*prb 01-26-96 11:47pm  
7090200 1 632 cntrlvar 010 \*RX Power, % \*jam 7-27-96  
\*  
\* %pwr liq.flow . \*prb 01-26-96 11:47pm  
7090201 0.0 0.0 0.0 0.0 \*prb 01-26-96 11:47pm  
7090202 25.0 22.4352 0.0 0.0 \*242,300/3 lb/hr \*prb 01-26-96 11:47pm  
7090203 50.0 54.9444 0.0 0.0 \*593,400/3 lb/hr \*prb 01-26-96 11:47pm  
7090204 75.0 82.8714 0.0 0.0 \*895,011/3 lb/hr \*prb 01-26-96 11:47pm  
7090205 90.0 105.3094 0.0 0.0 \*1,137,342/3 lb/hr \*prb 01-26-96 11:47pm  
7090206 100.0 120.7569 0.0 0.0 \*1,304,175/3 lb/hr \*prb 01-26-96  
11:47pm  
\*  
\* component 710 - RFW Heater A1 steam supply vlv - jam 7-27-96  
7100000 a1stmvlv valve \*jam 7-27-96  
\* from to juna kf kr fvcahs  
7100101 701000000 720000000 1.3417 15.7355 15.7355 000000 \*jam 7-27-96  
\* liq\_vel vap\_vel vel.int.  
7100201 0 60.166 118.13 0.0 \*jam 7-26-96  
7100300 trpvlv \*jam 7-26-96  
7100301 632 \*jam 7-26-96  
\*  
\* component 720 - RFW Heater A1 Steam Dome (top of vertical shell)  
7200000 'HTRA1-s1' branch  
\*  
\* #juns vel/flow  
\*7200001 2 0  
7200001 1 0 \*jam 7-27-96  
\*  
\* area length vol theta phi elev rough hyd pvbfe  
7200101 12.34 13.7904 0. 0. -90.0 -13.7904 1.5e-4 0.0772 00100

\*  
\* ebt press Uf Uv voidv  
7200200 000 198.29 354.09 1113.5 0.99410  
\*  
\* from to juna kf kr fvcahs  
\*7201101 701000000 720000000 1.3417 15.7355 15.7355 000000 \*jam 7-27-96  
\*7202101 720010000 721000000 0. 0. 0. 101000 \*jam 7-27-96  
7201101 720010000 721000000 0. 0. 0. 101000 \*jam 7-27-96  
\*  
\* jun\_Dh flood gas-int slope  
\*7201110 0.0 0.0 1.0 1.0 \*jam 7-27-96  
\*7202110 0.0772 0.0 1.0 1.0 \*jam 7-27-96  
7201110 0.0772 0.0 1.0 1.0  
\*  
\* liq\_vel vap\_vel vel.int.  
\*7201201 60.166 118.13 0. \*jam 7-27-96  
\*7202201 7.3903 8.4137 0. \*jam 7-27-96  
7201201 7.3903 8.4137 0. \*jam 7-27-96  
\*  
\*  
\* component 721 - RFW Heater A1 Shellside middle volumes  
7210000 'HTRA1-s2' pipe  
\*  
\* nv  
7210001 3  
\*  
\* flowa vn  
7210101 12.34 3 \*Shell area (60.75" ID) minus tube area (5/8"OD)  
\* \*tube area = (2)(1906 tubes)(tube area)  
\*  
\* flowl vn  
7210301 10.4596 1  
7210302 2.6667 3 \*same as corresponding primary tube length  
\*  
\* volume vn  
7210401 0.0 3  
\*  
\* incl vn  
7210601 -90.0 3  
\*  
\* roughness dhyd vn  
7210801 1.5e-4 0.0772 3  
\*  
\* kf kr jn

```
7210901 0.0  0.0  2
*
*   pvbfe      vn
7211001 00100    3
*
*   fvcahs     jn
7211101 101000   2
*
*   ebt  press. Uf      Uv      voidv          VN
7211201 0    198.33 354.09    1113.5  0.99189    0.    1
7211202 0    198.36 354.05    1113.5  0.96348    0.    2
7211203 0    198.89 336.85    1113.6  2.33801e-02  0.    3
*
*   vel/flow
7211300 0
*
*   liq-flo  vap-flo  vel.int    jn
7211301 11.168  2.4853  0.        1
7211302 3.0088  5.32454e-02 0.        2
*
*   jun_Dh    flood     gas-int    slope jn
7211401 0.0772  0.0       1.0       1.0    2
*
*
* component 722 - RFW Heater A1 Tubesheet Shellside (bottom of vertical shell)
7220000 'HTRA1-s3' branch
*
*   #juns vel/flow
7220001 1    0
*
*   area  length vol  theta phi elev  rough hyd  pvbfe
7220101 12.34  1.3307 0.    0.    -90.0 -1.3307 1.5e-4 0.0772 00100
*
*   ebt  press. Uf      Uv      voidv
7220200 000  199.30 338.19    1113.6  0.0
*
*   from      to      juna kf    kr    fvcahs
7221101 721010000 722000000 0.    0.0  0.    101000
*
*   jun_Dh    flood  gas-int slope
7221110 0.0772  0.0   1.0   1.0
*
*   liq_vel  vap_vel    vel.int.
7221201 0.11251 -1.1900    0.
```

\*  
\*  
\* component 723 - RFW Heater A1 Drain Piping  
7230000 'HTRA1drn' branch  
\*  
\* #juns vel/flow  
7230001 1 0  
\*  
\* area length vol theta phi elev rough hyd pvbfe  
7230101 0.3474 10.0 0. 0. 82.6 9.9167 1.5e-4 0.0 00000  
\*  
\* ebt press. Uf Uv voidv  
7230200 000 199.30 338.19 1113.6 0.0  
\*  
\* from to juna kf kr fvcahs  
7231101 722010000 723000000 0.3474 0.0 0. 000100  
\*  
\* liq\_vel vap\_vel vel.int.  
7231201 3.7345 3.7345 0.  
\*  
\*  
\* component 725 - RFW HTRA1 Drain Valve  
7250000 'LCV6-1' valve  
\*  
\* from to juna kf kr fvcahs  
7250101 723010000 731000000 0.0873 39.0223 39.0223 000000  
\*  
7250201 0 15.463 15.465 0. \* 819,483/3 lb/hr  
\*  
7250300 srvvlv  
\*  
7250301 0324 \* valve position demand from htr A1 level control system  
\*  
7250400 1.0 288.0 \* max Cv = 288.0 per BFN-VTD-K125-0060 for  
\* 4" linear double-seated full-port  
7250401 0.0 0.0001 0.0001 \* Assume linear Cv vs stroke for globe  
7250402 1.0 1.0 1.0 \* valve  
\*  
\* component 711 - RFW Heater A2 steam supply vlv - jam 7-27-96  
7110000 a2stmvlv valve \*jam 7-27-96  
\* from to juna kf kr fvcahs  
7110101 702000000 730000000 0.7854 14.1087 14.1087 000000 \*jam 7-27-96  
\* liq\_vel vap\_vel vel.int.  
7110201 0 74.200 202.58 0.0 \*jam 7-26-96

7110300 trpvlv \*jam 7-26-96  
7110301 632 \*jam 7-26-96  
\*  
\* component 730 - RFW Heater A2 Steam Dome (top of vertical shell)  
7300000 'HTRA2-s1' branch  
\*  
\* #juns vel/flow  
\*7300001 2 0 \*jam 9-27-96  
7300001 1 0 \*jam 9-27-96  
\*  
\* area length vol theta phi elev rough hyd pvbfe  
7300101 12.34 10.2904 0. 0. -90.0 -10.2904 1.5e-4 0.0772 00100  
\*  
\* ebt press Uf Uv voidv  
7300200 000 109.21 304.89 1106.3 0.99832  
\*  
\* from to juna kf kr fvcahs  
\*7301101 702000000 730000000 0.7854 14.1087 14.1087 000001 \*jam 9-27-96  
\*7302101 730010000 731000000 12.34 0. 0. 101000 \*jam 9-27-96  
7301101 730010000 731000000 12.34 0. 0. 101000 \*jam 9-27-96  
\*  
\* jun\_Dh flood gas-int slope  
\*7301110 0.0 0.0 1.0 1.0 \*jam 9-27-96  
\*7302110 0.0772 0.0 1.0 1.0 \*jam 9-27-96  
7301110 0.0772 0.0 1.0 1.0 \*jam 9-27-96  
\*  
\* liq\_vel vap\_vel vel.int.  
\*7301201 74.200 202.58 0. \*jam 9-27-96  
\*7302201 12.027 7.9267 0. \*jam 9-27-96  
7301201 12.027 7.9267 0. \*jam 9-27-96  
\*  
\*  
\* component 731 - RFW Heater A2 drain junction volume  
7310000 'HTRA2-s2' branch  
\*  
\* #juns vel/flow  
7310001 1 0  
\*  
\* area length vol theta phi elev rough hyd pvbfe  
7310101 12.34 8.8763 0. 0. -90.0 -8.8763 1.5e-4 0.0772 00100  
\*  
\* ebt press Uf Uv voidv  
7310200 000 109.23 305.04 1106.4 0.97393  
\*

```
*      from      to      juna kf     kr     fvcahs
7311101 731010000    732000000   12.34 0.    0.    101000
*
*      jun_Dh      flood  gas-int slope
7311110 0.0772      0.0   1.0   1.0
*
*      liq_vel    vap_vel      vel.int.
7311201 10.895     3.4280      0.
*
*
* component 732 - RFW Heater A2 Shellside middle volumes
7320000 'HTRA2-s2' pipe
*
*      nv
7320001 2
*
*      flowa      vn
7320101 12.34      2      *Shell area (60.75" ID) minus tube area (5/8"OD)
*                          *tube area = (2)(1906 tubes)(tube area)
*
*      flowl      vn
7320301 3.0000      2      *same as corresponding primary tube length
*
*      volume      vn
7320401 0.0         2
*
*      incl       vn
7320601 -90.0       2
*
*      roughness   dhyd  vn
7320801 1.5e-4      0.0772 2
*
*      kf     kr     jn
7320901 0.0   0.0   1
*
*      pvbfe      vn
7321001 00100      2
*
*      fvcahs      jn
7321101 101000      1
*
*      ebt      press. Uf      Uv      voidv      VN
7321201 000   109.25 304.86   1106.4  0.91724   0.   1
7321202 000   109.87 298.86   1106.4  5.89169e-02  0.   2
```

```
*  
*   vel/flow  
7321300 0  
*  
*   liq-flo  vap-flo  vel.int    jn  
7321301 4.2183  0.30784  0.      1  
*  
*   jun_Dh    flood     gas-int    slope  jn  
7321401 0.0772  0.0      1.0      1.0   1  
*  
*  
* component 733 - RFW Heater A2 Tubesheet Shellside (bottom of vertical shell)  
7330000 'HTRA2-s3' branch  
*  
*   #juns vel/flow  
7330001 1    0  
*  
*   area  length vol  theta  phi  elev  rough hyd  pvbfe  
7330101 12.34 5.4974 0.  0.  -90.0 -5.4974 1.5e-4 0.0772 00100  
*  
*   ebt  press. Uf      Uv      voidv  
7330200 000  111.52 291.80  1106.6  0.0  
*  
*   from      to      juna  kf    kr    fvcahs  
7331101 732010000 733000000 12.34 0.0  0.  101000  
*  
*   jun_Dh    flood   gas-int slope  
7331110 0.0772  0.0    1.0    1.0  
*  
*   liq_vel   vap_vel   vel.int.  
7331201 0.42029 -0.82167    0.  
*  
*  
* component 734 - RFW Heater A2 Drain Piping  
7340000 'HTRA2drn' branch  
*  
*   #juns vel/flow  
7340001 1    0  
*  
*   area  length vol  theta  phi  elev  rough hyd  pvbfe  
7340101 0.5475 25.0 0.  0.  65.0 22.6667 1.5e-4 0.0 00000  
*  
*   ebt  press. Uf      Uv      voidv  
7340200 000  199.30 338.19  1113.6  0.0
```

---

```

*
*   from      to      juna  kf    kr    fvcahs
7341101 733010000  734000000  0.5475 0.0  0.  000100
*
*   liq_vel  vap_vel      vel.int.
7341201 8.2628    7.7109     0.
*
*
* component 735 - RFW HTRA2 Drain Valve
7350000 'LCV6-4A'  valve
*
*   from      to      juna  kf    kr    fvcahs
7350101 734010000 741000000  0.3491 22.8653 22.8653 000000
*
7350201 1      228.5294  0.0  0.  *2,468,117/3 lb/hr
*
7350300 srvv1v
*
7350301 0349 * valve position demand based from htr A2 level control
*
7350400 1.0    950.0    * max Cv = 950.0 per BFN-VTD-K125-0060 for
*                      8" linear double-seated full-port
7350401 0.0    0.0001   0.0001 * Assume linear Cv vs stroke for globe
7350402 1.0    1.0      1.0   * valve
*
*
* component 737 - RFW HTRA2 Bypass Valve          *prb 01-18-96
10:16am
7370000 'LCV6-4B'  valve                         *prb 01-18-96 10:16am
*
*   from      to      juna  kf    kr    fvcahs      *prb 01-18-96 10:16am
*7370101 734010000 738000000  0.3491 0.0  0.0  000000  *prb 01-18-96
10:16am
7370101 734010000 738000000  0.3491 22.8653 22.8653 000000  *jam 7-26-96
*
7370201 1      0.0      0.0  0.0               *prb 01-18-96 10:16am
*
7370300 srvv1v                         *prb 01-18-96 10:16am
*
7370301 0355 * valve position demand          *prb 01-18-96 10:16am
*
7370400 1.0    950.0    * max Cv = 950.0 per BFN-VTD-K125-0060 for  *prb 01-18-96
10:16am
*                      8" linear double-seated full-port  *prb 01-18-96 10:16am

```

7370401 0.0 0.0001 0.0001 \* Assume linear Cv vs stroke for globe \*prb 01-18-96  
10:16am  
7370402 1.0 1.0 1.0 \* valve \*prb 01-18-96 10:16am

\* component 738 - RFW bank 2 bypass drain piping to condenser \*prb 01-18-96 10:28am  
7380000 'HTR2byp' branch \*prb 01-18-96 10:28am  
\* \*prb 01-18-96 10:28am  
\* #juns vel/flow \*prb 01-18-96 10:28am  
7380001 1 0 \*prb 01-18-96 10:28am  
\* \*prb 01-18-96 10:28am  
\* area length vol theta phi elev rough hyd pvbfe \*prb 01-18-96 10:28am  
\*7380101 1.0472 50.0 0. 0. -17.72 -37.887 1.5e-4 0.6667 00000 \*prb 01-23-96  
01:02pm  
7380101 1.0472 10.0 0. 0. -90.00 -10.000 1.5e-4 0.6667 00000 \*jam 7-28-96  
\* \*prb 01-18-96 10:28am  
\* ebt press. temp \*prb 01-18-96 10:28am  
7380200 003 1.0 101.14 \*prb 01-18-96 10:28am  
\* \*prb 01-18-96 10:28am  
\* from to juna kf kr fvcahs \*prb 01-18-96 10:28am  
\*7381101 738010000 969010000 1.0472 0.0 0.0 000000 \*prb 01-18-96  
10:28am  
7381101 738010000 971000000 1.0472 0.0 0.0 001000 \*jam 7-28-96  
\* \*prb 01-18-96 10:28am  
\* liq\_vel vap\_vel vel.int. \*prb 01-18-96 10:28am  
7381201 0.0 0.0 0. \*prb 01-18-96 10:28am  
\*  
\* component 712 - RFW Heater A3 steam supply vlv - jam 7-27-96  
7120000 a3stmvlv valve \*jam 7-27-96  
\* from to juna kf kr fvcahs  
7120101 703000000 740000000 3.1416 23.4899 23.4899 000000 \*jam 7-27-96  
\* liq\_vel vap\_vel vel.int.  
7120201 0 7.7263 124.84 0.0 \*jam 7-26-96  
7120300 trpvlv \*jam 7-26-96  
7120301 632 \*jam 7-26-96  
\*  
\* component 740 - RFW Heater A3 Steam Dome (top of vertical shell)  
7400000 'HTRA3-s1' branch  
\*  
\* #juns vel/flow  
\*7400001 2 0 \*jam 7-26-96  
7400001 1 0 \*jam 7-26-96  
\*

```
* area length vol theta phi elev rough hyd pvbfe
7400101 13.5335 12.4284 0. 0. -90.0 -12.4284 1.5e-4 0.0864 00100
*
* ebt press Uf      Uv      voidv
7400200 000 69.300 271.84 1099.9 0.99613
*
* from      to      juna kf      kr      fvcahs
*7401101 703000000 740000000 3.1416 23.4899 23.4899 000000 *jam 7-26-96
*7402101 740010000 741000000 13.5335 0. 0. 101000 *jam 7-26-96
7401101 740010000 741000000 13.5335 0. 0. 101000 *jam 7-26-96
*
* jun_Dh      flood gas-int slope
*7401110 0.0      0.0 1.0 1.0 *jam 7-26-96
*7402110 0.0864 0.0 1.0 1.0 *jam 7-26-96
7401110 0.0864 0.0 1.0 1.0 *jam 7-26-96
*
* liq_vel      vap_vel      vel.int.
*7401201 7.7263 124.84 0. *jam 7-26-96
*7402201 8.9171 19.266 0. *jam 7-26-96
7401201 8.9171 19.266 0. *jam 7-26-96
*
*
* component 741 - RFW Heater A3 drain junction volume
7410000 'HTRA3-s2' branch
*
* #juns vel/flow
7410001 1 0
*
* area length vol theta phi elev rough hyd pvbfe
7410101 13.5335 11.1133 0. 0. -90.0 -11.1133 1.5e-4 0.0864 00100
*
* ebt press Uf      Uv      voidv
7410200 000 69.309 271.88 1100.0 0.96083
*
* from      to      juna kf      kr      fvcahs
7411101 741010000 742000000 13.5335 0. 0. 101000
*
* jun_Dh      flood gas-int slope
7411110 0.0864 0.0 1.0 1.0
*
* liq_vel      vap_vel      vel.int.
7411201 9.3922 5.8524 0.
*
```

\* component 742 - RFW Heater A3 Shellside middle & lower volumes  
7420000 'HTRA3-s3' pipe  
\*  
\* nv  
7420001 4  
\*  
\* flowa vn  
7420101 13.5335 1  
7420102 6.7667 4 \*volumes 2-4 share space with subcooling zone  
\*  
\* flowl vn  
7420301 3.0000 2 \*same as corresponding primary tube length  
7420302 7.0534 4 \*same as corresponding primary tube length  
\*  
\* volume vn  
7420401 0.0 4  
\*  
\* incl vn  
7420601 -90.0 4  
\*  
\* roughness dhyd vn  
7420801 1.5e-4 0.0864 4  
\*  
\* kf kr jn  
7420901 0.0 0.0 3  
\*  
\* pvbfe vn  
7421001 00100 4  
\*  
\* fvcahs jn  
7421101 101000 3  
\*  
\* ebt press. Uf Uv voidv VN  
7421201 000 69.322 271.84 1100.0 0.98918 0. 1  
7421202 000 69.529 271.38 1099.9 0.16248 0. 2  
7421203 000 72.030 269.21 1100.5 2.68060e-06 0. 3  
7421204 000 74.835 267.04 1101.0 8.83757e-06 0. 4  
\*  
\* vel/flow  
7421300 0  
\*  
\* liq-flo vap-flo vel.int jn  
7421301 70.794 0.44862 0. 1  
7421302 0.75643 -0.90429 0. 2

7421303 0.63162 0.77799 0. 3  
\*  
\* jun\_Dh flood gas-int slope jn  
7421401 0.0864 0.0 1.0 1.0 3  
\*  
\*  
\* component 743 - RFW Heater A3 Subcooling Zone  
7430000 'HTRA3-s4' pipe  
\*  
\* nv  
7430001 3  
\*  
\* flowa vn  
7430101 6.7667 3  
\*  
\* flowl vn  
7430301 3.0000 1 \*same as corresponding primary tube length  
7430302 7.0534 3 \*same as corresponding primary tube length  
\*  
\* volume vn  
7430401 0.0 3  
\*  
\* incl vn  
7430601 -90.0 3  
\*  
\* roughness dhyd vn  
7430801 1.5e-4 0.0864 3  
\*  
\* kf kr jn  
7430901 0.0 0.0 2  
\*  
\* pvbfe vn  
7431001 00100 3  
\*  
\* fvcahs jn  
7431101 101000 2  
\*  
\* ebt press. Uf Uv voidv VN  
7431201 000 69.415 233.60 1100.1 8.99481e-02 0. 1  
7431202 000 71.404 226.39 1100.4 1.57683e-07 0. 2  
7431203 000 74.264 242.61 1100.9 3.17648e-06 0. 3  
\*  
\* vel/flow  
7431300 0

---

*RELAP5 Model INPUT DECK WITH NEW RECIRCULATION CONTROLS*

\*  
\* liq-flo vap-flo vel.int jn  
7431301 3.53376e-02 -1.6814 0. 1  
7431302 3.03089e-02 3.099473e-02 0. 2  
\*  
\* jun\_Dh flood gas-int slope jn  
7431401 0.0864 0.0 1.0 1.0 2  
\*  
\*  
\* component 744 - RFW Heater A3 Drain Piping  
7440000 'HTRA3drn' branch  
\*  
\* #juns vel/flow  
7440001 1 1  
\*  
\* area length vol theta phi elev rough hyd pvbfe  
7440101 0.5475 5.0 0. 0. 0. 0. 1.5e-4 0.0 00000  
\*  
\* ebt press. Uf Uv voidv  
7440200 000 199.30 338.19 1113.6 0.0  
\*  
\* from to juna kf kr fvcahs  
7441101 743010000 744000000 0.5475 0.0 0. 000100  
\*  
\* liq\_vel vap\_vel vel.int.  
7441201 228.5294 0.0 0.  
\*  
\*  
\* component 745 - RFW HTRA3 Drain Valve  
7450000 'LCV6-7' valve  
\*  
\* from to juna kf kr fvcahs  
7450101 744010000 752000000 0.3491 7.4816 7.4816 000000  
\*  
7450201 0 12.689 44.886 0. \*2,468,117/3 lb/hr target  
\*  
7450300 srvlv  
\*  
7450301 0379 \* valve position demand based on htr A3 level error  
\*  
7450400 1.0 950.0 \* max Cv = 950.0 per BFN-VTD-K125-0060 for  
\* 8" linear double-seated full-port  
7450401 0.0 0.0001 0.0001 \* Assume linear Cv vs stroke for globe  
7450402 1.0 1.0 1.0 \* valve

---

```

*
*
7470000 'HTRA3jun' mtpljun
7470001 2 0
*
*   from    to    juna kf kr fvcahs      incr1 incr2 jn
7470011 742020004 743010003 .1 5. 5. 001000 1. 1. 1. 0 0 0 1
7470021 742040004 743030003 1. 5. 5. 001000 1. 1. 1. 0 0 0 2
*
*   liq-flo  vap-flo  jn
7471011 4.0946 4.0946 1
7471021 0.0 0.0 2
*
* component 713 - RFW Heater A4 steam supply vlv - jam 7-27-96
7130000 a4stv1 valve *jam 7-27-96
*   from    to    juna kf kr fvcahs
7130101 705000000 750000000 2.8229 6197.85 6197.85 000000 *jam 7-27-96
*   liq_vel  vap_vel  vel.int.
7130201 0 0.83437 24.814 0.0 *jam 7-26-96
7130300 trpv1 *jam 7-26-96
7130301 632 *jam 7-26-96
*
*
* component 750 - RFW Heater A4 (top of shell nearest tubesheet)
7500000 'HTRA4-s1' branch
*
*   #juns  vel/flow
*7500001 2 0 *jam 7-26-96
7500001 1 0 *jam 7-26-96
*
*   area  length  vol  theta  phi  elev  rough  hyd  pvbfe
7500101 0.0 2.9375 153.2704 0. -90.0 -2.9375 1.5e-4 0.1309 00100
*
*   ebt  press  Uf  Uv  voidv
7500200 000 27.276 213.37 1086.4 0.99962
*
*   from    to    juna kf kr fvcahs
*7501101 705000000 750000000 2.8229 6197.85 6197.85 000000 *jam 7-27-96
*7502101 750010000 751000000 9.7832 0. 0. 001003 *jam 7-27-96
7501101 750010000 751000000 9.7832 0. 0. 001003 *jam 7-27-96
*
*   jun_Dh  flood  gas-int slope
*7501110 0.0 0.0 1.0 1.0 *jam 7-27-96
*7502110 0.1309 0.0 1.0 1.0 *jam 7-27-96

```

7501110 0.1309 0.0 1.0 1.0 \*jam 7-27-96  
\*  
\* liq\_vel vap\_vel vel.int.  
\*7501201 0.83437 24.814 0. \*jam 7-27-96  
\*7502201 9.1016 8.7249 0. \*jam 7-27-96  
7501201 9.1016 8.7249 0. \*jam 7-27-96  
\*  
\* component 714 - RFW Heater A4 steam supply vlv - jam 7-27-96  
7140000 a4stvlv2 valve \*jam 7-27-96  
\* from to juna kf kr fvcahs  
7140101 704000000 751000000 2.8229 4.4554 4.4554 000000 \*jam 7-27-96  
\* liq\_vel vap\_vel vel.int.  
7140201 0 41.854 271.59 0.0 \*jam 7-26-96  
7140300 trpvlv \*jam 7-26-96  
7140301 632 \*jam 7-26-96  
\*  
\*  
\* component 751 - RFW Heater A4 (top of shell furthest from tubesheet)  
7510000 'HTRA4-s2' branch  
\*  
\* #juns vel/flow  
\*7510001 2 0 \*jam 7-27-96  
7510001 1 0 \*jam 7-27-96  
\*  
\* area length vol theta phi elev rough hyd pvbfe  
7510101 0.0 2.9375 265.4972 0. -90.0 -2.9375 1.5e-4 0.1309 00100  
\*  
\* ebt press Uf Uv voidv  
7510200 000 27.276 213.38 1086.4 0.99996  
\*  
\* from to juna kf kr fvcahs  
\*7511101 704000000 751000000 2.8229 4.4554 4.4554 000000 \*jam 7-27-96  
\*7512101 751010000 752000000 153.4359 0. 0. 101000 \*jam 7-27-96  
7511101 751010000 752000000 153.4359 0. 0. 101000 \*jam 7-27-96  
\*  
\* jun\_Dh flood gas-int slope  
\*7511110 0.0 0.0 1.0 1.0 \*jam 7-27-96  
\*7512110 0.1309 0.0 1.0 1.0 \*jam 7-27-96  
7511110 0.1309 0.0 1.0 1.0 \*jam 7-27-96  
\*  
\* liq\_vel vap\_vel vel.int.  
\*7511201 41.854 271.59 0. \*jam 7-27-96  
\*7512201 38.784 4.5911 0. \*jam 7-27-96  
7511201 38.784 4.5911 0. \*jam 7-27-96

```
*  
*  
* component 752 - RFW Heater A4 (bottom of shell furthest from tubesheet)  
7520000 'HTRA4-s3' branch  
*  
* #juns vel/flow  
7520001 0 0  
*  
* area length vol theta phi elev rough hyd pvbfe  
7520101 0.0 2.9375 265.4972 0. -90.0 -2.9375 1.5e-4 0.1309 00100  
*  
* ebt press Uf Uv voidv  
7520200 000 27.292 209.34 1086.4 0.52487  
*  
*  
* component 753 - RFW Heater A4 Subcooling Zone  
7530000 'HTRA4-s4' branch  
*  
* #juns vel/flow  
7530001 1 0  
*  
* area length vol theta phi elev rough hyd pvbfe  
7530101 9.7832 15.6667 0.0 0. 0.0 0.0 1.5e-4 0.1309 00100  
*  
* ebt press Uf Uv voidv  
7530200 000 26.746 170.92 1086.2 2.46992e-02  
*  
* from to juna kf kr fvcahs  
7531101 752010000 753000000 1.7671 5.0 5.0 001000  
*  
* jun_Dh flood gas-int slope  
7531110 0.1309 0.0 1.0 1.0  
*  
* liq_vel vap_vel vel.int.  
7531201 6.4784 37.792 0.  
*  
*  
* component 754 - RFW Heater A4 Drain Piping  
7540000 'HTRA4drn' branch  
*  
* #juns vel/flow  
7540001 1 0  
*  
* area length vol theta phi elev rough hyd pvbfe
```

---

RELAP5 Model INPUT DECK WITH NEW RECIRCULATION CONTROLS

7540101 1.6230 10.0 0. 0. 50.15 7.6771 1.5e-4 0.0 00000  
\*  
\* ebt press. Uf Uv voidv  
7540200 000 26.326 174.57 1085.9 7.05438e-04  
\*  
\* from to juna kf kr fvcahs  
7541101 753010000 754000000 1.6230 0.0 0. 000100  
\*  
\* liq\_vel vap\_vel vel.int.  
7541201 3.1304 4.5777 0.  
\*  
\*  
\* component 755 - RFW HTA4 Drain Valve  
7550000 'LCV6-11A' valve  
\*  
\* from to juna kf kr fvcahs  
7550101 754010000 760010003 0.7854 23.7848 23.7848 000000  
\*  
7550201 0 7.5514 7.5514 0. \*3,184,100/3 lb/hr target  
\*  
7550300 srvlv  
\*  
7550301 0399 \* valve position demand based on htr A4 level error  
\*  
7550400 1.0 2180.0 \* max Cv = 2180.0 per BFN-VTD-K125-0060 for  
\* 12" linear double-seated full-port  
7550401 0.0 0.0001 0.0001 \* Assume linear Cv vs stroke for globe  
7550402 1.0 1.0 1.0 \* valve  
\*  
\*  
\* component 757 - RFW HTA4 Bypass Valve \*prb 01-24-96  
10:22am  
7570000 'LCV6-11B' valve \*prb 01-24-96 10:22am  
\* \*prb 01-24-96 10:22am  
\* from to juna kf kr fvcahs \*prb 01-24-96 10:22am  
\*7570101 754010000 758000000 0.7854 0.0 0.0 000000 \*prb 01-24-96  
10:22am  
7570101 754010000 758000000 0.7854 23.7848 23.7848 000000 \*jam 7-26-96  
\* \*prb 01-24-96 10:22am  
7570201 1 0.0 0.0 0.0 \*prb 01-24-96 10:22am  
\* \*prb 01-24-96 10:22am  
7570300 srvlv \*prb 01-24-96 10:22am  
\* \*prb 01-24-96 10:22am  
7570301 0405 \* valve position demand \*prb 01-24-96 10:22am

---

```

*                                              *prb 01-24-96 10:22am
7570400 1.0      2180.0    * max Cv = 2180.0 per BFN-VTD-K125-0060 for   *prb 01-24-
96 10:22am
*                                              12" linear double-seated full-port *prb 01-24-96 10:22am
7570401 0.0      0.0001    0.0001 * Assume linear Cv vs stroke for globe *prb 01-24-96
10:22am
7570402 1.0      1.0       1.0   * valve                               *prb 01-24-96 10:22am
*
*
* component 758 - RFW bank 4 bypass drain piping to condenser          *prb 01-24-
96 10:22am
7580000 'HTR4byp'   branch                                         *prb 01-24-96 10:22am
*
* #juns vel/flow                                         *prb 01-24-96 10:22am
7580001 1      0                                         *prb 01-24-96 10:22am
*
* area length vol theta phi elev rough hyd pvbfe *prb 01-24-96 10:22am
7580101 2.3562 25.0  0.  0.  -27.0 -11.40625 1.5e-4 1.0  00000 *prb 01-24-96
10:22am
*
* ebt press. temp                                         *prb 01-24-96 10:22am
7580200 003  1.0  101.14                                         *prb 01-24-96 10:22am
*
* from to juna kf kr fvcahs *prb 01-24-96 10:22am
*7581101 758010000 969010000 2.3562 0.0  0.0  000000 *prb 01-24-96
10:22am
7581101 758010000 969010000 2.3562 0.0  0.0  001000 *jam 7-26-96
*
* liq_vel vap_vel vel.int.                                     *prb 01-24-96 10:22am
7581201 0.0     0.0     0.                                         *prb 01-24-96 10:22am
*
*
* component 760 - RFW Heater A5 Flash Tank
7600000 'FL-TankA'   pipe
*
* nv
7600001 4
*
* flowa vn
7600101 16.4988    4
*
* flowl vn
7600301 1.4583     1
7600302 2.9583     2

```

---

*RELAP5 Model INPUT DECK WITH NEW RECIRCULATION CONTROLS*

```
7600303 2.500      3
7600304 5.2188     4
*
*      volume      vn
7600401 0.0        4
*
*      incl       vn
7600601 -90.0      4
*
*      roughness   dhyd  vn
7600801 0.0        0.0  4
*
*      kf    kr    jn
7600901 0.0        0.0  3
*
*      pvbfe      vn
7601001 00010      4
*
*      fvcahs     jn
7601101 101000     3
*
*      ebt  press. Uf    Uv    voidv      VN
7601201 000  9.6940 160.59  1071.8  0.98351  0.  1
7601202 000  9.6954 159.92  1071.8  0.99883  0.  2
7601203 000  9.9628 160.43  1072.2  0.53140  0.  3
7601204 000  12.394 159.48  1075.2  0.00000e+00  0.  4
*
*      vel/flow
7601300 0
*
*      liq-flo  vap-flo      vel.int     jn
7601301 19.581 0.27746    0.        1
7601302 282.58 0.63630    0.        2
7601303 0.63560 -4.2606   0.        3
*
*      jun_Dh    flood      gas-int     slope  jn
7601401 0.0        0.0      1.0        1.0  3
*
*
* component 761 - RFW Heater A5 Drain Piping
7610000 'HTRA5drn' branch
*
*      #juns  vel/flow
7610001 1      0
```

---

```

*
* area length vol theta phi elev rough hyd pvbfe
7610101 2.9483 10.0 0. 0. 0.0 0.0 1.5e-4 0.0 00000
*
* ebt press. Uf Uv voidv
7610200 000 13.552 159.14 1076.4 0.0
*
* from to juna kf kr fvcahs
7611101 760010000 761000000 2.9483 0.0 0. 000100
*
* liq_vel vap_vel vel.int.
7611201 1.6705 1.9099 0.
*
* component 715 - RFW Heater A5 steam supply vlv - jam 7-27-96
7150000 a5stvlv1 valve *jam 7-27-96
* from to juna kf kr fvcahs
7150101 706000000 762000000 9.0164 6243.8 6243.8 000000 *jam 7-27-96
* liq_vel vap_vel vel.int.
7150201 0 0.49198 22.264 0.0 *jam 7-26-96
7150300 trpvlv *jam 7-26-96
7150301 632 *jam 7-26-96
*
*
* component 762 - RFW Heater A5 (top of shell nearest tubesheet)
7620000 'HTRA5-s1' branch
*
* #juns vel/flow
*7620001 3 0 *jam 7-27-96
7620001 2 0 *jam 7-27-96
*
* area length vol theta phi elev rough hyd pvbfe
7620101 0.0 2.8333 170.5096 0. -90.0 -2.8333 1.5e-4 0.1128 00100
*
* ebt press Uf Uv voidv
7620200 000 9.4593 158.61 1071.3 0.99998
*
* from to juna kf kr fvcahs
*7621101 706000000 762000000 9.0164 6243.8 6243.8 001000
*jam 7-27-96
*7622101 762010000 763000000 8.7069 0. 0. 001003
*jam 7-27-96
7621101 762010000 763000000 8.7069 0. 0. 001003
*jam 7-27-96

```

---

*RELAP5 Model INPUT DECK WITH NEW RECIRCULATION CONTROLS*

```
*7623101 760000000    762000000    0.7530 1.50  1.50  001000
*jam 7-27-96
7622101 760000000    762000000    0.7530 1.50  1.50  001000
*jam 7-27-96
*
*   jun_Dh      flood  gas-int slope
*7621110 2.3958      0.0   1.0   1.0                           *jam 7-27-96
*7622110 0.1128      0.0   1.0   1.0                           *jam 7-27-96
7621110 0.1128      0.0   1.0   1.0                           *jam 7-27-96
*7623110 0.0         0.0   1.0   1.0                           *jam 7-27-96
7622110 0.0         0.0   1.0   1.0                           *jam 7-27-96
*
*   liq_vel    vap_vel    vel.int.
*7621201 0.49198     22.264      0.                           *jam 7-27-96
*7622201 -31.397     -26.477     0.                           *jam 7-27-96
7621201 -31.397     -26.477     0.                           *jam 7-27-96
*7623201 -30.730     237.56      0.                           *jam 7-27-96
7622201 -30.730     237.56      0.                           *jam 7-27-96
*
* component 716 - RFW Heater A5 steam supply vlv - jam 7-27-96
7160000 a5stvlv2      valve  *jam 7-27-96
*   from      to      juna  kf   kr   fvcahs
7160101 707000000    763000000  9.0164 2.9489  2.9489  0000000          *jam 7-27-96
*   liq_vel    vap Vel    vel.int.
7160201 0  26.337     161.50      0.0                         *jam 7-26-96
7160300 trpvlv          *jam 7-26-96
7160301 632          *jam 7-26-96
*
*
* component 763 - RFW Heater A5 (top of shell furthest from tubesheet)
7630000 'HTRA5-s2'    branch
*
*   #juns  vel/flow
*7630001 2  0           *jam 7-27-96
7630001 1  0           *jam 7-27-96
*
*   area  length vol   theta phi elev   rough hyd   pvbfe
7630101 0.0  2.8333 128.8119 0. -90.0 -2.8333 1.5e-4 0.1128 00100
*
*   ebt  press Uf      Uv      voidv
7630200 000  9.4589 158.60    1071.4  0.99992
*
*   from      to      juna  kf   kr   fvcahs
*7631101 707000000    763000000  9.0164 2.9489  2.9489  001000          *jam 9-27-96
```

```
*7632101 763010000    764000000    83.8342 0.  0.  001000  *jam 9-27-96
7631101 763010000    764000000    83.8342 0.  0.  001000  *jam 9-27-96
*
*   jun_Dh      flood  gas-int slope
*7631110 2.3958      0.0  1.0  1.0                                *jam 9-27-96
*7632110 0.1128      0.0  1.0  1.0                                *jam 9-27-96
7631110 0.1128      0.0  1.0  1.0                                *jam 9-27-96
*
*   liq_vel    vap_vel      vel.int.
*7631201 26.337     161.50      0.                                *jam 9-27-96
*7632201 34.542     8.5995      0.                                *jam 9-27-96
7631201 34.542     8.5995      0.                                *jam 9-27-96
*
*
* component 764 - RFW Heater A5 (bottom of shell furthest from tubesheet)
7640000 'HTRA5-s3' branch
*
*   #juns vel/flow
7640001 2      0
*
*   area  length vol  theta phi elev  rough hyd  pvbfe
7640101 0.0  2.8333 128.8119 0. -90.0 -2.8333 1.5e-4 0.1128 00100
*
*   ebt  press  Uf      Uv      voidv
7640200 000  9.6340 148.68  1071.7  0.39598
*
*   from      to      juna  kf   kr   fvcahs
7641101 764010004  765010003  8.7069 0.  0.  001000
7642101 764010000  766000000  0.8685 1.5 100.0 001001 * discourage reverse
flow
*
*   jun_Dh      flood  gas-int slope
7641110 0.1128      0.0  1.0  1.0
7642110 0.6651      0.0  1.0  1.0
*
*   liq_vel    vap_vel      vel.int.
7641201 3.4725     -8.5376      0.
7642201 0.47271    -9.3520      0.
*
*
* component 765 - RFW Heater A5 (bottom of shell nearest tubesheet)
7650000 'HTRA5-s4' branch
*
*   #juns vel/flow
```

```
7650001 2      0
*
*   area  length  vol   theta  phi  elev   rough  hyd   pvbfe
7650101 0.0    2.8333 170.5096 0. -90.0 -2.8333 1.5e-4 0.1128 00100
*
*   ebt  press  Uf      Uv      voidv
7650200 000    9.4996 134.05    1071.5  0.44943
*
*   from      to      juna   kf     kr     fvcahs
7651101 762010000 765000000 110.9722 0.0   0.0   001000
7652101 765010000 766000000 0.8685  1.5   100.0 001001 * discourage reverse
flow
*
*   jun_Dh    flood  gas-int slope
7651110 0.1128    0.0   1.0   1.0
7652110 0.6651    0.0   1.0   1.0
*
*   liq_vel   vap_vel    vel.int.
7651201 37.265    5.8851    0.
7652201 -0.42722   -10.256   0.
*
*
* component 766 - RFW Heater A5 Collector
7660000 'Coll-A5' branch
*
*   #juns vel/flow
7660001 1      0
*
*   area  length  vol   theta  phi  elev   rough  hyd   pvbfe
7660101 4.9087 0.0    145.2255 0.  0.0  0.0   1.5e-4 0.0   00000
*
*   ebt  press  Uf      Uv      voidv
7660200 000    9.9594 146.78    1072.2  0.10641
*
*   from      to      juna   kf     kr     fvcahs
7661101 766010002 760030003 4.9087  1.0   0.50   031000
*
*   jun_Dh    flood  gas-int slope
7661110 2.5      0.0   1.0   1.0
*
*   liq_vel   vap_vel    vel.int.
7661201 -0.18014   -1.3910   0.
*
```

\* component 767 - RFW HTRA5 Drain Valve  
\*  
7670000 'LCV6-14A' valve  
\*  
\* from to juna kf kr fvcahs  
7670101 761010000 969000000 0.7854 5.6209 5.6209 001000  
\*  
7670201 0 9.4 9.4 0. \*3,184,100/3 lb/hr target  
\*  
7670300 srvv lv  
\*  
7670301 0429 \* valve position demand based on htr A5 level error  
\*  
7670400 1.0 2180.0 \* max Cv = 2180.0 per BFN-VTD-K125-0060 for  
\* 12" linear double-seated full-port  
7670401 0.0 0.0001 0.0001 \* Assume linear Cv vs stroke for globe  
7670402 1.0 1.0 1.0 \* valve  
\*  
\*  
\* component 768 - RFW HTRA5 Bypass Valve \*prb 01-24-96  
10:22am  
7680000 'LCV6-14B' valve \*prb 01-24-96 10:22am  
\* \*prb 01-24-96 10:22am  
\* from to juna kf kr fvcahs \*prb 01-24-96 10:22am  
\*7680101 761010000 969000000 0.7854 0.0 0.0 000000 \*prb 01-24-96  
10:22am  
7680101 761010000 969000000 0.7854 0.0 5.6209 001000 \*jam 7-26-96  
\* \*prb 01-24-96 10:22am  
7680201 1 0.0 0.0 0.0 \*prb 01-24-96 10:22am  
\* \*prb 01-24-96 10:22am  
7680300 srvv lv \*prb 01-24-96 10:22am  
\* \*prb 01-24-96 10:22am  
7680301 0435 \* valve position demand \*prb 01-24-96 10:22am  
\* \*prb 01-24-96 10:22am  
7680400 1.0 2180.0 \* max Cv = 2180.0 per BFN-VTD-K125-0060 for \*prb 01-24-  
96 10:22am  
\* 12" linear double-seated full-port \*prb 01-24-96 10:22am  
7680401 0.0 0.0001 0.0001 \* Assume linear Cv vs stroke for globe \*prb 01-24-96  
10:22am  
7680402 1.0 1.0 1.0 \* valve \*prb 01-24-96 10:22am  
\*  
\*-----  
\* Train B Feedwater Heaters - Shellside

\*-----  
\*  
\* component 801 - RFW HTR B1 Steam Supply  
8010000 'STM-src1' tmdpvol  
\*  
\* area length vol azmth incl elev rough hyd fe  
8010101 5.0 10.0 0.0 0.0 90.0 10.0 0.0 0.0 10  
\*  
\* ebt trip variable  
8010200 002 0 cntrlvar 010 \*RX Power, % \*prb 01-25-96 11:25pm  
\*  
\* %pwr press qual.  
8010201 0.0 7.545 0.9107 \*extrapolated \*prb 01-26-96 10:38pm  
8010202 25.0 55.019 0.9022 \*prb 01-26-96 10:38pm  
8010203 50.0 110.02 0.8907 \*prb 01-26-96 10:38pm  
8010204 75.0 153.73 0.8837 \*prb 01-26-96 10:38pm  
8010205 90.0 186.86 0.8791 \*prb 01-26-96 10:38pm  
8010206 100.0 209.01 0.8765 \*prb 01-26-96 10:38pm  
\*  
\*  
\* component 802 - RFW HTR B2 Steam Supply  
8020000 'STM-src2' tmdpvol  
\*  
\* area length vol azmth incl elev rough hyd fe  
8020101 5.0 10.0 0.0 0.0 0.0 0.0 0.0 0.0 10  
\*  
\* ebt trip variable  
8020200 002 0 cntrlvar 010 \*RX Power, % \*prb 01-26-96 11:55pm  
\*  
\* %pwr press qual.  
8020201 0.0 3.43 0.9607 \*extrapolated \*prb 01-26-96 11:55pm  
8020202 25.0 31.30 0.9587 \*prb 01-26-96 11:55pm  
8020203 50.0 61.70 0.9533 \*prb 01-26-96 11:55pm  
8020204 75.0 88.31 0.9530 \*prb 01-26-96 11:55pm  
8020205 90.0 107.20 0.9508 \*prb 01-26-96 11:55pm  
8020206 100.0 119.81 0.9495 \*prb 01-26-96 11:55pm  
\*  
\*  
\* component 803 - RFW HTR B3 Steam Supply  
8030000 'STM-src3' tmdpvol  
\*  
\* area length vol azmth incl elev rough hyd fe  
8030101 5.0 10.0 0.0 0.0 0.0 0.0 0.0 0.0 10  
\*

---

```

*   ebt trip variable
8030200 002  0    cntrlvar 010  *RX Power, %           *prb 01-26-96 11:55pm
*
*   %pwr press qual.
8030201  0.0  1.99  0.9421      *extrapolated          *prb 01-26-96 11:55pm
8030202  25.0 19.80  0.9389          *prb 01-26-96 11:55pm
8030203  50.0 38.70  0.9316          *prb 01-26-96 11:55pm
8030204  75.0 55.97  0.9305          *prb 01-26-96 11:55pm
8030205  90.0 67.71  0.9276          *prb 01-26-96 11:55pm
8030206 100.0 75.51  0.9259          *prb 01-26-96 11:55pm
*
*
* component 804 - RFW HTR B4 Steam Supply #1
8040000 'STMsric4A'   tmdpvol
*
*   area length vol  azmth incl  elev  rough hyd  fe
8040101 2.8229 10.0  0.0  0.0  0.0  0.0  0.0  10
*
*   ebt trip variable
8040200 002  0    cntrlvar 010  *RX Power, %           *prb 01-27-96 10:08am
*                                         *prb 01-27-96 10:08am
*   %pwr press qual.
8040201  0.0  0.75  0.6576      *extrapolated          *prb 01-27-96 10:08am
8040202  25.0  7.66  0.7094          *prb 01-27-96 10:08am
8040203  50.0 14.80  0.8077          *prb 01-27-96 10:08am
8040204  75.0 21.59  0.8363          *prb 01-27-96 10:08am
8040205  90.0 26.05  0.8437          *prb 01-27-96 10:08am
8040206 100.0 29.00  0.8482          *prb 01-27-96 10:08am
*
*
* component 805 - RFW HTR B4 Steam Supply #2
8050000 'STMsric4B'   tmdpvol
*
*   area length vol  azmth incl  elev  rough hyd  fe
8050101 2.8229 10.0  0.0  0.0  0.0  0.0  0.0  10
*
*   ebt trip variable
8050200 002  0    cntrlvar 010  *RX Power, %           *prb 01-27-96 10:08am
*                                         *prb 01-27-96 10:08am
*   %pwr press qual.
8050201  0.0  1.127  0.3577      *extrapolated          *prb 01-27-96 10:08am
8050202  25.0 12.30  0.4394          *prb 01-27-96 10:08am
8050203  50.0 24.00  0.5701          *prb 01-27-96 10:08am
8050204  75.0 34.91  0.6273          *prb 01-27-96 10:08am

```

8050205 90.0 42.24 0.6434 \*prb 01-27-96 10:08am  
8050206 100.0 47.12 0.6485 \*prb 01-27-96 10:08am  
\*  
\*  
\* component 806 - RFW HTR B5 Steam Supply #1 (From "B" LP Turbine, point MR5)  
8060000 'STMsric5A' tmdpvol  
\*  
\* area length vol azmth incl elev rough hyd fe  
8060101 9.0164 10.0 0.0 0.0 0.0 0.0 0.0 10  
\*  
\* ebt trip variable  
8060200 002 0 cntrlvar 010 \*RX Power, % \*prb 01-27-96 12:31pm  
\* \*prb 01-27-96 12:31pm  
\* %pwr press qual. \*prb 01-27-96 12:31pm  
8060201 0.0 0.30 0.064 \*extrapolated \*prb 01-27-96 12:31pm  
8060202 25.0 4.59 0.1630 \*prb 01-27-96 12:31pm  
8060203 50.0 8.88 0.2620 \*prb 01-27-96 12:31pm  
8060204 75.0 13.01 0.5389 \*prb 01-27-96 12:31pm  
8060205 90.0 15.71 0.5008 \*prb 01-27-96 12:31pm  
8060206 100.0 17.49 0.4806 \*prb 01-27-96 12:31pm  
\*  
\*  
\* component 807 - RFW HTR B5 Steam Supply #2 (From "C" LP Turbine, point #5)  
8070000 'STMsric5B' tmdpvol  
\*  
\* area length vol azmth incl elev rough hyd fe  
8070101 9.0164 10.0 0.0 0.0 0.0 0.0 0.0 10  
\*  
\* ebt trip variable  
8070200 002 0 cntrlvar 010 \*RX Power, % \*prb 01-27-96 12:31pm  
\* \*prb 01-27-96 12:31pm  
\* %pwr press qual. \*prb 01-27-96 12:31pm  
8070201 0.0 0.45 0.2807 \*extrapolated \*prb 01-27-96 12:31pm  
8070202 25.0 2.69 0.4153 \*prb 01-27-96 12:31pm  
8070203 50.0 5.05 0.5633 \*prb 01-27-96 12:31pm  
8070204 75.0 7.23 0.6912 \*prb 01-27-96 12:31pm  
8070205 90.0 8.66 0.7368 \*prb 01-27-96 12:31pm  
8070206 100.0 9.60 0.7545 \*prb 01-27-96 12:31pm  
\*  
\*  
\* component 808 - Moisture Separator  
8080000 'Mois-Sep' tmdpvol  
\*  
\* area length vol azmth incl elev rough hyd fe

---

8080101 5.0 10.0 0.0 0.0 0.0 0.0 0.0 10  
 \*  
 \* ebt trip variable \*prb 01-26-96 11:47pm  
 8080200 001 0 cntrlvar 010 \*RX Power, % \*prb 01-26-96 11:47pm  
 \*  
 \* %pwr temp qual. \*prb 01-26-96 11:47pm  
 8080201 0.0 253.12 0.0 \*extrapolated \*prb 01-26-96 11:47pm  
 8080202 25.0 286.00 0.0 \*prb 01-26-96 11:47pm  
 8080203 50.0 333.40 0.0 \*prb 01-26-96 11:47pm  
 8080204 75.0 359.02 0.0 \*prb 01-26-96 11:47pm  
 8080205 90.0 374.74 0.0 \*prb 01-26-96 11:47pm  
 8080206 100.0 384.07 0.0 \*prb 01-26-96 11:47pm  
 \*  
 \*  
 \* component 809: Moisture Separator Drain to HTR B2  
 8090000 'MS-drain' tmdpjun  
 8090101 808000000 831000000 1.3963  
 \*  
 \* trip variable \*prb 01-26-96 11:47pm  
 \*8090200 1 0 cntrlvar 010 \*RX Power, % \*prb 01-26-96 11:47pm  
 8090200 1 633 cntrlvar 010 \*RX Power, % \*jam 7-27-96  
 \*  
 \* %pwr liq.flow . \*prb 01-26-96 11:47pm  
 8090201 0.0 0.0 0.0 0.0 \*prb 01-26-96 11:47pm  
 8090202 25.0 22.4352 0.0 0.0 \*242,300/3 lb/hr \*prb 01-26-96 11:47pm  
 8090203 50.0 54.9444 0.0 0.0 \*593,400/3 lb/hr \*prb 01-26-96 11:47pm  
 8090204 75.0 82.8714 0.0 0.0 \*895,011/3 lb/hr \*prb 01-26-96 11:47pm  
 8090205 90.0 105.3094 0.0 0.0 \*1,137,342/3 lb/hr \*prb 01-26-96 11:47pm  
 8090206 100.0 120.7569 0.0 0.0 \*1,304,175/3 lb/hr \*prb 01-26-96  
 11:47pm  
 \*  
 \*  
 \* component 810 - RFW Heater A1 steam supply vlv - jam 7-27-96  
 8100000 b1stmvlv valve \*jam 7-27-96  
 \* from to juna kf kr fvcahs  
 8100101 801000000 820000000 1.3417 15.7355 15.7355 000000 \*jam 7-27-96  
 \* liq\_vel vap Vel vel.int.  
 8100201 0 60.166 118.13 0.0 \*jam 7-26-96  
 8100300 trpvlv \*jam 7-26-96  
 8100301 633 \*jam 7-26-96  
 \*  
 \* component 820 - RFW Heater A1 Steam Dome (top of vertical shell)  
 8200000 'HTRB1-s1' branch  
 \*

```
* #juns vel/flow
*8200001 2 0
8200001 1 0 *jam 7-27-96
*
* area length vol theta phi elev rough hyd pvbfe
8200101 12.34 13.7904 0. 0. -90.0 -13.7904 1.5e-4 0.0772 00100
*
* ebt press Uf Uv voidv
8200200 000 198.29 354.09 1113.5 0.99410
*
* from to juna kf kr fvcahs
*8201101 801000000 820000000 1.3417 15.7355 15.7355 000000 *jam 7-27-96
*8202101 820010000 821000000 0. 0. 0. 101000 *jam 7-27-96
8201101 820010000 821000000 0. 0. 0. 101000 *jam 7-27-96
*
* jun_Dh flood gas-int slope
*8201110 0.0 0.0 1.0 1.0 *jam 7-27-96
*8202110 0.0772 0.0 1.0 1.0 *jam 7-27-96
8201110 0.0772 0.0 1.0 1.0
*
* liq_vel vap_vel vel.int.
*8201201 60.166 118.13 0. *jam 7-27-96
*8202201 7.3903 8.4137 0. *jam 7-27-96
8201201 7.3903 8.4137 0. *jam 7-27-96
*
* component 821 - RFW Heater B1 Shellside middle volumes
8210000 'HTRB1-s2' pipe
*
* nv
8210001 3
*
* flowa vn
8210101 12.34 3 *Shell area (60.75" ID) minus tube area (5/8"OD)
* *tube area = (2)(1906 tubes)(tube area)
*
* flowl vn
8210301 10.4596 1
8210302 2.6667 3 *same as corresponding primary tube length
*
* volume vn
8210401 0.0 3
*
* incl vn
8210601 -90.0 3
```

---

```

*
*   roughness    dhyd  vn
8210801 1.5e-4      0.0772 3
*
*   kf  kr  jn
8210901 0.0  0.0  2
*
*   pvbfe      vn
8211001 00100     3
*
*   fvcahs     jn
8211101 101000    2
*
*   ebt  press. Uf      Uv      voidv          VN
8211201 0    198.33 354.09  1113.5  0.99189   0.  1
8211202 0    198.36 354.05  1113.5  0.96348   0.  2
8211203 0    198.89 336.85  1113.6  2.33801e-02 0.  3
*
*   vel/flow
8211300 0
*
*   liq-flo  vap-flo  vel.int    jn
8211301 11.168  2.4853  0.        1
8211302 3.0088  5.32454e-02 0.        2
*
*   jun_Dh    flood     gas-int    slope jn
8211401 0.0772  0.0      1.0       1.0  2
*
*
* component 822 - RFW Heater B1 Tubesheet Shellside (bottom of vertical shell)
8220000 'HTRB1-s3' branch
*
*   #juns vel/flow
8220001 1    0
*
*   area  length vol  theta phi elev  rough hyd  pvbfe
8220101 12.34 1.3307 0.  0.  -90.0 -1.3307 1.5e-4 0.0772 00100
*
*   ebt  press. Uf      Uv      voidv
8220200 000  199.30 338.19  1113.6  0.0
*
*   from      to      juna  kf  kr  fvcahs
8221101 821010000 822000000 0.  0.0  0.  101000
*
```

---

*RELAP5 Model INPUT DECK WITH NEW RECIRCULATION CONTROLS*

```
*     jun_Dh      flood  gas-int slope
8221110 0.0772      0.0   1.0   1.0
*
*     liq_vel    vap_vel    vel.int.
8221201 0.11251    -1.1900      0.
*
*
* component 823 - RFW Heater B1 Drain Piping
8230000 'HTRB1drn' branch
*
*     #juns vel/flow
8230001 1      0
*
*     area  length vol  theta  phi elev  rough hyd  pvbfe
8230101 0.3474 10.0  0.   0.   82.6  9.9167  1.5e-4 0.0  00000
*
*     ebt  press. Uf      Uv      voidv
8230200 000  199.30 338.19  1113.6  0.0
*
*     from      to      juna kf      kr      fvcahs
8231101 822010000 823000000 0.3474 0.0  0.  000100
*
*     liq_vel    vap Vel    vel.int.
8231201 3.7345    3.7345      0.
*
*
* component 825 - RFW HTRB1 Drain Valve
8250000 'LCV6-19' valve
*
*     from      to      juna kf      kr      fvcahs
8250101 823010000 831000000 0.0873 39.0223 39.0223 000000
*
8250201 0      15.463  15.465 0.  * 819,483/3 lb/hr
*
8250300 srvvlv
*
8250301 0450 * valve position demand from htr B1 level control system
*
8250400 1.0    288.0    * max Cv = 288.0 per BFN-VTD-K125-0060 for
*                           4" linear double-seated full-port
8250401 0.0    0.0001   0.0001 * Assume linear Cv vs stroke for globe
8250402 1.0    1.0      1.0   * valve
*
* component 811 - RFW Heater B2 steam supply vlv - jam 7-27-96
```

---

```

8110000 b2stmvlv      valve *jam 7-27-96
*   from      to      juna kf kr fvcahs
8110101 802000000 830000000 0.7854 14.1087 14.1087 000000      *jam 7-27-96
*   liq_vel vap_vel     vel.int.
8110201 0 74.200    202.58      0.0                      *jam 7-26-96
8110300 trpvlv                                *jam 7-26-96
8110301 633                                *jam 7-26-96
*
* component 830 - RFW Heater A2 Steam Dome (top of vertical shell)
8300000 'HTRB2-s1' branch
*
* #juns vel/flow
*8300001 2 0                                *jam 9-27-96
8300001 1 0                                *jam 9-27-96
*
* area length vol theta phi elev rough hyd pvbfe
8300101 12.34 10.2904 0. 0. -90.0 -10.2904 1.5e-4 0.0772 00100
*
* ebt press Uf      Uv      voidv
8300200 000 109.21 304.89    1106.3 0.99832
*
* from      to      juna kf kr fvcahs
*8301101 802000000 830000000 0.7854 14.1087 14.1087 000001      *jam 9-27-96
*8302101 830010000 831000000 12.34 0. 0. 101000      *jam 9-27-96
8301101 830010000 831000000 12.34 0. 0. 101000      *jam 9-27-96
*
* jun_Dh      flood gas-int slope
*8301110 0.0      0.0 1.0 1.0                      *jam 9-27-96
*8302110 0.0772    0.0 1.0 1.0                      *jam 9-27-96
8301110 0.0772    0.0 1.0 1.0                      *jam 9-27-96
*
* liq_vel vap_vel     vel.int.
*8301201 74.200    202.58      0.0                      *jam 9-27-96
*8302201 12.027    7.9267      0.0                      *jam 9-27-96
8301201 12.027    7.9267      0.0                      *jam 9-27-96
*
*
* component 831 - RFW Heater B2 drain junction volume
8310000 'HTRB2-s2' branch
*
* #juns vel/flow
8310001 1 0
*
* area length vol theta phi elev rough hyd pvbfe

```

---

*RELAP5 Model INPUT DECK WITH NEW RECIRCULATION CONTROLS*

8310101 12.34 8.8763 0. 0. -90.0 -8.8763 1.5e-4 0.0772 00100  
\*  
\* ebt press Uf Uv voidv  
8310200 000 109.23 305.04 1106.4 0.97393  
\*  
\* from to juna kf kr fvcahs  
8311101 831010000 832000000 12.34 0. 0. 101000  
\*  
\* jun\_Dh flood gas-int slope  
8311110 0.0772 0.0 1.0 1.0  
\*  
\* liq\_vel vap\_vel vel.int.  
8311201 10.895 3.4280 0.  
\*  
\*  
\* component 832 - RFW Heater B2 Shellside middle volumes  
8320000 'HTRB2-s2' pipe  
\*  
\* nv  
8320001 2  
\*  
\* flowa vn  
8320101 12.34 2 \*Shell area (60.75" ID) minus tube area (5/8"OD)  
\* \*tube area = (2)(1906 tubes)(tube area)  
\*  
\* flowl vn  
8320301 3.0000 2 \*same as corresponding primary tube length  
\*  
\* volume vn  
8320401 0.0 2  
\*  
\* incl vn  
8320601 -90.0 2  
\*  
\* roughness dhyd vn  
8320801 1.5e-4 0.0772 2  
\*  
\* kf kr jn  
8320901 0.0 0.0 1  
\*  
\* pvbfe vn  
8321001 00100 2  
\*  
\* fvcahs jn

```
8321101 101000      1
*
*   ebt  press. Uf      Uv      voidv      VN
8321201 000  109.25 304.86  1106.4  0.91724  0.  1
8321202 000  109.87 298.86  1106.4  5.89169e-02  0.  2
*
*   vel/flow
8321300 0
*
*   liq-flo  vap-flo  vel.int  jn
8321301 4.2183  0.30784  0.      1
*
*   jun_Dh    flood    gas-int    slope  jn
8321401 0.0772  0.0      1.0      1.0  1
*
*
* component 833 - RFW Heater B2 Tubesheet Shellside (bottom of vertical shell)
8330000 'HTRB2-s3' branch
*
*   #juns vel/flow
8330001 1      0
*
*   area  length vol  theta  phi  elev  rough  hyd  pvbfe
8330101 12.34  5.4974 0.  0.  -90.0 -5.4974 1.5e-4 0.0772 00100
*
*   ebt  press. Uf      Uv      voidv
8330200 000  111.52 291.80  1106.6  0.0
*
*   from      to      juna  kf   kr   fvcahs
8331101 832010000  833000000 12.34 0.0  0.  101000
*
*   jun_Dh    flood  gas-int slope
8331110 0.0772  0.0  1.0  1.0
*
*   liq_vel  vap_vel  vel.int.
8331201 0.42029 -0.82167  0.
*
*
* component 834 - RFW Heater B2 Drain Piping
8340000 'HTRB2drn' branch
*
*   #juns vel/flow
8340001 1      0
*
```

---

RELAP5 Model INPUT DECK WITH NEW RECIRCULATION CONTROLS

```
* area length vol theta phi elev rough hyd pvbfe
8340101 0.5475 25.0 0. 0. 65.0 22.6667 1.5e-4 0.0 00000
*
* ebt press. Uf Uv voidv
8340200 000 199.30 338.19 1113.6 0.0
*
* from to juna kf kr fvcahs
8341101 833010000 834000000 0.5475 0.0 0. 000100
*
* liq_vel vap_vel vel.int.
8341201 8.2628 7.7109 0.
*
*
* component 835 - RFW HTRB2 Drain Valve
8350000 'LCV6-22A' valve
*
* from to juna kf kr fvcahs
8350101 834010000 841000000 0.3491 22.8653 22.8653 000000
*
8350201 1 228.5294 0.0 0. *2,468,117/3 lb/hr
*
8350300 srvvlv
*
8350301 0458 * valve position demand based from htr B2 level control *prb 01-24-
96 10:40am
*
8350400 1.0 950.0 * max Cv = 950.0 per BFN-VTD-K125-0060 for
* 8" linear double-seated full-port
8350401 0.0 0.0001 0.0001 * Assume linear Cv vs stroke for globe
8350402 1.0 1.0 1.0 * valve
*
*
* component 837 - RFW HTRB2 Bypass Valve *prb 01-23-96
01:05pm
8370000 'LCV6-4B' valve *prb 01-23-96 01:05pm
*
* from to juna kf kr fvcahs *prb 01-23-96 01:05pm
*8370101 834010000 738000000 0.3491 0.0 0.0 000000 *prb 01-23-96
01:05pm
8370101 834010000 738000000 0.3491 22.8653 22.8653 000000 *prb 01-23-96
01:05pm
*
8370201 1 0.0 0.0 0.0 *prb 01-23-96 01:05pm
* *prb 01-23-96 01:05pm
* *prb 01-23-96 01:05pm
```

---

```

8370300 srvv1v *prb 01-23-96 01:05pm
*
8370301 0460 * valve position demand *prb 01-23-96 01:05pm
* *prb 01-23-96 01:05pm
8370400 1.0    950.0   * max Cv = 950.0 per BFN-VTD-K125-0060 for *prb 01-23-96
01:05pm
*          8" linear double-seated full-port *prb 01-23-96 01:05pm
8370401 0.0    0.0001  0.0001 * Assume linear Cv vs stroke for globe *prb 01-23-96
01:05pm
8370402 1.0    1.0     1.0   * valve *prb 01-23-96 01:05pm
*
* component 812 - RFW Heater B3 steam supply vlv - jam 7-27-96
8120000 b3stmvlv valve *jam 7-27-96
* from to juna kf kr fvcahs
8120101 803000000 840000000 3.1416 23.4899 23.4899 000000 *jam 7-27-96
* liq_vel vap Vel vel.int.
8120201 0 7.7263 124.84 0.0 *jam 7-26-96
8120300 trpv1v *jam 7-26-96
8120301 633      *jam 7-26-96
*
* component 840 - RFW Heater A3 Steam Dome (top of vertical shell)
8400000 'HTRB3-s1' branch
*
* #juns vel/flow
*8400001 2 0 *jam 7-26-96
8400001 1 0 *jam 7-26-96
*
* area length vol theta phi elev rough hyd pvbfe
8400101 13.5335 12.4284 0. 0. -90.0 -12.4284 1.5e-4 0.0864 00100
*
* ebt press Uf Uv voidv
8400200 000 69.300 271.84 1099.9 0.99613
*
* from to juna kf kr fvcahs
*8401101 803000000 840000000 3.1416 23.4899 23.4899 000000 *jam 7-26-96
*8402101 840010000 841000000 13.5335 0. 0. 101000 *jam 7-26-96
8401101 840010000 841000000 13.5335 0. 0. 101000 *jam 7-26-96
*
* jun_Dh flood gas-int slope
*8401110 0.0 0.0 1.0 1.0 *jam 7-26-96
*8402110 0.0864 0.0 1.0 1.0 *jam 7-26-96
8401110 0.0864 0.0 1.0 1.0 *jam 7-26-96
*
* liq_vel vap Vel vel.int.

```

---

*RELAP5 Model INPUT DECK WITH NEW RECIRCULATION CONTROLS*

```
*8401201 7.7263    124.84      0.          *jam 7-26-96
*8402201 8.9171    19.266     0.          *jam 7-26-96
8401201 8.9171    19.266     0.          *jam 7-26-96
*
*
* component 841 - RFW Heater B3 drain junction volume
8410000 'HTRB3-s2' branch
*
* #juns vel/flow
8410001 1    0
*
* area length vol theta phi elev rough hyd pvbfe
8410101 13.5335 11.1133 0.   0.   -90.0 -11.1133 1.5e-4 0.0864 00100
*
* ebt press Uf      Uv      voidv
8410200 000 69.309 271.88   1100.0  0.96083
*
* from      to      juna kf      kr      fvcahs
8411101 841010000 842000000 13.5335 0.   0.   101000
*
* jun_Dh      flood gas-int slope
8411110 0.0864    0.0  1.0  1.0
*
* liq_vel      vap_vel      vel.int.
8411201 9.3922    5.8524    0.
*
*
* component 842 - RFW Heater B3 Shellside middle & lower volumes
8420000 'HTRB3-s3' pipe
*
* nv
8420001 4
*
* flowa      vn
8420101 13.5335    1
8420102 6.7667    4  *volumes 2-4 share space with subcooling zone
*
* flowl      vn
8420301 3.0000    2  *same as corresponding primary tube length
8420302 7.0534    4  *same as corresponding primary tube length
*
* volume      vn
8420401 0.0       4
*
```

---

```

*      incl      vn
8420601 -90.0      4
*
*      roughness   dhyd  vn
8420801 1.5e-4     0.0864 4
*
*      kf   kr   jn
8420901 0.0   0.0   3
*
*      pvbfe      vn
8421001 00100     4
*
*      fvcahs     jn
8421101 101000    3
*
*      ebt  press. Uf      Uv      voidv      VN
8421201 000  69.322 271.84  1100.0  0.98918  0.  1
8421202 000  69.529 271.38  1099.9  0.16248  0.  2
8421203 000  72.030 269.21  1100.5  2.68060e-06 0.  3
8421204 000  74.835 267.04  1101.0  8.83757e-06 0.  4
*
*      vel/flow
8421300 0
*
*      liq-flo  vap-flo      vel.int     jn
8421301 70.794  0.44862  0.        1
8421302 0.75643 -0.90429  0.        2
8421303 0.63162  0.77799  0.        3
*
*      jun_Dh      flood      gas-int      slope  jn
8421401 0.0864    0.0      1.0      1.0  3
*
*
* component 843 - RFW Heater B3 Subcooling Zone
8430000 'HTRB3-s4'  pipe
*
*      nv
8430001 3
*
*      flowa      vn
8430101 6.7667     3
*
*      flowl      vn
8430301 3.0000     1      *same as corresponding primary tube length

```

8430302 7.0534 3 \*same as corresponding primary tube length  
\*  
\* volume vn  
8430401 0.0 3  
\*  
\* incl vn  
8430601 -90.0 3  
\*  
\* roughness dhyd vn  
8430801 1.5e-4 0.0864 3  
\*  
\* kf kr jn  
8430901 0.0 0.0 2  
\*  
\* pvbfe vn  
8431001 00100 3  
\*  
\* fvcahs jn  
8431101 101000 2  
\*  
\* ebt press. Uf Uv voidv VN  
8431201 000 69.415 233.60 1100.1 8.99481e-02 0. 1  
8431202 000 71.404 226.39 1100.4 1.57683e-07 0. 2  
8431203 000 74.264 242.61 1100.9 3.17648e-06 0. 3  
\*  
\* vel/flow  
8431300 0  
\*  
\* liq-flo vap-flo vel.int jn  
8431301 3.53376e-02 -1.6814 0. 1  
8431302 3.03089e-02 3.099473e-02 0. 2  
\*  
\* jun\_Dh flood gas-int slope jn  
8431401 0.0864 0.0 1.0 1.0 2  
\*  
\* component 844 - RFW Heater B3 Drain Piping  
8440000 'HTRB3drn' branch  
\*  
\* #juns vel/flow  
8440001 1 1  
\*  
\* area length vol theta phi elev rough hyd pvbfe  
8440101 0.5475 5.0 0. 0. 0. 0. 1.5e-4 0.0 00000

\*  
\* ebt press. Uf Uv voidv  
8440200 000 199.30 338.19 1113.6 0.0  
\*  
\* from to juna kf kr fvcahs  
8441101 843010000 844000000 0.5475 0.0 0. 000100  
\*  
\* liq\_vel vap\_vel vel.int.  
8441201 228.5294 0.0 0.  
\*  
\*  
\* component 845 - RFW HTRB3 Drain Valve  
8450000 'LCV6-23' valve  
\*  
\* from to juna kf kr fvcahs  
8450101 844010000 852000000 0.3491 7.4816 7.4816 000000  
\*  
8450201 0 12.689 44.886 0. \*2,468,117/3 lb/hr target  
\*  
8450300 srvvlv  
\*  
8450301 0472 \* valve position demand based on htr B3 level error  
\*  
8450400 1.0 950.0 \* max Cv = 950.0 per BFN-VTD-K125-0060 for  
\* 8" linear double-seated full-port  
8450401 0.0 0.0001 0.0001 \* Assume linear Cv vs stroke for globe  
8450402 1.0 1.0 1.0 \* valve  
\*  
\*  
8470000 'HTRB3jun' mtpljun  
8470001 2 0  
\*  
\* from to juna kf kr fvcahs incr1 incr2 jn  
8470011 842020004 843010003 .1 5. 5. 001000 1. 1. 1. 0 0 0 1  
8470021 842040004 843030003 1. 5. 5. 001000 1. 1. 1. 0 0 0 2  
\*  
\* liq-flo vap-flo jn  
8471011 4.0946 4.0946 1  
8471021 0.0 0.0 2  
\*  
\* component 813 - RFW Heater B4 steam supply vlv - jam 7-27-96  
8130000 b4stv1 valve \*jam 7-27-96  
\* from to juna kf kr fvcahs  
8130101 805000000 850000000 2.8229 6197.85 6197.85 000000 \*jam 7-27-96

```
*      liq_vel    vap_vel      vel.int.
8130201 0   0.83437   24.814       0.0          *jam 7-26-96
8130300 trpvlv                         *jam 7-26-96
8130301 633                         *jam 7-26-96
*
*
* component 850 - RFW Heater A4 (top of shell nearest tubesheet)
8500000 'HTRB4-s1' branch
*
* #juns vel/flow
*8500001 2   0          *jam 7-26-96
8500001 1   0          *jam 7-26-96
*
* area length vol theta phi elev rough hyd pvbfe
8500101 0.0  2.9375 153.2704 0. -90.0 -2.9375 1.5e-4 0.1309 00100
*
* ebt press Uf      Uv      voidv
8500200 000  27.276 213.37   1086.4  0.99962
*
* from      to      juna kf      kr      fvcahs
*8501101 805000000 850000000 2.8229 6197.85 6197.85 000000 *jam 7-27-96
*8502101 850010000 851000000 9.7832 0. 0. 001003 *jam 7-27-96
8501101 850010000 851000000 9.7832 0. 0. 001003 *jam 7-27-96
*
* jun_Dh      flood gas-int slope
*8501110 0.0      0.0  1.0  1.0          *jam 7-27-96
*8502110 0.1309  0.0  1.0  1.0          *jam 7-27-96
8501110 0.1309  0.0  1.0  1.0          *jam 7-27-96
*
* liq_vel    vap Vel      vel.int.
*8501201 0.83437  24.814       0.          *jam 7-27-96
*8502201 9.1016   8.7249       0.          *jam 7-27-96
8501201 9.1016   8.7249       0.          *jam 7-27-96
*
* component 814 - RFW Heater B4 steam supply vlv - jam 7-27-96
8140000 b4stv1v2 valve *jam 7-27-96
* from      to      juna kf      kr      fvcahs
8140101 804000000 851000000 2.8229 4.4554 4.4554 000000 *jam 7-27-96
* liq_vel    vap Vel      vel.int.
8140201 0  41.854   271.59      0.0          *jam 7-26-96
8140300 trpvlv                         *jam 7-26-96
8140301 633                         *jam 7-26-96
*
```

---

\* component 851 - RFW Heater A4 (top of shell furthest from tubesheet)  
 8510000 'HTRB4-s2' branch  
 \*  
 \* #juns vel/flow  
 \*8510001 2 0 \*jam 7-27-96  
 8510001 1 0 \*jam 7-27-96  
 \*  
 \* area length vol theta phi elev rough hyd pvbfe  
 8510101 0.0 2.9375 265.4972 0. -90.0 -2.9375 1.5e-4 0.1309 00100  
 \*  
 \* ebt press Uf Uv voidv  
 8510200 000 27.276 213.38 1086.4 0.99996  
 \*  
 \* from to juna kf kr fvcahs  
 \*8511101 804000000 851000000 2.8229 4.4554 4.4554 000000 \*jam 7-27-96  
 \*8512101 851010000 852000000 153.4359 0. 0. 101000 \*jam 7-27-96  
 8511101 851010000 852000000 153.4359 0. 0. 101000 \*jam 7-27-96  
 \*  
 \* jun\_Dh flood gas-int slope  
 \*8511110 0.0 0.0 1.0 1.0 \*jam 7-27-96  
 \*8512110 0.1309 0.0 1.0 1.0 \*jam 7-27-96  
 8511110 0.1309 0.0 1.0 1.0 \*jam 7-27-96  
 \*  
 \* liq\_vel vap\_vel vel.int.  
 \*8511201 41.854 271.59 0. \*jam 7-27-96  
 \*8512201 38.784 4.5911 0. \*jam 7-27-96  
 8511201 38.784 4.5911 0. \*jam 7-27-96  
 \*  
 \*  
 \* component 852 - RFW Heater B4 (bottom of shell furthest from tubesheet)  
 8520000 'HTRB4-s3' branch  
 \*  
 \* #juns vel/flow  
 8520001 0 0  
 \*  
 \* area length vol theta phi elev rough hyd pvbfe  
 8520101 0.0 2.9375 265.4972 0. -90.0 -2.9375 1.5e-4 0.1309 00100  
 \*  
 \* ebt press Uf Uv voidv  
 8520200 000 27.292 209.34 1086.4 0.52487  
 \*  
 \*  
 \* component 853 - RFW Heater B4 Subcooling Zone  
 8530000 'HTRB4-s4' branch

---

*RELAP5 Model INPUT DECK WITH NEW RECIRCULATION CONTROLS*

```
*  
* #juns vel/flow  
8530001 1 0  
*  
* area length vol theta phi elev rough hyd pvbfe  
8530101 9.7832 15.6667 0.0 0. 0.0 0.0 1.5e-4 0.1309 00100  
*  
* ebt press Uf Uv voidv  
8530200 000 26.746 170.92 1086.2 2.46992e-02  
*  
* from to juna kf kr fvcahs  
8531101 852010000 853000000 1.7671 5.0 5.0 001000  
*  
* jun_Dh flood gas-int slope  
8531110 0.1309 0.0 1.0 1.0  
*  
* liq_vel vap_vel vel.int.  
8531201 6.4784 37.792 0.  
*  
*  
* component 854 - RFW Heater B4 Drain Piping  
8540000 'HTRB4drn' branch  
*  
* #juns vel/flow  
8540001 1 0  
*  
* area length vol theta phi elev rough hyd pvbfe  
8540101 1.6230 10.0 0. 0. 50.15 7.6771 1.5e-4 0.0 00000  
*  
* ebt press. Uf Uv voidv  
8540200 000 26.326 174.57 1085.9 7.05438e-04  
*  
* from to juna kf kr fvcahs  
8541101 853010000 854000000 1.6230 0.0 0. 000100  
*  
* liq_vel vap_vel vel.int.  
8541201 3.1304 4.5777 0.  
*  
*  
* component 855 - RFW HTRB4 Drain Valve  
8550000 'LCV6-29A' valve  
*  
* from to juna kf kr fvcahs  
8550101 854010000 860010003 0.7854 23.7848 23.7848 000000
```

\*  
8550201 0 7.5514 7.5514 0. \*3,184,100/3 lb/hr target  
\*  
8550300 srvv lv  
\*  
8550301 0482 \* valve position demand based on htr B4 level error  
\*  
8550400 1.0 2180.0 \* max Cv = 2180.0 per BFN-VTD-K125-0060 for  
\* 12" linear double-seated full-port  
8550401 0.0 0.0001 0.0001 \* Assume linear Cv vs stroke for globe  
8550402 1.0 1.0 1.0 \* valve  
\*  
\*  
\* component 857 - RFW HTRB4 Bypass Valve \*prb 01-24-96  
10:22am  
8570000 'LCV6-29B' valve \*prb 01-24-96 10:22am  
\* \*prb 01-24-96 10:22am  
\* from to juna kf kr fvcahs \*prb 01-24-96 10:22am  
\*8570101 854010000 758000000 0.7854 0.0 0.0 000000 \*prb 01-24-96  
10:22am  
8570101 854010000 758000000 0.7854 23.7848 23.7848 000000 \*jam 7-26-96  
\* \*prb 01-24-96 10:22am  
\*prb 01-24-96 10:22am  
\*prb 01-24-96 10:22am  
\*prb 01-24-96 10:22am  
8570201 1 0.0 0.0 0.0 \*prb 01-24-96 10:22am  
\* \*prb 01-24-96 10:22am  
\*prb 01-24-96 10:22am  
\*prb 01-24-96 10:22am  
\*prb 01-24-96 10:22am  
8570300 srvv lv  
\*  
8570301 0460 \* valve position demand \*prb 01-24-96 10:22am  
\* \*prb 01-24-96 10:22am  
8570400 1.0 2180.0 \* max Cv = 2180.0 per BFN-VTD-K125-0060 for \*prb 01-24-  
96 10:22am  
\* 12" linear double-seated full-port \*prb 01-24-96 10:22am  
8570401 0.0 0.0001 0.0001 \* Assume linear Cv vs stroke for globe \*prb 01-24-96  
10:22am  
8570402 1.0 1.0 1.0 \* valve \*prb 01-24-96 10:22am  
\*  
\*  
\* component 860 - RFW Heater B5 Flash Tank  
8600000 'FL-TankB' pipe  
\*  
\* nv  
8600001 4  
\*  
\* flowa vn  
8600101 16.4988 4

\*  
\* flowl vn  
8600301 1.4583 1  
8600302 2.9583 2  
8600303 2.500 3  
8600304 5.2188 4  
\*  
\* volume vn  
8600401 0.0 4  
\*  
\* incl vn  
8600601 -90.0 4  
\*  
\* roughness dhyd vn  
8600801 0.0 0.0 4  
\*  
\* kf kr jn  
8600901 0.0 0.0 3  
\*  
\* pvbfe vn  
8601001 00010 4  
\*  
\* fvcahs jn  
8601101 101000 3  
\*  
\* ebt press. Uf Uv voidv VN  
8601201 000 9.6940 160.59 1071.8 0.98351 0. 1  
8601202 000 9.6954 159.92 1071.8 0.99883 0. 2  
8601203 000 9.9628 160.43 1072.2 0.53140 0. 3  
8601204 000 12.394 159.48 1075.2 0.00000e+00 0. 4  
\*  
\* vel/flow  
8601300 0  
\*  
\* liq-flo vap-flo vel.int jn  
8601301 19.581 0.27746 0. 1  
8601302 282.58 0.63630 0. 2  
8601303 0.63560 -4.2606 0. 3  
\*  
\* jun\_Dh flood gas-int slope jn  
8601401 0.0 0.0 1.0 1.0 3  
\*  
\* component 861 - RFW Heater B5 Drain Piping

```
8610000 'HTRB5drn' branch
*
* #juns vel/flow
8610001 1 0
*
* area length vol theta phi elev rough hyd pvbfe
8610101 2.9483 10.0 0. 0. 0.0 0.0 1.5e-4 0.0 00000
*
* ebt press. Uf Uv voidv
8610200 000 13.552 159.14 1076.4 0.0
*
* from to juna kf kr fvcahs
8611101 860010000 861000000 2.9483 0.0 0. 000100
*
* liq_vel vap_vel vel.int.
8611201 1.6705 1.9099 0.
*
* component 815 - RFW Heater B5 steam supply vlv - jam 7-27-96
8150000 b5stvlv1 valve *jam 7-27-96
* from to juna kf kr fvcahs
8150101 806000000 862000000 9.0164 6243.8 6243.8 000000 *jam 7-27-96
* liq_vel vap_vel vel.int.
8150201 0 0.49198 22.264 0.0 *jam 7-26-96
8150300 trpvlv *jam 7-26-96
8150301 633 *jam 7-26-96
*
*
* component 862 - RFW Heater B5 (top of shell nearest tubesheet)
8620000 'HTRB5-s1' branch
*
* #juns vel/flow
*8620001 3 0 *jam 7-27-96
8620001 2 0 *jam 7-27-96
*
* area length vol theta phi elev rough hyd pvbfe
8620101 0.0 2.8333 170.5096 0. -90.0 -2.8333 1.5e-4 0.1128 00100
*
* ebt press Uf Uv voidv
8620200 000 9.4593 158.61 1071.3 0.99998
*
* from to juna kf kr fvcahs
*8621101 806000000 862000000 9.0164 6243.8 6243.8 001000
*jam 7-27-96
```

---

RELAP5 Model INPUT DECK WITH NEW RECIRCULATION CONTROLS

```
*8622101 862010000    863000000    8.7069 0. 0. 001003
*jam 7-27-96
8621101 862010000    863000000    8.7069 0. 0. 001003
*jam 7-27-96
*8623101 8600000000    862000000    0.7530 1.50 1.50 001000
*jam 7-27-96
8622101 8600000000    862000000    0.7530 1.50 1.50 001000
*jam 7-27-96
*
*   jun_Dh      flood  gas-int slope
*8621110 2.3958      0.0  1.0  1.0                                *jam 7-27-96
*8622110 0.1128      0.0  1.0  1.0                                *jam 7-27-96
8621110 0.1128      0.0  1.0  1.0                                *jam 7-27-96
*8623110 0.0        0.0  1.0  1.0                                *jam 7-27-96
8622110 0.0        0.0  1.0  1.0                                *jam 7-27-96
*
*   liq_vel    vap_vel    vel.int.
*8621201 0.49198    22.264      0.                                *jam 7-27-96
*8622201 -31.397   -26.477      0.                                *jam 7-27-96
8621201 -31.397   -26.477      0.                                *jam 7-27-96
*8623201 -30.730    237.56     0.                                *jam 7-27-96
8622201 -30.730    237.56     0.                                *jam 7-27-96
*
* component 816 - RFW Heater B5 steam supply vlv - jam 7-27-96
8160000 b5stvlv2    valve *jam 7-27-96
*   from      to      juna kf kr fvcahs
8160101 807000000    863000000    9.0164 2.9489 2.9489 000000    *jam 7-27-96
*   liq_vel    vap Vel    vel.int.
8160201 0 26.337    161.50     0.0                                *jam 7-26-96
8160300 trpvlv
8160301 633
*
*
* component 863 - RFW Heater B5 (top of shell furthest from tubesheet)
8630000 'HTRB5-s2' branch
*
*   #juns  vel/flow
*8630001 2 0
*8630001 1 0                                *jam 7-27-96
*
*   area  length vol  theta phi elev  rough hyd  pvbfe
8630101 0.0 2.8333 128.8119 0. -90.0 -2.8333 1.5e-4 0.1128 00100
*
*   ebt  press  Uf      Uv      voidv
```

8630200 000 9.4589 158.60 1071.4 0.99992  
\*  
\* from to juna kf kr fvcahs  
\*8631101 807000000 863000000 9.0164 2.9489 2.9489 001000 \*jam 9-27-96  
\*8632101 863010000 864000000 83.8342 0. 0. 001000 \*jam 9-27-96  
8631101 863010000 864000000 83.8342 0. 0. 001000 \*jam 9-27-96  
\*  
\* jun\_Dh flood gas-int slope  
\*8631110 2.3958 0.0 1.0 1.0 \*jam 9-27-96  
\*8632110 0.1128 0.0 1.0 1.0 \*jam 9-27-96  
8631110 0.1128 0.0 1.0 1.0 \*jam 9-27-96  
\*  
\* liq\_vel vap\_vel vel.int.  
\*8631201 26.337 161.50 0. \*jam 9-27-96  
\*8632201 34.542 8.5995 0. \*jam 9-27-96  
8631201 34.542 8.5995 0. \*jam 9-27-96  
\*  
\*  
\* component 864 - RFW Heater B5 (bottom of shell furthest from tubesheet)  
8640000 'HTRB5-s3' branch  
\*  
\* #juns vel/flow  
8640001 2 0  
\*  
\* area length vol theta phi elev rough hyd pvbfe  
8640101 0.0 2.8333 128.8119 0. -90.0 -2.8333 1.5e-4 0.1128 00100  
\*  
\* ebt press Uf Uv voidv  
8640200 000 9.6340 148.68 1071.7 0.39598  
\*  
\* from to juna kf kr fvcahs  
8641101 864010004 865010003 8.7069 0. 0. 001000  
8642101 864010000 866000000 0.8685 1.5 100.0 001001 \* discourage reverse  
flow  
\*  
\* jun\_Dh flood gas-int slope  
8641110 0.1128 0.0 1.0 1.0  
8642110 0.6651 0.0 1.0 1.0  
\*  
\* liq\_vel vap\_vel vel.int.  
8641201 3.4725 -8.5376 0.  
8642201 0.47271 -9.3520 0.  
\*

\* component 865 - RFW Heater B5 (bottom of shell nearest tubesheet)  
8650000 'HTRB5-s4' branch  
\*  
\* #juns vel/flow  
8650001 2 0  
\*  
\* area length vol theta phi elev rough hyd pvbfe  
8650101 0.0 2.8333 170.5096 0. -90.0 -2.8333 1.5e-4 0.1128 00100  
\*  
\* ebt press Uf Uv voidv  
8650200 000 9.4996 134.05 1071.5 0.44943  
\*  
\* from to juna kf kr fvcahs  
8651101 862010000 865000000 110.9722 0.0 0.0 001000  
8652101 865010000 866000000 0.8685 1.5 100.0 001001 \* discourage reverse  
flow  
\*  
\* jun\_Dh flood gas-int slope  
8651110 0.1128 0.0 1.0 1.0  
8652110 0.6651 0.0 1.0 1.0  
\*  
\* liq\_vel vap\_vel vel.int.  
8651201 37.265 5.8851 0.  
8652201 -0.42722 -10.256 0.  
\*  
\*  
\* component 866 - RFW Heater B5 Collector  
8660000 'Coll-B5' branch  
\*  
\* #juns vel/flow  
8660001 1 0  
\*  
\* area length vol theta phi elev rough hyd pvbfe  
8660101 4.9087 0.0 145.2255 0. 0.0 0.0 1.5e-4 0.0 00000  
\*  
\* ebt press Uf Uv voidv  
8660200 000 9.9594 146.78 1072.2 0.10641  
\*  
\* from to juna kf kr fvcahs  
8661101 866010002 860030003 4.9087 1.0 0.50 031000  
\*  
\* jun\_Dh flood gas-int slope  
8661110 2.5 0.0 1.0 1.0  
\*

---

```

*      liq_vel    vap_vel      vel.int.
8661201 -0.18014   -1.3910      0.
*
*
* component 867 - RFW HTRB5 Drain Valve
*
8670000 'LCV6-32A'  valve
*
*      from      to      juna      kf      kr      fvcahs
8670101 861010000 969000000 0.7854  5.6209  5.6209  001000
*
8670201 0      9.4      9.4      0.  *3,184,100/3 lb/hr target
*
8670300 srvv1v
*
8670301 0493 * valve position demand based on htr B5 level error
*
8670400 1.0      2180.0  * max Cv = 2180.0 per BFN-VTD-K125-0060 for
*                      12" linear double-seated full-port
8670401 0.0      0.0001  0.0001 * Assume linear Cv vs stroke for globe
8670402 1.0      1.0      1.0      * valve
*
*
* component 868 - RFW HTRB5 Bypass Valve                                *prb 01-24-96
10:22am
8680000 'LCV6-32B'  valve                                         *prb 01-24-96 10:22am
*
*      from      to      juna      kf      kr      fvcahs      *prb 01-24-96 10:22am
*8680101 861010000 969000000 0.7854  0.0      0.0      000000      *prb 01-24-96
10:22am
8680101 861010000 969000000 0.7854  0.0      5.6209  001000      *jam 7-26-96
*
8680201 1      0.0      0.0      0.0      *prb 01-24-96 10:22am
*
8680300 srvv1v                                         *prb 01-24-96 10:22am
*
8680301 0495 * valve position demand                         *prb 01-24-96 10:22am
*
8680400 1.0      2180.0  * max Cv = 2180.0 per BFN-VTD-K125-0060 for  *prb 01-24-
96 10:22am
*
*                      12" linear double-seated full-port *prb 01-24-96 10:22am
8680401 0.0      0.0001  0.0001 * Assume linear Cv vs stroke for globe *prb 01-24-96
10:22am
8680402 1.0      1.0      1.0      * valve                         *prb 01-24-96 10:22am

```

\*  
\*  
\*-----  
\* Train C Feedwater Heaters - Shellside  
\*-----  
\*  
\* component 901 - RFW HTR C1 Steam Supply  
9010000 'STM-src1' tmdpvol  
\*  
\* area length vol azmth incl elev rough hyd fe  
9010101 5.0 10.0 0.0 0.0 90.0 10.0 0.0 0.0 10  
\*  
\* ebt trip variable  
9010200 002 0 cntrlvar 010 \*RX Power, % \*prb 01-25-96 11:25pm  
\*  
\* %pwr press qual.  
9010201 0.0 7.545 0.9107 \*extrapolated \*prb 01-26-96 10:38pm  
9010202 25.0 55.019 0.9022 \*prb 01-26-96 10:38pm  
9010203 50.0 110.02 0.8907 \*prb 01-26-96 10:38pm  
9010204 75.0 153.73 0.8837 \*prb 01-26-96 10:38pm  
9010205 90.0 186.86 0.8791 \*prb 01-26-96 10:38pm  
9010206 100.0 209.01 0.8765 \*prb 01-26-96 10:38pm  
\*  
\*  
\* component 902 - RFW HTR C2 Steam Supply  
9020000 'STM-src2' tmdpvol  
\*  
\* area length vol azmth incl elev rough hyd fe  
9020101 5.0 10.0 0.0 0.0 0.0 0.0 0.0 0.0 10  
\*  
\* ebt trip variable  
9020200 002 0 cntrlvar 010 \*RX Power, % \*prb 01-26-96 11:55pm  
\*  
\* %pwr press qual.  
9020201 0.0 3.43 0.9607 \*extrapolated \*prb 01-26-96 11:55pm  
9020202 25.0 31.30 0.9587 \*prb 01-26-96 11:55pm  
9020203 50.0 61.70 0.9533 \*prb 01-26-96 11:55pm  
9020204 75.0 88.31 0.9530 \*prb 01-26-96 11:55pm  
9020205 90.0 107.20 0.9508 \*prb 01-26-96 11:55pm  
9020206 100.0 119.81 0.9495 \*prb 01-26-96 11:55pm  
\*  
\*  
\* component 903 - RFW HTR C3 Steam Supply  
9030000 'STM-src3' tmdpvol

---

```

*
* area length vol azmth incl elev rough hyd fe
9030101 5.0 10.0 0.0 0.0 0.0 0.0 0.0 0.0 10
*
* ebt trip variable
9030200 002 0 cntrlvar 010 *RX Power, %           *prb 01-26-96 11:55pm
*
* %pwr press qual.                                *prb 01-26-96 11:55pm
9030201 0.0 1.99 0.9421      *extrapolated       *prb 01-26-96 11:55pm
9030202 25.0 19.80 0.9389    *prb 01-26-96 11:55pm
9030203 50.0 38.70 0.9316    *prb 01-26-96 11:55pm
9030204 75.0 55.97 0.9305    *prb 01-26-96 11:55pm
9030205 90.0 67.71 0.9276    *prb 01-26-96 11:55pm
9030206 100.0 75.51 0.9259   *prb 01-26-96 11:55pm
*
*
* component 904 - RFW HTR C4 Steam Supply #1
9040000 'STMsric4A' tmdpvol
*
* area length vol azmth incl elev rough hyd fe
9040101 2.8229 10.0 0.0 0.0 0.0 0.0 0.0 0.0 10
*
* ebt trip variable
9040200 002 0 cntrlvar 010 *RX Power, %           *prb 01-27-96 10:08am
*                                         *prb 01-27-96 10:08am
* %pwr press qual.                                *prb 01-27-96 10:08am
9040201 0.0 0.75 0.6576      *extrapolated       *prb 01-27-96 10:08am
9040202 25.0 7.66 0.7094     *prb 01-27-96 10:08am
9040203 50.0 14.80 0.8077    *prb 01-27-96 10:08am
9040204 75.0 21.59 0.8363    *prb 01-27-96 10:08am
9040205 90.0 26.05 0.8437    *prb 01-27-96 10:08am
9040206 100.0 29.00 0.8482   *prb 01-27-96 10:08am
*
*
* component 905 - RFW HTR C4 Steam Supply #2
9050000 'STMsric4B' tmdpvol
*
* area length vol azmth incl elev rough hyd fe
9050101 2.8229 10.0 0.0 0.0 0.0 0.0 0.0 0.0 10
*
* ebt trip variable
9050200 002 0 cntrlvar 010 *RX Power, %           *prb 01-27-96 10:08am
*                                         *prb 01-27-96 10:08am
* %pwr press qual.                                *prb 01-27-96 10:08am

```

9050201 0.0 1.127 0.3577 \*extrapolated \*prb 01-27-96 10:08am  
9050202 25.0 12.30 0.4394 \*prb 01-27-96 10:08am  
9050203 50.0 24.00 0.5701 \*prb 01-27-96 10:08am  
9050204 75.0 34.91 0.6273 \*prb 01-27-96 10:08am  
9050205 90.0 42.24 0.6434 \*prb 01-27-96 10:08am  
9050206 100.0 47.12 0.6485 \*prb 01-27-96 10:08am  
\*  
\*  
\* component 906 - RFW HTR C5 Steam Supply #1 (From "B" LP Turbine, point MR5)  
9060000 'STMsrc5A' tmdpvol  
\*  
\* area length vol azmth incl elev rough hyd fe  
9060101 9.0164 10.0 0.0 0.0 0.0 0.0 0.0 10  
\*  
\* ebt trip variable  
9060200 002 0 cntrlvar 010 \*RX Power, % \*prb 01-27-96 12:31pm  
\* \*prb 01-27-96 12:31pm  
\* %pwr press qual. \*prb 01-27-96 12:31pm  
9060201 0.0 0.30 0.064 \*extrapolated \*prb 01-27-96 12:31pm  
9060202 25.0 4.59 0.1630 \*prb 01-27-96 12:31pm  
9060203 50.0 8.88 0.2620 \*prb 01-27-96 12:31pm  
9060204 75.0 13.01 0.5389 \*prb 01-27-96 12:31pm  
9060205 90.0 15.71 0.5008 \*prb 01-27-96 12:31pm  
9060206 100.0 17.49 0.4806 \*prb 01-27-96 12:31pm  
\*  
\*  
\* component 907 - RFW HTR C5 Steam Supply #2 (From "C" LP Turbine, point #5)  
9070000 'STMsrc5B' tmdpvol  
\*  
\* area length vol azmth incl elev rough hyd fe  
9070101 9.0164 10.0 0.0 0.0 0.0 0.0 0.0 10  
\*  
\* ebt trip variable  
9070200 002 0 cntrlvar 010 \*RX Power, % \*prb 01-27-96 12:31pm  
\* \*prb 01-27-96 12:31pm  
\* %pwr press qual. \*prb 01-27-96 12:31pm  
9070201 0.0 0.45 0.2807 \*extrapolated \*prb 01-27-96 12:31pm  
9070202 25.0 2.69 0.4153 \*prb 01-27-96 12:31pm  
9070203 50.0 5.05 0.5633 \*prb 01-27-96 12:31pm  
9070204 75.0 7.23 0.6912 \*prb 01-27-96 12:31pm  
9070205 90.0 8.66 0.7368 \*prb 01-27-96 12:31pm  
9070206 100.0 9.60 0.7545 \*prb 01-27-96 12:31pm  
\*  
\*

---

\* component 908 - Moisture Separator  
 9080000 'Mois-Sep' tmdpvol  
 \*  
 \* area length vol azmth incl elev rough hyd fe  
 9080101 5.0 10.0 0.0 0.0 0.0 0.0 0.0 10  
 \*  
 \* ebt trip variable \*prb 01-26-96 11:47pm  
 9080200 001 0 cntrlvar 010 \*RX Power, % \*prb 01-26-96 11:47pm  
 \*  
 \* %pwr temp qual. \*prb 01-26-96 11:47pm  
 9080201 0.0 253.12 0.0 \*extrapolated \*prb 01-26-96 11:47pm  
 9080202 25.0 286.00 0.0 \*prb 01-26-96 11:47pm  
 9080203 50.0 333.40 0.0 \*prb 01-26-96 11:47pm  
 9080204 75.0 359.02 0.0 \*prb 01-26-96 11:47pm  
 9080205 90.0 374.74 0.0 \*prb 01-26-96 11:47pm  
 9080206 100.0 384.07 0.0 \*prb 01-26-96 11:47pm  
 \*  
 \*  
 \* component 909: Moisture Separator Drain to HTR C2  
 9090000 'MS-drain' tmdpjun  
 9090101 908000000 931000000 1.3963  
 \*  
 \* trip variable \*prb 01-26-96 11:47pm  
 \*9090200 1 0 cntrlvar 010 \*RX Power, % \*prb 01-26-96 11:47pm  
 9090200 1 634 cntrlvar 010 \*RX Power, % \*jam 7-27-96  
 \*  
 \* %pwr liq.flow . \*prb 01-26-96 11:47pm  
 9090201 0.0 0.0 0.0 0.0 \*prb 01-26-96 11:47pm  
 9090202 25.0 22.4352 0.0 0.0 \*242,300/3 lb/hr \*prb 01-26-96 11:47pm  
 9090203 50.0 54.9444 0.0 0.0 \*593,400/3 lb/hr \*prb 01-26-96 11:47pm  
 9090204 75.0 82.8714 0.0 0.0 \*895,011/3 lb/hr \*prb 01-26-96 11:47pm  
 9090205 90.0 105.3094 0.0 0.0 \*1,137,342/3 lb/hr \*prb 01-26-96 11:47pm  
 9090206 100.0 120.7569 0.0 0.0 \*1,304,175/3 lb/hr \*prb 01-26-96  
 11:47pm  
 \*  
 \* component 910 - RFW Heater C1 steam supply vlv - jam 7-27-96  
 9100000 c1stmvlv valve \*jam 7-27-96  
 \* from to juna kf kr fvcahs  
 9100101 901000000 920000000 1.3417 15.7355 15.7355 000000 \*jam 7-27-96  
 \* liq\_vel vap Vel vel.int.  
 9100201 0 60.166 118.13 0.0 \*jam 7-26-96  
 9100300 trpvlv \*jam 7-26-96  
 9100301 634 \*jam 7-26-96  
 \*

\* component 920 - RFW Heater C1 Steam Dome (top of vertical shell)  
9200000 'HTRC1-s1' branch  
\*  
\* #juns vel/flow  
\*9200001 2 0  
9200001 1 0 \*jam 7-27-96  
\*  
\* area length vol theta phi elev rough hyd pvbfe  
9200101 12.34 13.7904 0. 0. -90.0 -13.7904 1.5e-4 0.0772 00100  
\*  
\* ebt press Uf Uv voidv  
9200200 000 198.29 354.09 1113.5 0.99410  
\*  
\* from to juna kf kr fvcahs  
\*9201101 901000000 920000000 1.3417 15.7355 15.7355 000000 \*jam 7-27-96  
\*9202101 920010000 921000000 0. 0. 0. 101000 \*jam 7-27-96  
9201101 920010000 921000000 0. 0. 0. 101000 \*jam 7-27-96  
\*  
\* jun\_Dh flood gas-int slope  
\*9201110 0.0 0.0 1.0 1.0 \*jam 7-27-96  
\*9202110 0.0772 0.0 1.0 1.0 \*jam 7-27-96  
9201110 0.0772 0.0 1.0 1.0  
\*  
\* liq\_vel vap\_vel vel.int.  
\*9201201 60.166 118.13 0. \*jam 7-27-96  
\*9202201 7.3903 8.4137 0. \*jam 7-27-96  
9201201 7.3903 8.4137 0. \*jam 7-27-96  
\*  
\*  
\* component 921 - RFW Heater C1 Shellside middle volumes  
9210000 'HTRC1-s2' pipe  
\*  
\* nv  
9210001 3  
\*  
\* flowa vn  
9210101 12.34 3 \*Shell area (60.75" ID) minus tube area (5/8"OD)  
\* \*tube area = (2)(1906 tubes)(tube area)  
\*  
\* flowl vn  
9210301 10.4596 1  
9210302 2.6667 3 \*same as corresponding primary tube length  
\*  
\* volume vn

---

```

9210401 0.0      3
*
*   incl      vn
9210601 -90.0     3
*
*   roughness  dhyd  vn
9210801 1.5e-4    0.0772 3
*
*   kf   kr   jn
9210901 0.0   0.0   2
*
*   pvbfe      vn
9211001 00100     3
*
*   fvcahs      jn
9211101 101000     2
*
*   ebt  press. Uf      Uv      voidv          VN
9211201 0    198.33 354.09    1113.5  0.99189    0.    1
9211202 0    198.36 354.05    1113.5  0.96348    0.    2
9211203 0    198.89 336.85    1113.6  2.33801e-02  0.    3
*
*   vel/flow
9211300 0
*
*   liq-flo  vap-flo  vel.int   jn
9211301 11.168   2.4853  0.        1
9211302 3.0088   5.32454e-02 0.        2
*
*   jun_Dh      flood      gas-int      slope  jn
9211401 0.0772    0.0       1.0       1.0    2
*
*
* component 922 - RFW Heater C1 Tubesheet Shellsid (bottom of vertical shell)
9220000 'HTRC1-s3' branch
*
*   #juns  vel/flow
9220001 1    0
*
*   area  length vol  theta  phi  elev  rough  hyd  pvbfe
9220101 12.34  1.3307 0.    0.   -90.0 -1.3307 1.5e-4 0.0772 00100
*
*   ebt  press. Uf      Uv      voidv
9220200 000  199.30 338.19    1113.6  0.0

```

---

*RELAP5 Model INPUT DECK WITH NEW RECIRCULATION CONTROLS*

```
*  
*   from      to      juna  kf   kr   fvcahs  
9221101 921010000    922000000  0.   0.0  0.   101000  
*  
*   jun_Dh    flood  gas-int slope  
9221110 0.0772     0.0   1.0   1.0  
*  
*   liq_vel    vap_vel    vel.int.  
9221201 0.11251   -1.1900     0.  
*  
*  
* component 923 - RFW Heater C1 Drain Piping  
9230000 'HTRC1drn' branch  
*  
*   #juns vel/flow  
9230001 1     0  
*  
*   area  length vol  theta  phi elev  rough hyd  pvbfe  
9230101 0.3474 10.0  0.   0.   82.6 9.9167  1.5e-4 0.0  00000  
*  
*   ebt  press. Uf      Uv      voidv  
9230200 000  199.30 338.19   1113.6  0.0  
*  
*   from      to      juna  kf   kr   fvcahs  
9231101 922010000    923000000  0.3474 0.0   0.   000100  
*  
*   liq_vel    vap_vel    vel.int.  
9231201 3.7345   3.7345     0.  
*  
*  
* component 925 - RFW HTRC1 Drain Valve  
9250000 'LCV6-37' valve  
*  
*   from      to      juna  kf   kr   fvcahs  
9250101 923010000 931000000 0.0873 39.0223 39.0223 000000  
*  
9250201 0     15.463   15.465 0.   * 819,483/3 lb/hr  
*  
9250300 srvvlv  
*  
9250301 0950 * valve position demand from htr C1 level control system  
*  
9250400 1.0    288.0   * max Cv = 288.0 per BFN-VTD-K125-0060 for  
*           4" linear double-seated full-port
```

---

9250401 0.0 0.0001 0.0001 \* Assume linear Cv vs stroke for globe  
 9250402 1.0 1.0 1.0 \* valve  
 \*  
 \* component 911 - RFW Heater C2 steam supply vlv - jam 7-27-96  
 9110000 c2stmvlv valve \*jam 7-27-96  
 \* from to juna kf kr fvcahs  
 9110101 902000000 930000000 0.7854 14.1087 14.1087 000000 \*jam 7-27-96  
 \* liq\_vel vap\_vel vel.int.  
 9110201 0 74.200 202.58 0.0 \*jam 7-26-96  
 9110300 trpvlv \*jam 7-26-96  
 9110301 634 \*jam 7-26-96  
 \*  
 \* component 930 - RFW Heater C2 Steam Dome (top of vertical shell)  
 9300000 'HTRC2-s1' branch  
 \*  
 \* #juns vel/flow  
 \*9300001 2 0 \*jam 9-27-96  
 9300001 1 0 \*jam 9-27-96  
 \*  
 \* area length vol theta phi elev rough hyd pvbfe  
 9300101 12.34 10.2904 0. 0. -90.0 -10.2904 1.5e-4 0.0772 00100  
 \*  
 \* ebt press Uf Uv voidv  
 9300200 000 109.21 304.89 1106.3 0.99832  
 \*  
 \* from to juna kf kr fvcahs  
 \*9301101 902000000 930000000 0.7854 14.1087 14.1087 000001 \*jam 9-27-96  
 \*9302101 930010000 931000000 12.34 0. 0. 101000 \*jam 9-27-96  
 9301101 930010000 931000000 12.34 0. 0. 101000 \*jam 9-27-96  
 \*  
 \* jun\_Dh flood gas-int slope  
 \*9301110 0.0 0.0 1.0 1.0 \*jam 9-27-96  
 \*9302110 0.0772 0.0 1.0 1.0 \*jam 9-27-96  
 9301110 0.0772 0.0 1.0 1.0 \*jam 9-27-96  
 \*  
 \* liq\_vel vap\_vel vel.int.  
 \*9301201 74.200 202.58 0. \*jam 9-27-96  
 \*9302201 12.027 7.9267 0. \*jam 9-27-96  
 9301201 12.027 7.9267 0. \*jam 9-27-96  
 \*  
 \*  
 \* component 931 - RFW Heater C2 drain junction volume  
 9310000 'HTRC2-s2' branch  
 \*

---

*RELAP5 Model INPUT DECK WITH NEW RECIRCULATION CONTROLS*

```
* #juns vel/flow
9310001 1 0
*
* area length vol theta phi elev rough hyd pvbfe
9310101 12.34 8.8763 0. 0. -90.0 -8.8763 1.5e-4 0.0772 00100
*
* ebt press Uf Uv voidv
9310200 000 109.23 305.04 1106.4 0.97393
*
* from to juna kf kr fvcahs
9311101 931010000 932000000 12.34 0. 0. 101000
*
* jun_Dh flood gas-int slope
9311110 0.0772 0.0 1.0 1.0
*
* liq_vel vap_vel vel.int.
9311201 10.895 3.4280 0.
*
*
* component 932 - RFW Heater C2 Shellside middle volumes
9320000 'HTRC2-s2' pipe
*
* nv
9320001 2
*
* flowa vn
9320101 12.34 2 *Shell area (60.75" ID) minus tube area (5/8"OD)
* *tube area = (2)(1906 tubes)(tube area)
*
* flowl vn
9320301 3.0000 2 *same as corresponding primary tube length
*
* volume vn
9320401 0.0 2
*
* incl vn
9320601 -90.0 2
*
* roughness dhyd vn
9320801 1.5e-4 0.0772 2
*
* kf kr jn
9320901 0.0 0.0 1
*
```

```
*      pvbfe      vn
9321001 00100      2
*
*      fvcahs      jn
9321101 101000      1
*
*      ebt  press. Uf      Uv      voidv      VN
9321201 000  109.25 304.86    1106.4  0.91724    0.   1
9321202 000  109.87 298.86    1106.4  5.89169e-02  0.   2
*
*      vel/flow
9321300 0
*
*      liq-flo  vap-flo  vel.int      jn
9321301 4.2183  0.30784  0.        1
*
*      jun_Dh      flood      gas-int      slope jn
9321401 0.0772    0.0       1.0       1.0   1
*
*
* component 933 - RFW Heater C2 Tubesheet Shellside (bottom of vertical shell)
9330000 'HTRC2-s3' branch
*
*      #juns vel/flow
9330001 1      0
*
*      area  length vol  theta  phi elev  rough hyd  pvbfe
9330101 12.34  5.4974 0.   0.  -90.0 -5.4974  1.5e-4 0.0772 00100
*
*      ebt  press. Uf      Uv      voidv
9330200 000  111.52 291.80    1106.6  0.0
*
*      from      to      juna kf      kr      fvcahs
9331101 932010000  933000000  12.34  0.0  0.  101000
*
*      jun_Dh      flood  gas-int slope
9331110 0.0772    0.0   1.0   1.0
*
*      liq_vel  vap_vel      vel.int.
9331201 0.42029  -0.82167     0.
*
*
* component 934 - RFW Heater C2 Drain Piping
9340000 'HTRC2drn' branch
```

---

RELAP5 Model INPUT DECK WITH NEW RECIRCULATION CONTROLS

```
*  
* #juns vel/flow  
9340001 1 0  
*  
* area length vol theta phi elev rough hyd pvbfe  
9340101 0.5475 25.0 0. 0. 65.0 22.6667 1.5e-4 0.0 00000  
*  
* ebt press. Uf Uv voidv  
9340200 000 199.30 338.19 1113.6 0.0  
*  
* from to juna kf kr fvcahs  
9341101 933010000 934000000 0.5475 0.0 0. 000100  
*  
* liq_vel vap_vel vel.int.  
9341201 8.2628 7.7109 0.  
*  
*  
* component 935 - RFW HTRC2 Drain Valve  
9350000 'LCV6-40A' valve  
*  
* from to juna kf kr fvcahs  
9350101 934010000 941000000 0.3491 22.8653 22.8653 000000  
*  
9350201 1 228.5294 0.0 0. *2,468,117/3 lb/hr  
*  
9350300 srvlv  
*  
9350301 0958 * valve position demand based from htr C2 level control  
*  
9350400 1.0 950.0 * max Cv = 950.0 per BFN-VTD-K125-0060 for  
* 8" linear double-seated full-port  
9350401 0.0 0.0001 0.0001 * Assume linear Cv vs stroke for globe  
9350402 1.0 1.0 1.0 * valve  
*  
*  
* component 937 - RFW HTRB2 Bypass Valve *prb 01-23-96  
01:05pm  
9370000 'LCV6-4B' valve *prb 01-23-96 01:05pm  
* *prb 01-23-96 01:05pm  
* from to juna kf kr fvcahs *prb 01-23-96 01:05pm  
*9370101 934010000 738000000 0.3491 0.0 0.0 000000 *prb 01-23-96  
01:05pm  
9370101 934010000 738000000 0.3491 22.8653 22.8653 000000 *jam 7-26-96  
* *prb 01-23-96 01:05pm
```

---

9370201 1 0.0 0.0 0.0 \*prb 01-23-96 01:05pm  
 \* \*prb 01-23-96 01:05pm  
 9370300 srvv lv \*prb 01-23-96 01:05pm  
 \* \*prb 01-23-96 01:05pm  
 9370301 0960 \* valve position demand \*prb 01-23-96 01:05pm  
 \* \*prb 01-23-96 01:05pm  
 9370400 1.0 950.0 \* max Cv = 950.0 per BFN-VTD-K125-0060 for \*prb 01-23-96  
 01:05pm  
 \* 8" linear double-seated full-port \*prb 01-23-96 01:05pm  
 9370401 0.0 0.0001 0.0001 \* Assume linear Cv vs stroke for globe \*prb 01-23-96  
 01:05pm  
 9370402 1.0 1.0 1.0 \* valve \*prb 01-23-96 01:05pm  
 \*  
 \* component 912 - RFW Heater C3 steam supply vlv - jam 7-27-96  
 9120000 c3stmvlv valve \*jam 7-27-96  
 \* from to juna kf kr fvcahs  
 9120101 903000000 940000000 3.1416 23.4899 23.4899 000000 \*jam 7-27-96  
 \* liq\_vel vap\_vel vel.int.  
 9120201 0 7.7263 124.84 0.0 \*jam 7-26-96  
 9120300 trpv lv \*jam 7-26-96  
 9120301 634 \*jam 7-26-96  
 \*  
 \* component 940 - RFW Heater C3 Steam Dome (top of vertical shell)  
 9400000 'HTRC3-s1' branch  
 \*  
 \* #juns vel/flow  
 \*9400001 2 0 \*jam 7-26-96  
 9400001 1 0 \*jam 7-26-96  
 \*  
 \* area length vol theta phi elev rough hyd pvbfe  
 9400101 13.5335 12.4284 0. 0. -90.0 -12.4284 1.5e-4 0.0864 00100  
 \*  
 \* ebt press Uf Uv voidv  
 9400200 000 69.300 271.84 1099.9 0.99613  
 \*  
 \* from to juna kf kr fvcahs  
 \*9401101 903000000 940000000 3.1416 23.4899 23.4899 000000 \*jam 7-26-96  
 \*9402101 940010000 941000000 13.5335 0. 0. 101000 \*jam 7-26-96  
 9401101 940010000 941000000 13.5335 0. 0. 101000 \*jam 7-26-96  
 \*  
 \* jun\_Dh flood gas-int slope  
 \*9401110 0.0 0.0 1.0 1.0 \*jam 7-26-96  
 \*9402110 0.0864 0.0 1.0 1.0 \*jam 7-26-96  
 9401110 0.0864 0.0 1.0 1.0 \*jam 7-26-96

---

*RELAP5 Model INPUT DECK WITH NEW RECIRCULATION CONTROLS*

\*  
\* liq\_vel vap\_vel vel.int.  
\*9401201 7.7263 124.84 0. \*jam 7-26-96  
\*9402201 8.9171 19.266 0. \*jam 7-26-96  
9401201 8.9171 19.266 0. \*jam 7-26-96  
\*  
\*  
\* component 941 - RFW Heater C3 drain junction volume  
9410000 'HTRC3-s2' branch  
\*  
\* #juns vel/flow  
9410001 1 0  
\*  
\* area length vol theta phi elev rough hyd pvbfe  
9410101 13.5335 11.1133 0. 0. -90.0 -11.1133 1.5e-4 0.0864 00100  
\*  
\* ebt press Uf Uv voidv  
9410200 000 69.309 271.88 1100.0 0.96083  
\*  
\* from to juna kf kr fvcahs  
9411101 941010000 942000000 13.5335 0. 0. 101000  
\*  
\* jun\_Dh flood gas-int slope  
9411110 0.0864 0.0 1.0 1.0  
\*  
\* liq\_vel vap\_vel vel.int.  
9411201 9.3922 5.8524 0.  
\*  
\*  
\* component 942 - RFW Heater C3 Shellside middle & lower volumes  
9420000 'HTRC3-s3' pipe  
\*  
\* nv  
9420001 4  
\*  
\* flowa vn  
9420101 13.5335 1  
9420102 6.7667 4 \*volumes 2-4 share space with subcooling zone  
\*  
\* flowl vn  
9420301 3.0000 2 \*same as corresponding primary tube length  
9420302 7.0534 4 \*same as corresponding primary tube length  
\*  
\* volume vn

```
9420401 0.0      4
*
*     incl      vn
9420601 -90.0      4
*
*     roughness   dhyd  vn
9420801 1.5e-4      0.0864 4
*
*     kf      kr      jn
9420901 0.0  0.0  3
*
*     pvbfe      vn
9421001 00100      4
*
*     fvcahs      jn
9421101 101000      3
*
*     ebt  press. Uf      Uv      voidv      VN
9421201 000  69.322 271.84  1100.0  0.98918  0.  1
9421202 000  69.529 271.38  1099.9  0.16248  0.  2
9421203 000  72.030 269.21  1100.5  2.68060e-06  0.  3
9421204 000  74.835 267.04  1101.0  8.83757e-06  0.  4
*
*     vel/flow
9421300 0
*
*     liq-flo    vap-flo      vel.int      jn
9421301 70.794  0.44862      0.        1
9421302 0.75643 -0.90429      0.        2
9421303 0.63162  0.77799      0.        3
*
*     jun_Dh      flood      gas-int      slope  jn
9421401 0.0864  0.0       1.0       1.0  3
*
*
* component 943 - RFW Heater C3 Subcooling Zone
9430000 'HTRC3-s4'  pipe
*
*     nv
9430001 3
*
*     flowa      vn
9430101 6.7667      3
*
```

---

*RELAP5 Model INPUT DECK WITH NEW RECIRCULATION CONTROLS*

```
* flowl      vn
9430301 3.0000      1      *same as corresponding primary tube length
9430302 7.0534      3      *same as corresponding primary tube length
*
* volume      vn
9430401 0.0          3
*
* incl        vn
9430601 -90.0        3
*
* roughness   dhyd  vn
9430801 1.5e-4       0.0864 3
*
* kf  kr  jn
9430901 0.0  0.0  2
*
* pvbfe      vn
9431001 00100        3
*
* fvcahs     jn
9431101 101000       2
*
* ebt  press. Uf      Uv      voidv      VN
9431201 000  69.415 233.60  1100.1  8.99481e-02  0.  1
9431202 000  71.404 226.39  1100.4  1.57683e-07  0.  2
9431203 000  74.264 242.61  1100.9  3.17648e-06  0.  3
*
* vel/flow
9431300 0
*
* liq-flo    vap-flo    vel.int    jn
9431301 3.53376e-02 -1.6814    0.        1
9431302 3.03089e-02 3.099473e-02  0.        2
*
* jun_Dh     flood      gas-int    slope jn
9431401 0.0864      0.0        1.0       1.0  2
*
*
* component 944 - RFW Heater C3 Drain Piping
9440000 'HTRC3drn' branch
*
* #juns vel/flow
9440001 1      1
*
```

```
* area length vol theta phi elev rough hyd pvbfe
9440101 0.5475 5.0 0. 0. 0. 0. 1.5e-4 0.0 00000
*
* ebt press. Uf Uv voidv
9440200 000 199.30 338.19 1113.6 0.0
*
* from to juna kf kr fvcahs
9441101 943010000 944000000 0.5475 0.0 0. 000100
*
* liq_vel vap_vel vel.int.
9441201 228.5294 0.0 0.
*
*
* component 945 - RFW HTRC3 Drain Valve
9450000 'LCV6-43' valve
*
* from to juna kf kr fvcahs
9450101 944010000 952000000 0.3491 7.4816 7.4816 000000
*
9450201 0 12.689 44.886 0. *2,468,117/3 lb/hr target
*
9450300 srvvlv
*
9450301 0972 * valve position demand based on htr C3 level error
*
9450400 1.0 950.0 * max Cv = 950.0 per BFN-VTD-K125-0060 for
* 8" linear double-seated full-port
9450401 0.0 0.0001 0.0001 * Assume linear Cv vs stroke for globe
9450402 1.0 1.0 1.0 * valve
*
*
9470000 'HTRC3jun' mtpljun
9470001 2 0
*
* from to juna kf kr fvcahs incr1 incr2 jn
9470011 942020004 943010003 .1 5. 5. 001000 1. 1. 1. 0 0 0 1
9470021 942040004 943030003 1. 5. 5. 001000 1. 1. 1. 0 0 0 2
*
* liq-flo vap-flo jn
9471011 4.0946 4.0946 1
9471021 0.0 0.0 2
*
* component 913 - RFW Heater C4 steam supply vlv - jam 7-27-96
9130000 c4stv1 valve *jam 7-27-96
```

---

RELAP5 Model INPUT DECK WITH NEW RECIRCULATION CONTROLS

```
* from to juna kf kr fvcahs
9130101 905000000 950000000 2.8229 6197.85 6197.85 000000 *jam 7-27-96
* liq_vel vap_vel vel.int.
9130201 0 0.83437 24.814 0.0 *jam 7-26-96
9130300 trpvlv *jam 7-26-96
9130301 634 *jam 7-26-96
*
*
* component 950 - RFW Heater C4 (top of shell nearest tubesheet)
9500000 'HTRC4-s1' branch
*
* #juns vel/flow
*9500001 2 0 *jam 7-26-96
9500001 1 0 *jam 7-26-96
*
* area length vol theta phi elev rough hyd pvbfe
9500101 0.0 2.9375 153.2704 0. -90.0 -2.9375 1.5e-4 0.1309 00100
*
* ebt press Uf Uv voidv
9500200 000 27.276 213.37 1086.4 0.99962
*
* from to juna kf kr fvcahs
*9501101 905000000 950000000 2.8229 6197.85 6197.85 000000 *jam 7-27-96
*9502101 950010000 951000000 9.7832 0. 0. 001003 *jam 7-27-96
9501101 950010000 951000000 9.7832 0. 0. 001003 *jam 7-27-96
*
* jun_Dh flood gas-int slope
*9501110 0.0 0.0 1.0 1.0 *jam 7-27-96
*9502110 0.1309 0.0 1.0 1.0 *jam 7-27-96
9501110 0.1309 0.0 1.0 1.0 *jam 7-27-96
*
* liq_vel vap_vel vel.int.
*9501201 0.83437 24.814 0. *jam 7-27-96
*9502201 9.1016 8.7249 0. *jam 7-27-96
9501201 9.1016 8.7249 0. *jam 7-27-96
*
* component 914 - RFW Heater C4 steam supply vlv - jam 7-27-96
9140000 c4stvlv2 valve *jam 7-27-96
* from to juna kf kr fvcahs
9140101 904000000 951000000 2.8229 4.4554 4.4554 000000 *jam 7-27-96
* liq_vel vap_vel vel.int.
9140201 0 41.854 271.59 0.0 *jam 7-26-96
9140300 trpvlv *jam 7-26-96
9140301 634 *jam 7-26-96
```

\*  
\*  
\* component 951 - RFW Heater C4 (top of shell furthest from tubesheet)  
9510000 'HTRC4-s2' branch  
\*  
\* #juns vel/flow  
\*9510001 2 0 \*jam 7-27-96  
9510001 1 0 \*jam 7-27-96  
\*  
\* area length vol theta phi elev rough hyd pvbfe  
9510101 0.0 2.9375 265.4972 0. -90.0 -2.9375 1.5e-4 0.1309 00100  
\*  
\* ebt press Uf Uv voidv  
9510200 000 27.276 213.38 1086.4 0.99996  
\*  
\* from to juna kf kr fvcahs  
\*9511101 904000000 951000000 2.8229 4.4554 4.4554 000000 \*jam 7-27-96  
\*9512101 951010000 952000000 153.4359 0. 0. 101000 \*jam 7-27-96  
9511101 951010000 952000000 153.4359 0. 0. 101000 \*jam 7-27-96  
\*  
\* jun\_Dh flood gas-int slope  
\*9511110 0.0 0.0 1.0 1.0 \*jam 7-27-96  
\*9512110 0.1309 0.0 1.0 1.0 \*jam 7-27-96  
9511110 0.1309 0.0 1.0 1.0 \*jam 7-27-96  
\*  
\* liq\_vel vap\_vel vel.int.  
\*9511201 41.854 271.59 0. \*jam 7-27-96  
\*9512201 38.784 4.5911 0. \*jam 7-27-96  
9511201 38.784 4.5911 0. \*jam 7-27-96  
\*  
\*  
\* component 952 - RFW Heater C4 (bottom of shell furthest from tubesheet)  
9520000 'HTRC4-s3' branch  
\*  
\* #juns vel/flow  
9520001 0 0  
\*  
\* area length vol theta phi elev rough hyd pvbfe  
9520101 0.0 2.9375 265.4972 0. -90.0 -2.9375 1.5e-4 0.1309 00100  
\*  
\* ebt press Uf Uv voidv  
9520200 000 27.292 209.34 1086.4 0.52487  
\*

```
* component 953 - RFW Heater C4 Subcooling Zone
9530000 'HTRC4-s4' branch
*
* #juns vel/flow
9530001 1 0
*
* area length vol theta phi elev rough hyd pvbfe
9530101 9.7832 15.6667 0.0 0. 0.0 0.0 1.5e-4 0.1309 00100
*
* ebt press Uf Uv voidv
9530200 000 26.746 170.92 1086.2 2.46992e-02
*
* from to juna kf kr fvcahs
9531101 952010000 953000000 1.7671 5.0 5.0 001000
*
* jun_Dh flood gas-int slope
9531110 0.1309 0.0 1.0 1.0
*
* liq_vel vap_vel vel.int.
9531201 6.4784 37.792 0.
*
*
* component 954 - RFW Heater C4 Drain Piping
9540000 'HTRC4drn' branch
*
* #juns vel/flow
9540001 1 0
*
* area length vol theta phi elev rough hyd pvbfe
9540101 1.6230 10.0 0. 0. 50.15 7.6771 1.5e-4 0.0 00000
*
* ebt press. Uf Uv voidv
9540200 000 26.326 174.57 1085.9 7.05438e-04
*
* from to juna kf kr fvcahs
9541101 953010000 954000000 1.6230 0.0 0. 000100
*
* liq_vel vap_vel vel.int.
9541201 3.1304 4.5777 0.
*
*
* component 955 - RFW HTRC4 Drain Valve
9550000 'LCV6-47A' valve
*
```

---

```

*      from      to      juna      kf      kr      fvcahs
9550101 954010000 960010003 0.7854  23.7848 23.7848 000000
*
9550201 0      7.5514    7.5514 0. *3,184,100/3 lb/hr target
*
9550300 srvv lv
*
9550301 0982 * valve position demand based on htr C4 level error
*
9550400 1.0    2180.0   * max Cv = 2180.0 per BFN-VTD-K125-0060 for
*                      12" linear double-seated full-port
9550401 0.0    0.0001   0.0001 * Assume linear Cv vs stroke for globe
9550402 1.0    1.0      1.0      * valve
*
*
* component 957 - RFW HTRC4 Bypass Valve          *prb 01-24-96
10:22am
9570000 'LCV6-47B'  valve          *prb 01-24-96 10:22am
*
*      from      to      juna      kf      kr      fvcahs      *prb 01-24-96 10:22am
*9570101 954010000 758000000 0.7854 0.0    0.0    000000      *prb 01-24-96
10:22am
9570101 954010000 758000000 0.7854  23.7848 23.7848 000000      *jam 7-26-96
*
9570201 1      0.0      0.0      0.0          *prb 01-24-96 10:22am
*
9570300 srvv lv          *prb 01-24-96 10:22am
*
9570301 0984 * valve position demand          *prb 01-24-96 10:22am
*
9570400 1.0    2180.0   * max Cv = 2180.0 per BFN-VTD-K125-0060 for      *prb 01-24-
96 10:22am
*                      12" linear double-seated full-port *prb 01-24-96 10:22am
9570401 0.0    0.0001   0.0001 * Assume linear Cv vs stroke for globe *prb 01-24-96
10:22am
9570402 1.0    1.0      1.0      * valve          *prb 01-24-96 10:22am
*
*
* component 960 - RFW Heater C5 Flash Tank
9600000 'FL-TankC'  pipe
*
*      nv
9600001 4
*
```

```
*      flowa      vn
9600101 16.4988      4
*
*      flowl      vn
9600301 1.4583      1
9600302 2.9583      2
9600303 2.500       3
9600304 5.2188      4
*
*      volume     vn
9600401 0.0         4
*
*      incl       vn
9600601 -90.0       4
*
*      roughness   dhyd  vn
9600801 0.0         0.0   4
*
*      kf    kr    jn
9600901 0.0         0.0   3
*
*      pvbfe      vn
9601001 00010      4
*
*      fvcahs     jn
9601101 101000      3
*
*      ebt  press. Uf      Uv      voidv      VN
9601201 000  9.6940 160.59  1071.8  0.98351  0.  1
9601202 000  9.6954 159.92  1071.8  0.99883  0.  2
9601203 000  9.9628 160.43  1072.2  0.53140  0.  3
9601204 000  12.394 159.48  1075.2  0.00000e+00  0.  4
*
*      vel/flow
9601300 0
*
*      liq-flo  vap-flo      vel.int     jn
9601301 19.581 0.27746  0.        1
9601302 282.58 0.63630  0.        2
9601303 0.63560 -4.2606  0.        3
*
*      jun_Dh      flood      gas-int      slope  jn
9601401 0.0       0.0       1.0        1.0   3
*
```

---

```

*
* component 961 - RFW Heater C5 Drain Piping
9610000 'HTRC5drn' branch
*
* #juns vel/flow
9610001 1 0
*
* area length vol theta phi elev rough hyd pvbfe
9610101 2.9483 10.0 0. 0. 0.0 0.0 1.5e-4 0.0 00000
*
* ebt press. Uf Uv voidv
9610200 000 13.552 159.14 1076.4 0.0
*
* from to juna kf kr fvcahs
9611101 960010000 961000000 2.9483 0.0 0. 000100
*
* liq_vel vap_vel vel.int.
9611201 1.6705 1.9099 0.
*
* component 915 - RFW Heater C5 steam supply vlv - jam 7-27-96
9150000 c5stvlv1 valve *jam 7-27-96
* from to juna kf kr fvcahs
9150101 906000000 962000000 9.0164 6243.8 6243.8 000000 *jam 7-27-96
* liq_vel vap_vel vel.int.
9150201 0 0.49198 22.264 0.0 *jam 7-26-96
9150300 trpvlv *jam 7-26-96
9150301 634 *jam 7-26-96
*
*
* component 962 - RFW Heater C5 (top of shell nearest tubesheet)
9620000 'HTRC5-s1' branch
*
* #juns vel/flow
*9620001 3 0 *jam 7-27-96
9620001 2 0 *jam 7-27-96
*
* area length vol theta phi elev rough hyd pvbfe
9620101 0.0 2.8333 170.5096 0. -90.0 -2.8333 1.5e-4 0.1128 00100
*
* ebt press Uf Uv voidv
9620200 000 9.4593 158.61 1071.3 0.99998
*
* from to juna kf kr fvcahs

```

---

RELAP5 Model INPUT DECK WITH NEW RECIRCULATION CONTROLS

\*9621101 906000000 962000000 9.0164 6243.8 6243.8 001000  
\*jam 7-27-96  
\*9622101 962010000 963000000 8.7069 0. 0. 001003  
\*jam 7-27-96  
9621101 962010000 963000000 8.7069 0. 0. 001003  
\*jam 7-27-96  
\*9623101 960000000 962000000 0.7530 1.50 1.50 001000  
\*jam 7-27-96  
9622101 960000000 962000000 0.7530 1.50 1.50 001000  
\*jam 7-27-96  
\*  
\* jun\_Dh flood gas-int slope  
\*9621110 2.3958 0.0 1.0 1.0 \*jam 7-27-96  
\*9622110 0.1128 0.0 1.0 1.0 \*jam 7-27-96  
9621110 0.1128 0.0 1.0 1.0 \*jam 7-27-96  
\*9623110 0.0 0.0 1.0 1.0 \*jam 7-27-96  
9622110 0.0 0.0 1.0 1.0 \*jam 7-27-96  
\*  
\* liq\_vel vap\_vel vel.int.  
\*9621201 0.49198 22.264 0. \*jam 7-27-96  
\*9622201 -31.397 -26.477 0. \*jam 7-27-96  
9621201 -31.397 -26.477 0. \*jam 7-27-96  
\*9623201 -30.730 237.56 0. \*jam 7-27-96  
9622201 -30.730 237.56 0. \*jam 7-27-96  
\*  
\* component 916 - RFW Heater C5 steam supply vlv - jam 7-27-96  
9160000 c5stvlv2 valve \*jam 7-27-96  
\* from to juna kf kr fvcahs  
9160101 907000000 963000000 9.0164 2.9489 2.9489 000000 \*jam 7-27-96  
\* liq\_vel vap\_vel vel.int.  
9160201 0 26.337 161.50 0.0 \*jam 7-26-96  
9160300 trpvlv \*jam 7-26-96  
9160301 634 \*jam 7-26-96  
\*  
\*  
\* component 963 - RFW Heater C5 (top of shell furthest from tubesheet)  
9630000 'HTRC5-s2' branch  
\*  
\* #juns vel/flow  
\*9630001 2 0 \*jam 7-27-96  
9630001 1 0 \*jam 7-27-96  
\*  
\* area length vol theta phi elev rough hyd pvbfe  
9630101 0.0 2.8333 128.8119 0. -90.0 -2.8333 1.5e-4 0.1128 00100

---

```

*
*   ebt  press  Uf      Uv      voidv
9630200 000  9.4589 158.60    1071.4  0.99992
*
*   from      to      juna  kf   kr   fvcahs
*9631101 907000000  963000000  9.0164 2.9489 2.9489 001000 *jam 9-27-96
*9632101 963010000  964000000  83.8342 0.  0.  001000 *jam 9-27-96
9631101 963010000  964000000  83.8342 0.  0.  001000 *jam 9-27-96
*
*   jun_Dh    flood  gas-int slope
*9631110 2.3958    0.0  1.0  1.0          *jam 9-27-96
*9632110 0.1128    0.0  1.0  1.0          *jam 9-27-96
9631110 0.1128    0.0  1.0  1.0          *jam 9-27-96
*
*   liq_vel    vap_vel    vel.int.
*9631201 26.337   161.50    0.          *jam 9-27-96
*9632201 34.542   8.5995    0.          *jam 9-27-96
9631201 34.542   8.5995    0.          *jam 9-27-96
*
*
* component 964 - RFW Heater C5 (bottom of shell furthest from tubesheet)
9640000 'HTRC5-s3' branch
*
*   #juns vel/flow
9640001 2    0
*
*   area  length vol   theta phi elev   rough hyd   pvbfe
9640101 0.0  2.8333 128.8119 0.  -90.0 -2.8333 1.5e-4 0.1128 00100
*
*   ebt  press  Uf      Uv      voidv
9640200 000  9.6340 148.68    1071.7  0.39598
*
*   from      to      juna  kf   kr   fvcahs
9641101 964010004  965010003  8.7069 0.  0.  001000
9642101 964010000  966000000  0.8685 1.5 100.0 001001 * discourage reverse
flow
*
*   jun_Dh    flood  gas-int slope
9641110 0.1128    0.0  1.0  1.0
9642110 0.6651    0.0  1.0  1.0
*
*   liq_vel    vap_vel    vel.int.
9641201 3.4725   -8.5376    0.
9642201 0.47271   -9.3520    0.

```

```
*  
*  
* component 965 - RFW Heater C5 (bottom of shell nearest tubesheet)  
9650000 'HTRC5-s4' branch  
*  
* #juns vel/flow  
9650001 2 0  
*  
* area length vol theta phi elev rough hyd pvbfe  
9650101 0.0 2.8333 170.5096 0. -90.0 -2.8333 1.5e-4 0.1128 00100  
*  
* ebt press Uf Uv voidv  
9650200 000 9.4996 134.05 1071.5 0.44943  
*  
* from to juna kf kr fvcahs  
9651101 962010000 965000000 110.9722 0.0 0.0 001000  
9652101 965010000 966000000 0.8685 1.5 100.0 001001 * discourage reverse  
flow  
*  
* jun_Dh flood gas-int slope  
9651110 0.1128 0.0 1.0 1.0  
9652110 0.6651 0.0 1.0 1.0  
*  
* liq_vel vap_vel vel.int.  
9651201 37.265 5.8851 0.  
9652201 -0.42722 -10.256 0.  
*  
*  
* component 966 - RFW Heater C5 Collector  
9660000 'Coll-C5' branch  
*  
* #juns vel/flow  
9660001 1 0  
*  
* area length vol theta phi elev rough hyd pvbfe  
9660101 4.9087 0.0 145.2255 0. 0.0 0.0 1.5e-4 0.0 00000  
*  
* ebt press Uf Uv voidv  
9660200 000 9.9594 146.78 1072.2 0.10641  
*  
* from to juna kf kr fvcahs  
9661101 966010002 960030003 4.9087 1.0 0.50 031000  
*  
* jun_Dh flood gas-int slope
```

```

9661110 2.5      0.0  1.0  1.0
*
*      liq_vel    vap_vel     vel.int.
9661201 -0.18014   -1.3910      0.
*
*
* component 967 - RFW HTR C5 Drain Valve
*
9670000 'LCV6-50A'  valve
*
*      from      to      juna      kf      kr      fvcahs
9670101 961010000 969000000 0.7854  5.6209  5.6209  001000
*
9670201 0      9.4      9.4      0.      *3,184,100/3 lb/hr target
*
9670300 srvvvlv
*
9670301 0993 * valve position demand based on htr C5 level error
*
9670400 1.0      2180.0    * max Cv = 2180.0 per BFN-VTD-K125-0060 for
*                                12" linear double-seated full-port
9670401 0.0      0.0001    0.0001    * Assume linear Cv vs stroke for globe
9670402 1.0      1.0      1.0      * valve
*
*
* component 968 - RFW HTRC5 Bypass Valve                      *prb 01-25-96
09:19pm
9680000 'LCV6-50B'  valve                               *prb 01-25-96 09:19pm
*
*      from      to      juna      kf      kr      fvcahs      *prb 01-25-96 09:19pm
*9680101 961010000 969000000 0.7854  0.0      0.0      000000      *prb 01-25-96
09:19pm
9680101 961010000 969000000 0.7854  0.0      5.6209  001000      *jam 7-26-96
*
*      from      to      juna      kf      kr      fvcahs      *prb 01-25-96 09:19pm
9680201 1      0.0      0.0      0.0      0.0      0.0      000000      *prb 01-25-96 09:19pm
*
9680300 srvvvlv
*
9680301 0995 * valve position demand                  *prb 01-25-96 09:19pm
*
*      from      to      juna      kf      kr      fvcahs      *prb 01-25-96 09:19pm
9680400 1.0      2180.0    * max Cv = 2180.0 per BFN-VTD-K125-0060 for      *prb 01-25-
96 09:19pm
*                                12" linear double-seated full-port      *prb 01-25-96 09:19pm

```

---

*RELAP5 Model INPUT DECK WITH NEW RECIRCULATION CONTROLS*

9680401 0.0 0.0001 0.0001 \* Assume linear Cv vs stroke for globe \*prb 01-25-96  
09:19pm  
9680402 1.0 1.0 1.0 \* valve \*prb 01-25-96 09:19pm  
\*  
\*  
\* component 969 - RFW Heater sump header  
9690000 'HTR-sump' branch  
\*  
\* #juns vel/flow  
9690001 1 1  
\*  
\* area length vol theta phi elev rough hyd pvbfe  
\*9690101 5.0 10.0 0.0 0. 0.0 0.0 1.5e-4 0.0 00000  
9690101 8.0 50.0 0.0 0. 0.0 0.0 1.5e-4 0.0 00000 \*jam 7-28-96  
\*  
\* ebt press temp  
9690200 003 1.0 101.14  
\*  
\* from to juna kf kr fvcahs  
9691101 969010000 970000000 0.0 1.0 0.50 001000  
\*  
\* liq\_vel vap\_vel vel.int.  
9691201 884.4722 0.0 0.  
\*  
\*  
\* component 970 - HTR sump / condenser  
\*-----  
9700000 'HTR-cond' tmdpvol  
\*  
\* area length vol azmth incl elev rough hyd fe  
\*9700101 5.0 10.0 0.0 0.0 0.0 0.0 0.0 0.0 10  
9700101 8.0 50.0 0.0 0.0 0.0 0.0 0.0 0.0 10 \*jam 7-28-96  
\*  
\* ebt trip variable  
9700200 003  
\*  
\* time press temp.  
9700201 0.0 0.9823 101.14  
\*  
\* component 971 - HTR sump / condenser \*jam 7-28-96  
\*----- \*jam 7-28-96 \*jam 7-28-96  
9710000 'HTR2cond' tmdpvol \*jam 7-28-96  
\*  
\* area length vol azmth incl elev rough hyd fe \*jam 7-28-96

9710101 1.0 50.0 0.0 0.0 0.0 0.0 0.0 10 \*jam 7-28-96  
\* \*jam 7-28-96  
\* ebt trip variable \*jam 7-28-96  
9710200 003 \*jam 7-28-96  
\* \*jam 7-28-96  
\* time press temp. \*jam 7-28-96  
9710201 0.0 0.9823 101.14 \*jam 7-28-96  
\*  
\*  
\*-----  
\* feedwater train heat structures  
\*-----  
\*  
\* heat structure geometry per vendor spec shts. included with app. d  
\*\*\* drain cooler A tubes \*\*\*  
15201000 1 2 2 0 2.84000e-02  
15201100 0 1  
15201101 1 0.0313  
15201201 4 1  
15201301 1. 1  
15201400 -1  
15201401 1.3759e+02 1.3950e+02  
15201501 520010000 0 1 1 6.66e4 1  
15201601 0 0 0 1 6.66e4 1  
15201701 10816 1. 0. 0. 1  
15201801 0. 10. 10. 0. 0. 0. 1. 1  
15201901 0. 10. 10. 0. 0. 0. 0. 1. 1  
\*  
\*\*\* drain cooler B tubes \*\*\*  
15211000 1 2 2 0 2.84000e-02  
15211100 0 1  
15211101 1 0.0313  
15211201 4 1  
15211301 1. 1  
15211400 -1  
15211401 1.3759e+02 1.3950e+02  
15211501 521010000 0 1 1 6.66e4 1  
15211601 0 0 0 1 6.66e4 1  
15211701 10816 1. 0. 0. 1  
15211801 0. 10. 10. 0. 0. 0. 1. 1  
15211901 0. 10. 10. 0. 0. 0. 0. 1. 1  
\*  
\*\*\* drain cooler C tubes \*\*\*

---

*RELAP5 Model INPUT DECK WITH NEW RECIRCULATION CONTROLS*

15221000 1 2 2 0 2.84000e-02  
15221100 0 1  
15221101 1 0.0313  
15221201 4 1  
15221301 1. 1  
15221400 -1  
15221401 1.3759e+02 1.3950e+02  
15221501 522010000 0 1 1 6.66e4 1  
15221601 0 0 0 1 6.66e4 1  
15221701 10816 1. 0. 0. 1  
15221801 0. 10. 10. 0. 0. 0. 0. 1. 1  
15221901 0. 10. 10. 0. 0. 0. 0. 0. 1. 1  
\*  
\*  
\* heat structure 530-1 RFW Heater A5 Tubes  
\* nh np geom init lt.coord  
15301000 8 3 2 1 0.0231  
\*  
\* mesh loc'n format  
15301100 0 1  
\*  
\* # intervals rt.coord  
15301101 2 0.0260  
\*  
\* comp # inter#(in)  
15301201 004 2  
\*  
\* rel. source interval  
15301301 1. 2  
\*  
15301400 -1  
\*  
\* mesh point temperatures  
15301401 148.87 158.13 172.26  
15301402 161.67 165.87 172.99  
15301403 170.81 171.20 171.81  
15301404 175.92 172.87 171.76  
15301405 181.78 186.13 189.06  
15301406 185.58 187.62 189.36  
15301407 187.29 188.05 189.65  
15301408 188.65 188.95 189.53  
\*  
\* lt.boundary incr bdry code factor hs#  
15301501 530010000 0 1 1 12556.8 1 \*(0.7) 17938.3

```
15301502 530020000 0 1 1 12556.8 2 *(0.7) 17938.3
15301503 530030000 0 1 1 12556.8 3 *(0.7) 17938.3
15301504 530040000 0 1 1 12556.8 4 *(0.7) 17938.3
15301505 530050000 0 1 1 12556.8 5 *(0.7) 17938.3
15301506 530060000 0 1 1 12556.8 6 *(0.7) 17938.3
15301507 530070000 0 1 1 12556.8 7 *(0.7) 17938.3
15301508 530080000 0 1 1 12556.8 8 *(0.7) 17938.3
*
*
* rt.boundary incr bdry code factor hs#
15301601 765010000 0 1 1 12556.8 1 *(0.7) 17938.3
15301602 765010000 0 1 1 12556.8 2 *(0.7) 17938.3
15301603 764010000 0 1 1 12556.8 3 *(0.7) 17938.3
15301604 764010000 0 1 1 12556.8 4 *(0.7) 17938.3
15301605 763010000 0 1 1 12556.8 5 *(0.7) 17938.3
15301606 763010000 0 1 1 12556.8 6 *(0.7) 17938.3
15301607 762010000 0 1 1 12556.8 7 *(0.7) 17938.3
15301608 762010000 0 1 1 12556.8 8 *(0.7) 17938.3
*
* src.type s.mult dh-lt dh-rt hs#
15301701 0 0.0 0.0 0.0 8
*
* hed hlf hlr gslf gslr gkf gkr lbf hs#
15301801 0.0 5.4844 100.0 100.0 100.0 0.0 0.0 1.0 1
15301802 0.0 100.0 100.0 100.0 100.0 0.0 0.0 1.0 7
15301803 0.0 100.0 5.4844 100.0 100.0 100.0 0.0 0.0 1.0 8
*
15301901 0.0 100.0 100.0 100.0 100.0 0.0 0.0 1.0 8
*
*
* heat structure 531-1 RFW Heater B5 Tubes
* nh np geom init lt.coord
15311000 8 3 2 1 0.0231
*
* mesh loc'n format
15311100 0 1
*
* # intervals rt.coord
15311101 2 0.0260
*
* comp # inter#(in)
15311201 004 2
*
* rel. source interval
```

15311301 1. 2  
\*  
15311400 -1  
\*  
\* mesh point temperatures  
15311401 152.71 158.09 163.24  
15311402 153.75 159.06 164.11  
15311403 162.74 168.34 173.74  
15311404 168.95 173.40 177.69  
15311405 176.29 179.73 182.98  
15311406 181.27 183.49 185.58  
15311407 184.14 185.46 186.70  
15311408 185.89 186.61 187.28  
\*  
\* lt.boundary incr bdry code factor hs#  
15311501 531010000 0 1 1 12556.8 1 \*(0.7) 17938.3  
15311502 531020000 0 1 1 12556.8 2 \*(0.7) 17938.3  
15311503 531030000 0 1 1 12556.8 3 \*(0.7) 17938.3  
15311504 531040000 0 1 1 12556.8 4 \*(0.7) 17938.3  
15311505 531050000 0 1 1 12556.8 5 \*(0.7) 17938.3  
15311506 531060000 0 1 1 12556.8 6 \*(0.7) 17938.3  
15311507 531070000 0 1 1 12556.8 7 \*(0.7) 17938.3  
15311508 531080000 0 1 1 12556.8 8 \*(0.7) 17938.3  
\*  
\*  
\* rt.boundary incr bdry code factor hs#  
15311601 865010000 0 1 1 12556.8 1 \*(0.7) 17938.3  
15311602 865010000 0 1 1 12556.8 2 \*(0.7) 17938.3  
15311603 864010000 0 1 1 12556.8 3 \*(0.7) 17938.3  
15311604 864010000 0 1 1 12556.8 4 \*(0.7) 17938.3  
15311605 863010000 0 1 1 12556.8 5 \*(0.7) 17938.3  
15311606 863010000 0 1 1 12556.8 6 \*(0.7) 17938.3  
15311607 862010000 0 1 1 12556.8 7 \*(0.7) 17938.3  
15311608 862010000 0 1 1 12556.8 8 \*(0.7) 17938.3  
\*  
\* src.type s.mult dh-lt dh-rt hs#  
15311701 0 0.0 0.0 0.0 8  
\*  
\* hed hlf hlr gslf gslr gkf gkr lbf hs#  
15311801 0.0 5.4844 100.0 100.0 100.0 0.0 0.0 1.0 1  
15311802 0.0 100.0 100.0 100.0 100.0 0.0 0.0 1.0 7  
15311803 0.0 100.0 5.4844 100.0 100.0 0.0 0.0 1.0 8  
\*  
15311901 0.0 100.0 100.0 100.0 100.0 0.0 0.0 1.0 8

```
*  
*  
* heat structure 532-1 RFW Heater C5 Tubes  
* nh np geom init lt.coord  
15321000 8 3 2 1 0.0231  
*  
* mesh loc'n format  
15321100 0 1  
*  
* # intervals rt.coord  
15321101 2 0.0260  
*  
* comp # inter#(in)  
15321201 004 2  
*  
* rel. source interval  
15321301 1. 2  
*  
15321400 -1  
*  
* mesh point temperatures  
15321401 136.71 137.95 139.07  
15321402 136.55 137.75 138.87  
15321403 138.78 139.81 140.79  
15321404 140.92 141.87 142.77  
15321405 159.80 167.15 174.08  
15321406 170.62 175.64 180.38  
15321407 176.32 179.08 181.68  
15321408 180.69 182.69 184.57  
*  
* lt.boundary incr bdry code factor hs#  
15321501 532010000 0 1 1 12556.8 1 *(0.7) 17938.3  
15321502 532020000 0 1 1 12556.8 2 *(0.7) 17938.3  
15321503 532030000 0 1 1 12556.8 3 *(0.7) 17938.3  
15321504 532040000 0 1 1 12556.8 4 *(0.7) 17938.3  
15321505 532050000 0 1 1 12556.8 5 *(0.7) 17938.3  
15321506 532060000 0 1 1 12556.8 6 *(0.7) 17938.3  
15321507 532070000 0 1 1 12556.8 7 *(0.7) 17938.3  
15321508 532080000 0 1 1 12556.8 8 *(0.7) 17938.3  
*  
*  
* rt.boundary incr bdry code factor hs#  
15321601 965010000 0 1 1 12556.8 1 *(0.7) 17938.3  
15321602 965010000 0 1 1 12556.8 2 *(0.7) 17938.3
```

---

*RELAP5 Model INPUT DECK WITH NEW RECIRCULATION CONTROLS*

```
15321603 964010000  0   1   1   12556.8 3 *(0.7) 17938.3
15321604 964010000  0   1   1   12556.8 4 *(0.7) 17938.3
15321605 963010000  0   1   1   12556.8 5 *(0.7) 17938.3
15321606 963010000  0   1   1   12556.8 6 *(0.7) 17938.3
15321607 962010000  0   1   1   12556.8 7 *(0.7) 17938.3
15321608 962010000  0   1   1   12556.8 8 *(0.7) 17938.3
*
*      src.type    s.mult dh-lt dh-rt hs#
15321701 0          0.0  0.0  0.0  8
*
*      hed    hlf    hlr    gslf   gslr   gkf   gkr   lbf   hs#
15321801 0.0     5.4844 100.0 100.0 100.0 0.0  0.0  1.0  1
15321802 0.0     100.0 100.0 100.0 100.0 0.0  0.0  1.0  7
15321803 0.0     100.0 5.4844 100.0 100.0 0.0  0.0  1.0  8
*
15321901 0.0     100.0 100.0 100.0 100.0 0.0  0.0  1.0  8
*
*
* heat structure 540-1 RFW Heater A4 Tubes
*      nh    np    geom  init  lt.coord
15401000 10   3   2   1   0.0231
*
*      mesh loc'n  format
15401100 0       1
*
*      # intervals rt.coord
15401101 2       0.0260
*
*      comp #    inter#(in)
15401201 004     2
*
*      rel. source interval
15401301 1.       2
*
15401400 -1
*
*      mesh point temperatures
15401401 196.10  198.57  200.90
15401402 196.69  198.94  201.05
15401403 214.70  221.16  227.25
15401404 225.70  230.12  234.28
15401405 232.97  235.92  238.70
15401406 238.11  240.19  242.15
15401407 240.94  242.10  243.09
```

---

15401408 242.41 243.03 243.55  
 15401409 243.10 243.41 243.71  
 15401410 243.58 243.77 243.95  
 \*  
 \* lt.boundary incr bdry code factor hs#  
 15401501 540010000 0 1 1 14906.7 1 \*(1.5) 14906.7  
 15401502 540020000 0 1 1 13865.0 2 \*(1.5) 13865.0  
 15401503 540030000 0 1 1 13865.0 3 \*(1.0) 13865.0  
 15401504 540040000 0 1 1 13865.0 4 \*(1.0) 13865.0  
 15401505 540050000 0 1 1 13865.0 5 \*(1.0) 13865.0  
 15401506 540060000 0 1 1 13865.0 6 \*(1.0) 13865.0  
 15401507 540070000 0 1 1 13865.0 7 \*(1.0) 13865.0  
 15401508 540080000 0 1 1 13865.0 8 \*(1.0) 13865.0  
 15401509 540090000 0 1 1 13865.0 9 \*(1.0) 13865.0  
 15401510 540100000 0 1 1 14906.7 10 \*(1.0) 13865.0  
 \*  
 \* rt.boundary incr bdry code factor hs#  
 15401601 753010000 0 1 1 14906.7 1 \*(1.5) 14906.7  
 15401602 753010000 0 1 1 13865.0 2 \*(1.5) 13865.0  
 15401603 752010000 0 1 1 13865.0 3 \*(1.0) 13865.0  
 15401604 752010000 0 1 1 13865.0 4 \*(1.0) 13865.0  
 15401605 752010000 0 1 1 13865.0 5 \*(1.0) 13865.0  
 15401606 751010000 0 1 1 13865.0 6 \*(1.0) 13865.0  
 15401607 751010000 0 1 1 13865.0 7 \*(1.0) 13865.0  
 15401608 751010000 0 1 1 13865.0 8 \*(1.0) 13865.0  
 15401609 750010000 0 1 1 13865.0 9 \*(1.0) 13865.0  
 15401610 750010000 0 1 1 14906.7 10 \*(1.0) 14906.7  
 \*  
 \* src.type s.mult dh-lt dh-rt hs#  
 15401701 0 0.0 0.0 0.0 10  
 \*  
 \* hed hlf hlr gslf gslr gkf gkr lbf hs#  
 15401801 0.0 4.5052 100.0 100.0 100.0 0.0 0.0 1.0 01  
 15401802 0.0 100.0 100.0 100.0 100.0 0.0 0.0 1.0 09  
 15401803 0.0 100.0 4.5052 100.0 100.0 0.0 0.0 1.0 10  
 \*  
 15401901 0.0 100.0 100.0 5.0 5.0 0.1 0.1 1.0 10  
 \*  
 \* heat structure 541-1 RFW Heater B4 Tubes  
 \* nh np geom init lt.coord  
 15411000 10 3 2 1 0.0231  
 \*

```
*      mesh loc'n  format
15411100 0      1
*
*      # intervals  rt.coord
15411101 2      0.0260
*
*      comp #      inter#(in)
15411201 004      2
*
*      rel. source  interval
15411301 1.      2
*
15411400 -1
*
*      mesh point temperatures
15411401 196.10  198.57  200.90
15411402 196.69  198.94  201.05
15411403 214.70  221.16  227.25
15411404 225.70  230.12  234.28
15411405 232.97  235.92  238.70
15411406 238.11  240.19  242.15
15411407 240.94  242.10  243.09
15411408 242.41  243.03  243.55
15411409 243.10  243.41  243.71
15411410 243.58  243.77  243.95
*
*      lt.boundary  incr  bdry  code  factor hs#
15411501 541010000  0    1    1    14906.7 1  *(1.5) 14906.7
15411502 541020000  0    1    1    13865.0 2  *(1.5) 13865.0
15411503 541030000  0    1    1    13865.0 3  *(1.0) 13865.0
15411504 541040000  0    1    1    13865.0 4  *(1.0) 13865.0
15411505 541050000  0    1    1    13865.0 5  *(1.0) 13865.0
15411506 541060000  0    1    1    13865.0 6  *(1.0) 13865.0
15411507 541070000  0    1    1    13865.0 7  *(1.0) 13865.0
15411508 541080000  0    1    1    13865.0 8  *(1.0) 13865.0
15411509 541090000  0    1    1    13865.0 9  *(1.0) 13865.0
15411510 541100000  0    1    1    14906.7 10 *(1.0) 13865.0
*
*
*      rt.boundary  incr  bdry  code  factor hs#
15411601 853010000  0    1    1    14906.7 1  *(1.5) 14906.7
15411602 853010000  0    1    1    13865.0 2  *(1.5) 13865.0
15411603 852010000  0    1    1    13865.0 3  *(1.0) 13865.0
15411604 852010000  0    1    1    13865.0 4  *(1.0) 13865.0
```

```
15411605 852010000  0   1   1   13865.0 5 *(1.0) 13865.0
15411606 851010000  0   1   1   13865.0 6 *(1.0) 13865.0
15411607 851010000  0   1   1   13865.0 7 *(1.0) 13865.0
15411608 851010000  0   1   1   13865.0 8 *(1.0) 13865.0
15411609 850010000  0   1   1   13865.0 9 *(1.0) 13865.0
15411610 850010000  0   1   1   14906.7 10 *(1.0) 14906.7
*
*   src.type   s.mult dh-lt dh-rt hs#
15411701 0       0.0  0.0  0.0  10
*
*   hed   hlf   hlr   gslf  gslr  gkf  gkr  lbf  hs#
15411801 0.0    4.5052 100.0 100.0 100.0 0.0  0.0  1.0  01
15411802 0.0    100.0 100.0 100.0 100.0 0.0  0.0  1.0  09
15411803 0.0    100.0 4.5052 100.0 100.0 0.0  0.0  1.0  10
*
15411901 0.0    100.0 100.0 5.0   5.0   0.1  0.1  1.0  10
*
*
* heat structure 542-1 RFW Heater C4 Tubes
*   nh   np   geom  init  lt.coord
15421000 10   3   2   1   0.0231
*
*   mesh loc'n  format
15421100 0       1
*
*   # intervals rt.coord
15421101 2       0.0260
*
*   comp #   inter#(in)
15421201 004     2
*
*   rel. source interval
15421301 1.       2
*
15421400 -1
*
*   mesh point temperatures
15421401 196.10  198.57  200.90
15421402 196.69  198.94  201.05
15421403 214.70  221.16  227.25
15421404 225.70  230.12  234.28
15421405 232.97  235.92  238.70
15421406 238.11  240.19  242.15
15421407 240.94  242.10  243.09
```

15421408 242.41 243.03 243.55  
15421409 243.10 243.41 243.71  
15421410 243.58 243.77 243.95  
\*  
\* lt.boundary incr bdry code factor hs#  
15421501 542010000 0 1 1 14906.7 1 \*(1.5) 14906.7  
15421502 542020000 0 1 1 13865.0 2 \*(1.5) 13865.0  
15421503 542030000 0 1 1 13865.0 3 \*(1.0) 13865.0  
15421504 542040000 0 1 1 13865.0 4 \*(1.0) 13865.0  
15421505 542050000 0 1 1 13865.0 5 \*(1.0) 13865.0  
15421506 542060000 0 1 1 13865.0 6 \*(1.0) 13865.0  
15421507 542070000 0 1 1 13865.0 7 \*(1.0) 13865.0  
15421508 542080000 0 1 1 13865.0 8 \*(1.0) 13865.0  
15421509 542090000 0 1 1 13865.0 9 \*(1.0) 13865.0  
15421510 542100000 0 1 1 14906.7 10 \*(1.0) 13865.0  
\*  
\*  
\* rt.boundary incr bdry code factor hs#  
15421601 953010000 0 1 1 14906.7 1 \*(1.5) 14906.7  
15421602 953010000 0 1 1 13865.0 2 \*(1.5) 13865.0  
15421603 952010000 0 1 1 13865.0 3 \*(1.0) 13865.0  
15421604 952010000 0 1 1 13865.0 4 \*(1.0) 13865.0  
15421605 952010000 0 1 1 13865.0 5 \*(1.0) 13865.0  
15421606 951010000 0 1 1 13865.0 6 \*(1.0) 13865.0  
15421607 951010000 0 1 1 13865.0 7 \*(1.0) 13865.0  
15421608 951010000 0 1 1 13865.0 8 \*(1.0) 13865.0  
15421609 950010000 0 1 1 13865.0 9 \*(1.0) 13865.0  
15421610 950010000 0 1 1 14906.7 10 \*(1.0) 14906.7  
\*  
\* src.type s.mult dh-lt dh-rt hs#  
15421701 0 0.0 0.0 0.0 10  
\*  
\* hed hlf hlr gslf gslr gkf gkr lbf hs#  
15421801 0.0 4.5052 100.0 100.0 100.0 0.0 0.0 1.0 01  
15421802 0.0 100.0 100.0 100.0 100.0 0.0 0.0 1.0 09  
15421803 0.0 100.0 4.5052 100.0 100.0 0.0 0.0 1.0 10  
\*  
15421901 0.0 100.0 100.0 5.0 5.0 0.1 0.1 1.0 10  
\*  
\*  
\* heat structure 550-1 RFW Heater A3 Tubes  
\* nh np geom init lt.coord  
15501000 12 3 2 1 0.0231  
\*

---

```

*      mesh loc'n  format
15501100 0      1
*
*      # intervals  rt.coord
15501101 2      0.026
*
*      comp #      inter#(in)
15501201 004      2
*
*      rel. source  interval
15501301 1.      2
*
15501400 -1
*
*      mesh point temperatures
15501401 246.43   247.53   248.56
15501402 246.17   246.52   246.83
15501403 247.68   248.25   248.78
15501404 269.73   276.87   283.59
15501405 281.70   286.31   290.65
15501406 289.69   292.67   295.49
15501407 294.81   296.72   298.52
15501408 297.99   299.19   300.32
15501409 298.66   299.68   300.63
15501410 298.35   298.90   299.40
15501411 297.82   297.95   298.06
15501412 297.58   297.58   297.58
*
*      lt.boundary  incr  bdry  code  factor hs#
15501501 550010000  0    1    1    21221.2 1 *(1.5) 14147.5
15501502 550020000  0    1    1    19721.3 2 *(1.5) 13147.5
15501503 550030000  0    1    1    8388.0 3 *(1.0) 5592.0
15501504 550040000  0    1    1    5592.0 4 *(1.0) 5592.0
15501505 550050000  0    1    1    20715.2 5 *(1.0) 20715.2
15501506 550060000  0    1    1    20715.2 6 *(1.0) 20715.2
15501507 550070000  0    1    1    20715.2 7 *(1.0) 20715.2
15501508 550080000  0    1    1    20715.2 8 *(1.0) 20715.2
15501509 550090000  0    1    1    5592.0 9 *(1.0) 5592.0
15501510 550100000  0    1    1    5592.0 10 *(1.0) 5592.0
15501511 550110000  0    1    1    13147.5 11 *(1.0) 13147.5
15501512 550120000  0    1    1    14147.5 12 *(1.0) 14147.5
*
*
*      rt.boundary  incr  bdry  code  factor hs#

```

---

*RELAP5 Model INPUT DECK WITH NEW RECIRCULATION CONTROLS*

15501601 743030000 0 1 1 21221.2 1 \*(1.5) 14147.5  
15501602 743020000 0 1 1 19721.3 2 \*(1.5) 13147.5  
15501603 743010000 0 1 1 8388.0 3 \*(1.0) 5592.0  
15501604 742010000 0 1 1 5592.0 4 \*(1.0) 5592.0  
15501605 741010000 0 1 1 20715.2 5 \*(1.0) 20715.2  
15501606 740010000 0 1 1 20715.2 6 \*(1.0) 20715.2  
15501607 740010000 0 1 1 20715.2 7 \*(1.0) 20715.2  
15501608 741010000 0 1 1 20715.2 8 \*(1.0) 20715.2  
15501609 742010000 0 1 1 5592.0 9 \*(1.0) 5592.0  
15501610 742020000 0 1 1 5592.0 10 \*(1.0) 5592.0  
15501611 742030000 0 1 1 13147.5 11 \*(1.0) 13147.5  
15501612 742040000 0 1 1 14147.5 12 \*(1.0) 14147.5  
\*  
\* src.type s.mult dh-lt dh-rt hs#  
15501701 0 0.0 0.0 0.0 12  
\*  
\* hed hlf hlr gslf gslr gkf gkr lbf hs#  
15501801 0.0 4.0632 100.0 100.0 100.0 0.0 0.0 1.0 01  
15501802 0.0 100.0 100.0 100.0 100.0 0.0 0.0 1.0 11  
15501803 0.0 100.0 4.0632 100.0 100.0 0.0 0.0 1.0 12  
\*  
15501901 0.0 100.0 100.0 5.0 5.0 0.1 0.1 1.0 12  
\*  
\*  
\* heat structure 551-1 RFW Heater B3 Tubes  
\* nh np geom init lt.coord  
15511000 12 3 2 1 0.0231  
\*  
\* mesh loc'n format  
15511100 0 1  
\*  
\* # intervals rt.coord  
15511101 2 0.026  
\*  
\* comp # inter#(in)  
15511201 004 2  
\*  
\* rel. source interval  
15511301 1. 2  
\*  
15511400 -1  
\*  
\* mesh point temperatures  
15511401 246.43 247.53 248.56

---

15511402	246.17	246.52	246.83			
15511403	247.68	248.25	248.78			
15511404	269.73	276.87	283.59			
15511405	281.70	286.31	290.65			
15511406	289.69	292.67	295.49			
15511407	294.81	296.72	298.52			
15511408	297.99	299.19	300.32			
15511409	298.66	299.68	300.63			
15511410	298.35	298.90	299.40			
15511411	297.82	297.95	298.06			
15511412	297.58	297.58	297.58			
*						
*	lt.boundary	incr	bdry	code	factor	hs#
15511501	551010000	0	1	1	21221.2	1 *(1.5) 14147.5
15511502	551020000	0	1	1	19721.3	2 *(1.5) 13147.5
15511503	551030000	0	1	1	8388.0	3 *(1.0) 5592.0
15511504	551040000	0	1	1	5592.0	4 *(1.0) 5592.0
15511505	551050000	0	1	1	20715.2	5 *(1.0) 20715.2
15511506	551060000	0	1	1	20715.2	6 *(1.0) 20715.2
15511507	551070000	0	1	1	20715.2	7 *(1.0) 20715.2
15511508	551080000	0	1	1	20715.2	8 *(1.0) 20715.2
15511509	551090000	0	1	1	5592.0	9 *(1.0) 5592.0
15511510	551100000	0	1	1	5592.0	10 *(1.0) 5592.0
15511511	551110000	0	1	1	13147.5	11 *(1.0) 13147.5
15511512	551120000	0	1	1	14147.5	12 *(1.0) 14147.5
*						
*	rt.boundary	incr	bdry	code	factor	hs#
15511601	843030000	0	1	1	21221.2	1 *(1.5) 14147.5
15511602	843020000	0	1	1	19721.3	2 *(1.5) 13147.5
15511603	843010000	0	1	1	8388.0	3 *(1.0) 5592.0
15511604	842010000	0	1	1	5592.0	4 *(1.0) 5592.0
15511605	841010000	0	1	1	20715.2	5 *(1.0) 20715.2
15511606	840010000	0	1	1	20715.2	6 *(1.0) 20715.2
15511607	840010000	0	1	1	20715.2	7 *(1.0) 20715.2
15511608	841010000	0	1	1	20715.2	8 *(1.0) 20715.2
15511609	842010000	0	1	1	5592.0	9 *(1.0) 5592.0
15511610	842020000	0	1	1	5592.0	10 *(1.0) 5592.0
15511611	842030000	0	1	1	13147.5	11 *(1.0) 13147.5
15511612	842040000	0	1	1	14147.5	12 *(1.0) 14147.5
*						
*	src.type	s.mult	dh-lt	dh-rt	hs#	
15511701	0	0.0	0.0	0.0	12	
*						

---

*RELAP5 Model INPUT DECK WITH NEW RECIRCULATION CONTROLS*

```
*     hed     hlf     hlr     gslf    gslr    gkf    gkr    lbf    hs#
15511801 0.0     4.0632 100.0 100.0 100.0 0.0 0.0 1.0 01
15511802 0.0     100.0 100.0 100.0 100.0 0.0 0.0 1.0 11
15511803 0.0     100.0 4.0632 100.0 100.0 0.0 0.0 1.0 12
*
15511901 0.0     100.0 100.0 5.0   5.0   0.1 0.1 1.0 12
*
*
* heat structure 552-1 RFW Heater C3 Tubes
*     nh     np     geom    init   lt.coord
15521000 12    3     2     1     0.0231
*
*     mesh loc'n  format
15521100 0       1
*
*     # intervals rt.coord
15521101 2       0.026
*
*     comp #     inter#(in)
15521201 004      2
*
*     rel. source interval
15521301 1.       2
*
15521400 -1
*
*     mesh point temperatures
15521401 246.43   247.53   248.56
15521402 246.17   246.52   246.83
15521403 247.68   248.25   248.78
15521404 269.73   276.87   283.59
15521405 281.70   286.31   290.65
15521406 289.69   292.67   295.49
15521407 294.81   296.72   298.52
15521408 297.99   299.19   300.32
15521409 298.66   299.68   300.63
15521410 298.35   298.90   299.40
15521411 297.82   297.95   298.06
15521412 297.58   297.58   297.58
*
*     lt.boundary  incr  bdry   code   factor hs#
15521501 552010000 0     1     1     21221.2 1 *(1.5) 14147.5
15521502 552020000 0     1     1     19721.3 2 *(1.5) 13147.5
15521503 552030000 0     1     1     8388.0 3 *(1.0) 5592.0
```

```
15521504 552040000 0 1 1 5592.0 4 *(1.0) 5592.0
15521505 552050000 0 1 1 20715.2 5 *(1.0) 20715.2
15521506 552060000 0 1 1 20715.2 6 *(1.0) 20715.2
15521507 552070000 0 1 1 20715.2 7 *(1.0) 20715.2
15521508 552080000 0 1 1 20715.2 8 *(1.0) 20715.2
15521509 552090000 0 1 1 5592.0 9 *(1.0) 5592.0
15521510 552100000 0 1 1 5592.0 10 *(1.0) 5592.0
15521511 552110000 0 1 1 13147.5 11 *(1.0) 13147.5
15521512 552120000 0 1 1 14147.5 12 *(1.0) 14147.5
*
*
*      rt.boundary  incr  bdry  code  factor hs#
15521601 943030000 0 1 1 21221.2 1 *(1.5) 14147.5
15521602 943020000 0 1 1 19721.3 2 *(1.5) 13147.5
15521603 943010000 0 1 1 8388.0 3 *(1.0) 5592.0
15521604 942010000 0 1 1 5592.0 4 *(1.0) 5592.0
15521605 941010000 0 1 1 20715.2 5 *(1.0) 20715.2
15521606 940010000 0 1 1 20715.2 6 *(1.0) 20715.2
15521607 940010000 0 1 1 20715.2 7 *(1.0) 20715.2
15521608 941010000 0 1 1 20715.2 8 *(1.0) 20715.2
15521609 942010000 0 1 1 5592.0 9 *(1.0) 5592.0
15521610 942020000 0 1 1 5592.0 10 *(1.0) 5592.0
15521611 942030000 0 1 1 13147.5 11 *(1.0) 13147.5
15521612 942040000 0 1 1 14147.5 12 *(1.0) 14147.5
*
*
*      src.type    s.mult  dh-lt  dh-rt  hs#
15521701 0       0.0   0.0   0.0   12
*
*
*      hed    hlf    hlr    gslf   gslr   gkf   gkr   lbf   hs#
15521801 0.0    4.0632 100.0 100.0 100.0 0.0 0.0 1.0 01
15521802 0.0    100.0 100.0 100.0 100.0 0.0 0.0 1.0 11
15521803 0.0    100.0 4.0632 100.0 100.0 0.0 0.0 1.0 12
*
15521901 0.0    100.0 100.0 5.0   5.0   0.1 0.1 1.0 12
*
*
* heat structure 590-1 RFW Heater A2 Tubes
*      nh    np    geom   init  lt.coord
15901000 10   3   2   1   0.022
*
*
*      mesh loc'n  format
15901100 0       1
*
*
*      # intervals  rt.coord
```

15901101 2 0.026  
\*  
\* comp # inter#(in)  
15901201 004 2  
\*  
\* rel. source interval  
15901301 1. 2  
\*  
15901400 -1  
\*  
\* mesh point temperatures  
15901401 303.62 304.79 305.86  
15901402 306.11 307.75 309.25  
15901403 318.82 324.86 330.41  
15901404 328.06 331.84 335.32  
15901405 333.40 335.65 337.72  
15901406 336.33 337.62 338.81  
15901407 337.88 338.59 339.25  
15901408 338.29 338.84 339.35  
15901409 337.26 337.13 337.02  
15901410 335.67 335.19 334.76  
\*  
\* lt.boundary incr bdry code factor hs#  
15901501 590010000 0 1 1 14896.8 1 \*(1.5) 11917.5  
15901502 590020000 0 1 1 7147.5 2 \*(1.5) 5718.0  
15901503 590030000 0 1 1 7147.5 3 \*(1.5) 5718.0  
15901504 590040000 0 1 1 21147.8 4 \*(1.5) 16918.2  
15901505 590050000 0 1 1 21147.8 5 \*(1.5) 16918.2  
15901506 590060000 0 1 1 21147.8 6 \*(1.5) 16918.2  
15901507 590070000 0 1 1 21147.8 7 \*(1.5) 16918.2  
15901508 590080000 0 1 1 7147.5 8 \*(1.5) 5718.0  
15901509 590090000 0 1 1 7147.5 9 \*(1.5) 5718.0  
15901510 590100000 0 1 1 14896.8 10 \*(1.5) 11917.5  
\*  
\*  
\* rt.boundary incr bdry code factor hs#  
15901601 733010000 0 1 1 14896.8 1 \*(1.5) 11917.5  
15901602 732020000 0 1 1 7147.5 2 \*(1.5) 5718.0  
15901603 732010000 0 1 1 7147.5 3 \*(1.5) 5718.0  
15901604 731010000 0 1 1 21147.8 4 \*(1.5) 16918.2  
15901605 730010000 0 1 1 21147.8 5 \*(1.5) 16918.2  
15901606 730010000 0 1 1 21147.8 6 \*(1.5) 16918.2  
15901607 731010000 0 1 1 21147.8 7 \*(1.5) 16918.2  
15901608 732010000 0 1 1 7147.5 8 \*(1.5) 5718.0

```
15901609 732020000  0   1   1   7147.5 9 *(1.5) 5718.0
15901610 733010000  0   1   1   14896.8 10 *(1.5) 11917.5
*
*      src.type    s.mult dh-lt dh-rt hs#
15901701 0        0.0  0.0  0.0  10
*
*      hed    hlf    hlr    gslf   gslr   gkf   gkr   lbf   hs#
15901801 0.0    3.5039 100.0 100.0 100.0 0.0 0.0 1.0  01
15901802 0.0    100.0 100.0 100.0 100.0 0.0 0.0 1.0  09
15901803 0.0    100.0 3.5039 100.0 100.0 0.0 0.0 1.0  10
*
15901901 0.0    100.0 100.0 5.0   5.0   0.1  0.1  1.0  10
*
*
* heat structure 591-1 RFW Heater B2 Tubes
*      nh    np    geom  init  lt.coord
15911000 10   3   2   1   0.022
*
*      mesh loc'n  format
15911100 0        1
*
*      # intervals rt.coord
15911101 2        0.026
*
*      comp #    inter#(in)
15911201 004     2
*
*      rel. source interval
15911301 1.       2
*
15911400 -1
*
*      mesh point temperatures
15911401 303.62  304.79  305.86
15911402 306.11  307.75  309.25
15911403 318.82  324.86  330.41
15911404 328.06  331.84  335.32
15911405 333.40  335.65  337.72
15911406 336.33  337.62  338.81
15911407 337.88  338.59  339.25
15911408 338.29  338.84  339.35
15911409 337.26  337.13  337.02
15911410 335.67  335.19  334.76
*
```

```
* lt.boundary incr bdry code factor hs#
15911501 591010000 0 1 1 14896.8 1 *(1.5) 11917.5
15911502 591020000 0 1 1 7147.5 2 *(1.5) 5718.0
15911503 591030000 0 1 1 7147.5 3 *(1.5) 5718.0
15911504 591040000 0 1 1 21147.8 4 *(1.5) 16918.2
15911505 591050000 0 1 1 21147.8 5 *(1.5) 16918.2
15911506 591060000 0 1 1 21147.8 6 *(1.5) 16918.2
15911507 591070000 0 1 1 21147.8 7 *(1.5) 16918.2
15911508 591080000 0 1 1 7147.5 8 *(1.5) 5718.0
15911509 591090000 0 1 1 7147.5 9 *(1.5) 5718.0
15911510 591100000 0 1 1 14896.8 10 *(1.5) 11917.5
*
*
* rt.boundary incr bdry code factor hs#
15911601 833010000 0 1 1 14896.8 1 *(1.5) 11917.5
15911602 832020000 0 1 1 7147.5 2 *(1.5) 5718.0
15911603 832010000 0 1 1 7147.5 3 *(1.5) 5718.0
15911604 831010000 0 1 1 21147.8 4 *(1.5) 16918.2
15911605 830010000 0 1 1 21147.8 5 *(1.5) 16918.2
15911606 830010000 0 1 1 21147.8 6 *(1.5) 16918.2
15911607 831010000 0 1 1 21147.8 7 *(1.5) 16918.2
15911608 832010000 0 1 1 7147.5 8 *(1.5) 5718.0
15911609 832020000 0 1 1 7147.5 9 *(1.5) 5718.0
15911610 833010000 0 1 1 14896.8 10 *(1.5) 11917.5
*
*
* src.type s.mult dh-lt dh-rt hs#
15911701 0 0.0 0.0 0.0 10
*
*
* hed hlf hlr gslf gslr gkf gkr lbf hs#
15911801 0.0 3.5039 100.0 100.0 100.0 0.0 0.0 1.0 01
15911802 0.0 100.0 100.0 100.0 100.0 0.0 0.0 1.0 09
15911803 0.0 100.0 3.5039 100.0 100.0 0.0 0.0 1.0 10
*
15911901 0.0 100.0 100.0 5.0 5.0 0.1 0.1 1.0 10
*
*
* heat structure 592-1 RFW Heater C2 Tubes
* nh np geom init lt.coord
15921000 10 3 2 1 0.022
*
* mesh loc'n format
15921100 0 1
*
* # intervals rt.coord
```

---

15921101 2 0.026  
 \*  
 \* comp # inter#(in)  
 15921201 004 2  
 \*  
 \* rel. source interval  
 15921301 1. 2  
 \*  
 15921400 -1  
 \*  
 \* mesh point temperatures  
 15921401 303.62 304.79 305.86  
 15921402 306.11 307.75 309.25  
 15921403 318.82 324.86 330.41  
 15921404 328.06 331.84 335.32  
 15921405 333.40 335.65 337.72  
 15921406 336.33 337.62 338.81  
 15921407 337.88 338.59 339.25  
 15921408 338.29 338.84 339.35  
 15921409 337.26 337.13 337.02  
 15921410 335.67 335.19 334.76  
 \*  
 \* lt.boundary incr bdry code factor hs#  
 15921501 592010000 0 1 1 14896.8 1 \*(1.5) 11917.5  
 15921502 592020000 0 1 1 7147.5 2 \*(1.5) 5718.0  
 15921503 592030000 0 1 1 7147.5 3 \*(1.5) 5718.0  
 15921504 592040000 0 1 1 21147.8 4 \*(1.5) 16918.2  
 15921505 592050000 0 1 1 21147.8 5 \*(1.5) 16918.2  
 15921506 592060000 0 1 1 21147.8 6 \*(1.5) 16918.2  
 15921507 592070000 0 1 1 21147.8 7 \*(1.5) 16918.2  
 15921508 592080000 0 1 1 7147.5 8 \*(1.5) 5718.0  
 15921509 592090000 0 1 1 7147.5 9 \*(1.5) 5718.0  
 15921510 592100000 0 1 1 14896.8 10 \*(1.5) 11917.5  
 \*  
 \*  
 \* rt.boundary incr bdry code factor hs#  
 15921601 933010000 0 1 1 14896.8 1 \*(1.5) 11917.5  
 15921602 932020000 0 1 1 7147.5 2 \*(1.5) 5718.0  
 15921603 932010000 0 1 1 7147.5 3 \*(1.5) 5718.0  
 15921604 931010000 0 1 1 21147.8 4 \*(1.5) 16918.2  
 15921605 930010000 0 1 1 21147.8 5 \*(1.5) 16918.2  
 15921606 930010000 0 1 1 21147.8 6 \*(1.5) 16918.2  
 15921607 931010000 0 1 1 21147.8 7 \*(1.5) 16918.2  
 15921608 932010000 0 1 1 7147.5 8 \*(1.5) 5718.0

---

*RELAP5 Model INPUT DECK WITH NEW RECIRCULATION CONTROLS*

```
15921609 932020000    0    1    1    7147.5 9 *(1.5) 5718.0
15921610 933010000    0    1    1    14896.8 10 *(1.5) 11917.5
*
*      src.type   s.mult dh-lt dh-rt hs#
15921701 0        0.0  0.0  0.0  10
*
*      hed   hlf   hlr   gslf  gslr  gkf  gkr lbf hs#
15921801 0.0    3.5039 100.0 100.0 100.0 0.0 0.0 1.0 01
15921802 0.0    100.0 100.0 100.0 100.0 0.0 0.0 1.0 09
15921803 0.0    100.0 3.5039 100.0 100.0 0.0 0.0 1.0 10
*
15921901 0.0    100.0 100.0 5.0   5.0   0.1  0.1  1.0  10
*
*
* heat structure 600-1 RFW Heater A1 Tubes
*      nh   np   geom  init lt.coord
16001000 10   3    2    1    0.022
*
*      mesh loc'n  format
16001100 0        1
*
*      # intervals rt.coord
16001101 2        0.026
*
*      comp #   inter#(in)
16001201 004      2
*
*      rel. source interval
16001301 1.        2
*
16001400 -1
*
*      mesh point temperatures
16001401 334.73   337.01   339.10
16001402 342.92   348.65   353.94
16001403 350.65   358.47   365.67
16001404 361.40   366.91   372.00
16001405 370.28   374.50   378.38
16001406 375.68   378.54   381.17
16001407 378.82   380.63   382.30
16001408 379.67   381.32   382.84
16001409 377.60   377.59   377.59
16001410 374.79   373.19   371.71
*
```

---

```

* lt.boundary incr bdry code factor hs#
16001501 600010000 0 1 1 5963.7 1 *(1.5) 3975.8
16001502 600020000 0 1 1 7624.0 2 *(1.5) 5082.7
16001503 600030000 0 1 1 7624.0 3 *(1.5) 5082.7
16001504 600040000 0 1 1 29904.1 4 *(1.5) 19936.1
16001505 600050000 0 1 1 29904.1 5 *(1.5) 19936.1
16001506 600060000 0 1 1 29904.1 6 *(1.5) 19936.1
16001507 600070000 0 1 1 29904.1 7 *(1.5) 19936.1
16001508 600080000 0 1 1 7624.0 8 *(1.5) 5082.7
16001509 600090000 0 1 1 7624.0 9 *(1.5) 5082.7
16001510 600100000 0 1 1 5963.7 10 *(1.5) 3975.8
*
*
* rt.boundary incr bdry code factor hs#
16001601 722010000 0 1 1 5963.7 1 *(1.5) 3975.8
16001602 721030000 0 1 1 7624.0 2 *(1.5) 5082.7
16001603 721020000 0 1 1 7624.0 3 *(1.5) 5082.7
16001604 721010000 0 1 1 29904.1 4 *(1.5) 19936.1
16001605 720010000 0 1 1 29904.1 5 *(1.5) 19936.1
16001606 720010000 0 1 1 29904.1 6 *(1.5) 19936.1
16001607 721010000 0 1 1 29904.1 7 *(1.5) 19936.1
16001608 721020000 0 1 1 7624.0 8 *(1.5) 5082.7
16001609 721030000 0 1 1 7624.0 9 *(1.5) 5082.7
16001610 722010000 0 1 1 5963.7 10 *(1.5) 3975.8
*
*
* src.type s.mult dh-lt dh-rt hs#
16001701 0 0.0 0.0 0.0 10
*
*
* hed hlf hlr gslf gslr gkf gkr lbf hs#
16001801 0.0 1.4206 100.0 100.0 100.0 0.0 0.0 1.0 01
16001802 0.0 100.0 100.0 100.0 100.0 0.0 0.0 1.0 09
16001803 0.0 100.0 1.4206 100.0 100.0 0.0 0.0 1.0 10
*
16001901 0.0 100.0 100.0 5.0 5.0 0.1 0.1 1.0 10
*
*
* heat structure 601-1 RFW Heater B1 Tubes
* nh np geom init lt.coord
16011000 10 3 2 1 0.022
*
* mesh loc'n format
16011100 0 1
*
* # intervals rt.coord

```

```
16011101 2      0.026
*
*      comp #    inter#(in)
16011201 004      2
*
*      rel. source  interval
16011301 1.      2
*
16011400 -1
*
*      mesh point temperatures
16011401 334.73   337.01   339.10
16011402 342.92   348.65   353.94
16011403 350.65   358.47   365.67
16011404 361.40   366.91   372.00
16011405 370.28   374.50   378.38
16011406 375.68   378.54   381.17
16011407 378.82   380.63   382.30
16011408 379.67   381.32   382.84
16011409 377.60   377.59   377.59
16011410 374.79   373.19   371.71
*
*      lt.boundary  incr  bdry  code  factor hs#
16011501 601010000   0   1   1   5963.7 1 *(1.5) 3975.8
16011502 601020000   0   1   1   7624.0 2 *(1.5) 5082.7
16011503 601030000   0   1   1   7624.0 3 *(1.5) 5082.7
16011504 601040000   0   1   1   29904.1 4 *(1.5) 19936.1
16011505 601050000   0   1   1   29904.1 5 *(1.5) 19936.1
16011506 601060000   0   1   1   29904.1 6 *(1.5) 19936.1
16011507 601070000   0   1   1   29904.1 7 *(1.5) 19936.1
16011508 601080000   0   1   1   7624.0 8 *(1.5) 5082.7
16011509 601090000   0   1   1   7624.0 9 *(1.5) 5082.7
16011510 601100000   0   1   1   5963.7 10 *(1.5) 3975.8
*
*
*      rt.boundary  incr  bdry  code  factor hs#
16011601 822010000   0   1   1   5963.7 1 *(1.5) 3975.8
16011602 821030000   0   1   1   7624.0 2 *(1.5) 5082.7
16011603 821020000   0   1   1   7624.0 3 *(1.5) 5082.7
16011604 821010000   0   1   1   29904.1 4 *(1.5) 19936.1
16011605 820010000   0   1   1   29904.1 5 *(1.5) 19936.1
16011606 820010000   0   1   1   29904.1 6 *(1.5) 19936.1
16011607 821010000   0   1   1   29904.1 7 *(1.5) 19936.1
16011608 821020000   0   1   1   7624.0 8 *(1.5) 5082.7
```

```
16011609 821030000  0   1   1   7624.0 9 *(1.5) 5082.7
16011610 822010000  0   1   1   5963.7 10 *(1.5) 3975.8
*
*      src.type    s.mult dh-lt dh-rt hs#
16011701 0        0.0  0.0  0.0  10
*
*      hed    hlf    hlr    gslf   gslr   gkf   gkr   lbf   hs#
16011801 0.0     1.4206 100.0 100.0 100.0 0.0  0.0  1.0  01
16011802 0.0     100.0  100.0 100.0 100.0 0.0  0.0  1.0  09
16011803 0.0     100.0  1.4206 100.0 100.0 0.0  0.0  1.0  10
*
16011901 0.0     100.0 100.0 5.0   5.0   0.1  0.1  1.0  10
*
*
* heat structure 602-1 RFW Heater C1 Tubes
*      nh    np    geom  init  lt.coord
16021000 10   3   2   1   0.022
*
*      mesh loc'n  format
16021100 0       1
*
*      # intervals rt.coord
16021101 2       0.026
*
*      comp #    inter#(in)
16021201 004     2
*
*      rel. source interval
16021301 1.       2
*
16021400 -1
*
*      mesh point temperatures
16021401 334.73  337.01 339.10
16021402 342.92  348.65 353.94
16021403 350.65  358.47 365.67
16021404 361.40  366.91 372.00
16021405 370.28  374.50 378.38
16021406 375.68  378.54 381.17
16021407 378.82  380.63 382.30
16021408 379.67  381.32 382.84
16021409 377.60  377.59 377.59
16021410 374.79  373.19 371.71
*
```

```
* lt.boundary incr bdry code factor hs#
16021501 602010000 0 1 1 5963.7 1 *(1.5) 3975.8
16021502 602020000 0 1 1 7624.0 2 *(1.5) 5082.7
16021503 602030000 0 1 1 7624.0 3 *(1.5) 5082.7
16021504 602040000 0 1 1 29904.1 4 *(1.5) 19936.1
16021505 602050000 0 1 1 29904.1 5 *(1.5) 19936.1
16021506 602060000 0 1 1 29904.1 6 *(1.5) 19936.1
16021507 602070000 0 1 1 29904.1 7 *(1.5) 19936.1
16021508 602080000 0 1 1 7624.0 8 *(1.5) 5082.7
16021509 602090000 0 1 1 7624.0 9 *(1.5) 5082.7
16021510 602100000 0 1 1 5963.7 10 *(1.5) 3975.8
*
*
* rt.boundary incr bdry code factor hs#
16021601 922010000 0 1 1 5963.7 1 *(1.5) 3975.8
16021602 921030000 0 1 1 7624.0 2 *(1.5) 5082.7
16021603 921020000 0 1 1 7624.0 3 *(1.5) 5082.7
16021604 921010000 0 1 1 29904.1 4 *(1.5) 19936.1
16021605 920010000 0 1 1 29904.1 5 *(1.5) 19936.1
16021606 920010000 0 1 1 29904.1 6 *(1.5) 19936.1
16021607 921010000 0 1 1 29904.1 7 *(1.5) 19936.1
16021608 921020000 0 1 1 7624.0 8 *(1.5) 5082.7
16021609 921030000 0 1 1 7624.0 9 *(1.5) 5082.7
16021610 922010000 0 1 1 5963.7 10 *(1.5) 3975.8
*
*
* src.type s.mult dh-lt dh-rt hs#
16021701 0 0.0 0.0 0.0 10
*
*
* hed hlf hlr gslf gslr gkf gkr lbf hs#
16021801 0.0 1.4206 100.0 100.0 100.0 0.0 0.0 1.0 01
16021802 0.0 100.0 100.0 100.0 100.0 0.0 0.0 1.0 09
16021803 0.0 100.0 1.4206 100.0 100.0 0.0 0.0 1.0 10
*
16021901 0.0 100.0 100.0 5.0 5.0 0.1 0.1 1.0 10
*
*
* heater tube thermal properties (type 304 stainless steel)
*-----
*
```

20100400 tbl/fctn 1 1

\* thermal conductivity (btu/s-ft-degf)

20100401 2.26e-3

\*

\* volumetric heat capacity (btu/ft\*\*3-degf)

20100451 53.7

\*

\*

\* tables of heater-tube heat flux [w/m\*\*2] vs rx power [w]

\*-----

\*

\* tables derived from refs. [188 - 193, 204, & 205] as per calcs. of app. d

\*

\* drain coolers

20258000 reac-t

20258009 3.293e9 31374. \* jam

20258008 3.1284e9 29002. \* jam

20258007 2.9637e9 26666. \* jam

20258006 2.7991e9 24368. \* jam

20258005 2.6344e9 21872. \* jam

20258004 2.4698e9 19382. \* jam

20258003 1.8384e9 9524. \* jam

20258002 9.775e8 2047. \* jam

20258001 0. 0.

\*

\*

\*

\* heater related control variables (tube powers [w])

\*-----

\*

\* tube power = surface area \* heat flux

\*

\* reactor power [w] = % rated power \* rated power [w]

20580100 rxpower mult 3.293e+07 3.3125499e+09 0

20580101 cntrlvar 010

\*

\* drain cooler (single)

20581600 pwrdc\_s function 1.217e+03 3.8182160e+07 0

20581601 cntrlvar 801 580

\*

\* drain cooler (double)

\*20508260 pwrdc\_d function 2.433e+03 7.6332944e+07 0

\*20508261 cntrlvar 801 580

\*

\* cntrlvar 0815: HTRA5 power (BTU/HR)

20581500 'HTR5-PWR' sum 3.414426 250700000. 0

20581501 0.0 1.0 q 530010000 1.0 q 530050000

20581502 1.0 q 530020000 1.0 q 530060000

20581503 1.0 q 530030000 1.0 q 530070000

20581504        1.0 q 530040000     1.0 q 530080000  
\*  
\* heater 5 (double)  
\*20508250 pwhtr5\_d function 3.804e+03 1.3729779e+08 0  
\*20508251 cntrlvar 801 620  
\*  
\* cntrlvar 0814: HTRA4 power (BTU/HR)  
20581400 'HTR4-PWR' sum 3.414426 266000000.     0  
20581401 0.0    1.0 q 540010000     1.0 q 540060000  
20581402        1.0 q 540020000     1.0 q 540070000  
20581403        1.0 q 540030000     1.0 q 540080000  
20581404        1.0 q 540040000     1.0 q 540090000  
20581405        1.0 q 540050000     1.0 q 540100000  
\*  
\* heater 4 (double)  
\*20508240 pwhtr4\_d function 4.233e+03 1.4764280e+08 0  
\*20508241 cntrlvar 801 660  
\*  
\* cntrlvar 0813: HTRA3 power (BTU/HR)  
20581300 'HTR3-PWR' sum 3.414426 283000000.     0  
20581301 0.0    1.0 q 550010000     1.0 q 550070000  
20581302        1.0 q 550020000     1.0 q 550080000  
20581303        1.0 q 550030000     1.0 q 550090000  
20581304        1.0 q 550040000     1.0 q 550100000  
20581305        1.0 q 550050000     1.0 q 550110000  
20581306        1.0 q 550060000     1.0 q 550120000  
\*  
\* heater 3 (double)  
\*20508230 pwhtr3\_d function 4.826e+03 1.5564330e+08 0  
\*20508231 cntrlvar 801 700  
\*  
\* cntrlvar 0812: HTRA2 power (BTU/HR)  
20581200 'HTR2-PWR' sum 3.414426 150800000.     0  
20581201 0.0    1.0 q 590010000     1.0 q 590060000  
20581202        1.0 q 590020000     1.0 q 590070000  
20581203        1.0 q 590030000     1.0 q 590080000  
20581204        1.0 q 590040000     1.0 q 590090000  
20581205        1.0 q 590050000     1.0 q 590100000  
\*  
\* heater 2 (double)  
\*20508220 pwhtr2\_d function 3.403e+03 8.3856728e+07 0  
\*20508221 cntrlvar 801 770  
\*  
\* cntrlvar 811: HTRA1 power (BTU/HR)

20581100 'HTR1-PWR' sum 3.414426 227800000. 0

20581101 0.0 1.0 q 600010000 1.0 q 600060000

20581102 1.0 q 600020000 1.0 q 600070000

20581103 1.0 q 600030000 1.0 q 600080000

20581104 1.0 q 600040000 1.0 q 600090000

20581105 1.0 q 600050000 1.0 q 600100000

\*

\*

\* heater 1 (double)

\*20508210 pwhtr1\_d function 3.431e+03 1.2596570e+08 0

\*20508211 cntrlvar 801 810

.

## About EPRI

EPRI creates science and technology solutions for the global energy and energy services industry. U.S. electric utilities established the Electric Power Research Institute in 1973 as a nonprofit research consortium for the benefit of utility members, their customers, and society. Now known simply as EPRI, the company provides a wide range of innovative products and services to more than 1000 energy-related organizations in 40 countries. EPRI's multidisciplinary team of scientists and engineers draws on a worldwide network of technical and business expertise to help solve today's toughest energy and environmental problems.

EPRI. Electrify the World

**WARNING: This Document contains information classified under U.S. Export control regulations as restricted from export outside the United States. You are under an obligation to ensure that you have a legal right to obtain access to this information and to ensure that you obtain an export license prior to any re-export of this information. Special restrictions apply to access by anyone that is not a United States citizen or a Permanent United States resident. For further information regarding your obligations, please see the information contained below in the section entitled "Export Control Restrictions."**

### Export Control Restrictions

Access to and use of EPRI Intellectual Property is granted with the specific understanding and requirement that responsibility for ensuring full compliance with all applicable U.S. and foreign export laws and regulations is being undertaken by you and your company. This includes an obligation to ensure that any individual receiving access hereunder who is not a U.S. citizen or permanent U.S. resident is permitted access under applicable U.S. and foreign export laws and regulations. In the event you are uncertain whether you or your company may lawfully obtain access to this EPRI Intellectual Property, you acknowledge that it is your obligation to consult with your company's legal counsel to determine whether this access is lawful. Although EPRI may make available on a case by case basis an informal assessment of the applicable U.S. export classification for specific EPRI Intellectual Property, you and your company acknowledge that this assessment is solely for informational purposes and not for reliance purposes. You and your company acknowledge that it is still the obligation of you and your company to make your own assessment of the applicable U.S. export classification and ensure compliance accordingly. You and your company understand and acknowledge your obligations to make a prompt report to EPRI and the appropriate authorities regarding any access to or use of EPRI Intellectual Property hereunder that may be in violation of applicable U.S. or foreign export laws or regulations.

© 1999 Electric Power Research Institute (EPRI), Inc. All rights reserved. Electric Power Research Institute and EPRI are registered service marks of the Electric Power Research Institute, Inc. EPRI. ELECTRIFY THE WORLD is a service mark of the Electric Power Research Institute, Inc.

TP-112229